


American Society of Plumbing Engineers

# Plumbing Engineering Design Handbook

A Plumbing Engineer's Guide to System Design and Specifications


## Volume 4

### Plumbing Components and Equipment



American Society of Plumbing Engineers

The ASPE *Plumbing Engineering Design Handbook* is designed to provide accurate and authoritative information for the design and specification of plumbing systems. The publisher makes no guarantees or warranties, expressed or implied, regarding the data and information contained in this publication. All data and information are provided with the understanding that the publisher is not engaged in rendering legal, consulting, engineering, or other professional services. If legal, consulting, or engineering advice or other expert assistance is required, the services of a competent professional should be engaged.



American Society of Plumbing Engineers  
6400 Shafer Court, Suite 350  
Rosemont, IL 60018  
(847) 296-0002 • Fax: (847) 269-2963  
E-mail: [info@aspe.org](mailto:info@aspe.org) • Internet: [www.aspe.org](http://www.aspe.org)

Copyright © 2012 by American Society of Plumbing Engineers

**All rights reserved, including rights of reproduction and use in any form or by any means, including the making of copies by any photographic process, or by any electronic or mechanical device, printed or written or oral, or recording for sound or visual reproduction, or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the publisher.**

ISBN 978-1-891255-22-9

10 9 8 7 6 5 4 3 2 1

# Plumbing Engineering Design Handbook Volume 4 Plumbing Components and Equipment

**Chair** L. Richard Ellis, CPD, FASPE

**ASPE Vice President, Technical** Timothy A. Smith, CPD, FASPE

**Editor** Gretchen Pienta

**Graphic Designer** Rachel Boger

## CONTRIBUTORS

### **Chapter 1: Plumbing Fixtures**

Anthony J. Curiale, CPD, LEED AP  
Joseph F. Ficek, CPD

### **Chapter 2: Piping Systems**

James Paschal, PE, CPD, LEED AP  
Bruce S. Weiss, CPD

### **Chapter 3: Valves**

Anthony J. Curiale, CPD, LEED AP  
Jason Geller  
Tom A. Wilson, CPD

### **Chapter 4: Pumps**

Steven P. Skattebo, PE  
Stephen F. Ziga, CPD, SET, CFPS

### **Chapter 5: Piping Insulation**

Carol L. Johnson, CPD, LEED AP  
James Paschal, PE, CPD, LEED AP  
Dennis F. Richards Jr., CPD  
Bruce S. Weiss, CPD

### **Chapter 6: Hangers and Supports**

Jason S.A. McDonald, CPD  
Stephen F. Ziga, CPD, SET, CFPS

### **Chapter 7: Vibration Isolation**

Mark Stickney  
L. Richard Ellis, CPD, FASPE

### **Chapter 8: Grease Interceptors**

Gregory G. Aymong  
L. Richard Ellis, CPD, FASPE  
Michael Gauthier  
Mark J. Kaulas  
Dennis F. Richards Jr., CPD

### **Chapter 9: Cross-Connection Control**

Larisa Miro, CPD  
Steven P. Skattebo, PE

### **Chapter 10: Water Treatment**

David E. DeBord, CPD, LEED AP, ARCSA AP  
Carol L. Johnson, CPD, LEED AP  
E.W. Boulware, PE

### **Chapter 11: Thermal Expansion**

Jodie L. Sherven, PE, CPD  
Karl E. Yrjanainen, PE, CPD

### **Chapter 12: Potable Water Coolers and Central Water Systems**

Frank Sanchez, CPD  
Karl E. Yrjanainen, PE, CPD

### **Chapter 13: Bioremediation Pretreatment Systems**

Max Weiss

### **Chapter 14: Green Plumbing**

David E. DeBord, CPD, LEED AP, ARCSA AP  
Larisa Miro, CPD

# About ASPE

The American Society of Plumbing Engineers (ASPE) is the international organization for professionals skilled in the design and specification of plumbing systems. ASPE is dedicated to the advancement of the science of plumbing engineering, to the professional growth and advancement of its members, and to the health, welfare, and safety of the public.

The Society disseminates technical data and information, sponsors activities that facilitate interaction with fellow professionals, and, through research and education programs, expands the base of knowledge of the plumbing engineering industry. ASPE members are leaders in innovative plumbing design, effective materials and energy use, and the application of advanced techniques from around the world.

**WORLDWIDE MEMBERSHIP** — ASPE was founded in 1964 and currently has 6,000 members. Spanning the globe, members are located in the United States, Canada, Asia, Mexico, South America, the South Pacific, Australia, and Europe. They represent an extensive network of experienced engineers, designers, contractors, educators, code officials, and manufacturers interested in furthering their careers, their profession, and the industry. ASPE is at the forefront of technology. In addition, ASPE represents members and promotes the profession among all segments of the construction industry.

**ASPE MEMBERSHIP COMMUNICATION** — All members belong to ASPE worldwide and have the opportunity to belong to and participate in one of the 61 state, provincial, or local chapters throughout the U.S. and Canada. ASPE chapters provide the major communication links and the first line of services and programs for the individual member. Communication with the membership is enhanced through the Society's official publication, *Plumbing Engineer*, and the e-newsletter *ASPE Pipeline*.

**TECHNICAL PUBLICATIONS** — The Society maintains a comprehensive publishing program, spearheaded by the profession's basic reference text, the *Plumbing Engineering Design Handbook*. The *Plumbing Engineering Design Handbook*, encompassing 51 chapters in four volumes, provides comprehensive details of the accepted practices and design criteria used in the field of plumbing engineering. In 2011, the *Illustrated Plumbing Codes Design Handbook* joined ASPE's published library of professional technical manuals and handbooks.

**CONVENTION AND TECHNICAL SYMPOSIUM** — The Society hosts a biennial Convention & Exposition in even-numbered years and a Technical Symposium in odd-numbered years to allow professional plumbing engineers and designers to improve their skills, learn original concepts, and make important networking contacts to help them stay abreast of current trends and technologies. The ASPE Exposition is the largest gathering of plumbing engineering and design products, equipment, and services. Everything from pipes to pumps to fixtures, from compressors to computers to consulting services is on display, giving engineers and specifiers the opportunity to view the newest and most innovative materials and equipment available to them.

**CERTIFIED IN PLUMBING DESIGN** — ASPE sponsors a national certification program for engineers and designers of plumbing systems, which carries the designation "Certified in Plumbing Design" or CPD. The certification program provides the profession, the plumbing industry, and the general public with a single, comprehensive qualification of professional competence for engineers and designers of plumbing systems. The CPD, designed exclusively by and for plumbing engineers, tests hundreds of engineers and designers at centers throughout the United States. Created to provide a single, uniform national credential in the field of engineered plumbing systems, the CPD program is not in any way connected to state-regulated Professional Engineer (PE) registration.

**ASPE RESEARCH FOUNDATION** — The ASPE Research Foundation, established in 1976, is the only independent, impartial organization involved in plumbing engineering and design research. The science of plumbing engineering affects everything, from the quality of our drinking water to the conservation of our water resources to the building codes for plumbing systems. Our lives are impacted daily by the advances made in plumbing engineering technology through the Foundation's research and development.

# American Society of Plumbing Engineers

# Plumbing Engineering Design Handbook

(4 Volumes — 51 Chapters)

## **Volume 1**    **Fundamentals of Plumbing Engineering** (Revised 2009)

- Chapter 1    **Formulas, Symbols, and Terminology**
- 2    **Standards for Plumbing Materials and Equipment**
- 3    **Specifications**
- 4    **Plumbing Cost Estimation**
- 5    **Job Preparation, Drawings, and Field Reports**
- 6    **Plumbing for People with Disabilities**
- 7    **Energy and Resource Conservation in Plumbing Systems**
- 8    **Corrosion**
- 9    **Seismic Protection of Plumbing Equipment**
- 10    **Acoustics in Plumbing Systems**
- 11    **Basics of Value Engineering**
- 12    **Ensuring High-Quality Plumbing Installations**
- 13    **Existing Building Job Preparation and Condition Survey**

## **Volume 2**    **Plumbing Systems** (Revised 2010)

- Chapter 1    **Sanitary Drainage Systems**
- 2    **On-Site Wastewater Reuse and Storm Water Harvesting**
- 3    **Vents and Venting**
- 4    **Storm Drainage Systems**
- 5    **Cold Water Systems**
- 6    **Domestic Water Heating Systems**
- 7    **Fuel Gas Piping Systems**
- 8    **Private On-Site Wastewater Treatment Systems**
- 9    **Private Water Wells**
- 10    **Vacuum Systems**
- 11    **Water Treatment, Conditioning, and Purification**
- 12    **Special Waste Drainage Systems**

## **Volume 3**    **Special Plumbing Systems** (Revised 2011)

- Chapter 1    **Fire Protection Systems**
- 2    **Plumbing Design for Healthcare Facilities**
- 3    **Treatment of Industrial Waste**
- 4    **Irrigation Systems**
- 5    **Reflecting Pools and Fountains**
- 6    **Public Swimming Pools**
- 7    **Gasoline and Diesel Oil Systems**
- 8    **Steam and Condensate Piping**
- 9    **Compressed Air Systems**
- 10    **Solar Energy**
- 11    **Site Utility Systems**
- 12    **Laboratory Gases**

(The chapters and subjects listed for these volume are subject to modification, adjustment and change.  
The contents shown for each volume are proposed and may not represent the final contents of the volume.  
A final listing of included chapters for each volume will appear in the actual publication.)



# Table of Contents

<b>Chapter 1: Plumbing Fixtures</b> . . . . .	<b>1</b>
Fixture Materials . . . . .	1
Vitreous China . . . . .	1
Nonvitreous China . . . . .	1
Enameled Cast Iron . . . . .	1
Porcelain Enameled Steel . . . . .	1
Stainless Steel . . . . .	1
Plastic . . . . .	1
Glass . . . . .	1
Soapstone . . . . .	1
Terrazzo . . . . .	1
Accessibility . . . . .	2
Applicable Standards . . . . .	2
LEED and Plumbing Fixtures . . . . .	2
Water Closets . . . . .	2
Water Closet Bowl Shape and Size . . . . .	3
Bariatric Water Closets . . . . .	4
Water Closet Seat . . . . .	4
Water Closet Flushing Performance . . . . .	4
Water Closet Installation Requirements . . . . .	5
Water Closet Flushing Systems . . . . .	6
Urinals . . . . .	8
Urinal Styles . . . . .	8
Urinal Flushing Performance . . . . .	8
Urinal Flushing Requirements . . . . .	8
Urinal Installation Requirements . . . . .	9
Lavatories . . . . .	9
Lavatory Size and Shape . . . . .	9
Lavatory Installation . . . . .	10
Kitchen Sinks . . . . .	10
Residential Kitchen Sinks . . . . .	11
Commercial Kitchen Sinks . . . . .	11
Service Sinks . . . . .	12

Sinks . . . . .	12
Laundry Trays . . . . .	12
Faucets . . . . .	12
Faucet Categories . . . . .	12
Faucet Flow Rates . . . . .	12
Backflow Protection for Faucets . . . . .	12
Drinking Fountains . . . . .	13
Showers . . . . .	13
Shower Valves . . . . .	16
Bathtubs . . . . .	16
Bathtub Fill Valves . . . . .	17
Bidet . . . . .	17
Floor Drains . . . . .	17
Emergency Fixtures . . . . .	17
Minimum Fixture Requirements for Buildings . . . . .	18
Single-Occupant Toilet Rooms . . . . .	19
<b>Chapter 2: Piping Systems . . . . .</b>	<b>25</b>
Specification . . . . .	25
Installation . . . . .	25
Cast Iron Soil Pipe . . . . .	25
Hub and Spigot Pipe and Fittings . . . . .	25
Hubless Pipe and Fittings . . . . .	26
Ductile Iron Water and Sewer Pipe . . . . .	26
Concrete Pipe . . . . .	29
Copper Pipe . . . . .	29
Copper Water Tube . . . . .	29
Copper Drainage Tube . . . . .	33
Medical Gas Tube . . . . .	33
Natural and Liquefied Petroleum . . . . .	34
Glass Pipe . . . . .	34
Steel Pipe . . . . .	36
Plastic Pipe . . . . .	39
Polybutylene . . . . .	41
Polyethylene . . . . .	42
Cross-Linked Polyethylene . . . . .	48
Cross-Linked Polyethylene, Aluminum, Cross-Linked Polyethylene . . . . .	49
Polyethylene/Aluminum/Polyethylene . . . . .	49
Polyvinyl Chloride . . . . .	49
Chlorinated Polyvinyl Chloride . . . . .	51
Acrylonitrile-Butadiene-Styrene . . . . .	51
Polypropylene . . . . .	51
Polyvinylidene Fluoride . . . . .	52
Polypropylene-Random . . . . .	52
Teflon (PTFE) . . . . .	52
Low-Extractable PVC . . . . .	52



Fiberglass and Reinforced Thermosetting Resin . . . . .	53
Vitrified Clay Pipe . . . . .	53
High Silicon Iron Pipe . . . . .	53
Special-Purpose Piping Materials . . . . .	54
Aluminum . . . . .	54
Stainless Steel . . . . .	54
Corrugated Stainless Steel Tubing . . . . .	56
Double Containment . . . . .	56
Pipe Joining Practices . . . . .	57
Mechanical Joints . . . . .	57
Compression Joints . . . . .	57
Lead and Oakum Joints (Caulked Joints) . . . . .	57
Shielded Hubless Coupling . . . . .	57
Mechanically Formed Tee Fittings for Copper Tube . . . . .	58
Mechanical Joining of Copper Tube . . . . .	58
Joining Plastic Pipe . . . . .	59
Assembling Flanged Joints . . . . .	60
Making Up Threaded Pipe . . . . .	60
Thread Cutting . . . . .	61
Welding . . . . .	61
Joining Glass Pipe . . . . .	61
Bending Pipe and Tubing . . . . .	61
Electrofusion Joining . . . . .	61
Socket Fusion Joining . . . . .	61
Infrared Butt Fusion Joining . . . . .	61
Beadless Butt Fusion Joining . . . . .	62
Accessories and Joints . . . . .	62
Anchors . . . . .	62
Dielectric Unions and Flanges . . . . .	62
Expansion Joints and Guides . . . . .	62
Ball Joints . . . . .	63
Flexible Couplings (Compression or Slip) . . . . .	63
Gaskets (Flanged Pipe) . . . . .	63
Mechanical Couplings . . . . .	63
Pipe Supports . . . . .	63
Pipe Unions (Flanged Connections) . . . . .	66
Pipe Sleeves . . . . .	67
Service Connections (Water Piping) . . . . .	67
Expansion and Contraction . . . . .	67
Appendix 2-A: Pipe and Fittings Reference Standards . . . . .	68
Cast Iron Soil Pipe . . . . .	68
Ductile Iron Water and Sewer Pipe . . . . .	68
Concrete . . . . .	68
Copper . . . . .	68
Glass . . . . .	68

Steel . . . . .	69
Polybutylene . . . . .	69
Polyethylene . . . . .	69
PEX . . . . .	69
PEX-AL-PEX . . . . .	69
PE-AL-PE . . . . .	69
PVC . . . . .	69
CPVC . . . . .	70
ABS . . . . .	70
Polypropylene . . . . .	70
PVDF . . . . .	70
PP-R . . . . .	70
Vitrified Clay Pipe . . . . .	71
High-Silicon Iron . . . . .	71
<b>Chapter 3: Valves . . . . .</b>	<b>73</b>
Types of Valves . . . . .	73
Gate Valve . . . . .	73
Globe Valve . . . . .	74
Angle Valve . . . . .	75
Ball Valve . . . . .	75
Butterfly Valve . . . . .	76
Check Valve . . . . .	76
Plug Valve . . . . .	77
Valve Materials . . . . .	77
Brass and Bronze . . . . .	77
Iron . . . . .	77
Malleable Iron . . . . .	77
Stainless Steel . . . . .	77
Thermoplastic . . . . .	77
Valve Ratings . . . . .	78
Valve Components . . . . .	78
Stems . . . . .	78
Bonnets . . . . .	79
End Connections . . . . .	79
Water Pressure Regulators . . . . .	80
Regulator Selection and Sizing . . . . .	80
Common Regulating Valves . . . . .	82
Common Types of Regulator Installations . . . . .	82
Valve Sizing and Pressure Losses . . . . .	83
Hot and Cold Domestic Water Service Valve Specifications . . . . .	83
Gate Valves 2 Inches and Smaller . . . . .	83
Gate Valves 2½ Inches and Larger . . . . .	83
Ball Valves 2 Inches and Smaller . . . . .	83
Globe Valves 2 Inches and Smaller . . . . .	83
Globe Valves 2½ Inches and Larger . . . . .	83

Butterfly Valves 2½ Inches and Larger . . . . .	83
Check Valves 2 Inches and Smaller . . . . .	84
Check Valves 2½ Inches and Larger . . . . .	84
Compressed Air Service Valve Specifications . . . . .	84
Ball Valves 2 Inches and Smaller . . . . .	84
Butterfly Valves 2½ Inches and Larger . . . . .	84
Check Valves 2 Inches and Smaller . . . . .	84
Check Valves 2½ Inches and Larger . . . . .	84
Vacuum Service Valve Specifications . . . . .	84
Ball Valves 2 Inches and Smaller . . . . .	84
Medical Gas Service Valve Specifications . . . . .	85
Ball Valves 2 Inches and Smaller . . . . .	85
Ball Valves 2½ Inches and Larger . . . . .	85
Low-Pressure Steam and General Service Valve Specifications . . . . .	85
Butterfly Valves . . . . .	85
Gate Valves 2 Inches and Smaller . . . . .	85
Gate Valves 2½ Inches and Larger . . . . .	85
Ball Valves 2 Inches and Smaller . . . . .	85
Globe Valves 2 Inches and Smaller . . . . .	85
Globe Valves 2½ Inches and Larger . . . . .	86
Check Valves 2 Inches and Smaller . . . . .	86
Check Valves 2½ Inches and Larger . . . . .	86
Medium-Pressure Steam Service Valve Specifications . . . . .	86
Butterfly Valves . . . . .	86
Gate Valves 2 Inches and Smaller . . . . .	86
Gate Valves 2½ Inches and Larger . . . . .	86
Globe Valves 2 Inches and Smaller . . . . .	86
Globe Valves 2½ Inches and Larger . . . . .	86
Check Valves 2 Inches and Smaller . . . . .	86
Check Valves 2½ Inches and Larger . . . . .	86
High-Pressure Steam Service Valve Specifications . . . . .	86
Gate Valves 2 Inches and Smaller . . . . .	86
Gate Valves 2½ Inches and Larger . . . . .	87
Globe Valves 2 Inches and Smaller . . . . .	87
Globe Valves 2½ Inches and Larger . . . . .	87
Check Valves 2 Inches and Smaller . . . . .	87
Check Valves 2½ Inches and Larger . . . . .	87
High-Temperature Hot Water Service Valve Specifications . . . . .	87
Nonlubricated Plug Valves . . . . .	87
Gasoline and LPG Service Valve Specifications . . . . .	87
Plug Valves . . . . .	87
Fire Protection System Valve Specifications . . . . .	87
Gate Valves 2 Inches and Smaller . . . . .	87
Gate Valves 2½ Inches and Larger . . . . .	88
Valves 4 Inches and Larger for Underground Bury . . . . .	88

High-Rise Service Valve Specifications . . . . .	88
Gate Valves 2½ Inches to 12 Inches . . . . .	88
Check Valves 2½ Inches to 12 Inches . . . . .	88
Ball Valves 2 Inches and Smaller . . . . .	88
Butterfly Valves 4 Inches to 12 Inches . . . . .	88
Check Valves. . . . .	88
Glossary . . . . .	88
<b>Chapter 4: Pumps . . . . .</b>	<b>91</b>
Applications . . . . .	91
Pump Basics . . . . .	91
Pump Types and Components . . . . .	91
Determining Pump Efficiency . . . . .	93
Centrifugal Pump Characteristics. . . . .	94
Performance Curves. . . . .	95
Staging . . . . .	97
Specialty Pumps . . . . .	97
Domestic Booster Pumps . . . . .	97
Fire Pumps. . . . .	98
Water Circulation Pumps . . . . .	98
Drainage Pumps . . . . .	98
Pump Maintenance . . . . .	99
Environmental Concerns. . . . .	99
Pump Controls . . . . .	99
Installation . . . . .	100
Glossary . . . . .	100
<b>Chapter 5: Piping Insulation. . . . .</b>	<b>103</b>
Terminology . . . . .	103
The Physics of Water Vapor Transmission. . . . .	103
Types of Insulation. . . . .	104
Fiberglass. . . . .	105
Elastomeric . . . . .	105
Cellular Glass. . . . .	106
Foamed Plastic. . . . .	106
Calcium Silicate . . . . .	106
Insulating Cement. . . . .	106
Jacket Types. . . . .	106
All-Service Jacket . . . . .	108
Aluminum Jacket. . . . .	108
Stainless Steel Jacket . . . . .	108
Plastic and Laminates. . . . .	108
Wire Mesh . . . . .	108
Lagging. . . . .	109
Installation Techniques . . . . .	110
Insulation for Valves and Fittings . . . . .	110

Insulation for Tanks . . . . .	110
Insulation Around Pipe Supports . . . . .	110
Selecting Insulation Thickness . . . . .	110
Controlling Heat Loss . . . . .	110
Condensation Control . . . . .	110
Personnel Protection . . . . .	112
Economics . . . . .	112
Freeze Protection . . . . .	113
Insulation Design Considerations . . . . .	113
<b>Chapter 6: Hangers and Supports . . . . .</b>	<b>115</b>
Hanger and Support Considerations . . . . .	115
Loads . . . . .	115
Thermal Stresses . . . . .	116
Pressure Fluctuations . . . . .	117
Structural Stresses . . . . .	117
Natural Environmental Conditions . . . . .	117
Reactivity and Conductivity . . . . .	117
Acoustics . . . . .	118
Manmade Environmental Conditions . . . . .	118
Hanger and Support Selection and Installation . . . . .	118
Hanger Types . . . . .	118
Selection Criteria . . . . .	118
Hanger and Support Spacing . . . . .	122
Anchoring . . . . .	123
Anchor Types . . . . .	123
Sleeves . . . . .	123
Hanger, Support, and Anchor Materials . . . . .	125
Glossary . . . . .	125
<b>Chapter 7: Vibration Isolation . . . . .</b>	<b>137</b>
Terminology . . . . .	137
Vibration Isolator . . . . .	137
Static Deflection . . . . .	137
Natural Frequency . . . . .	137
Disturbing Frequency . . . . .	137
Resonant Amplification . . . . .	137
Transmissibility . . . . .	137
Damping . . . . .	137
Theory of Vibration Control . . . . .	138
Types of Vibration and Shock Mountings . . . . .	139
Cork . . . . .	139
Elastomers and Neoprene Rubber . . . . .	139
Steel Spring Isolators . . . . .	139
Applications . . . . .	142

<b>Chapter 8: Grease Interceptors. . . . .</b>	<b>145</b>
Principles of Operation . . . . .	145
Retention Period . . . . .	147
Flow-Through Period. . . . .	147
Factors Affecting Flotation in the Ideal Basin. . . . .	147
Grease Interceptor Design Example. . . . .	148
Practical Design . . . . .	150
Grease Interceptor Types . . . . .	150
Hydromechanical Grease Interceptors. . . . .	150
Semiautomatic Units. . . . .	151
Separators . . . . .	151
Grease Removal Devices . . . . .	151
FOG Disposal Systems . . . . .	152
Gravity Grease Interceptors . . . . .	153
Installation . . . . .	154
Flow Control. . . . .	154
Guidelines for Sizing . . . . .	155
Code Requirements . . . . .	156
UPC Requirements for Interceptors . . . . .	156
IPC Requirements for Hydromechanical Grease Interceptors. . . . .	157
Operation and Maintenance . . . . .	157
 <b>Chapter 9: Cross-Connection Control . . . . .</b>	 <b>159</b>
Hydrostatic Fundamentals . . . . .	159
Causes of Reverse Flow . . . . .	160
Hazards in Water Distribution . . . . .	162
Control Paradox. . . . .	162
Classification of Hazards. . . . .	162
Control Techniques . . . . .	162
Passive Techniques . . . . .	162
Active Techniques . . . . .	164
Hybrid Technique . . . . .	166
Installation . . . . .	166
Installation Shortfalls . . . . .	167
Quality Control. . . . .	168
Product Standards and Listings . . . . .	168
Field Testing . . . . .	168
Regulatory Requirements . . . . .	168
Glossary . . . . .	169
 <b>Chapter 10: Water Treatment . . . . .</b>	 <b>173</b>
Basic Water Types . . . . .	174
Raw Water . . . . .	174
Potable Water. . . . .	174
Process Wastewater. . . . .	175
Soft and Hard Water . . . . .	175

Deionized Water . . . . .	175
Distilled Water . . . . .	175
Purified Water . . . . .	175
Water Conditions and Recommended Treatments. . . . .	175
Turbidity . . . . .	175
Hardness . . . . .	176
Aeration and Deaeration. . . . .	176
Minerals . . . . .	176
Chlorination . . . . .	177
Clarification . . . . .	178
Filtration. . . . .	179
Gravity Filters . . . . .	179
Pressure Filters . . . . .	180
Backwashing . . . . .	181
Diatomaceous Earth Filters . . . . .	181
Demineralization . . . . .	182
Ion Exchange . . . . .	182
Water Softening . . . . .	184
Water Softener Selection. . . . .	185
Salt Recycling Systems . . . . .	189
Salt Storage Options . . . . .	189
Distillation . . . . .	189
The Distillation Process . . . . .	191
Distillation Equipment Applications and Selection. . . . .	192
Feed Water . . . . .	194
Distribution Pressure . . . . .	194
Specialized Water Treatment . . . . .	194
Ozone Treatment. . . . .	194
Ultraviolet Light Treatment. . . . .	195
Reverse Osmosis . . . . .	195
Nanofiltration . . . . .	199
Ultrafiltration . . . . .	199
Copper-Silver Ionization . . . . .	199
Glossary . . . . .	199
<b>Chapter 11: Thermal Expansion . . . . .</b>	<b>205</b>
Thermal Stress . . . . .	205
Expansion Loops and Offsets . . . . .	206
Expansion Joints . . . . .	206
Aboveground Piping. . . . .	207
Pressure Piping . . . . .	207
Drain, Waste, and Vent Piping . . . . .	207
Thermoplastic Piping. . . . .	208
Underground Piping . . . . .	208
Expansion Tanks . . . . .	209
Expansion of Water . . . . .	209

Expansion of Material . . . . .	211
Boyle's Law . . . . .	211
Summary . . . . .	213
<b>Chapter 12: Potable Water Coolers and Central Water Systems . . . . .</b>	<b>215</b>
Water and the Human Body . . . . .	215
Unitary Coolers . . . . .	215
Ratings . . . . .	215
Water Cooler Types . . . . .	216
Options and Accessories . . . . .	218
Water Cooler Components . . . . .	219
Stream Regulators . . . . .	219
Refrigeration Systems . . . . .	219
Water Conditioning . . . . .	220
Central Systems . . . . .	221
Components . . . . .	221
System Design . . . . .	222
Standards, Codes, and Regulations . . . . .	224
<b>Chapter 13: Bioremediation Pretreatment Systems . . . . .</b>	<b>227</b>
Principle of Operation . . . . .	227
Separation . . . . .	228
Retention . . . . .	228
Disposal . . . . .	228
Flow Control . . . . .	229
Sizing Guidelines . . . . .	229
Design Standards . . . . .	229
Materials . . . . .	230
Concrete . . . . .	230
Stainless Steel . . . . .	230
Fiberglass-Reinforced Polyester . . . . .	230
Polyethylene . . . . .	230
Structural Considerations . . . . .	230
Dimension and Performance Considerations . . . . .	230
Installation and Workmanship . . . . .	231
<b>Chapter 14: Green Plumbing . . . . .</b>	<b>233</b>
What Is Sustainable Design? . . . . .	233
Assessment and Validation . . . . .	233
The USGBC and LEED . . . . .	233
Real-Life Financial Benefits . . . . .	234
How Plumbing Systems Contribute to Sustainability . . . . .	234
Domestic Water Use Reduction for Irrigation . . . . .	234
Domestic Water Use Reduction for Fixtures . . . . .	236
Wastewater Management . . . . .	236
Rainwater Capture and Reuse . . . . .	238



Graywater and Black Water .....	238
Biosolids Technology .....	238
Energy Requirements .....	241
Energy Efficiency and Energy-Saving Strategies .....	241
Solar Water Heating .....	241
Geothermal Systems .....	241
<b>Index .....</b>	<b>243</b>

# Figures

Figure 1-1	Blowout (A) and Siphon-Jet (B) Water Closets .....	3
Figure 1-2	(A) Close-Coupled, (B) One-Piece, and (C) Flushometer Water Closets .....	3
Figure 1-3	Floor-Mounted, Back-Outlet Water Closet .....	4
Figure 1-4	Wall-Hung Water Closet .....	4
Figure 1-5	Standard Rough-In Dimension for Water Closet Outlet to the Back Wall .....	4
Figure 1-6	Water Closet Compartment Spacing Requirements .....	6
Figure 1-7	Minimum Chase Sizes for Carriers .....	7
Figure 1-8	(A) Gravity Tank and (B) Flushometer Tank .....	8
Figure 1-9	Required Urinal Spacing .....	9
Figure 1-10	Minimum Chase Sizes for Urinals .....	9
Figure 1-11	Recommended Installation Dimensions for a Lavatory .....	10
Figure 1-12	Minimum Chase Sizes for Lavatories .....	10
Figure 1-13	Standard Dimensions for a Residential Kitchen Sink .....	11
Figure 1-14	Commercial Kitchen Sink Discharging to a Grease Interceptor .....	11
Figure 1-15	Typical Drinking Fountain Height .....	13
Figure 1-16	Built-in-Place Shower .....	16
Figure 1-17	Standard Bathtub .....	17
Figure 1-18	Floor Drain .....	18
Figure 1-19	Trench Drain .....	18
Figure 1-20	Emergency Shower .....	18
Figure 2-1	Cast Iron Soil Pipe Joints .....	26
Figure 2-2	Cast Iron Soil Pipe (Extra-Heavy and Service Classes) .....	26
Figure 2-3	Hubless Cast Iron Soil Pipe and Fittings .....	26
Figure 2-4	Joints and Fittings for Ductile Iron Pipe .....	31
Figure 2-5	Copper Tube Flared Fittings .....	39
Figure 2-6	Copper and Bronze Joints and Fittings .....	39
Figure 2-7	Copper Drainage Fittings .....	40
Figure 2-8	Standard Glass Pipe .....	41
Figure 2-9	Standard Glass Pipe Couplings .....	41

Figure 2-10	Typical Glass Pipe Joint Reference Chart.....	41
Figure 2-11	Standard Glass Fittings.....	42
Figure 2-12	Plastic Pipe Fittings .....	48
Figure 2-13	Fusion Lock Process in Operation .....	51
Figure 2-14	(A) Duriron Pipe and (B) Duriron Joint.....	53
Figure 2-15	Copper Pipe Mechanical T-joint .....	58
Figure 2-16	Typical Welding Fittings.....	58
Figure 2-17	Types of Welded Joints .....	58
Figure 2-18	Anchors and Inserts.....	59
Figure 2-19	Dielectric Fittings .....	62
Figure 2-20	Expansion Joints and Guides.....	62
Figure 2-21	Compression Fittings.....	63
Figure 2-22	Mechanical Joint.....	63
Figure 2-23	Hangers, Clamps, and Supports.....	64
Figure 2-24	Pipe Union.....	65
Figure 2-25	Sleeves .....	66
Figure 3-1	Gate Valve.....	73
Figure 3-2	Globe Valve.....	74
Figure 3-3	Angle Valve .....	75
Figure 3-4	Ball Valves .....	75
Figure 3-5	Butterfly Valves.....	76
Figure 3-6	Check Valves.....	76
Figure 3-7	Valve Stems .....	78
Figure 4-1	Portion of a Close-Coupled Centrifugal Pump With an End-Suction Design .....	92
Figure 4-2	Inline Centrifugal Pump with a Vertical Shaft .....	92
Figure 4-3	Enclosed Impeller .....	93
Figure 4-4	Centrifugal Pump with a Double-Suction Inlet Design.....	93
Figure 4-5	Net Fluid Movement From an Impeller Represented by Vector Y .....	95
Figure 4-6	Typical Pump Curve Crossing a System Curve .....	95
Figure 4-7	Typical Pump Curves and Power Requirements .....	96
Figure 4-8	Blade Shape and Quantity Versus Performance Curve .....	96
Figure 4-9	Multistage or Vertical Lineshaft Turbine Pump.....	97
Figure 4-10	Cross-Section of a Grinder Pump with Cutting Blades at the Inlet .....	99
Figure 5-1	Insulating Around a Split Ring Hanger .....	104
Figure 5-2	Insulating Around a Clevis Hanger .....	105
Figure 5-3	Temperature Drop of Flowing Water in a Pipeline.....	112
Figure 6-1	Types of Hangers and Supports .....	120
Figure 6-2	Types of Hanger and Support Anchors .....	124
Figure 6-3	Hanger and Support Anchors for Particular Applications .....	127
Figure 7-1	Transmissibility vs. Frequency Ratio.....	139
Figure 7-2	Calculator for Vibration Isolation.....	140

Figure 7-2(M)	Calculator for Vibration Isolation .....	141
Figure 7-3	Typical Elastomer and Elastomer-Cork Mountings .....	142
Figure 7-4	Typical Steel Spring Mounting .....	142
Figure 8-1	Rising and Settling Rates in Still Water .....	146
Figure 8-2	Cross-Section of a Grease Interceptor Chamber .....	147
Figure 8-3	Trajectory Diagram.....	148
Figure 8-4	(A) Hydromechanical Grease Interceptor; (B) Timer-controlled Grease Removal Device; (C) FOG Disposal System.....	150
Figure 8-5	(A) Gravity Grease Interceptor; (B) Passive, Tank-Type Grease Interceptor .....	152
Figure 9-1	Hydrostatics Showing Reduced Absolute Pressure in a Siphon .....	160
Figure 9-2	Pipe Network With Four Endpoints .....	160
Figure 9-3	Five Typical Plumbing Details Without Cross-Connection Control .....	160
Figure 9-4	Siphon Sufficiently High to Create a Barometric Loop .....	164
Figure 9-5	Five Typical Plumbing Details With Cross-Connection Control.....	164
Figure 9-6	Example of Cross-Connection Controls in a Building .....	165
Figure 9-7	Double Check Valve .....	165
Figure 9-8	Reduced-Pressure Principle Backflow Preventer .....	166
Figure 9-9	Dual-Check with Atmospheric Vent.....	167
Figure 9-10	Atmospheric Vacuum Breaker.....	167
Figure 9-11	Hose Connection Vacuum Breaker .....	167
Figure 10-1	Automatic Chlorinators.....	177
Figure 10-2	Manual Control Chlorinator .....	178
Figure 10-3	Settling Basin.....	179
Figure 10-4	Mechanical Clarifier.....	179
Figure 10-5	Rectangular Gravity Sand Filter .....	179
Figure 10-6	Vertical Pressure Sand Filter .....	180
Figure 10-7	Backwashing .....	180
Figure 10-8	Filtration and Backsplash Cycles.....	180
Figure 10-9	Mudballs.....	181
Figure 10-10	Fissures .....	181
Figure 10-11	Gravel Upheaval .....	181
Figure 10-12	Leaf Design, Diatomaceous Earth Filter .....	182
Figure 10-13	Ion Exchange Vessel—Internal Arrangement.....	183
Figure 10-14	Hydrogen-Sodium Ion Exchange Plant .....	184
Figure 10-15	Sodium Cycle Softener Plus Acid Addition .....	184
Figure 10-16	Lime Deposited from Water of 10 Grains Hardness as a Function of Water Use and Temperature .....	185
Figure 10-17	Water Softener Survey Data.....	189
Figure 10-18	Water Softener Sizing Procedure.....	190
Figure 10-19	Water Softener with Salt Recycling System.....	191
Figure 10-20	Distillation.....	191

Figure 10-21 Typical Air Filter .....	193
Figure 10-22 Schematic Diagram of a Large-Scale Ozone System .....	195
Figure 10-23 Simplified Plan View of Ozone System.....	196
Figure 10-24 Osmosis.....	197
Figure 10-25 Reverse Osmosis .....	197
Figure 10-26 Approaches to Providing Laboratory-Grade and Reagent-Grade Water .....	198
Figure 10-27 Silver Ionization Unit and Control Panel.....	199
Figure 11-1 Expansion Loop Detail .....	207
Figure 11-2 Closed Hot Water System Showing the Effects as Water and Pressure Increase .....	210
Figure 11-3 Effects of an Expansion Tank in a Closed System as Pressure and Temperature Increase .....	210
Figure 11-4 Sizing the Expansion Tank .....	212
Figure 12-1 Early Drinking Faucet .....	215
Figure 12-2 Bottled Water Cooler .....	216
Figure 12-3 Wheelchair-Accessible Pressure-Type Water Cooler.....	216
Figure 12-4 Pressure-Type Pedestal Water Cooler.....	216
Figure 12-5 Wheelchair-Accessible Unit.....	217
Figure 12-6 Dual-Height Design .....	217
Figure 12-7 Dual-Height Design with Chilling Unit Mounted Above Dispenser .....	217
Figure 12-8 Fully Recessed Water Cooler .....	218
Figure 12-9 Fully Recessed Water Cooler with Accessories.....	218
Figure 12-10 Fully Recessed, Barrier-Free Water Cooler .....	218
Figure 12-11 Semi-Recessed or Simulated Recessed Water Cooler.....	218
Figure 12-12 Bottle Filler .....	219
Figure 12-13 Water Cooler Accessories.....	219
Figure 12-14 Upfeed Central System.....	220
Figure 12-15 Downfeed Central System .....	221
Figure 12-16 Drinking Fountains.....	222
Figure 13-1 Kinetically Operated Aerobic Bioremediation System .....	228
Figure 14-1 Typical Small Rainwater Cistern System Diagram .....	236
Figure 14-2 Graywater vs. Black Water .....	239
Figure 14-3 Simple Solar Domestic Water Heater Diagram.....	240

# Tables

Table 1-1	Plumbing Fixture Standards .....	2
Table 1-2	Faucet Flow Rate Restrictions .....	12
Table 1-3	Minimum Number of Required Plumbing Fixtures (IPC Table 403.1).....	20
Table 1-4	Minimum Plumbing Facilities (UPC Table 422.1).....	22
Table 2-1	Dimensions of Hubs, Spigots, and Barrels for Extra-Heavy Cast Iron Soil Pipe and Fittings .....	27
Table 2-1(M)	Dimensions of Hubs, Spigots, and Barrels for Extra-Heavy Cast Iron Soil Pipe and Fittings .....	27
Table 2-2	Dimensions of Hubs, Spigots, and Barrels for Service Cast Iron Soil Pipe and Fittings ...	28
Table 2-2(M)	Dimensions of Hubs, Spigots, and Barrels for Service Cast Iron Soil Pipe and Fittings.....	28
Table 2-3	Dimensions of Spigots and Barrels for Hubless Pipe and Fittings.....	29
Table 2-4	Standard Minimum Pressure Classes of Ductile Iron Single-Thickness Cement-Lined Pipe .....	30
Table 2-5	Dimensions and Approximate Weights of Circular Concrete Pipe .....	30
Table 2-6	Commercially Available Lengths of Copper Plumbing Tube .....	32
Table 2-7	Dimensional and Capacity Data—Type K Copper Tube .....	33
Table 2-7(M)	Dimensional and Capacity Data—Type K Copper Tube .....	34
Table 2-8	Dimensional and Capacity Data—Type L Copper Tube.....	35
Table 2-8(M)	Dimensional and Capacity Data—Type L Copper Tube .....	36
Table 2-9	Dimensional and Capacity Data—Type M Copper Tube.....	37
Table 2-9(M)	Dimensional and Capacity Data—Type M Copper Tube .....	38
Table 2-10	Dimensional Data—Type DWV Copper Tube.....	38
Table 2-11	Dimensional and Capacity Data—Schedule 40 Steel Pipe .....	44
Table 2-11(M)	Dimensional and Capacity Data—Schedule 40 Steel Pipe .....	45
Table 2-12	Dimensional and Capacity Data—Schedule 80 Steel Pipe .....	46
Table 2-12(M)	Dimensional and Capacity Data—Schedule 80 Steel Pipe .....	47
Table 2-13	Plastic Pipe Data .....	48
Table 2-13(M)	Plastic Pipe Data .....	48
Table 2-14	Physical Properties of Plastic Piping Materials.....	50
Table 2-14(M)	Physical Properties of Plastic Piping Materials.....	50
Table 2-15	Dimensions of Class 1 Standard Strength Perforated Clay Pipe.....	54

Table 2-15(M)	Dimensions of Class 1 Standard Strength Perforated Clay Pipe.....	54
Table 2-16	Dimensions of Class 1 Extra Strength Clay Pipe .....	55
Table 2-16(M)	Dimensions of Class 1 Extra Strength Clay Pipe .....	55
Table 2-17	Maximum and Minimum Rod Sizes for Copper Piping.....	65
Table 2-18	Pipe Union Dimensions.....	65
Table 4-1	Centrifugal Pump Affinity Laws.....	95
Table 5-1	Heat Loss in Btuh/ft Length of Fiberglass Insulation.....	106
Table 5-2	Heat Loss from Piping.....	107
Table 5-3	Insulation Thickness - Equivalent Thickness (in.).....	108
Table 5-4	Dewpoint Temperature .....	109
Table 5-5	Insulation Thickness to Prevent Condensation.....	109
Table 5-6	Insulation Thickness for Personnel Protection .....	111
Table 5-7	Time for Dormant Water to Freeze .....	111
Table 6-1	Maximum Horizontal Pipe Hanger and Support Spacing.....	116
Table 6-2	Pipe Classification by Temperature.....	118
Table 6-3	Hanger and Support Selections .....	119
Table 6-4	Recommended Minimum Rod Diameter for Single Rigid Rod Hangers .....	122
Table 6-5	Load Ratings of Carbon Steel Threaded Hanger Rods.....	122
Table 6-6	Minimum Design Load Ratings for Pipe Hanger Assemblies.....	123
Table 7-1	The Relative Effectiveness of Steel Springs, Rubber, and Cork in the Various Speed Ranges .....	139
Table 8-1	Droplet Rise Time.....	149
Table 9-1	Plumbing System Hazards.....	161
Table 9-2	Application of Cross-Connection Control Devices .....	163
Table 9-3	Types of Back-Pressure Backflow Preventer .....	164
Table 9-4	Types of Vacuum Breakers.....	164
Table 10-1	Chemical Names, Common Names, and Formulas.....	173
Table 10-2	Water Treatment—Impurities and Constituents, Possible Effects and Suggested Treatments.....	174
Table 10-3	Water Consumption Guide.....	187
Table 10-4	Comparison of Laboratory-Grade Water Quality Produced by Centralized Systems..	197
Table 10-5	Applications of Purified Water .....	199
Table 11-1	Linear Coefficients of Thermal Expansion or Contraction .....	207
Table 11-2	Developed Length of Pipe to Accommodate 1½-inch Movement.....	207
Table 11-3	Approximate Sine Wave Configuration With Displacement .....	208
Table 11-4	Thermodynamic Properties of Water at a Saturated Liquid.....	209
Table 11-5	Nominal Volume of Piping .....	211
Table 12-1	Standard Rating Conditions .....	216
Table 12-2	Drinking Water Requirements.....	223
Table 12-3	Refrigeration Load.....	223
Table 12-4	Circulating System Line Loss .....	224

Table 12-5	Circulating Pump Heat Input.....	224
Table 12-6	Circulating Pump Capacity.....	224
Table 12-7	Friction of Water in Pipes.....	225
Table 12-8	Pressure Drop Calculations for Example 12-1.....	225
Table 14-1	Treatment Stages for Water Reuse.....	234
Table 14-2	Rainwater Treatment Options.....	237
Table 14-3	Filtration/Disinfection Method Comparison.....	237
Table 14-4	Storage Tank Options.....	238
Table 14-5	Comparison of Graywater and Black Water.....	239



# 1 Plumbing Fixtures

It has been said that without plumbing fixtures, there would be no indoor plumbing. Each fixture is designed for a specific function to maintain public health and sanitation, such as discharging potable water or carrying away waste. Some of the numerous plumbing fixtures used in plumbing systems are water closets and urinals, showerheads, faucets, drinking fountains, bidets, floor drains, and emergency eyewashes.

Fixtures are connected to the plumbing system piping by different types of fittings that also help regulate flow or perform some other function to ensure that the fixture and the entire system work properly.

## **FIXTURE MATERIALS**

The surface of a plumbing fixture must be smooth, impervious, and easily cleanable to maintain a high level of sanitation. Common plumbing fixture materials include the following.

### **Vitreous China**

This is a unique material that is specially suited to plumbing fixtures. Unlike other ceramic materials, vitreous china does not absorb water because it is not porous. Vitreous china plumbing fixture surfaces are glazed, which provides an appealing finish that is easily cleaned. Vitreous china is also an extremely strong material. Because vitreous china is nonporous, it has a very high shrinkage rate when fired in a kiln, which accounts for the slight differences among otherwise identical plumbing fixtures.

### **Nonvitreous China**

Nonvitreous china is a porous ceramic that requires glazing to prevent water absorption. The advantage of nonvitreous china is its low shrinkage rate, which allows the fixture to be more ornately designed.

### **Enameled Cast Iron**

The base of enameled cast iron fixtures is a high-grade cast iron. The exposed surfaces have an enameled coating, which is fused to the cast iron, resulting in

a hard, glossy, opaque, and acid-resistant surface. Enameled cast iron plumbing fixtures are heavy, strong, ductile, and long-lasting.

### **Porcelain Enameled Steel**

Porcelain enamel is a substantially vitreous or glossy inorganic coating that is bonded to sheet steel by fusion to create this material.

### **Stainless Steel**

A variety of stainless steels is used to produce plumbing fixtures, including 316, 304, 302, 301, 202, 201, and 430. One of the key ingredients in stainless steel is nickel, and a higher nickel content tends to produce a superior finish in the stainless steel. Types 302 and 304 have 8 percent nickel, and Type 316 has 10 percent nickel.

### **Plastic**

Plastic is a generic category for a variety of synthetic materials used in plumbing fixtures. The various plastic materials used to produce plumbing fixtures include acrylonitrile butadiene styrene (ABS), polyvinyl chloride (PVC), gel-coated fiberglass-reinforced plastic, acrylic, cultured marble, cast-filled fiberglass, polyester, cast-filled acrylic, gel-coated plastic, cultured marble acrylic, and acrylic polymer. Plastics used in plumbing fixtures are subject to numerous tests to determine their quality, including ignition (torch) test, cigarette burn test, stain-resistance test, and chemical-resistance test.

### **Glass**

Tempered glass fixtures can be ornately designed and are found in numerous designs and colors.

### **Soapstone**

This material is used predominantly in the manufacture of laundry trays and service sinks. Soapstone is steatite, which is extremely heavy and very durable.

### **Terrazzo**

This composite material consists of marble, quartz, granite, glass, or other suitable chips sprinkled or

poured with a cementitious chemical or combination binder. It is cured, ground, and polished to a smooth finish to produce a uniformly textured surface.

## ACCESSIBILITY

Several federal and plumbing industry codes and standards require certain plumbing fixtures to be accessible to people with disabilities. The federal guidelines are the *Americans with Disabilities Act (ADA) Standards for Accessible Design*. Accessibility standards also are found in American National Standards Institute (ANSI)/International Code Council (ICC) A117.1: *Accessible and Usable Buildings and Facilities*. More information about accessibility requirements can be found in *Plumbing Engineering Design Handbook, Volume 1*, Chapter 6.

## APPLICABLE STANDARDS

Plumbing fixtures are regulated by nationally developed consensus standards, which specify materials, fixture designs, and testing requirements. While standards for plumbing fixtures are considered voluntary, the requirements become mandatory when they are referenced in plumbing codes. Most fixture manufacturers enlist a third-party testing laboratory to certify their products as being in conformance with the applicable standard.

Table 1-1 identifies the most common consensus standards regulating plumbing fixtures. A complete list of standards can be found in *Plumbing Engineering Design Handbook, Volume 1*, Chapter 2.

## LEED AND PLUMBING FIXTURES

The LEED (Leadership in Energy and Environmental Design) program is put forth by the U.S. Green Building Council (USGBC) to provide a benchmark for the design of energy- and water-efficient buildings. Efficient plumbing systems can earn a building points in several categories, including irrigation, wastewater treatment, and water use reduction, by including water-efficient fixtures. For instance, at least one LEED point can be obtained simply by specifying dual-flush water closets (not recommended for public spaces), high-efficiency toilets (1.28 gallons per flush [gpf] or less), high-efficiency urinals (0.5 gpf or less), and low-flow faucets (0.5 gallon per minute [gpm] for public spaces and 0.38 gpm for non-public spaces). For current information on the LEED program, visit the USGBC website at [usgbc.org](http://usgbc.org) or turn to Chapter 14 of this volume for more information on green building in general.

## WATER CLOSETS

Passage of the Energy Policy Act of 1992 by the U.S. government changed the way water closets (WCs) were designed. The act imposed a maximum flushing rate of 1.6 gpf, which was a significant decrease in the amount of water used to flush a toilet. Prior to the first enactment of water conservation in the late 1970s, water closets typically flushed between 5 and 7 gallons of water. Now, ultra-low-flow WCs, which flush as little as 0.4 gpf, and dual-flush models are available. Dual-flush WCs give the user the option to flush the full 1.6 gallons for solid waste or one-third less for liquid waste.

With the modification in water flush volume, the style of each manufacturer's water closets changed, and the former terminology for identifying water closets no longer fit. Water closets previously were categorized as blowout, siphon jet, washout, reverse trap, and washdown. Of these styles, the only two commonly in use now are siphon jet and blowout (see Figure 1-1). In the siphon jet, a jet of water is directed through the trapway to quickly fill the bowl and start the siphonic action immediately upon flush-

**Table 1-1 Plumbing Fixture Standards**

Plumbing Fixture	Applicable Standard	Fixture Material
Water closet	ANSI/ASME A112.19.2	Vitreous china
	ANSI Z124.4	Plastic
Urinal	ANSI/ASME A112.19.2	Vitreous china
	ANSI Z124.9	Plastic
Lavatory	ANSI/ASME A112.19.1	Enameled cast iron
	ANSI/ASME A112.19.2	Vitreous china
	ANSI/ASME A112.19.3	Stainless steel
	ANSI/ASME A112.19.4	Porcelain enameled steel
	ANSI/ASME A112.19.9	Nonvitreous china
	ANSI Z124.3	Plastic
Sink	ANSI/ASME A112.19.1	Enameled cast iron
	ANSI/ASME A112.19.2	Vitreous china
	ANSI/ASME A112.19.3	Stainless steel
	ANSI/ASME A112.19.4	Porcelain enameled steel
	ANSI/ASME A112.19.9	Nonvitreous china
	ANSI Z124.6	Plastic
Drinking fountain	ANSI/ASME A112.19.1	Enameled cast iron
	ANSI/ASME A112.19.2	Vitreous china
	ANSI/ASME A112.19.9	Nonvitreous china
Water cooler	ARI 1010	All materials
Shower	IAPMO/ANSI Z124.1.2	Plastic
Bathtub	ANSI/ASME A112.19.1	Enameled cast iron
	ANSI/ASME A112.19.4	Porcelain enameled steel
	ANSI/ASME A112.19.9	Nonvitreous china
	IAPMO/ANSI Z124.1.2	Plastic
Bidet	ANSI/ASME A112.19.2	Vitreous china
	ANSI/ASME A112.19.9	Nonvitreous china
Floor drain	ANSI/ASME A112.6.3	All materials
Emergency fixtures	ANSI Z358.1	All materials
Faucets and fixture fittings	ANSI/ASME A112.18.1	All materials
Waste fittings	ANSI/ASME A112.18.2	All materials




Figure 1-1 Blowout (A) and Siphon-Jet (B) Water Closets

ing. The blowout operates via a high-velocity direct jet action.

Water closets are further categorized as the following:

- Close coupled: A two-piece fixture comprised of a separate tank and bowl (see Figure 1-2A)
- One piece: The tank and the bowl are molded as one piece (see Figure 1-2B)
- Flushometer: A bowl with a spud connection that receives the connection from a flushometer valve (see Figure 1-2C). Flushometer water closets also are referred to as “top spud” or “back spud” bowls depending on the location of the connection for the flushometer valve.

Water closets are flushed via one of the following methods:

- In a gravity flush, used with tank-type water closets, the water is not under pressure and flushes by gravity.
- With a flushometer tank, the water is stored in a pressurized vessel and flushed under a pressure ranging between 25 and 35 pounds per square inch (psi).
- A flushometer valve uses the water supply line pressure to flush the water closet. Because of the demand for a fast, large-volume flush, the water supply pipe must be larger in diameter than that for gravity or flushometer tank flushes. Flushometer water closets require 35–80-psi static pressure and 25 gpm to operate properly.

Another distinction used to identify a water closet is the manner of mounting and connection. The common methods are as follows:

- A floor-mounted water closet sits on the floor and connects directly to the piping through the floor.
- Floor-mounted, back-outlet water closets sit on the floor yet connect to the piping through the wall (see Figure 1-3). The advantage of this model is that floor penetrations are reduced.
- A wall-hung water closet is supported by a wall hanger and never comes in contact with the floor

(see Figure 1-4). This model is advantageous from a maintenance standpoint because it doesn’t interfere with floor cleaning.

### Water Closet Bowl Shape and Size

A water closet bowl is classified as either round or elongated. The front opening of an elongated bowl extends 2 inches farther than a round bowl. Most plumbing codes require elongated bowls for public and employee use. The additional 2 inches provides a larger opening, often called a “target area.” With the larger opening, the ability to maintain a cleaner water closet for each user is increased.

For floor-mounted water closets, the outlet is identified based on the rough-in dimension, or the distance from the back wall to the center of the outlet when the water closet is installed. A standard rough-in bowl outlet is 12 inches (see Figure 1-5).




Figure 1-2 (A) Close-Coupled, (B) One-Piece, and (C) Flushometer Water Closets




Figure 1-3 Floor-Mounted, Back-Outlet Water Closet




Figure 1-4 Wall-Hung Water Closet




Figure 1-5 Standard Rough-In Dimension for Water Closet Outlet to the Back Wall

Most manufacturers also make water closets with a 10-inch or 14-inch rough-in.

The size of the bowl also is based on the height of the bowl's rim from the floor, as follows:

- The rim height of a standard water closet is 14 to 15 inches. This is the most common water closet installed.
- A child's water closet has a rim height of 10 inches. Many plumbing codes require these water closets in daycare centers and kindergarten toilet rooms for use by small children.
- A water closet for juvenile use has a rim height of 13 inches.
- A water closet for the physically challenged has a rim height of 17 inches. With the addition of the water closet seat, the fixture is designed to conform to the accessibility requirement of 17 to 19 inches.

### Bariatric Water Closets

Bariatric WCs are made to accommodate overweight and obese people and support weights of 500 to 1,000 pounds. They are available in vitreous china as well as stainless steel. Wall-hung bariatric fixtures require special, larger carriers designed for the increased loads, which also requires a deeper chase. Thus, most bariatric WCs are floor mounted. Bariatric WCs should be mounted at the accessibility-required height.

### Water Closet Seat

A water closet seat must be designed for the shape of the bowl to which it connects. Two styles of water closet seat are available: solid and open front. Plumbing codes typically require an open front seat for public and employee use. The open front seat is designed to facilitate easy wiping by females and to prevent contact between the seat and the penis with males. This helps maintain a high level of hygiene in public facilities.

Many public water closets include a plastic wrap around the seat that can be changed after each use. The seat is intended to replace the open rim seat in public and employee locations.

### Water Closet Flushing Performance

The flushing performance requirements for a water closet are found in ANSI/American Society of Mechanical Engineers (ASME) A112.19.6: *Hydraulic Performance Requirements for Water Closets and Urinals*. The testing requirements also can be found in ANSI/ASME A112.19.2/CSA B45.1: *Ceramic Plumbing Fixtures*, which is a consolidation and revision of several ASME and Canadian Standards Association (CSA) standards developed in response to industry requests for uniform standards that would be acceptable in both the United States and Canada. These

standards identify the following tests that must be performed to certify a water closet.

- The ball removal test utilizes 100 polypropylene balls that are  $\frac{3}{4}$  inch in diameter. The water closet must flush at least an average of 75 balls on the initial flush of three different flushes. The polypropylene balls are intended to replicate the density of human feces.
- The granule test utilizes approximately 2,500 disc-shaped granules of polyethylene. The initial flush of three different flushes must result in no more than 125 granules on average remaining in the bowl. The granule test is intended to simulate a flush of watery feces (diarrhea).
- The ink test is performed on the inside wall of the water closet bowl. A felt-tip marker is used to draw a line around the inside of the bowl. After flushing, no individual segment of line can exceed  $\frac{1}{2}$  inch. The total length of the remaining ink line must not exceed 2 inches. This test determines that the water flushes all interior surfaces of the bowl.
- The dye test uses a colored dye added to the water closet's trap seal. The concentration of the dye is determined both before and after flushing the water closet. A dilution ratio of 100:1 must be obtained for each flush. This test determines the evacuation of urine in the trap seal.
- The water consumption test determines that the water closet meets the federal mandate of 1.6 gpf.
- The trap seal restoration test determines that the water closet refills the trap of the bowl after each flush. The remaining trap seal must be a minimum of 2 inches in depth.
- The water rise test evaluates the rise of water in the bowl when the water closet is flushed. The water cannot rise above a point 3 inches below the top of the bowl.
- The back-pressure test is used to determine that the water seal remains in place when exposed to a back pressure (from the outlet side of the bowl) of  $2\frac{1}{2}$  inches of water column (wc). This test determines if sewer gas will escape through the fixture when high pressure occurs in the drainage system piping.
- The rim top and seat fouling test determines if the water splashes onto the top of the rim or seat of the water closet. This test ensures that the user does not encounter a wet seat.
- The drainline carry test determines the performance of the water closet's flush. The water closet is connected to a 4-inch drain 60 feet in length pitched  $\frac{1}{4}$  inch per foot. The same 100 polypropylene balls used in the flush test are used in the

drainline carry test. The average carry distance of the polypropylene balls must be 40 feet. This test determines the ability of the water closet to flush the contents in such a manner that they properly flow down the drainage piping.

### Water Closet Installation Requirements

The water closet must be properly connected to the drainage piping system. For floor-mounted water closets, a water closet flange is attached to the piping and permanently secured to the building. For wood-frame buildings, the flange is screwed to the floor. For concrete floors, the flange sits on the floor.

Noncorrosive closet bolts connect the water closet to the floor flange. The seal between the floor flange and the water closet is made with either a wax ring or an elastomeric seal. The connection formed between the water closet and the floor must be sealed with caulking or tile grout.

For wall-hung water closets, the fixture must connect to a wall carrier. The carrier must transfer the loading of the water closet to the floor. A wall-hung water closet must be capable of supporting a load of 500 pounds at the end of the water closet. When the water closet is connected to the carrier, none of this load can be transferred to the piping system. Water closet carriers must conform to ANSI/ASME A112.6.1M: *Supports for Off-the-Floor Plumbing Fixtures for Public Use*. For bariatric WCs, the loads listed by the manufacturers vary from 650 to 1,000 pounds. These carriers must conform to ANSI/ASME A112.6.1 as well.

The minimum spacing required for a water closet is 15 inches from the centerline of the bowl to the side wall and 21 inches from the front of the water closet to any obstruction in front of the water closet (see Figure 1-6). The standard dimension for a water closet compartment is 30 inches wide by 60 inches long. The water closet must be installed in the center of the standard compartment. The minimum distance required between water closets is 30 inches.

While a 3-inch double sanitary tee or a 3-inch double fixture fitting could be used to connect back-to-back 3.5-gpf water closets, current plumbing codes prohibit the installation of a double sanitary tee or double fixture fitting for back-to-back 1.6-gpf water closets due to their superior flushing. The only acceptable fitting is the double combination wye and eighth bend. Also, since the minimum spacing required to use a double sanitary tee fitting is 30 inches from the centerline of the water closet outlet to the entrance of the fitting, this rules out a back-to-back water closet connection.

One of the problems associated with short pattern fittings is the siphon action created in the initial flush of the water closet. This siphon action can draw the water out of the trap of the water closet connected




Figure 1-6 Water Closet Compartment Spacing Requirements

to the other side of the fitting. Another potential problem is the interruption of flow when flushing a water closet. The flow from one water closet can propel water across the fitting, interfering with the other water closet.

Proper clearances within chases for wall-hung carriers should be maintained. Figure 1-7 shows the minimum chase sizes for carriers (as published by the Plumbing and Drainage Institute [PDI]). Carrier sizes vary by manufacturer, so always check the manufacturer's specifications before committing to chase size. Also, wall-hung bariatric carriers require more space than indicated by PDI. Bariatric chases should be coordinated with the specified carrier manufacturer.

## Water Closet Flushing Systems

### Gravity Flush


The most common means of flushing a water closet is a gravity flush (see Figure 1-8A), used with tank-type water closets. The tank stores a quantity of nonpressurized water to establish the initial flush of the bowl. A trip lever raises either a flapper or a ball, allowing the flush to achieve the maximum siphon in the bowl. After the flush, the flapper or ball reseals, closing off the tank from the bowl. To achieve the lowest flow in the dual-flush WC, the trip lever raises the flapper or ball a bit less, which results in a reduced-volume flush.

The ballcock, located inside the tank, controls the flow of water into the tank. A float mechanism opens and closes the ballcock. The ballcock directs the majority of the water into the tank and a smaller portion of water into the bowl to refill the trap seal. The ballcock must be an antisiphon ballcock conforming to ANSI/American Society of Sanitary Engineering (ASSE) 1002: *Siphon Fill Valves for Water Closet Tanks*. This prevents the contents of the tank from being siphoned back into the potable water supply.

### Flushometer Tank

A flushometer tank (see Figure 1-8B) has the same outside appearance as a gravity tank. However, inside the tank is a pressure vessel that stores the water for flushing. The water in the pressure vessel must be a minimum of 25 psi to operate properly. Thus, the line pressure on the connection to the flushometer tank must be a minimum of 25 psi. A pressure regulator prevents the pressure in the vessel from rising above 35 psi (typical of most manufacturers).

The higher pressure from the flushometer tank results in a flush similar to a flushometer valve. One of the differences between the flushometer tank and the flushometer valve is the sizing of the water distribution system. The water piping to a flushometer tank is sized the same as the water piping to a gravity flush tank. Typically, the individual water connection is  $\frac{1}{2}$  inch in diameter. A flushometer valve requires a high flow rate demand, resulting in a larger piping connection, typically 1 inch in diameter.



© PDL, 1991

Figure 1-7 Minimum Chase Sizes for Carriers

Courtesy of Plumbing and Drainage Institute

The flushometer tank WC tends to be noisier than the gravity tank WC. Their advantage over gravity tanks is that the increased velocity of the waste stream provides as much as a 50 percent increase in drainline carry. In long horizontal run situations, this means fewer drainline and sewer blockages.


**Flushometer Valve**

A flushometer valve, also referred to as a flush valve, is available in two designs. A diaphragm valve is designed with upper and lower chambers separated by a diaphragm. A piston valve is designed with upper and lower chambers separated by a piston. The water pressure in the upper chamber keeps the valve in the closed position. When the trip lever is activated, the water in the upper chamber escapes to the lower

chamber, starting the flush. The flush of 1.6 gallons or less passes through the flush valve. The valve is closed by line pressure as water reenters the upper chamber.

For 1.6-gpf water closets, flushometer valves are set to flow 25 gpm at peak to flush the water closet. The flushing cycle is very short, lasting 4 to 5 seconds. The water distribution system must be properly designed to allow the peak flow during heavy use of the plumbing system.

Flushometer valves have either a manual or an automatic means of flushing. The most popular manual means of flushing is a handle mounted on the side of the flush valve. The wave-activated flushometer provides manual activation without touching the



**Figure 1-8 (A) Gravity Tank and (B) Flushometer Tank**

valve, promoting maximum sanitation. Automatic, electronic sensor flushometer valves are available in a variety of styles. The sensor-operated valves can be battery operated, directly connected to the power supply of the building, or powered by a 30-year hybrid energy system or other ecofriendly power generation system.

## URINALS

The urinal was developed to expedite use of a toilet room. It is designed for the removal of urine and the quick exchange of users. The Energy Policy Act of 1992 restricted urinals to a maximum water use of 1 gpf, but most urinals now use 0.5 gpf or less. Ultra-low-flow (0.125 gpf) and waterless urinals are becoming more common in LEED-certified buildings.

### Urinal Styles

Urinals are identified as blowout, siphon jet, washout, stall, washdown, and waterless. A stall urinal is a type of washdown urinal. Blowout, siphon-jet, and washout urinals all have integral traps. Stall and washdown urinals have an outlet to which an external trap is connected. Many plumbing codes prohibit the use of stall and washdown urinals in public and employee toilet rooms because of concerns about the ability to maintain a high level of sanitation after each flush. Waterless urinals are gaining acceptance by code enforcement bodies, but are not allowed in all jurisdictions.

The style identifies the type of flushing action in the urinal. Blowout and siphon-jet types rely on complete evacuation of the trap. Blowout urinals force the water and waste from the trap to the drain. Siphon-jet urinals create a siphon action to evacuate the trap. Washout urinals rely on a water exchange to flush, with no siphon action or complete evacuation of the trapway. Stall and washdown urinals have an external trap. The flushing action is a water exchange; however, it is a less efficient water exchange than that of a washout urinal.

Urinals with an integral trap must be capable of passing a  $\frac{3}{4}$ -inch-diameter ball. The outlet connection is typically 2 inches in diameter. Stall and washdown urinals can have a  $1\frac{1}{2}$ -inch outlet with an external  $1\frac{1}{2}$ -inch trap.

Waterless urinals are used in many jurisdictions to reduce water consumption. Some waterless urinals utilize a cartridge filled with a biodegradable liquid sealant. A more sanitary option utilizes a trap to contain the biodegradable liquid sealant, eliminating the biohazard of disposing of old cartridges. Urine is heavier than

the sealant, so it flows through the cartridge or trap while leaving the sealant. According to manufacturer literature, a typical cartridge lasts for 7,000 uses. The cartridge-less system lasts equally long, and the trap must be flushed when the sealant is reinstalled. Waterless urinals are inexpensive to install. The waste and vent piping are the same as for conventional urinals, but no water piping is required. The inside walls of the urinal must be washed with a special solution on a periodic basis for proper sanitation.

### Urinal Flushing Performance

The flushing performance for a urinal is regulated by ANSI/ASME A112.19.2/CSA B45.1. The three tests for urinals are the ink test, dye test, and water consumption test.

In the ink test, a felt-tip marker is utilized to draw a line on the inside wall of the urinal. The urinal is flushed, and the remaining ink line is measured. The total length of the ink line cannot exceed 1 inch, and no segment can exceed  $\frac{1}{2}$  inch in length.

The dye test uses a colored dye to evaluate the water exchange rate in the trap. After one flush, the trap must have a dilution ratio of 100:1. The dye test is performed only on urinals with an integral trap. This includes blowout, siphon-jet, and washout urinals. It is not possible to dye test stall and washdown urinals since they have external traps. This is one of the concerns that has resulted in the restricted use of these fixtures.


The water consumption test determines if the urinal flushes with 1 gallon of water or less.

### Urinal Flushing Requirements

With the federal requirements for water consumption, urinals must be flushed with a flushometer valve. The valve can be either manually or automatically activated.

A urinal flushometer valve has a lower flush volume and flow rate than a water closet flushometer valve. The total volume is 1 gpf or less, and the peak flow rate is 15 gpm. The water distribution system





**Figure 1-9 Required Urinal Spacing**

must be properly sized for the peak flow rate for the urinal.

Urinal flushometer valves operate the same as water closet flushometer valves. For additional information, refer back to the “Water Closet Flushing Systems” section.

### Urinal Installation Requirements


The minimum spacing required between urinals is 30 inches center to center. The minimum spacing between a urinal and the sidewall is 15 inches. This spacing provides access to the urinal without the user coming in contact with the user of the adjacent fixture (see Figure 1-9). The minimum spacing required in front of the urinal is 21 inches.

For urinals with an integral trap, the outlet is located 21 inches above the floor for a standard-height installation. Stall urinals are mounted on the floor. Wall-hung urinals must be mounted on carriers that transfer the weight of the urinal to the floor. The carrier also connects the urinal to the waste piping system. Sufficient room should be provided in the chase for the carrier. Figure 1-10 shows the minimum chase sizes recommended by PDI.

Many plumbing codes require urinals for public and employee use to have a visible trap seal. This refers to blowout, siphon-jet, and washout urinals.

## LAVATORIES

A lavatory is a washbasin used for personal hygiene. In public locations, a lavatory is intended to be used



**Figure 1-10 Minimum Chase Sizes for Urinals**

Courtesy of Plumbing and Drainage Institute


for washing one’s hands and face. Residential lavatories are intended for hand and face washing, shaving, applying makeup, cleaning contact lenses, and similar hygienic activities.

Lavatory faucet flow rates are regulated as part of the Energy Policy Act of 1992. The original flow rate established by the government was 2.5 gpm at 80 psi for private-use lavatories and 0.5 gpm, or a cycle discharging 0.25 gallon, for public-use lavatories. Now the regulations require 2.2 gpm at 60 psi for private (and residential) lavatories and 0.5 gpm at 60 psi, or a cycle discharging 0.25 gallon, for public lavatories.

Lavatory faucets are available with electronic valves. These faucets can reduce water usage by supplying water only when hands are inside the bowl.

### Lavatory Size and Shape

Manufacturers produce lavatories in every conceivable size and shape: square, round, oblong, rectangular,



**Figure 1-11 Recommended Installation Dimensions for a Lavatory**

shaped for corners, with or without ledges, decorative bowls, and molded into countertops.

The standard outlet for a lavatory is 1¼ inches in diameter. The standard lavatory has three holes on the ledge for the faucet. With a typical faucet, the two outside holes are 4 inches apart. The faucets installed in these lavatories are called 4-inch centersets. When spread faucets are to be installed, the spacing between the two outer holes is 8 inches.


For many years, fixture standards required lavatories to have an overflow based on the concept that the basin was filled prior to cleaning. If the user left the room while the lavatory was being filled, the water would not overflow onto the floor. However, studies have shown that lavatories are rarely used in this capacity. It is more common to not fill the basin with water during use. As a result, overflows now are typically an optional item for lavatories, yet some plumbing codes still require them. The minimum cross-sectional area of an overflow is 1⅝ inches.

Another style of lavatory is the circular or semi-circular group washup. The plumbing codes consider every 20 inches of space along a group washup to be equivalent to one lavatory.

**Lavatory Installation**

The standard height of a lavatory is 31 inches above the finished floor. A spacing of 21 inches is required in front of the lavatory to access the fixture (see Figure 1-11).

Lavatories can be counter mounted, under-counter mounted, or wall hung. When lavatories are wall hung in public and employee facilities, they must be connected to a carrier that transfers the weight of the fixture to the floor. Proper clearances within chases for wall-hung lavatories should be maintained. Figure



**Figure 1-12 Minimum Chase Sizes for Lavatories**

Courtesy of Plumbing and Drainage Institute

1-12 shows the minimum chase sizes recommended by PDI.

**KITCHEN SINKS**

A kitchen sink is used for culinary purposes. The two distinct classifications of kitchen sink are residential and commercial. Residential kitchen sinks

can be installed in commercial buildings, typically in kitchens used by employees. Commercial kitchen sinks are designed for restaurant and food-handling establishments.

The Energy Policy Act of 1992 required the flow rate of faucets for residential kitchen sinks to be 2.5 gpm at 80 psi. Fixture standards have since modified the flow rate to 2.2 gpm at 60 psi.

### Residential Kitchen Sinks

Common residential kitchen sinks are single- or double-compartment (or bowl) sinks. No standard dimension for the size of the sink exists; however, most kitchen sinks are 22 inches measured from the front edge to the rear edge. For single-compartment sinks, the most common width of the sink is 25 inches. For double-compartment kitchen sinks, the most common width is 33 inches. The common depth of the compartments is 9 to 10 inches. Accessible sinks are 5.5 to 6.5 inches deep.

Most plumbing codes require the outlet of a residential kitchen sink to be 3½ inches in diameter. This is to accommodate the installation of a food waste grinder.




Figure 1-13 Standard Dimensions for a Residential Kitchen Sink




Figure 1-14 Commercial Kitchen Sink Discharging to a Grease Interceptor

Some specialty residential kitchen sinks have three compartments. Typically, the third compartment is smaller and does not extend the full depth of the other compartments.

Kitchen sinks have one, three, or four holes for the installation of the faucet. Some single-lever faucets require only one hole for installation. The three-hole arrangement is for a standard two-handle valve installation. The four-hole arrangement is designed to allow the installation of a side spray or other kitchen appurtenance such as a soap dispenser.

The standard installation height for a residential kitchen sink is 36 inches above the finished floor (see Figure 1-13). Most architects tend to follow the 6-foot triangle rule when locating a kitchen sink. The sink is placed no more than 6 feet from the range and 6 feet from the refrigerator.

Residential kitchen sinks mount either above or below the counter. Counter-mounted kitchen sinks are available with a self-rimming ledge or a sink frame.

### Commercial Kitchen Sinks

Commercial kitchen sinks are typically larger in size and have a deeper bowl than residential kitchen sinks. The depth of the bowl typically ranges from 16 to 20 inches. Commercial kitchen sinks are often freestanding sinks with legs for support. Because of health authority requirements, most commercial kitchen sinks are stainless steel.

In commercial kitchens, three types of sinks typically are provided: hand sinks, prep sinks, and triple-basin sinks. Prep sinks usually are a single basin used in conjunction with food preparation. Triple-basin sinks are used for washing pots, pans, and utensils.

Health authorities require either a two- or three-compartment sink in every commercial kitchen. The requirement for a three-compartment sink dates back to the use of the first compartment for dishwashing, the second compartment for rinsing the dishes, and the third compartment for sanitizing the dishes. With the increased use of dishwashers in commercial kitchens, some health codes have modified the requirements for a three-compartment sink.

Commercial kitchen sinks used for food preparation are required to connect to the drainage system through an indirect waste. This prevents the possibility of contaminating food in the event of a drainline backup resulting from a stoppage in the line.

Commercial kitchen sinks that could discharge grease-laden waste must connect to either a grease interceptor or a grease trap (see Figure 1-14). Plumbing codes used to permit the grease trap to serve as the trap for the sink if it was

located within 60 inches of the sink. Most plumbing codes have since modified this requirement by mandating a separate trap for each kitchen sink to provide better protection against the escape of sewer gas. An alternative to this is to spill the sink into an indirect waste drain that flows to a grease trap.

## SERVICE SINKS

A service sink is a general-purpose sink intended to be used in the cleaning or decorating of a building, such as to fill mop buckets and dispose of their waste or for cleaning paint brushes, rollers, and paper-hanging equipment.

There is no standard size, shape, or style of a service sink. They are available both wall mounted and floor mounted. Mop basins, installed on the floor, qualify as service sinks in the plumbing codes.

A service sink typically is located in a janitor's storage closet or a separate room for use by custodial employees. The plumbing codes do not specify the location or a standard height for installing a service sink. Furthermore, the flow rate from the service sink faucet has no limitations.

Service sinks are selected based on the anticipated use of the fixture and the type of building in which it is installed. The plumbing codes require either a 1½-inch or 2-inch trap for the service sink. Service sinks also may be fitted with a 2-inch or 3-inch trap standard.

## SINKS

A general classification for fixtures that are neither kitchen sinks nor service sinks is simply "sinks." This category contains those fixtures typically not required but installed for the convenience of the building users. Some installations include doctors' offices, hospitals, laboratories, photo-processing facilities, quick marts, and office buildings.

Sinks come in a variety of sizes and shapes. There are no height or spacing requirements, and the flow rate from the faucet is not regulated. Most plumbing codes require a 1½-inch drain connection.

## LAUNDRY TRAYS

A laundry tray, or laundry sink, is located in the laundry room and is used in conjunction with washing clothes. The sink has either one or two compartments. The depth of the bowl is typically 14 inches. There are no standard dimensions for the size of laundry trays; however, most single-compartment laundry trays measure 22 inches by 24 inches, and most double-compartment laundry trays measure 22 inches by 45 inches.

Plumbing codes permit a domestic clothes washer to discharge into a laundry tray. The minimum size of a trap and outlet for a laundry tray is 1½ inches.

At one time, laundry trays were made predominantly of soapstone. Today, the majority of laundry trays are plastic. However, stainless steel, enameled cast iron, and porcelain enameled steel laundry trays also are available.

## FAUCETS

All sinks and lavatories need a faucet to direct and control the flow of water into the fixture. A faucet performs the simple operations of opening, closing, and mixing hot and cold water. While the process is relatively simple, fixture manufacturers have developed extensive lines of faucets.

### Faucet Categories

Faucets are categorized by application, such as lavatory faucets, residential kitchen sink faucets, laundry faucets, sink faucets, and commercial faucets. The classification "commercial faucets" includes commercial kitchen faucets and commercial sink faucets. It does not include lavatory faucets. All lavatories are classified the same, whether they are installed in residential or commercial buildings. It should be noted, however, that some lavatory faucet styles are used strictly in commercial applications. These include self-metering lavatory faucets that discharge a specified quantity of water and electronic lavatory faucets that operate via sensors. The sensor-operated lavatory faucets can be battery operated, directly connected to the power supply of the building, or powered by a 30-year hybrid energy system or other ecofriendly power generation system.

### Faucet Flow Rates

The flow rates are regulated for lavatories and non-commercial kitchen sinks. Table 1-2 identifies the flow rate limitations of faucets.

**Table 1-2 Faucet Flow Rate Restrictions**

Type of Faucet	Maximum Flow Rate
Kitchen faucet	2.2 gpm @ 60 psi
Lavatory faucet	2.2 gpm @ 60 psi
Lavatory faucet (public use)	0.5 gpm @ 60 psi
Lavatory faucet (public use, metering)	0.25 gal per cycle

### Backflow Protection for Faucets

In addition to controlling the flow of water, a faucet must protect the potable water supply against backflow. This is often a forgotten requirement, since most faucets rely on an air gap to provide protection against backflow. When an air gap is provided between the outlet of the faucet and the flood-level rim of the fixture (by manufacturer design), no additional protection is necessary.

Backflow protection becomes a concern whenever a faucet has a hose thread outlet, a flexible hose connection, or a pull-out spray connection. For these styles, additional backflow protection is necessary. The hose or hose connection potentially eliminates the air gap by submerging the spout or outlet in a nonpotable water source.

The most common form of backflow protection for faucets not having an air gap is the use of a vacuum breaker. Many manufacturers include an atmospheric vacuum breaker in the design of faucets that require additional backflow protection. Atmospheric vacuum breakers must conform to ANSI/ASSE 1001: *Performance Requirements for Atmospheric-type Vacuum Breakers*.

Faucets with pull-out sprays or gooseneck spouts can be protected by a vacuum breaker or a backflow system that conforms to ANSI/ASME A112.18.3: *Performance Requirements for Backflow Protection Devices and Systems in Plumbing Fixture Fittings*. This standard specifies the testing requirements for a faucet to be certified as protecting the water supply against backflow. Many of the new pull-out spray kitchen faucets are listed in ANSI/ASME A112.18.3. These faucets have a spout attached to a flexible hose whereby the spout can detach from the faucet body and be used similarly to a side spray.

Side-spray kitchen faucets must have a diverter that ensures that the faucet switches to an air gap whenever the pressure in the supply line decreases. Air gaps are regulated by ANSI/ASME A112.1.2: *Air Gaps in Plumbing Systems*.

The most important installation requirement is the proper location of the backflow preventer (or the maintenance of the air gap). When atmospheric vacuum breakers are installed, they must be located a minimum distance above the flood-level rim of the fixture, as specified by the manufacturer.

## DRINKING FOUNTAINS

A drinking fountain is designed to provide drinking water to users. The two classifications of drinking fountains are water coolers and drinking fountains. A water cooler has a refrigeration component that chills the water. A drinking fountain is a nonrefrigerated water dispenser.

Drinking fountains and water coolers come in many styles. The height of a drinking fountain is not regulated, except for accessible drinking fountains conforming to ANSI/ICC A117.1. For grade school installations, drinking fountains typically are installed 30 inches above the finished floor to the rim of the fountain. In other locations, the drinking fountain is typically 36 to 44 inches above the finished floor (see Figure 1-15).

Space must be provided in front of the drinking fountain to allow proper access to the fixture. Plumbing codes prohibit drinking fountains from being installed in toilets or bathrooms.

The water supply to a drinking fountain is  $\frac{3}{8}$  inch or  $\frac{1}{2}$  inch in diameter. The drainage connection is  $1\frac{1}{4}$  inches.

Many plumbing codes permit bottled water or the service of water in a restaurant to be substituted for the installation of a drinking fountain. However, the authority having jurisdiction must be consulted to determine if such a substitution is permitted.

## SHOWERS

A shower is designed to allow full-body cleansing. The size and configuration of a shower must permit an individual to bend at the waist to clean lower-body extremities. Plumbing codes require a minimum size shower enclosure of 30 inches by 30 inches. The codes further stipulate that a shower must have a 30-inch-diameter circle within the shower to allow free movement by the bather.

The water flow rate for showers is regulated by the Energy Policy Act of 1992. The maximum permitted flow rate from a shower valve is 2.5 gpm at 80 psi.

Three different types of shower are available: prefabricated shower enclosure, prefabricated shower base, and built-in-place shower. Prefabricated shower enclosures are available from plumbing fixture manufacturers in a variety of sizes and shapes. A prefabricated shower base is the floor of a shower designed so that the walls can be either prefabricated assemblies or built-in-place ceramic tile walls. Built-in-place showers are typically ceramic tile installations for both the floor and walls.




Figure 1-15 Typical Drinking Fountain Height

WHEN THE SITUATION CALLS FOR UPDATING  
YOUR WATER SYSTEMS, **ZURN LISTENS.**

“  
*When I was tasked  
with retrofitting  
every backflow valve  
in a 90 year old hotel,  
I called Zurn.*”



## RETROFIT AND REPLACEMENT SOLUTIONS

A complete line of products for any project. A 100-year history of quality and innovation. And the lowest life-cycle costs in the industry. When it comes to total building solutions for your water needs, one name stands above the rest. Zurn. For your next retrofit and replacement project, give us a call. We'll listen.

*“When your building sees 30,000 workers every day, you need sustainable plumbing products that not only look good, but also last. We called Zurn.”*

*“We needed to replace every drain in a hospital built in 1917. We called Zurn.”*

**Visit us at ASPE booth 1455!**



[zurn.com](http://zurn.com) 1.855.ONE.ZURN

[far@erga.com](mailto:far@erga.com) 17/01/15

Prefabricated shower enclosures and prefabricated shower bases have a drainage outlet designed for a connection to a 2-inch drain. Certain plumbing codes have decreased the shower drain size to 1½ inches. The connection to a 1½-inch drain also can be made with prefabricated showers.

A built-in-place shower allows the installation of a shower of any shape and size. The important installation requirement for a built-in-place shower is the shower pan (see Figure 1-16). The pan is placed on the floor prior to the installation of the ceramic base. The pan must turn up at the sides of the shower a minimum of 2 inches above the finished threshold of the shower (except the threshold entrance). The materials commonly used to make a shower pan include sheet lead, sheet copper, PVC sheet, and chlorinated polyethylene sheet. The sheet goods are commonly referred to as a waterproof membrane.

At the drainage connection, weep holes are required to be installed at the base of the shower pan. The weep holes and shower pan are intended to serve as a backup drain in the event that the ceramic floor leaks or cracks.


### Shower Valves

Shower valves must be thermostatic mixing, pressure balancing, or a combination of thermostatic mixing and pressure balancing and conform to ANSI/ASSE 1016/ASME A112.1016/CSA B125.16: *Performance Requirements for Automatic Compensating Valves for Individual Showers and Tub/Shower Combinations*. Shower valves control the flow and temperature of the water as well as any variation in the water temperature. These valves provide protection against scalding and sudden changes in water temperature, which can cause slips and falls.

A pressure-balancing valve maintains a constant temperature of the shower water by constantly adjusting the pressure of the hot and cold water supply. If the pressure on the cold water supply changes, the hot water supply balances to the equivalent pressure setting. When tested, a pressure-balancing valve cannot have a fluctuation in temperature that exceeds 3°F. If the cold water shuts off completely, the hot water shuts off as well.

Thermostatic mixing valves adjust the temperature of the water by maintaining a constant temperature once the water temperature is set. This is accomplished by thermally sensing controls that modify the quantity of hot and cold water to keep the set temperature.

The maximum flow rate permitted for each shower is 2.5 gpm at 80 psi. If body sprays are added to the shower, the total water flow rate is still 2.5 gpm at 80 psi. A handheld shower spray is considered a showerhead.



**Figure 1-16 Built-in-Place Shower**

The shower valve typically is located 48 to 50 inches above the floor. The installation height for a showerhead ranges from 65 to 84 inches above the floor of the shower. The standard height is 78 inches for showers used by adult males.

### BATHTUBS

The bathtub was the original fixture used to bathe or cleanse one's body. Eventually, the shower was added to the bathtub to expedite the bathing process. The standard installation is a combination tub/shower, but some installations come with a separate whirlpool bathtub and shower.

Bathtubs tend to be installed within residential units only. The standard bathtub size is 5 feet long by 30 inches wide, with a depth of 14 to 16 inches (see Figure 1-17). However, many different sizes and shapes of bathtubs and whirlpool bathtubs are available. The drain can be either a left-hand (drain hole on the left side as you face the bathtub) or right-hand outlet. When whirlpool bathtubs are installed, the controls for the whirlpool must be accessible.

All bathtubs must have an overflow drain. This is necessary since the bathtub often is filled while the bather is not present. Porcelain enameled steel and enameled cast-iron bathtubs are required to have a slip-resistant base to prevent slips and falls. Plastic bathtubs are not required to have the slip-resistant surface since the plastic is considered to have an inherent slip resistance. However, slip resistance can be specified for plastic bathtub surfaces.



## Bathtub Fill Valves

The two types of bathtub fill valve are the tub filler and the combination tub and shower valve. Tub and shower valves must be pressure-balancing, thermostatic mixing, or combination pressure-balancing and thermostatic mixing valves conforming to ANSI/ASSE 1016/ASME A112.1016/CSA B125.16. The tub filler is not required to meet these requirements, although pressure-balancing and thermostatic mixing tub filler valves are available.

The spout of the tub filler must be properly installed to maintain a 2-inch air gap between the outlet and the flood-level rim of the bathtub. If this air gap is not maintained, the outlet must be protected from backflow by some other means. Certain decorative tub fillers have an atmospheric vacuum breaker installed to protect the opening that is located below the flood-level rim.

The standard location of the bathtub fill valve is 14 inches above the top rim of the bathtub. The spout typically is located 4 inches above the top rim of the bathtub to the centerline of the pipe connection.

## BIDET

The bidet is a fixture designed for cleaning the perineal area. The bidet often is mistaken to be a fixture designed for use by the female population only. However, the fixture is meant for both male and female cleaning. The bidet has a faucet that comes with or without a water spray connection. When a water spray is provided, the outlet must be protected against backflow since the opening is located below the flood-level rim of the bidet. Manufacturers provide a decorative atmospheric vacuum breaker that is located on the deck of the bidet.




Figure 1-17 Standard Bathtub

Bidets are vitreous china fixtures that are mounted on the floor. The fixture, being similar to a lavatory, has a 1¼-inch drainage connection. Access must be provided around the bidet to allow a bather to straddle the fixture and sit down on the rim. Most bidets have a flushing rim to cleanse the fixture after each use.

The bidet is used only for external cleansing. It is not designed for internal body cleansing. This often is misunderstood since the body spray may be referred to as a douche (the French word for shower).

## FLOOR DRAINS

A floor drain (see Figure 1-18) is a plumbing fixture that is the exception to the definition of a plumbing fixture because it has no supply of cold and/or hot water. Floor drains typically are provided as an emergency fixture in the event of a leak or overflow of water. They also are used to assist in the cleaning of a toilet or bathroom.

Floor drains are available in a variety of shapes and sizes. The minimum size drainage outlet required by the plumbing codes is 2 inches. Most plumbing codes do not require floor drains; it is considered an optional fixture that the plumbing engineer may consider installing. Most public toilet rooms have at least one floor drain. They also are used on the lower levels of commercial buildings and in storage areas, commercial kitchens, and areas subject to potential leaks. Floor drains may serve as indirect waste receptors for condensate lines, overflow lines, and similar indirect waste lines.


A trench drain is considered a type of floor drain (see Figure 1-19). Trench drains are continuous drains that can extend for a number of feet in length. Trench drains are popular in indoor parking structures and factory and industrial areas. Each section of a trench drain must have a separate trap.

When floor drains are installed for emergency purposes, the lack of use can result in the evaporation of the trap seal and the escape of sewer gases. Floor drain traps subject to such evaporation are required to be protected with trap seal primer valves or devices. These valves or devices ensure that the trap seal remains intact and prevents the escape of sewer gases.


## EMERGENCY FIXTURES

The two types of emergency fixture are the emergency shower (see Figure 1-20) and the eyewash station. Combination emergency shower and eyewash stations also are available. These fixtures are designed to wash a victim with large volumes of water in the event of a chemical spill or burn or another hazardous material spill.

Emergency fixtures typically are required by Occupational Safety and Health Administration (OSHA)



**Figure 1-18 Floor Drain**



**Figure 1-19 Trench Drain**

Source: Courtesy of Jay R. Smith Company

regulations. In industrial buildings and chemical laboratories, emergency fixtures are sometimes added at the owner's request in addition to the minimum number required by OSHA.

An emergency shower is also called a drench shower because of the large volume of water discharged. An emergency shower should discharge 20 gpm at 30 psi to comply with ANSI/ISEA Z358.1: *Emergency Eyewash and Shower Equipment*. The minimum size water connection is 1 inch for showers and 1¼ inches for combination units. The showerhead typically is installed 7 feet above the finished floor.

Eyewash stations are used to flush the eyes and face, and the water flow rate is gentle so the eyes can remain open during the washing process. The flow rates for an eyewash station range from 0.4 gpm for an eyewash to 3 gpm for an eye/facewash.

Most plumbing codes do not require a drain for emergency showers and eyewash stations to allow greater flexibility in the location of the fixtures and the spot cleanup of any chemicals that may be washed off the victim.



**Figure 1-20 Emergency Shower**

Source: Courtesy of Haws Corporation

ANSI/ISEA Z358.1 requires the water supply to emergency fixtures to be tepid, which is assumed to be in the range of 85°F to 95°F. A medical professional should be consulted to determine the optimal water temperature. When controlling the water temperature, the thermostatic control valve must permit the full flow of cold water in the event of a failure of the hot water supply. This can be accomplished with the use of a fail-safe thermostatic mixing valve or a bypass valve for the thermostatic mixing valve. Since showers and eyewash stations are for extreme emergencies, a supply of water to the fixtures must always be available.

## MINIMUM FIXTURE REQUIREMENTS FOR BUILDINGS

The minimum number of required plumbing fixtures for buildings is specified in the plumbing codes (see Table 1-3 and Table 1-4). Both the International Plumbing Code and the Uniform Plumbing Code base the minimum number of plumbing fixtures on the occupant load of the building. It should be recognized that the occupant load and occupancy of the building

are sometimes significantly different. For example, in an office building, the occupancy is typically 25 percent of the occupant load. The fixture tables have taken this into account in determining the minimum number of fixtures required. Most model plumbing codes do not provide occupancy criteria. The occupant load rules can be found in the building codes.

### **Single-Occupant Toilet Rooms**

The International Plumbing Code has added a requirement for a single-occupant toilet room for use by both sexes. This toilet room is also called a unisex toilet room. The single-occupant toilet room must be designed to meet the accessible fixture requirements of ANSI/ICC A117.1. The purpose of the single-occupant toilet room is to allow a husband to help a wife or vice versa. It also allows a father to oversee a daughter or a mother to oversee a son. These rooms

are especially important for those temporarily incapacitated and the severely incapacitated.

The International Plumbing Code requires a single-occupant toilet room in mercantile and assembly buildings when the total number of water closets required (both men and women) is six or more. When installed in airports, the facilities must be located to allow use before an individual passes through the security checkpoint.

Another feature typically added to single-occupant toilet rooms is a diaper-changing station. This allows either the mother or the father to change a baby's diaper in privacy. To allow all possible uses of the single-occupant toilet room, it often is identified as a family toilet room to clearly indicate that the room is not reserved for the physically challenged.

Table 1-3 Minimum Number of Required Plumbing Fixtures (IPC Table 403.1) <sup>a</sup>										
No.	Classification	Occupancy	Description	Water Closets (Urinals See Section 419.2)		Lavatories		Bathtubs/ Showers	Drinking Fountain <sup>st</sup> (See Section 410.1)	Other
				Male	Female	Male	Female			
1	Assembly	A-1 <sup>d</sup>	Theaters and other buildings for the performing arts and motion pictures	1 per 125	1 per 65	1 per 200		—	1 per 500	1 service sink
			Nightclubs, bars, taverns, dance halls and buildings for similar purposes	1 per 40	1 per 40	1 per 75		—	1 per 500	1 service sink
		A-2 <sup>d</sup>	Restaurants, banquet halls and food courts	1 per 75	1 per 75	1 per 200		—	1 per 500	1 service sink
			Auditoriums without permanent seating, art galleries, exhibition halls, museums, lecture halls, libraries, arcades and gymnasiums	1 per 125	1 per 65	1 per 200		—	1 per 500	1 service sink
			Passenger terminals and transportation facilities	1 per 500	1 per 500	1 per 750		—	1 per 1,000	1 service sink
		A-3 <sup>d</sup>	Places of worship and other religious services	1 per 150	1 per 75	1 per 200		—	1 per 1,000	1 service sink
			Coliseums, arenas, skating rinks, pools and tennis courts for indoor sporting events and activities	1 per 75 for the first 1,500 and 1 per 120 for the remainder exceeding 1,500	1 per 40 for the first 1,520 and 1 per 60 for the remainder exceeding 1,520	1 per 200	1 per 150	—	1 per 1,000	1 service sink
		A-4	Stadiums, amusement parks, bleachers and grandstands for outdoor sporting events and activities	1 per 75 for the first 1,500 and 1 per 120 for the remainder exceeding 1,500	1 per 40 for the first 1,520 and 1 per 60 for the remainder exceeding 1,520	1 per 200	1 per 150	—	1 per 1,000	1 service sink
		A-5	Buildings for the transaction of business, professional services, other services involving merchandise, office buildings, banks, light industrial and similar uses	1 per 25 for the first 50 and 1 per 50 for the remainder exceeding 50		1 per 40 for the first 80 and 1 per 80 for the remainder exceeding 80		—	1 per 100	1 service sink <sup>g</sup>
		2	Business	B	Educational facilities	1 per 50		1 per 50		—
3	Educational	E	Structures in which occupants are engaged in work fabricating, assembly or processing of products or materials	1 per 100		1 per 100		(see Section 411)	1 per 400	1 service sink
4	Factory and industrial	F-1 and F-2	Residential care	1 per 10		1 per 10		1 per 8	1 per 100	1 service sink
			Hospitals, ambulatory nursing home care recipient	1 per room <sup>c</sup>		1 per room <sup>c</sup>		1 per 15	1 per 100	1 service sink per floor
		I-2	Employees, other than residential care <sup>b</sup>	1 per 25		1 per 35		—	1 per 100	—
			Visitors, other than residential care	1 per 75		1 per 100		—	1 per 500	—
		I-3	Prisons <sup>b</sup>	1 per cell		1 per cell		1 per 15	1 per 100	1 service sink
			Reformatories detention centers, and correctional centers <sup>b</sup>	1 per 15		1 per 15		1 per 15	1 per 100	1 service sink
		I-4	Employees <sup>b</sup>	1 per 25		1 per 35		—	1 per 100	—
I-4	Adult day care and child care	1 per 15		1 per 15		1	1 per 100	1 service sink		

<b>Table 1-3 Minimum Number of Required Plumbing Fixtures (IPC Table 403.1)<sup>a</sup></b>										
No.	Classification	Occupancy	Description	Water Closets (Urinals See Section 419.2)		Lavatories		Bathtubs/ Showers	Drinking Fountain <sup>b1</sup> (See Section 410.1)	Other
				Male	Female	Male	Female			
6	<b>Mercantile</b>	<b>M</b>	Retail stores, service stations, shops, salesrooms, markets and shopping centers	1 per 500		1 per 750		—	1 per 1,000	1 service sink <sup>3</sup>
7	<b>Residential</b>	<b>R-1</b>	Hotels, motels, boarding houses (transient)	1 per sleeping unit		1 per sleeping unit		1 per sleeping unit	—	1 service sink
		<b>R-2</b>	Dormitories, fraternities, sororities and boarding houses (not transient)	1 per 10		1 per 10		1 per 8	1 per 100	1 service sink
		<b>R-2</b>	Apartment house	1 per dwelling unit		1 per dwelling unit		1 per dwelling unit	—	1 kitchen sink per dwelling unit; 1 automatic clothes washer connection per 20 dwelling units
		<b>R-3</b>	One- and two-family dwellings	1 per dwelling unit		1 per dwelling unit		1 per dwelling unit	—	1 kitchen sink per dwelling unit; 1 automatic clothes washer connection per dwelling unit
		<b>R-4</b>	Congregate living facilities with 16 or fewer persons	1 per 10		1 per 10		1 per 8	1 per 100	1 service sink
8	<b>Storage</b>	<b>S-1</b> <b>S-2</b>	Structures for the storage of goods, warehouses, storehouse and freight depots. Low and Moderate Hazard	1 per 100		1 per 100		See Section 411	1 per 1,000	1 sink

a. The fixtures shown are based on one fixture being the minimum required for the number of persons indicated or any fraction of the number of persons indicated. The number of occupants shall be determined by the International Building Code.

b. Toilet facilities for employees shall be separate from facilities for inmates or care recipients.

c. A single-occupant toilet room with one water closet and one lavatory serving not more than two adjacent patient sleeping units shall be permitted where such room is provided with direct access from each patient sleeping unit and with provisions for privacy.

d. The occupant load for seasonal outdoor seating and entertainment areas shall be included when determining the minimum number of facilities required.

e. The minimum number of required drinking fountains shall comply with Table 403.1 and Chapter 11 of the International Building Code.

f. Drinking fountains are not required for an occupant load of 15 or fewer.

g. For business and mercantile occupancies with an occupant load of 15 or fewer, service sinks shall not be required.

Excerpted from the 2012 International Plumbing Code, Copyright 2011. Washington, D.C.: International Code Council. Reproduced with permission. All rights reserved. [www.iccsafe.org](http://www.iccsafe.org)

**Table 1-4 Minimum Plumbing Facilities (UPC Table 422.1)<sup>1</sup>**

Each building shall be provided with sanitary facilities, including provisions for persons with disabilities as prescribed by the Department Having Jurisdiction. Table 422.1 applies to new buildings, additions to a building, and changes of occupancy or type in an existing building resulting in increased occupant load.

Type of Occupancy <sup>2</sup>	Water Closets (Fixtures per Person) <sup>3</sup>		Urinals (Fixtures per Person)	Lavatories (Fixtures per Person)		Bathubs or Showers (Fixtures per Person)	Drinking Fountains/Facilities (Fixtures per Person)	Other
<b>A-1</b> Assembly occupancy (fixed or permanent seating) – theatres, concert halls, and auditoriums	Male 1: 1-100 2: 101-200 3: 201-400	Female 1: 1-25 2: 26-50 3: 51-100 4: 101-200 5: 201-300 6: 301-400	Male 1: 1-200 2: 201-300 3: 301-400 4: 401-600	Male 1: 1-200 2: 201-400 3: 401-600 4: 601-750	Female 1: 1-100 2: 101-200 3: 201-300 4: 201-300 5: 301-500 6: 501-750		1: 1-250 2: 251-500 3: 501-750	1 service sink or laundry tray
	Over 400, add 1 fixture for each additional 500 males and 1 fixture for each additional 125 females.		Over 600, add 1 fixture for each additional 300 males.	Over 750, add 1 fixture for each additional 250 males and 1 fixture for each additional 200 females.			Over 750, add 1 fixture for each additional 500 persons.	
<b>A-2</b> Assembly occupancy – restaurants, pubs, lounges, nightclubs, and banquet halls	Male 1: 1-50 2: 51-150 3: 151-300 4: 301-400	Female 1: 1-25 2: 26-50 3: 51-100 4: 101-200 6: 201-300 8: 301-400	Male 1: 1-200 2: 201-300 3: 301-400 4: 401-600	Male 1: 1-150 2: 151-200 3: 201-400	Female 1: 1-150 2: 151-200 4: 201-400		1: 1-250 2: 251-500 3: 501-750	1 service sink or laundry tray
	Over 400, add 1 fixture for each additional 250 males and 1 fixture for each 125 females.		Over 600, add 1 fixture for each additional 300 males.	Over 400, add 1 fixture for each additional 250 males and 1 fixture for each additional 200 females.			Over 750, add 1 fixture for each additional 500 persons.	
<b>A-3</b> Assembly occupancy (typically without fixed or permanent seating) – arcades, places of worship, museums, libraries, lecture halls, gymnasiums (without spectator seating), indoor pools (without spectator seating)	Male 1: 1-100 2: 101-200 3: 201-400	Female 1: 1-25 2: 26-50 3: 51-100 4: 101-200 5: 201-300 6: 301-400	Male 1: 1-200 2: 201-300 3: 301-400 4: 401-600	Male 1: 1-200 2: 201-400 3: 401-600 4: 601-750	Female 1: 1-100 2: 101-200 4: 201-300 5: 301-500 6: 501-750		1: 1-250 2: 251-500 3: 501-750	1 service sink or laundry tray
	Over 400, add 1 fixture for each additional 500 males and 1 fixture for each additional 125 females.		Over 600, add 1 fixture for each additional 300 males.	Over 750, add 1 fixture for each additional 250 males and 1 fixture for each additional 200 females.			Over 750, add 1 fixture for each additional 500 persons.	
<b>A-4</b> Assembly occupancy (indoor activities or sporting events with spectator seating) – swimming pools, skating rinks, arenas, and gymnasiums	Male 1: 1-100 2: 101-200 3: 201-400	Female 1: 1-25 2: 26-50 3: 51-100 4: 101-200 6: 201-300 8: 301-400	Male 1: 1-100 2: 101-200 3: 201-400 4: 401-600	Male 1: 1-200 2: 201-400 3: 401-750	Female 1: 1-100 2: 101-200 4: 201-300 5: 301-500 6: 501-750		1: 1-250 2: 251-500 3: 501-750	1 service sink of laundry tray
	Over 400, add 1 fixture for each additional 500 males and 1 fixture for each 125 females.		Over 600, add 1 fixture for each additional 300 males.	Over 750, add 1 fixture for each additional 250 males and 1 fixture for each additional 200 females.			Over 750, add 1 fixture for each additional 500 persons.	
<b>A-5</b> Assembly occupancy (outdoor activities or sporting events) – amusement parks, grandstands, and stadiums	Male 1: 1-100 2: 101-200 3: 201-400	Female 1: 1-25 2: 26-50 3: 51-100 4: 101-200 6: 201-300 8: 301-400	Male 1: 1-100 2: 101-200 3: 201-400 4: 401-600	Male 1: 1-200 2: 201-400 3: 401-750	Female 1: 1-100 2: 101-200 4: 201-300 5: 301-500 6: 501-750		1: 1-250 2: 251-500 3: 501-750	1 service sink of laundry tray
	Over 400, add 1 fixture for each additional 500 males and 1 fixture for each 125 females.		Over 600, add 1 fixture for each additional 300 males.	Over 750, add 1 fixture for each additional 250 males and 1 fixture for each additional 200 females.			Over 750, add 1 fixture for each additional 500 persons.	
<b>B</b> Business occupancy (office, professional, or service-type transactions) – banks, vet clinics, hospitals, car wash, beauty salons, ambulatory healthcare facilities, laundries and dry cleaning, educational institutions (above high school), or training facilities not located within schools, post offices, and printing shops	Male 1: 1-50 2: 51-100 3: 101-200 4: 201-400	Female 1: 1-15 2: 16-30 3: 31-50 4: 51-100 8: 101-200 11: 201-400	Male 1: 1-100 2: 101-200 3: 201-400 4: 401-600	Male 1: 1-75 2: 76-150 3: 151-200 4: 201-300 5: 301-400	Female 1: 1-50 2: 51-100 3: 101-150 4: 151-200 5: 201-300 6: 301-400		1 per 150	1 service sink or laundry tray
	Over 400, add 1 additional fixture for each additional 500 males and 1 fixture for each additional 150 females.		Over 600, add 1 fixture for each additional 300 males.	Over 400, add 1 fixture for each additional 250 males and 1 fixture for each additional 200 females.				
<b>E</b> Educational occupancy – private or public schools	Male 1 per 50	Female 1 per 30	Male 1 per 100	Male 1 per 40	Female 1 per 40		1 per 150	1 service sink or laundry tray
<b>F1, F2</b> Factory or industrial occupancy – fabricating or assembly work	Male 1: 1-50 2: 51-75 3: 76-100	Female 1: 1-50 2: 51-75 3: 76-100		Male 1: 1-50 2: 51-75 3: 76-100	Female 1: 1-50 2: 51-75 3: 76-100	1 shower for each 15 persons exposed to excessive heat or to skin contamination with poisonous, infectious, or irritating material	1: 1-250 2: 251-500 3: 501-750	1 service sink or laundry tray
	Over 100, add 1 fixture for each additional 40 persons.			Over 100, add 1 fixture for each additional 40 persons.			Over 750, add 1 fixture for each additional 500 persons.	
<b>I-1</b> Institutional occupancy (houses more than 16 persons on a 24-hour basis) – substance abuse centers, assisted living, group homes, or residential facilities	Male 1 per 15	Female 1 per 15		Male 1 per 15	Female 1 per 15	1 per 8	1 per 150	1 service sink or laundry tub

Type of Occupancy <sup>2</sup>		Water Closets (Fixtures per Person) <sup>3</sup>		Urinals (Fixtures per Person)	Lavatories (Fixtures per Person)		Bathtubs or Showers (Fixtures per Person)	Drinking Fountains/Facilities (Fixtures per Person)	Other
I-2 Institutional occupancy – medical, psychiatric, surgical, or nursing home	Prisons	1 per cell			1 per cell		1 per 20	1 per cell block/floor	
	Correctional facilities or juvenile center	1 per 8			1 per 10		1 per 8	1 per floor	1 service sink or laundry tray
	Employee use	Male 1: 1-15 2: 16-35 3: 36-55	Female 1: 1-15 3: 16-35 4: 36-55		Male 1 per 40	Female 1 per 40		1 per 150	
		Over 55, add 1 fixture for each additional 40 persons.							
I-2 Institutional occupancy (any age that receives care for less than 24 hours)		Male 1: 1-15 2: 16-35 3: 36-55	Female 1: 1-15 3: 16-35 4: 36-55		Male 1 per 40	Female 1 per 40		1 per 150	1 service sink or laundry tray
		Over 55, add 1 fixture for each additional 40 persons.							
M Mercantile occupancy (the sale of merchandise and accessible to the public)		Male 1: 1-100 2: 101-200 3: 201-400	Female 1: 1-100 2: 101-200 4: 201-300 6: 301-400	Male 0: 1-200 1: 201-400	Male 1: 1-200 2: 201-400	Female 1: 1-200 2: 201-300 3: 301-400		1: 1-250 2: 251-500 3: 501-750	1 service sink or laundry tray
		Over 400, add 1 fixture for each additional 500 males and 1 fixture for each additional 200 females.		Over 400, add 1 fixture for each additional 500 males.	Over 400, add 1 fixture for each additional 500 males and 1 fixture for each additional 400 females.			Over 750, add 1 fixture for each additional 500 persons.	
R-1 Residential occupancy (minimal stay) – hotels, motels, bed and breakfast homes		1 per sleeping room			1 per sleeping room		1 per sleeping room		1 service sink or laundry tray
R-2 Residential occupancy (long-term or permanent)	Dormitories	Male 1 per 10	Female 1 per 8	1 per 25	Male 1 per 12	Female 1 per 12	1 per 8	1 per 150	1 service sink or laundry tray
		Add 1 fixture for each additional 25 males and 1 fixture for each additional 20 females.		Over 150, add 1 fixture for each additional 50 males.	Add 1 fixture for each additional 20 males and 1 fixture for each additional 15 females.				
	Employee use	Male 1: 1-15 2: 16-35 3: 36-55	Female 1: 1-15 2: 16-35 3: 36-55		Male 1 per 40	Female 1 per 40			
		Over 55, add 1 fixture for each additional 40 persons.							
Apartment house/unit	1 per apartment			1 per apartment		1 per apartment		1 kitchen sink per apartment. 1 laundry tray or 1 automatic clothes washer connection per unit or 1 laundry tray or 1 automatic clothes washer connection for each 12 units	
R-3 Residential occupancy (long-term or permanent in nature) for more than 5 but does not exceed 16 occupants		Male 1 per 10	Female 1 per 8		Male 1 per 12	Female 1 per 12	1 per 8	1 per 150	1 service sink or laundry tray
		Add 1 fixture for each additional 25 males and 1 fixture for each additional 20 females.			Add 1 fixture for each additional 20 males and 1 fixture for each additional 15 females.				
R-3 Residential occupancy (one- and two-family dwellings)	1 per one- and two-family dwelling			1 per one- and two-family dwelling		1 per one- and two-family dwelling		1 kitchen sink and 1 automatic clothes washer connection per one- and two-family dwelling	
R-4 Residential occupancy (residential care or assisted living)		Male 1 per 10	Female 1 per 8		Male 1 per 12	Female 1 per 12	1 per 8	1 per 150	1 service sink or laundry tray
		Add 1 fixture for each additional 25 males and 1 fixture for each additional 20 females.			Add 1 fixture for each additional 20 males and 1 fixture for each additional 15 females.				
S-1, S-2 Storage occupancy – storage of goods, warehouse, aircraft hangar, food products, appliances		Male 1: 1-100 2: 101-200 3: 201-400	Female 1: 1-100 2: 101-200 3: 201-400		Male 1: 1-200 2: 201-400 3: 401-750	Female 1: 1-200 2: 201-400 3: 401-750		1: 1-250 2: 251-500 3: 501-750	1 service sink or laundry tray
		Over 400, add 1 fixture for each additional 500 males and 1 fixture for each additional 150 females.			Over 750, add 1 fixture for each additional 500 persons.			Over 750, add 1 fixture for each additional 500 persons.	

Notes:

1 The figures shown are based upon one fixture being the minimum required for the number of persons indicated or any fraction thereof.

2 A restaurant is defined as a business that sells food to be consumed on the premises.

a. The number of occupants for a drive-in restaurant shall be considered as equal to the number of parking stalls.

b. Hand-washing facilities shall be available in the kitchen for employees.

3 The total number of required water closets for females shall be not less than the total number of required water closets and urinals for males.

Source: 2012 Uniform Plumbing Code Table 422.1 Reprinted with the permission of the International Association of Plumbing and Mechanical Officials. This copyright material and all points or statements in using this material have not been reviewed by IAPMO. The opinions expressed herein are not representations of fact from IAPMO.

# ***Get Connected***

## ***Become a Member Today!***

- 20% discount on *UPC*, *UMC*, and all other IAPMO publications
- Discounts on IAPMO training
- Free subscription to award-winning *Official* magazine



Join Today by calling 800-85-IAPMO, ext 4211 or  
email [MemberServices@iapmo.org](mailto:MemberServices@iapmo.org) for more information





# 2

## Piping Systems

The selection of piping materials depends on the pressure, velocity, temperature, and corrosiveness of the medium conveyed within, initial cost, installation costs, operating costs, and good engineering practice. This chapter provides general application information and guidance regarding common types of pipe materials. The local plumbing code and other regulations regarding specific piping requirements should be referred to prior to beginning any design.

### **SPECIFICATION**

Only new materials should be specified. A typical piping specification should include the following items: type of system and materials, applicable standards, wall thickness, joining and support methods, type of end connection and filler material, bolting, gasket materials, testing, and cleaning.

Piping usually is tested at 1.5 times the working pressure of the system. It should not be buried, concealed, or insulated until it has been inspected, tested, and approved. All defective piping shall be replaced and retested.

All domestic water piping and fittings must conform to NSF/ANSI Standard 61.

### **INSTALLATION**

Pipes should be neatly arranged—straight, parallel, or at right angles to walls—and cut accurately to established measurements. Pipes should be worked into place without springing or forcing. Sufficient headroom should be provided to enable the clearing of lighting fixtures, ductwork, sprinklers, aisles, passageways, windows, doors, and other openings. Pipes should not interfere with access to maintain equipment.

Pipes should be clean (free of cuttings and foreign matter inside), and exposed ends of piping should be covered during site storage and installation. Split, bent, flattened, or otherwise damaged pipe or tubing should not be used. Sufficient clearance should be provided from walls, ceilings, and floors to permit the welding, soldering, or connecting of joints and valves. A minimum of 6 to 10 inches (152.4 to 254 millime-

ters) of clearance should be provided. Installation of pipe above electrical equipment, such as switchgear, panel boards, and elevator machine rooms, should be avoided. Piping systems should not interfere with safety or relief valves.

A means of draining the piping system should be provided. A ½-inch or ¾-inch (12.7-mm or 19.1-mm) hose bibb (provided with a threaded end and vacuum breaker) should be placed at the lowest point of the piping system for this purpose. Constant grades should be maintained for proper drainage, and piping systems should be free of pockets due to changes in elevation.

### **CAST IRON SOIL PIPE**

Cast iron soil pipe is primarily used for sanitary drain, waste, vent, and storm systems. Cast iron soil pipe used in the United States is classified into two major types: hub and spigot and hubless (also called no-hub).

The Cast Iron Soil Pipe Institute (CISPI) utilizes a quality control program to verify that its member foundries are manufacturing cast iron soil pipe and fittings, which are marked with the Institute's collective trademark, to the appropriate standards (CISPI 301 for no-hub and ASTM A74 for hub and spigot). Engineers are encouraged to add the following language to their specification for cast iron soil pipe and fittings: "All cast iron soil pipe and fittings shall bear the collective trademark of the Cast Iron Soil Pipe Institute or receive prior approval by the engineer."

### **Hub and Spigot Pipe and Fittings**

Hub and spigot pipe and fittings have hubs into which the spigot (plain end) of the pipe or fitting is inserted. Both single and double hub versions are available. Hub and spigot pipe and fittings are available in two classes, or thicknesses: service (SV) and extra heavy (XH). The extra-heavy class often is used for underground applications. Service and extra-heavy classes have different outside diameters and are not readily interchangeable (see Tables 2-1 and 2-2). However,

these two different types of pipe and fittings can be connected with adapters available from the manufacturer.

Hub and spigot pipe and fittings are joined using rubber (neoprene) compression gaskets and molten lead and oakum (see Figure 2-1). Sizes include 2-inch to 15-inch (50.8-mm to 381-mm) diameters, and the pipe comes in 5-foot or 10-foot (1.5-meter or 3.1-meter) lengths (see Figure 2-2).

**Hubless Pipe and Fittings**

Hubless cast iron soil pipe and fittings are simply pipe and fittings manufactured without a hub (see Figure 2-3). The method of joining these pipes and fittings utilizes a hubless shielded coupling or a heavy-duty

shielded coupling, which slips over the plain ends of the pipe and fittings and is tightened to seal the joint (see Figure 2-1). Many configurations of fittings ranging in size and shape are available. Hubless cast iron soil pipe and fittings are made in only one class, or thickness. They are available in 1½-inch to 15-inch (38.1-mm to 254-mm) diameters, and the pipe is manufactured in 5-foot to 10-foot (1.5-m to 3.1-m) lengths (see Table 2-3).

**DUCTILE IRON WATER AND SEWER PIPE**

Ductile iron pipe is primarily used in water and sewer systems for underground and industrial applications. Ductile iron is a strong material and is not




Figure 2-1 Cast Iron Soil Pipe Joints




Figure 2-2 Cast Iron Soil Pipe (Extra-Heavy and Service Classes)

Notes : 1. Laying length, all sizes: single hub 5 ft; double hub 5 ft less Y, 5-ft lengths; single hub 10 ft; double hub 10 ft less Y, for 10 ft lengths. 2. If a bead is provided on the spigot end, M may be any diameter between J and M. 3. Hub ends and spigot ends can be made with or without draft, and spigot ends can be made with or without spigot bead.




Figure 2-3 Hubless Cast Iron Soil Pipe and Fittings

**Table 2-1 Dimensions of Hubs, Spigots, and Barrels for Extra-Heavy Cast Iron Soil Pipe and Fittings**

Nominal Inside Diameter (in.)	Inside Diameter of Hub (in.)	Outside Diameter of Spigot <sup>a</sup> (in.)	Outside Diameter of Barrel (in.)	Telescoping Length (in.)	Thickness of Barrel (in.)	
	A	M	J	Y	T (nominal)	T (minimum)
2	3.06	2.75	2.38	2.50	0.19	0.16
3	4.19	3.88	3.50	2.75	0.25	0.22
4	5.19	4.88	4.50	3.00	0.25	0.22
5	6.19	5.88	5.50	3.00	0.25	0.22
6	7.19	6.88	6.50	3.00	0.25	0.22
8	9.50	9.00	8.62	3.50	0.31	0.25
10	11.62	11.13	10.75	3.50	0.37	0.31
12	13.75	13.13	12.75	4.25	0.37	0.31
15	16.95	16.25	15.88	4.25	0.44	0.38

Nominal Inside Diameter Size (in.)	Thickness of Hub (in.)		Width of Hub Bead <sup>b</sup> (in.)	Width of Spigot Bead <sup>b</sup> (in.)	Distance from Lead Groove to End, Pipe and Fittings (in.)	Depth of Lead Groove (in.)	
	Hub Body S (minimum)	Over Bead R (minimum)	F	N	P	G (minimum)	G (maximum)
2	0.18	0.37	0.75	0.69	0.22	0.10	0.19
3	0.25	0.43	0.81	0.75	0.22	0.10	0.19
4	0.25	0.43	0.88	0.81	0.22	0.10	0.19
5	0.25	0.43	0.88	0.81	0.22	0.10	0.19
6	0.25	0.43	0.88	0.81	0.22	0.10	0.19
8	0.34	0.59	1.19	1.12	0.38	0.15	0.22
10	0.40	0.65	1.19	1.12	0.38	0.15	0.22
12	0.40	0.65	1.44	1.38	0.47	0.15	0.29
15	0.46	0.71	1.44	1.38	0.47	0.15	0.22

Note: Laying length, all sizes: single hub 5 ft; double hub 5 ft less Y, 5-ft lengths; single hub 10 ft; double hub 10 ft less Y, for 10 ft lengths.

<sup>a</sup> If a bead is provided on the spigot end, M may be any diameter between J and N.

<sup>b</sup> Hub ends and spigot ends can be made with or without draft, and spigot ends can be made with or without spigot bead.

**Table 2-1(M) Dimensions of Hubs, Spigots, and Barrels for Extra-Heavy Cast Iron Soil Pipe and Fittings**

Nominal Inside Diameter (in.)	Inside Diameter of Hub (mm)	Outside Diameter of Spigot <sup>a</sup> (mm)	Outside Diameter of Barrel (mm)	Telescoping Length (mm)	Thickness of Barrel (mm)	
	A	M	J	Y	T (nominal)	T (minimum)
2	77.72	69.85	60.45	63.50	4.83	4.06
3	106.43	98.55	88.90	69.85	6.35	5.59
4	131.83	123.95	114.30	76.20	6.35	5.59
5	157.23	149.35	139.70	76.20	6.35	5.59
6	182.63	174.75	165.10	76.20	6.35	

Nominal Inside Diameter Size (in.)	Thickness of Hub (mm)		Width of Hub Bead <sup>b</sup> (mm)	Width of Spigot Bead <sup>b</sup> (mm)	Distance from Lead Groove to End, Pipe and Fittings (mm)	Depth of Lead Groove (mm)	
	Hub Body S (minimum)	Over Bead R (minimum)	F	N	P	G (minimum)	G (maximum)
2	4.57	9.40	19.05	17.53	5.59	2.54	4.83
3	6.35	10.92	20.57	19.05	5.59	2.54	4.83
4	6.35	10.92	22.35	20.57	5.59	2.54	4.83
5	6.35	10.92	22.35	20.57	5.59	2.54	4.83
6	6.35	10.92	22.35	20.57	5.59	2.54	4.83
8	8.64	14.99	30.23	28.45	9.65	3.81	5.59
10	10.16	16.51	30.23	28.45	9.65	3.81	5.59
12	10.16	16.51	36.54	35.05	11.94	3.81	5.59
15	11.68	18.03	36.54	35.05	11.94	3.81	5.59

Note: Laying length, all sizes: single hub 1.5 m; double hub 1.5 m less Y, 1.5 m lengths; single hub 3.1 m; double hub 3.1 m less Y, for 3.1 m lengths.

<sup>a</sup> If a bead is provided on the spigot end, M may be any diameter between J and N.

<sup>b</sup> Hub ends and spigot ends can be made with or without draft, and spigot ends can be made with or without spigot bead.

**Table 2-2 Dimensions of Hubs, Spigots, and Barrels for Service Cast Iron Soil Pipe and Fittings**

Nominal Inside Diameter Size (in.)	Inside Diameter of Hub (in.)	Outside Diameter of Spigot <sup>a</sup> (in.)	Outside Diameter of Barrel (in.)	Telescoping Length (in.)	Thickness of Barrel (in.)	
	A	M	J	Y	T (nominal)	T (minimum)
2	2.94	2.62	2.30	2.50	0.17	0.14
3	3.94	3.62	3.30	2.75	0.17	0.14
4	4.94	4.62	4.30	3.00	0.18	0.15
5	5.94	5.62	5.30	3.00	0.18	0.15
6	6.94	6.62	6.30	3.00	0.18	0.15
8	9.25	8.75	8.38	3.50	0.23	0.17
10	11.38	10.88	10.50	3.50	0.28	0.22
12	13.50	12.88	12.50	4.25	0.28	0.22
15	16.95	16.00	15.88	4.25	0.36	0.30

Nominal Inside Diameter Size (in.)	Thickness of Hub (in.)		Width of Hub Bead <sup>b</sup> (in.)	Width of Spigot Bead <sup>b</sup> (in.)	Distance from Lead Groove to End, Pipe and Fittings (in.)	Depth of Lead Groove (in.)	
	Hub Body S (minimum)	Over Bead R (minimum)	F	N	P	G (minimum)	G (maximum)
2	0.13	0.34	0.75	0.69	0.22	0.10	0.19
3	0.16	0.37	0.81	0.75	0.22	0.10	0.19
4	0.16	0.37	0.88	0.81	0.22	0.10	0.19
5	0.16	0.37	0.88	0.81	0.22	0.10	0.19
6	0.18	0.37	0.88	0.81	0.22	0.10	0.19
8	0.19	0.44	1.19	1.12	0.38	0.15	0.22
10	0.27	0.53	1.19	1.12	0.38	0.15	0.22
12	0.27	0.53	1.44	1.38	0.47	0.15	0.22
15	0.30	0.58	1.44	1.38	0.47	0.15	0.22

Note: Laying length, all sizes: single hub 5 ft; double hub 5 ft less Y, 5-ft lengths; single hub 10 ft; double hub 10 ft less Y, for 10 ft lengths.

<sup>a</sup> If a bead is provided on the spigot end, M may be any diameter between J and M.

<sup>b</sup> Hub ends and spigot ends can be made with or without draft, and spigot ends can be made with or without spigot bead.

**Table 2-2(M) Dimensions of Hubs, Spigots, and Barrels for Service Cast Iron Soil Pipe and Fittings**

Nominal Inside Diameter Size (in.)	Inside Diameter of Hub (mm)	Outside Diameter of Spigot <sup>a</sup> (mm)	Outside Diameter of Barrel (mm)	Telescoping Length (mm)	Thickness of Barrel (mm)	
	A	M	J	Y	T (nominal)	T (minimum)
2	74.68	66.55	58.42	63.50	4.32	3.56
3	100.08	91.95	83.82	69.85	4.32	3.56
4	125.48	117.35	109.22	76.20	4.57	3.81
5	150.88	142.75	134.62	76.20	4.57	3.81
6	176.28	168.15	160.02	76.20	5.57	

Diameter Size (in.)	Inside of Hub (mm)		Spigot Bead <sup>b</sup> (mm)	Lead Groove to End (mm)	Lead Groove (mm)	
	Hub Body S (minimum)	Over Bead R (minimum)	F	P	G (minimum)	G (maximum)
2	3.30	8.64	19.05	5.59	2.54	4.83
3	4.06	9.40	20.57	5.59	2.54	4.83
4	4.06	9.40	22.35	5.59	2.54	4.83
5	4.06	9.40	22.35	5.59	2.54	4.83
6	4.57	9.40	22.35	5.59	2.54	4.83
8	4.83	11.26	30.23	9.65	3.81	5.59
10	6.86	13.46	30.23	9.65	3.81	5.59
12	6.86	13.46	36.58	11.94	3.81	5.59
15	7.62	14.73	36.58	11.94	3.81	5.59

Note: Laying length, all sizes: single hub 1.5 m; double hub 1.5 m less Y, 1.5 m lengths; single hub 3.1 m; double hub 3.1 m less Y, for 3.1 m lengths.

<sup>a</sup> If a bead is provided on the spigot end, M may be any diameter between J and M.

<sup>b</sup> Hub ends and spigot ends can be made with or without draft, and spigot ends can be made with or without spigot bead.

as brittle as cast iron. Ductile iron pipe is available in seven classes (50–56) and in 3-inch to 64-inch (76-mm to 1,626-mm) diameters. The pipe is manufactured with bell ends and in a length of either 18 feet or 20 feet (5.49 m or 6.1 m).

Cement-lined piping typically is required for water distribution systems. The cement lining provides a protective barrier between the potable water supply and the ductile iron pipe to prevent impurities and contaminants from leaching into the water supply. The pressure ratings for cement-lined ductile iron pipe can be found in Table 2-4.

The methods of joining are push-on rubber (neoprene) compression gasket, mechanical, and flanged. Special joints also are available, such as restrained, ball and socket, and grooved and shouldered. (See Figure 2-4.)

## CONCRETE PIPE

Concrete pipe is used for sanitary sewers, storm sewers, culverts, detention systems, and low-pressure force mains. Reinforced concrete pipe is the most durable and economical of all piping products. It is recommended for installations where low, moderate, or severe cover and/or live load conditions exist and structural failure might endanger life or property. Reinforced pipe, even after ultimate failure, retains its shape and will not collapse. Concrete pipe typically is installed by the site contractor during site preparation rather than the plumbing trade.

This pipe is available in 4-inch to 36-inch (100-mm to 900-mm) diameters. Nonreinforced concrete pipe is not available in all markets. Reinforced concrete pipe is made by the addition of steel wire or steel bars. It is used primarily for sewage and storm drainage and is available in 12-inch to 144-inch (300-mm to 3,600-mm) diameters (see Table 2-5). Concrete pipe is available as a bell and spigot or gasketed bell design.

The methods of joining are rubber (elastomeric) gasket and cement plaster (becoming obsolete).

## COPPER PIPE

Copper pipe is used for drain, waste, and vent (DWV), water supply, boiler feed lines, refrigeration, and similar purposes.

### Copper Water Tube

Copper water tube is a seamless, almost pure copper material manufactured to the requirements of ASTM B88. It has three basic wall thickness dimensions, designated as Types K, L, and M, with Type K being the thickest, Type L being of intermediate thickness, and Type M being the thinnest. All three types of tube are commonly manufactured from copper alloy C12200, which has a chemical composition of 99.9 percent minimum copper (Cu) and silver (Ag) combined and a maximum allowable range of phosphorus (P) of 0.015–0.040 percent.

Seamless copper water tube is manufactured in sizes of ¼-inch to 12-inch (6.35-mm to 304.8-mm) (nominal) diameters. Types K and L are manufactured in drawn temper (hard) of ¼-inch to 12-inch (6.35-mm to 304.8-mm) and annealed temper (soft) coils of ¼-inch to 2-inch (6.35-mm to 50.8-mm) (nominal) diameters, while Type M is manufactured only in drawn (hard) temper of ¼-inch to 12-inch (6.35-mm to 304.8-mm) (nominal) diameters. See Table 2-6 for the commercially available lengths of copper plumbing tube. See Tables 2-7, 2-8, and 2-9 for dimensional and capacity data for Type K, L, and M copper tube respectively.

Seamless copper water tube of drawn temper is required to be identified with a colored stripe that contains the manufacturer's name or trademark, type of tube, and nation of origin. This stripe is green for Type K, blue for Type L, and red for Type M. In addition

**Table 2-3 Dimensions of Spigots and Barrels for Hubless Pipe and Fittings**

Nom. Size	Inside Diam. Barrel		Outside Diam. Barrel		Outside Diam. Spigot		Width Spigot Bead		Thickness of Barrel				Gasket Positioning Lug		Laying Length, L <sup>a, b</sup>	
	(in.)	(mm)	(in.)	(mm)	(in.)	(mm)	(in.)	(mm)	(in.)	(mm)	(in.)	(mm)	(in.)	(mm)	5 Ft	10 Ft
	B		J		M		N		T-Nom.		T-Min.		W			
1½	1.50	38.1	1.90	48.26	1.96	48.78	0.25	6.35	0.16	3.3	0.13	0.33	1.13	28.7	60	120
2	1.96	49.8	2.35	59.69	2.41	61.21	0.25	6.35	0.16	3.3	0.13	0.33	1.13	28.7	60	120
3	2.96	75.2	3.35	85.09	3.41	86.61	0.25	6.35	0.16	3.3	0.13	0.33	1.13	28.7	60	120
4	3.94	100.08	4.38	111.25	4.44	112.78	0.31	7.87	0.19	3.81	0.15	0.38	1.13	28.7	60	120
5	4.94	125.48	5.30	134.62	5.36	136.14	0.31	7.87	0.19	3.81	0.15	0.38	1.50	38.1	60	120
6	5.94	150.88	6.30	160.02	6.36	161.54	0.31	7.87	0.19	3.81	0.15	0.38	1.50	38.1	60	120
8	7.94	201.68	8.38	212.85	8.44	214.38	0.31	7.87	0.23	4.32	0.17	0.43	2.00	50.8	60	120
10	10.00	254	10.56	268.22	10.62	269.75	0.31	7.87	0.28	5.59	0.22	0.56	2.00	50.8	60	120
12	11.94	303.28	12.50	317.5	12.62	320.55	0.31	7.87	0.28	5.59	0.22		2.75	69.85	60	120
15	15.11	383.79	15.83	402.08	16.12	409.55	0.31	7.87	0.36	7.62	0.30		2.75	69.85	60	120

<sup>a</sup> Laying lengths as listed are for pipe only.

<sup>b</sup> Laying lengths may be either 5 ft 0 in. or 10 ft 0 in. (1.5 or 3.1 m) long.

to the colored stripe, the tube is incised with the type of tube and the manufacturer's name or trademark at intervals not in excess of 1½ feet. Annealed (soft) coils or straight lengths are not required to be identified with a colored stripe.

Various types of fittings of the compression, grooved, and mechanical types may be used (see Figures 2-5 and 2-6). O-rings in fittings are to be ethylene propylene diene monomer (EPDM) or hydrogenated nitrile butadiene rubber (HNBR).

Joints in copper water tube typically are soldered, flared, or brazed, although roll-grooved and mechanical joints also are permitted. Soldered joints should be installed in accordance with the requirements and procedures detailed in ASTM B828, and the flux used should meet the requirements of ASTM B813. The mechanical joining of copper tubing is done with specially manufactured fittings. One type known as press-connect is


**Table 2-4 Standard Minimum Pressure Classes of Ductile Iron Single-Thickness Cement-Lined Pipe**

Size (in.)	Pressure Rating (psi)	Nominal Wall Thickness (in.)	Pipe O.D. (in.)	Weight in Pounds			
				Per Foot Plain End	Flange	Fastite Bell	Maximum Length
4	350+	0.32	4.8	13.8	13	10	262
6	350+	0.34	6.9	21.4	17	15	450
8	350+	0.36	9.05	30.1	27	21	635
10	350+	0.38	11.1	39.2	38	27	830
12	350+	0.4	13.2	49.2	59	32	1050
14	350+	0.42	15.3	60.1	70	57	1300
16	350+	0.43	17.4	70.1	90	64	1520
18	350+	0.44	19.5	80.6	88	73	1735
20	350+	0.45	21.6	91.5	112	81	1980
24	350+	0.47	25.8	114.4	155	96	2480
30	250	0.51	32	154.4	245	164	3420
36	250	0.58	38.3	210.3	354	214	4670
42	250	0.65	44.5	274	512	289	6140
48	250	0.72	50.8	346.6	632	354	7745
54	250	0.81	57.56	441.9	716	439	9770
60	250	0.83	61.61	485	1113	819	11390
64	250	0.87	65.67	542	1824	932	13320


fastened with a crimping tool with interchangeable jaws of ½ inch to 4 inches (12.7 mm to 101.6 mm). Another known as push-connect is pushed on the tube to make a connection and is held in place by an internal or integral stainless steel gripper ring. A third method is accomplished by roll-grooving the end of the tube and using a gasketed fitting.

**Table 2-5 Dimensions and Approximate Weights of Circular Concrete Pipe**



Reinforced Concrete Culvert, Storm Drain and Sewer Pipe						
Internal Diameter, in.	Internal Diameter, mm	Waterway Area, square meters	WALL B		WALL C	
			Minimum Wall Thickness, mm	Approximate Weight, Kg/meter	Minimum Wall Thickness, mm	Approximate Weight, Kg/meter
8*	200	0.03	51	90	—	—
10*	250	0.05	51	130	—	—
12	300	0.07	51	140	—	—
15	375	0.11	57	190	—	—
18	450	0.16	64	250	—	—
21	525	0.22	70	320	—	—
24	600	0.29	76	390	95	545
27	675	0.37	83	480	102	625
30	750	0.46	89	570	108	710
33	825	0.55	95	670	114	820
36	900	0.66	102	780	121	975
42	1050	0.89	114	1020	133	1205
48	1200	1.17	127	1290	146	1505
54	1350	1.48	140	1590	159	1800
60	1500	1.82	152	1925	171	2190
66	1650	2.21	165	2295	184	2580
72	1800	2.62	178	2695	197	3000
78	1950	3.08	190	3125	210	3585
84	2100	3.57	203	3585	222	3960
90	2250	4.1	216	4075	235	4495
96	2400	4.67	229	4600	248	4990
102	2550	5.27	241	5180	260	5595
108	2700	5.91	254	5750	273	6190



Standard Push-On Joint




Cast Iron Flanged Fittings



Push-On Fittings



Standard Bends & Offsets



Standard Tees & Crosses



Standard Bends

Figure 2-4 Joints and Fittings for Ductile Iron Pipe

**Table 2-6 Commercially Available Lengths of Copper Plumbing Tube**Tube type: Type K; Color code: Green ASTM B88<sup>a</sup>

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¼ to 8 in.	20 ft	20 ft	¼ to 1 in.	60 ft	100 ft
10 in.	18 ft	18 ft	1¼ and 1½ in.	60 ft	—
12 in.	12 ft	12 ft	2 in.	40 ft	45 ft

Standard applications<sup>c</sup>: Domestic water service and distribution, fire protection, solar, fuel/fuel oil, HVAC, snow melting

Tube type: Type L; Color code: Blue ASTM B88

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¼ to 8 in.	20 ft	20 ft	¼ to 1 in.	60 ft	100 ft
12 in.	18 ft	18 ft	1¼ and 1½ in.	60 ft	—
—	—	—	2 in.	40 ft	45 ft

Standard applications<sup>c</sup>: Domestic water service and distribution, fire protection, solar, fuel/fuel oil, HVAC, snow melting, natural gas, liquefied petroleum gas

Tube type: Type M; Color code: Red ASTM B88

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¼ to 12 in.	20 ft	—	—	—	—

Standard applications<sup>c</sup>: Domestic water service and distribution, fire protection, solar, fuel/fuel oil, HVAC, snow melting

Tube type: DWV; Color code: Yellow ASTM B306

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¼ to 8 in.	20 ft	—	—	—	—

Standard applications<sup>c</sup>: Drain, waste, and vent, solar, HVAC

Tube type: ACR; Color code: Blue ASTM B280

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¾ to 4½ in.	20 ft	<sup>d</sup>	½ and 1½ in.	50 ft	—

Standard applications<sup>c</sup>: Air-conditioning, refrigeration, natural gas, liquefied petroleum gas

Tube type: OXY, MED, OXY/MED, OXY/ACR, ACR/MED; Color code: (K) Green, (L) Blue ASTM B819

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¼ to 8 in.	20 ft	N/A	—	—	—

Standard applications<sup>c</sup>: Medical gas

Tube type: Type G; Color code: Yellow ASTM B837

Commercially Available Lengths <sup>b</sup>					
Straight Lengths			Coils		
Pipe Diameter	Drawn	Annealed	Pipe Diameter	Drawn	Annealed
¾ to 1½ in.	12 ft	12 ft	¾ to 7⁄8 in.	60 ft	100 ft

Standard applications<sup>c</sup>: Natural gas, liquefied petroleum gas

a Tube made to other ASTM standards is also intended for plumbing applications, although ASTM B88 is by far the most widely used. ASTM B698: *Standard Classifications* lists six plumbing tube standards, including ASTM B88.

b Individual manufacturers may have commercially available lengths in addition to those shown in this table.

c Many other copper and copper alloy tubes and pipes are available for specialized applications. For information on these products, contact the Copper Development Association.

d Available as special order only.



### Copper Drainage Tube

Copper drainage tube for DWV applications is a seamless copper tube conforming to the requirements of ASTM B306. Copper drainage tube is furnished in drawn (hard) temper only in sizes of 1¼ inch to 8 inches (31.8 mm to 203.2 mm). It is required to be identified by a yellow stripe giving the manufacturer’s name or trademark, nation of origin, and the letters “DWV.” It also is required to be incised with the manufacturer’s name or trademark and the letters “DWV” at intervals no greater than 1½ feet. See Table 2-10 for dimensional data for Type DWV copper tube.

Fittings for use with copper drainage pipe are usually those conforming to either ANSI/ASME B16.23 or ANSI/ASME B16.29. They are required to carry the incised mark “DWV.”

Joints for drainage applications can be soldered or brazed (see Figure 2-7).

### Medical Gas Tube

Medical gas tube is shipped cleaned and capped and is furnished in Type K or L wall thickness in drawn (hard) temper only. It is identified with an incised mark containing the manufacturer’s name or trademark at

**Table 2-7 Dimensional and Capacity Data—Type K Copper Tube**

Diameter (in.)			Wall thickness (in.)	Cross-sectional area (sq. in.)			Weight per foot (lb)		
Nominal (in.)	Actual inside	Actual outside		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
¼	0.305	0.375	0.035	0.110	0.073	0.034	0.145	0.033	0.167
⅜	0.402	0.500	0.049	0.196	0.127	0.069	0.269	0.055	0.324
½	0.527	0.625	0.049	0.307	0.218	0.089	0.344	0.094	0.438
⅝	0.652	0.750	0.049	0.442	0.334	0.108	0.418	0.145	0.563
¾	0.745	0.875	0.065	0.601	0.436	0.165	0.641	0.189	0.830
1	0.995	1.125	0.065	0.993	0.778	0.216	0.839	0.338	1.177
1¼	1.245	1.375	0.065	1.484	1.217	0.267	1.04	0.53	1.57
1½	1.481	1.625	0.072	2.072	1.722	0.350	1.36	1.22	2.58
2	1.959	2.125	0.083	3.546	3.013	0.533	2.06	1.31	3.37
2½	2.435	2.625	0.095	5.409	4.654	0.755	2.93	2.02	4.95
3	2.907	3.125	0.109	7.669	6.634	1.035	4.00	2.88	6.88
3½	3.385	3.625	0.120	10.321	8.999	1.322	5.12	3.91	9.03
4	3.857	4.125	0.134	13.361	11.682	1.679	6.51	5.07	11.58
5	4.805	5.125	0.160	20.626	18.126	2.500	9.67	7.87	17.54
6	5.741	6.125	0.192	29.453	25.874	3.579	13.9	11.2	25.1
8	7.583	8.125	0.271	51.826	45.138	6.888	25.9	19.6	45.5
10	9.449	10.125	0.338	80.463	70.085	10.378	40.3	30.4	70.7
12	11.315	12.125	0.405	115.395	100.480	14.915	57.8	43.6	101.4

Nominal Diam. (in.)	Circumference (in.)		Ft <sup>2</sup> of Surface per Lineal Foot		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	Ft <sup>3</sup>	Gal	1 Ft <sup>3</sup>	1 Gal	1 Lb of Water
¼	1.178	0.977	0.098	0.081	.00052	.00389	1923	257	30.8
⅜	1.570	1.262	0.131	0.105	.00088	.00658	1136	152	18.2
½	1.963	1.655	0.164	0.138	.00151	.01129	662	88.6	10.6
⅝	2.355	2.047	0.196	0.171	.00232	.01735	431	57.6	6.90
¾	2.748	2.339	0.229	0.195	.00303	.02664	330	37.5	5.28
1	3.533	3.124	0.294	0.260	.00540	.04039	185	24.8	2.96
1¼	4.318	3.909	0.360	0.326	.00845	.06321	118	15.8	1.89
1½	5.103	4.650	0.425	0.388	.01958	.14646	51.1	6.83	0.817
2	6.673	6.151	0.556	0.513	.02092	.15648	47.8	6.39	0.765
2½	8.243	7.646	0.688	0.637	.03232	.24175	30.9	4.14	0.495
3	9.813	9.128	0.818	0.761	.04607	.34460	21.7	2.90	0.347
3 ½	11.388	10.634	0.949	0.886	.06249	.46745	15.8	2.14	0.257
4	12.953	12.111	1.080	1.009	.08113	.60682	12.3	1.65	0.197
5	16.093	15.088	1.341	1.257	.12587	.94151	7.94	1.06	0.127
6	19.233	18.027	1.603	1.502	.17968	1.3440	5.56	0.744	0.089
8	25.513	23.811	2.126	1.984	.31345	2.3446	3.19	0.426	0.051
10	31.793	29.670	2.649	2.473	.48670	3.4405	2.05	0.291	0.033
12	38.073	35.529	3.173	2.961	.69778	5.2194	1.43	0.192	0.023

intervals not in excess of 1½ feet. It is color-coded green for Type K and blue for Type L.

Fittings for medical gas tube may be those conforming to ANSI/ASME B16.22, ANSI/ASME B16.18 (where wrought copper fittings are not available), or ANSI/ASME B16.50. They also may be fittings meeting the requirements of MSS SP-73.

Joints in medical gas systems are of the socket/lap type and are typically brazed with copper-phosphorous or copper-phosphorous-silver (BCuP) alloys while being purged with oil-free nitrogen.

### Natural and Liquefied Petroleum

Natural and liquefied petroleum pipe is furnished in Type G wall thickness. It is color-coded yellow per ASTM B837.

The methods of joining are brazing, compression fittings, and specialized mechanical compression couplings.

### GLASS PIPE

Glass is unique for several reasons. First, it is clear, allowing the contents to be visible. Second, it is the

**Table 2-7(M) Dimensional and Capacity Data—Type K Copper Tube**

Diameter			Wall thickness (mm)	Cross-sectional area (10 <sup>3</sup> mm <sup>2</sup> )			Weight per foot (kg)		
Nominal (in.)	Actual inside (mm)	Actual outside (mm)		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
¼	7.90	9.53	0.89	0.071	0.049	0.022	0.216	0.049	0.249
⅜	10.21	12.70	1.25	0.127	0.082	0.045	0.401	0.082	0.483
½	13.39	15.88	1.25	0.198	0.141	0.057	0.512	0.140	0.652
⅝	16.56	19.05	1.25	0.285	0.216	0.070	0.623	0.216	0.839
¾	18.92	22.23	1.65	0.388	0.281	0.107	0.955	0.282	1.236
1	25.27	28.58	1.65	0.641	0.501	0.139	1.250	0.504	1.753
1¼	31.62	34.93	1.65	0.957	0.785	0.172	1.549	0.789	2.339
1½	37.62	41.28	1.83	1.337	1.111	0.226	2.026	1.817	3.843
2	49.76	53.98	2.11	2.288	1.944	0.344	3.068	1.951	5.020
2½	61.85	66.68	2.41	3.490	3.003	0.487	4.364	3.009	7.373
3	73.84	79.38	2.77	4.948	4.280	0.668	5.958	4.290	10.248
3½	85.98	92.08	3.05	6.659	5.806	0.853	7.626	5.824	13.450
4	97.97	104.78	3.40	8.620	7.537	1.083	9.697	7.552	17.248
5	122.05	130.18	4.06	13.307	11.694	1.613	14.404	11.722	26.126
6	145.82	155.58	4.88	19.002	16.693	2.309	20.704	16.682	37.387
8	192.61	206.38	6.88	33.436	29.121	4.444	38.578	29.194	67.772
10	240.01	257.18	8.59	51.912	45.216	6.696	60.027	45.281	105.308
12	287.40	307.98	10.29	74.448	64.826	9.623	86.093	64.942	151.035

Nominal Diam. (in.)	Circumference (mm)		M <sup>2</sup> of surface per Meter		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	(L)	(L)	1 L	1 L	1 kg of Water
¼	29.92	24.82	0.030	0.025	0.048	0.048	20.699	20.696	20.678
⅜	39.88	32.06	0.040	0.032	0.077	0.082	12.228	12.240	12.219
½	49.86	42.04	0.050	0.042	0.140	0.140	7.126	7.135	7.117
⅝	59.82	51.99	0.060	0.052	0.216	0.216	4.639	4.638	4.632
¾	69.80	59.41	0.070	0.059	0.282	0.331	3.552	3.020	3.545
1	89.74	79.35	0.090	0.079	0.502	0.502	1.991	1.997	1.987
1¼	109.68	99.29	0.110	0.099	0.785	0.785	1.270	1.272	1.269
1½	129.62	118.11	0.130	0.118	1.819	1.819	0.550	0.550	0.549
2	169.49	156.24	0.170	0.156	1.944	1.943	0.515	0.515	0.514
2½	209.37	194.21	0.210	0.194	3.003	3.002	0.333	0.333	0.332
3	249.25	231.85	0.249	0.232	4.280	4.279	0.234	0.234	0.233
3½	289.26	270.10	0.289	0.270	5.806	5.805	0.170	0.172	0.173
4	329.01	307.62	0.329	0.308	7.537	7.536	0.133	0.133	0.132
5	408.76	383.24	0.409	0.383	11.694	11.692	0.086	0.085	0.085
6	488.52	457.89	0.489	0.458	16.693	16.690	0.060	0.060	0.060
8	648.03	604.80	0.648	0.605	29.121	29.115	0.034	0.034	0.034
10	807.54	753.62	0.807	0.754	45.216	42.724	0.022	0.023	0.022
12	967.05	902.44	0.967	0.903	64.826	64.814	0.015	0.016	0.015

piping system that is least susceptible to fire. Glass does not burn, but with enough heat, it can melt. In buildings with a return air plenum for heating, ventilation, and air-conditioning (HVAC), glass pipe can be used to meet building fire code requirements.

Glass pipe (see Figure 2-8) is made of low-expansion borosilicate glass with a low alkali content. It most commonly is used for chemical waste drainlines, vent piping, and purified water piping. Glass also is used for chemical waste DWV systems in high schools, colleges, laboratories, industrial plants, and hospitals where hot fluids are disposed down the system constantly. (Hot fluids are those at 200°F with no dilu-

tion.) The coefficient of glass expansion is 0.2 inch/100 feet/100°F (5 mm/30.4 m/37.8°C), and glass is very stable and can operate up to 300°F (148.9°C).

Glass pipe comes in two options: as pressure ½-inch to 8-inch (13-mm to 203-mm) pipe and as drainage 1½-inch to 6-inch (38-mm to 153-mm) pipe. It is available in standard 5-foot and 10-foot (1.5-m and 3.1-m) lengths. Nonstandard lengths are available, or the pipe can be field cut or fabricated to special lengths. Glass can be installed aboveground (padded or with coated hangers) or buried (with Styrofoam blocking around the pipe). Glass is fragile, so care must be taken to prevent scratches or impact by sharp objects.

**Table 2-8 Dimensional and Capacity Data—Type L Copper Tube**

Diameter (in.)			Wall thickness (in.)	Cross-sectional area (sq. in.)			Weight per foot (lb)		
Nominal (in.)	Actual inside	Actual outside		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
¼	0.315	0.375	0.030	0.110	0.078	0.032	0.126	0.034	0.160
⅜	0.430	0.500	0.035	0.196	0.145	0.051	0.198	0.063	0.261
½	0.545	0.625	0.040	0.307	0.233	0.074	0.285	0.101	0.386
⅝	0.666	0.750	0.042	0.442	0.348	0.094	0.362	0.151	0.513
¾	0.785	0.875	0.045	0.601	0.484	0.117	0.445	0.210	0.665
1	1.025	1.125	0.050	0.993	0.825	0.168	0.655	0.358	1.013
1¼	1.265	1.375	0.055	1.484	1.256	0.228	0.884	0.545	1.429
1½	1.505	1.625	0.060	2.072	1.778	0.294	1.14	0.77	1.91
2	1.985	2.125	0.070	3.546	3.093	0.453	1.75	1.34	3.09
2½	2.465	2.625	0.080	5.409	4.770	0.639	2.48	2.07	4.55
3	2.945	3.125	0.090	7.669	6.808	0.861	3.33	2.96	6.29
3½	3.425	3.625	0.100	10.321	9.214	1.107	4.29	4.00	8.29
4	3.905	4.125	0.110	13.361	11.971	1.390	5.38	5.20	10.58
5	4.875	5.125	0.125	20.626	18.659	1.967	7.61	8.10	15.71
6	5.845	6.125	0.140	29.453	26.817	2.636	10.2	11.6	21.8
8	7.725	8.125	0.200	51.826	46.849	4.977	19.3	20.3	39.6
10	9.625	10.125	0.250	80.463	72.722	7.741	30.1	31.6	61.7
12	11.565	12.125	0.280	115.395	104.994	10.401	40.4	45.6	86.0

Nominal Diam. (in.)	Circumference (in.)		Ft <sup>2</sup> of Surface per Lineal Foot		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	Ft <sup>3</sup>	Gal	1 Ft <sup>3</sup>	1 Gal	1 Lb of Water
¼	1.178	0.989	0.098	0.082	.00054	.0040	1852	250	29.6
⅜	1.570	1.350	0.131	0.113	.00100	.0075	1000	133	16.0
½	1.963	1.711	0.164	0.143	.00162	.0121	617.3	82.6	9.87
⅝	2.355	2.091	0.196	0.174	.00242	.0181	413.2	55.2	6.61
¾	2.748	2.465	0.229	0.205	.00336	.0251	297.6	40.5	4.76
1	3.533	3.219	0.294	0.268	.00573	.0429	174.5	23.3	2.79
1¼	4.318	3.972	0.360	0.331	.00872	.0652	114.7	15.3	1.83
1½	5.103	4.726	0.425	0.394	.01237	.0925	80.84	10.8	1.29
2	6.673	6.233	0.556	0.519	.02147	.1606	46.58	6.23	0.745
2½	8.243	7.740	0.688	0.645	.03312	.2478	30.19	4.04	0.483
3	9.813	9.247	0.818	0.771	.04728	.3537	21.15	2.83	0.338
3½	11.388	10.760	0.949	0.897	.06398	.4786	15.63	2.09	0.251
4	12.953	12.262	1.080	1.022	.08313	.6218	12.03	1.61	0.192
5	16.093	15.308	1.341	1.276	.12958	.9693	7.220	1.03	0.123
6	19.233	18.353	1.603	1.529	.18622	1.393	5.371	0.718	0.0592
8	25.513	24.465	2.126	2.039	.32534	2.434	3.074	0.411	0.0492
10	31.793	30.223	2.649	2.519	.50501	3.777	1.980	0.265	0.0317
12	38.073	36.314	3.173	3.026	.72912	5.454	1.372	0.183	0.0219

Glass pipe is joined with either of two types of coupling, depending on whether it is a “bead to bead” or “bead to cut glass end” application (see Figures 2-9 and 2-10). Joints are made by using compression-type couplings consisting of 300 series stainless steel outer bands, electrometric compression liners, and sealing members of chemically inert tetrafluoroethylene (TFE).

Fittings are made of borosilicate glass and include a full range of sanitary and plumbing fittings (see Figure 2-11).

## STEEL PIPE

Steel pipe specified for heating, air-conditioning, plumbing, gas, and air lines conforms to ASTM A53. Steel pipe conforming to ASTM A53 is intended for coiling, bending, forming, and other special purposes. Steel pipe that meets the requirements of ASTM A106 is used for high-temperature service and is suitable for coiling, bending, and forming.

Steel pipe is also available manufactured to standards of the American Petroleum Institute (API). For example, API 5L steel pipe is in all respects the same as ASTM A53, but manufactured under API standards

**Table 2-8(M) Dimensional and Capacity Data—Type L Copper Tube**

Nominal (in.)	Diameter		Wall thickness (mm)	Cross-sectional area (10 <sup>3</sup> mm <sup>2</sup> )			Weight per foot (kg)		
	Actual inside (mm)	Actual outside (mm)		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
¼	8.00	9.53	0.76	0.071	0.050	0.021	0.188	0.051	0.239
⅜	10.92	12.70	0.89	0.127	0.094	0.033	0.295	0.094	0.389
½	13.84	15.88	1.02	0.198	0.150	0.048	0.425	0.150	0.575
⅝	16.92	19.05	1.07	0.285	0.225	0.061	0.539	0.225	0.764
¾	19.94	22.23	1.14	0.388	0.312	0.076	0.678	0.313	0.991
1	26.04	28.58	1.27	0.641	0.532	0.108	0.976	0.533	1.509
1¼	32.13	34.93	1.40	0.957	0.810	0.147	1.317	0.812	2.129
1½	38.23	41.28	1.52	1.337	1.147	0.190	1.698	1.147	2.845
2	50.42	53.98	1.78	2.288	1.996	0.292	2.607	1.996	4.603
2½	62.61	66.68	2.03	3.490	3.077	0.412	3.694	3.083	6.777
3	74.80	79.38	2.29	4.948	4.392	0.556	4.960	4.409	9.369
3½	87.00	92.08	2.54	6.659	5.945	0.714	6.390	5.958	12.348
4	99.19	104.78	2.79	8.620	7.723	0.897	8.014	7.745	15.759
5	123.83	130.18	3.18	13.307	12.038	1.269	11.335	12.065	23.400
6	148.46	155.58	3.56	19.002	17.301	1.701	15.193	17.278	32.471
8	196.22	206.38	5.08	33.436	30.225	3.211	28.747	30.237	58.984
10	244.48	257.18	6.35	51.912	46.917	4.994	44.834	47.068	91.902
12	293.75	307.98	7.11	74.448	67.738	6.710	60.176	67.921	128.097

Nominal Diam. (in.)	Circumference (mm)		M <sup>2</sup> of surface per Meter		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	(L)	(L)	1L	1L	1 kg of Water
¼	29.92	25.12	0.030	0.025	0.050	0.050	19.935	20.132	19.872
⅜	39.88	34.29	0.040	0.034	0.093	0.093	10.764	10.710	10.742
½	49.86	43.46	0.050	0.044	0.151	0.150	6.645	6.652	6.626
⅝	59.82	53.11	0.060	0.053	0.225	0.225	4.448	4.445	4.438
¾	69.80	62.61	0.070	0.063	0.312	0.312	3.203	3.261	3.196
1	89.74	81.76	0.090	0.082	0.532	0.533	1.878	1.876	1.873
1¼	109.68	100.89	0.110	0.101	0.810	0.810	1.235	1.232	1.229
1½	129.62	120.04	0.130	0.120	1.149	1.149	0.870	0.870	0.866
2	169.49	158.32	0.170	0.158	1.995	1.994	0.501	0.502	0.500
2½	209.37	196.60	0.210	0.197	3.077	3.077	0.325	0.325	0.324
3	249.25	234.87	0.249	0.235	4.393	4.392	0.228	0.228	0.227
3½	289.26	273.30	0.289	0.273	5.944	5.943	0.168	0.168	0.169
4	329.01	311.46	0.329	0.312	7.723	7.722	0.130	0.130	0.129
5	408.76	388.82	0.409	0.389	12.038	12.037	0.078	0.083	0.083
6	488.52	466.17	0.489	0.466	17.301	17.298	0.058	0.058	0.040
8	648.03	621.41	0.648	0.621	30.225	30.225	0.033	0.033	0.033
10	807.54	767.66	0.807	0.768	46.917	46.903	0.021	0.021	0.021
12	967.05	922.38	0.967	0.922	67.738	67.728	0.015	0.015	0.015

for use in petroleum refineries and petrochemical facilities. It is rarely specified for use in building services.

Steel pipe may be either seamless (extruded) or welded. The welding of steel piping is accomplished by two methods: continuous or electric-resistance welding (ERW). Continuous welded pipe is heated and formed. Electric-resistance welding is cold rolled and then welded. Steel pipe also may be black iron or galvanized (zinc coated). Galvanized steel pipe is dipped and zinc coated to produce a galvanized protective coating both inside and out.

Steel pipe is produced in three basic weight classifications: standard, extra strong, and double extra strong. Steel pipe in standard weight and various weights, or schedules—ranging from Schedule 10, also known as light wall pipe, to Schedule 160—is typically supplied in random lengths of 6 feet to 22

feet (1.8 m to 6.7 m) and is available in 1/8-inch to 24-inch (3.2-mm to 660-mm) diameters. Exceptions to this are butt-welded standard weight and extra strong, which are not available in diameters larger than 4 inches, and butt-welded double extra-strong steel pipe, which is not made in diameters larger than 2½ inches. See Tables 2-11 and 2-12 for dimensional and capacity data for Schedule 40 and Schedule 80 steel pipe respectively.

Steel pipe conforming to ASTM A135 is made in sizes through 12 inches by the electric-resistance welding method only. Grade A is suitable for flanging or binding. Pipe meeting ASTM A135 is used extensively for light-wall pipe in fire sprinkler systems.

The methods of joining steel pipe are welding, threading, and grooved.

**Table 2-9 Dimensional and Capacity Data—Type M Copper Tube**

Diameter (in.)			Wall thickness (in.)	Cross-sectional area (sq. in.)			Weight per foot (lb)		
Nominal (in.)	Actual inside	Actual outside		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
3/8	0.450	0.500	0.025	0.196	0.159	0.037	0.145	0.069	0.214
1/2	0.569	0.625	0.028	0.307	0.254	0.053	0.204	0.110	0.314
3/4	0.811	0.875	0.032	0.601	0.516	0.085	0.328	0.224	0.552
1	1.055	1.125	0.035	0.993	0.874	0.119	0.465	0.379	0.844
1¼	1.291	1.375	0.042	1.48	1.31	0.17	0.682	0.569	1.251
1½	1.527	1.625	0.049	2.07	1.83	0.24	0.94	0.83	1.77
2	2.009	2.125	0.058	3.55	3.17	0.38	1.46	1.35	2.81
2½	2.495	2.625	0.065	5.41	4.89	0.52	2.03	2.12	4.15
3	2.981	3.125	0.072	7.67	6.98	0.69	2.68	3.03	5.71
3½	3.459	3.625	0.083	10.32	9.40	0.924	3.58	4.08	7.66
4	3.935	4.125	0.095	13.36	12.15	1.21	4.66	5.23	9.89
5	4.907	5.125	0.109	20.63	18.90	1.73	6.66	8.20	14.86
6	5.881	6.125	0.122	29.45	25.15	2.30	8.92	11.78	20.70
8	7.785	8.125	0.170	51.83	47.58	4.25	16.5	20.7	37.2
10	9.701	10.125	0.212	80.46	73.88	6.58	25.6	32.1	57.7
12	11.617	12.125	0.254	115.47	105.99	9.48	36.7	46.0	82.7

Nominal Diam. (in.)	Circumference (in.)		Ft² of Surface per Lineal Foot		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	Ft³	Gal	1 Ft³	1 Gal	1 Lb of Water
3/8	1.570	1.413	0.131	0.118	0.00110	0.00823	909	122	14.5
1/2	1.963	1.787	0.164	0.149	0.00176	0.01316	568	76.0	9.09
3/4	2.748	2.547	0.229	0.212	0.00358	0.02678	379	37.3	4.47
1	3.533	3.313	0.294	0.276	0.00607	0.04540	164.7	22.0	2.64
1¼	4.318	4.054	0.360	0.338	0.00910	0.06807	109.9	14.7	1.76
1½	5.103	4.795	0.425	0.400	0.01333	0.09971	75.02	10.0	1.20
2	6.673	6.308	0.556	0.526	0.02201	0.16463	45.43	6.08	0.727
2½	8.243	7.834	0.688	0.653	0.03396	0.25402	29.45	3.94	0.471
3	9.813	9.360	0.818	0.780	0.04847	0.36256	20.63	2.76	0.330
3½	11.388	10.867	0.949	0.906	0.06525	0.48813	15.33	2.05	0.246
4	12.953	12.356	1.080	1.030	0.08368	0.62593	11.95	1.60	0.191
5	16.093	15.408	1.341	1.284	0.13125	0.98175	7.62	1.02	0.122
6	19.233	18.466	1.603	1.539	0.18854	1.410	5.30	0.709	0.849
8	25.513	24.445	2.126	2.037	0.33044	2.472	3.03	0.405	0.484
10	31.793	30.461	2.649	2.538	0.51306	3.838	1.91	0.261	0.312
12	38.073	36.477	3.173	3.039	0.73569	5.503	1.36	0.182	0.217

**Table 2-9(M) Dimensional and Capacity Data—Type M Copper Tube**

Diameter			Wall thickness (mm)	Cross-sectional area (10 <sup>3</sup> mm <sup>2</sup> )			Weight per foot (kg)		
Nominal (in.)	Actual inside (mm)	Actual outside (mm)		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
3/8	11.43	12.70	0.64	0.127	0.103	0.024	0.216	0.103	0.319
1/2	14.45	15.88	0.71	0.198	0.164	0.034	0.304	0.164	0.468
3/4	20.60	22.23	0.81	0.388	0.333	0.055	0.489	0.334	0.823
1	26.80	28.58	0.89	0.641	0.564	0.077	0.693	0.565	1.258
1 1/4	32.79	34.93	1.07	0.955	0.845	0.110	1.016	0.848	1.864
1 1/2	38.79	41.28	1.25	1.336	1.181	0.155	1.400	1.236	2.636
2	51.03	53.98	1.47	2.290	2.045	0.245	2.175	2.011	4.186
2 1/2	63.38	66.68	1.65	3.490	3.155	0.336	3.024	3.158	6.182
3	75.2	79.38	1.83	4.948	4.503	0.445	3.992	4.513	8.505
3 1/2	87.86	92.08	2.11	6.658	6.065	0.596	5.332	6.077	11.409
4	99.95	104.78	2.41	8.619	7.839	0.781	6.941	7.790	14.731
5	124.64	130.18	2.77	13.310	12.194	1.116	9.920	12.214	22.134
6	149.38	155.58	3.10	19.000	16.226	1.484	13.286	17.546	30.832
8	197.74	206.38	4.32	33.439	30.697	2.742	24.577	30.833	55.410
10	246.41	257.18	5.39	51.910	47.664	4.245	38.131	47.813	85.944
12	295.07	307.98	6.45	74.497	68.381	6.116	54.665	68.517	123.182

Nominal Diam. (in.)	Circumference (mm)		M <sup>2</sup> of surface per Meter		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	(L)	(L)	1 L	1 L	1 kg of Water
3/8	39.88	35.89	0.040	0.036	0.102	0.102	9.784	9.825	9.735
1/2	49.86	45.39	0.050	0.045	0.164	0.163	6.114	6.120	6.103
3/4	69.80	64.69	0.070	0.065	0.033	0.333	4.080	3.004	3.001
1	89.74	84.15	0.090	0.084	0.564	0.564	1.773	1.772	1.772
1 1/4	109.68	102.97	0.110	0.103	0.845	0.845	1.183	1.184	1.182
1 1/2	129.62	121.79	0.130	0.122	1.238	1.238	0.808	0.805	0.806
2	169.49	160.22	0.170	0.160	2.045	2.044	0.489	0.490	0.488
2 1/2	209.37	198.98	0.210	0.199	3.155	3.154	0.317	0.317	0.316
3	249.25	237.74	0.249	0.238	4.503	4.502	0.222	0.222	0.222
3 1/2	289.26	276.02	0.289	0.276	6.62	6.062	0.165	0.165	0.165
4	329.01	313.84	0.329	0.314	7.774	7.773	0.129	0.129	0.128
5	408.76	391.36	0.409	0.391	12.194	12.191	0.082	0.082	0.082
6	488.52	469.04	0.489	0.469	17.516	17.509	0.057	0.057	0.570
8	648.03	620.90	0.648	0.621	30.699	30.697	0.033	0.033	0.325
10	807.54	773.71	0.807	0.774	47.665	47.660	0.021	0.021	0.210
12	967.05	926.52	0.967	0.926	68.348	68.336	0.015	0.015	0.146

**Table 2-10 Dimensional Data—Type DWV Copper Tube**

Nominal Size	Nominal Dimensions						Calculated Values, Based on Nominal Dimensions							
	Outside Diameter		Inside Diameter		Wall Thickness		Cross Sectional Area of Bore		External Surface		Internal Surface		Weight kg	
	(in.)	(mm)	(in.)	(mm)	(in.)	(mm)	(in. <sup>2</sup> )	(cm <sup>2</sup> )	(ft <sup>2</sup> /lin ft)	(m <sup>2</sup> /m)	(ft <sup>2</sup> /lin ft)	(m <sup>2</sup> /m)	(/ft)	(/m)
1 1/4	1.375	34.93	1.295	32.89	.040	1.02	1.32	8.52	0.360	0.03	0.339	0.03	0.65	0.29
1 1/2	1.625	41.28	1.541	39.14	.042	1.07	1.87	12.06	0.425	0.04	0.403	0.04	0.81	0.37
2	2.125	53.98	2.041	51.84	.042	1.07	3.27	21.10	0.556	0.05	0.534	0.05	1.07	0.49
3	3.125	79.38	3.030	76.96	.045	1.14	7.21	46.52	0.818	0.08	0.793	0.07	1.69	0.77
4	4.125	104.78	4.009	101.83	.058	1.47	12.6	81.29	1.08	0.10	1.05	0.10	2.87	1.30
5	5.125	130.18	4.981	126.52	.072	1.83	19.5	125.81	1.34	0.12	1.30	0.12	4.43	2.01
6	6.125	155.58	5.959	151.36	.083	2.11	27.9	180.00	1.60	0.15	1.56	0.15	6.10	2.77
8	8.125	206.38	7.907	200.84	.109	2.77	49.1	316.77	2.13	0.20	2.07	0.19	10.6	4.81




Figure 2-5 Copper Tube Flared Fittings




Figure 2-6 Copper and Bronze Joints and Fittings

### PLASTIC PIPE

Plastic pipe is available in compositions designed for numerous applications, including DWV, water supply, gas service and transmission lines, and laboratory and other chemical drainage and piping systems. Fuel double-containment systems, high-purity pharmaceutical and electronic grade water, and R-13, R-13A, and R-13D fire protection sprinkler systems are additional applications.

The two basic types of plastic pipe are thermoset and thermoplastic. A thermoset plastic is permanent-

ly rigid. Epoxy and phenolics are examples of thermosets. A thermoplastic is a material that softens when heated and hardens when cooled. Acrylonitrile butadiene styrene (ABS), polyvinyl chloride (PVC), polybutylene (PB), polyethylene (PE), polypropylene (PP), polyvinylidene fluoride (PVDF), cross-linked polyethylene (PEX), and chlorinated polyvinyl chloride (CPVC) are thermoplastics. With thermoplastics, consideration must be given to the temperature/pressure relationship when selecting the support spacing and method of installation.




Figure 2-7 Copper Drainage Fittings






Figure 2-8 Standard Glass Pipe




Figure 2-9 Standard Glass Pipe Couplings

With all plastics, certain considerations must be reviewed before installation. These include code compliance, chemical compatibility, correct maximum temperature, and allowance for proper expansion and contraction movement. Certain plastics are installed with solvent cements; others require heating to join piping networks along with mechanical joints. The designer should consult the manufacturer's recommendations for the proper connection of all piping systems.

See Figure 2-12 and Tables 2-13 and 2-14 for general information on plastic pipe and fittings.

**Polybutylene**

Polybutylene is a flexible thermoplastic that was manufactured to pipe and tubing specifications. PB tubing is no longer manufactured, but a plumbing engineer may encounter the material during a retrofit of an existing system.

Polybutylene is an inert polyolefin material, meaning that it is chemically resistant, so it cannot be solvent cemented like other plastic piping systems. PB pipe was one of the most flexible piping materials acceptable for potable water. It is typically blue or gray in color.

Its applications included hydronic slab heating systems, fire sprinklers systems, hot and cold water distribution, and plumbing and water supply.




Figure 2-10 Typical Glass Pipe Joint Reference Chart

Joints were made by mechanical, flared, and heat fusion methods.

**Polyethylene**

Polyethylene also is an inert polyolefin (chemically resistant) material, so it cannot be solvent cemented. This type of piping typically is supplied in blue or black for water and cooling water applications. Black PE pipe incorporates carbon black for colorization and UV radiation (sunlight) protection. Orange-colored polyethylene piping is typically used for gas pipe installations.

Joints are made with inserts and clamps and by heat fusion. PE cannot be threaded or solvent welded.

PE pipe is classified into the following types: low density, high density, and medium density. The terms refer to ASTM designations based on material densities. Sizes range from 1/2 inch to 63 inches (12.7 mm to 1,600.2 mm) in diameter in both iron pipe size (IPS) and copper tube size (CTS). Pressures range from 50 psi to 250 psi depending on wall thickness (SDR 7 to SDR 32.5).

**High-Density Polyethylene**

HDPE comprises 90 percent of the polyethylene piping industry. It has a wide variety of belowground and aboveground applications, including domestic water supply, well water systems, lawn sprinkler systems, irrigation systems, skating rinks, buried chilled water pipe, underground FM Global-approved fire mains, chemical lines, snow-making lines at ski slopes, pressurized chilled water piping underground between buildings and a central heating or cooling plant, methane gas collection piping, leachate collection lines at landfills, relining water and sewer mains, water transmission mains over highway bridges (it absorbs vibration), brine at skating rinks, and residential swimming pools.

Typically, HDPE is installed with mechanical barbed joints or compression fittings through 2 inches (50.8 mm), and the pipe comes in coils, which can be 100 feet to 5,000 feet (30.5 m to 1,542 m) on special reels. It is also available heat socket fused from 1/2 inch to 40 inches (12.7 mm to 1,016 mm), butt fused from 2 inches to 63 inches (50.8 mm to 1,600.2 mm) in 40-foot (12.2-m) pipe lengths, and







Figure 2-11 Standard Glass Fittings



**STANDARD GLASS TRAPS  
(Special Lab. Use)**



**STANDARD GLASS CUP SINKS  
(Special Lab. Use)**

Figure 2-11 (continued)

Table 2-11 Dimensional and Capacity Data—Schedule 40 Steel Pipe

Diameter (in.)			Wall thickness (in.)	Cross-sectional area (sq. in.)			Weight per foot (lb)		
Nominal (in.)	Actual inside	Actual outside		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
1/8	0.269	0.405	0.068	0.129	0.057	0.072	0.25	0.028	0.278
1/4	0.364	0.540	0.088	0.229	0.104	0.125	0.43	0.045	0.475
3/8	0.493	0.675	0.091	0.358	0.191	0.167	0.57	0.083	0.653
1/2	0.622	0.840	0.109	0.554	0.304	0.250	0.86	0.132	0.992
3/4	0.824	1.050	0.113	0.866	0.533	0.333	1.14	0.232	1.372
1	1.049	1.315	0.133	1.358	0.864	0.494	1.68	0.375	2.055
1 1/4	1.380	1.660	0.140	2.164	1.495	0.669	2.28	0.649	2.929
1 1/2	1.610	1.900	0.145	2.835	2.036	0.799	2.72	0.882	3.602
2	2.067	2.375	0.154	4.431	3.356	1.075	3.66	1.454	5.114
2 1/2	2.469	2.875	0.203	6.492	4.788	1.704	5.80	2.073	7.873
3	3.068	3.500	0.216	9.621	7.393	2.228	7.58	3.201	10.781
3 1/2	3.548	4.000	0.226	12.568	9.888	2.680	9.11	4.287	13.397
4	4.026	4.500	0.237	15.903	12.730	3.173	10.80	5.516	16.316
5	5.047	5.563	0.258	24.308	20.004	4.304	14.70	8.674	23.374
6	6.065	6.625	0.280	34.474	28.890	5.584	19.00	12.52	31.52
8	7.981	8.625	0.322	58.426	50.030	8.396	28.60	21.68	50.28
10	10.020	10.750	0.365	90.79	78.85	11.90	40.50	34.16	74.66
12	11.938	12.750	0.406	127.67	113.09	15.77	53.60	48.50	102.10
14	13.126	14.000	0.437	153.94	135.33	18.61	63.30	58.64	121.94
16	15.000	16.000	0.500	201.06	176.71	24.35	82.80	76.58	159.38
18	16.876	18.000	0.562	254.47	223.68	30.79	105.00	96.93	201.93
20	18.814	20.000	0.593	314.16	278.01	36.15	123.00	120.46	243.46

Nominal Diam. (in.)	Circumference (in.)		Ft <sup>2</sup> of Surface per Lineal Foot		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	Ft <sup>3</sup>	Gal	1 Ft <sup>3</sup>	1 Gal	1 Lb of Water
1/8	1.27	0.84	0.106	0.070	0.0004	0.003	2533.775	338.74	35.714
1/4	1.69	1.14	0.141	0.095	0.0007	0.005	1383.789	185.00	22.222
3/8	2.12	1.55	0.177	0.129	0.0013	0.010	754.360	100.85	12.048
1/2	2.65	1.95	0.221	0.167	0.0021	0.016	473.906	63.36	7.576
3/4	3.29	2.58	0.275	0.215	0.0037	0.028	270.034	36.10	4.310
1	4.13	3.29	0.344	0.274	0.0062	0.045	166.618	22.38	2.667
1 1/4	5.21	4.33	0.435	0.361	0.0104	0.077	96.275	12.87	1.541
1 1/2	5.96	5.06	0.497	0.422	0.0141	0.106	70.733	9.46	1.134
2	7.46	6.49	0.622	0.540	0.0233	0.174	42.913	5.74	0.688
2 1/2	9.03	7.75	0.753	0.654	0.0332	0.248	30.077	4.02	0.482
3	10.96	9.63	0.916	0.803	0.0514	0.383	19.479	2.60	0.312
3 1/2	12.56	11.14	1.047	0.928	0.0682	0.513	14.565	1.95	0.233
4	14.13	12.64	1.178	1.052	0.0884	0.660	11.312	1.51	0.181
5	17.47	15.84	1.456	1.319	0.1390	1.040	7.198	0.96	0.115
6	20.81	19.05	1.734	1.585	0.2010	1.500	4.984	0.67	0.080
8	27.90	25.07	2.258	2.090	0.3480	2.600	2.878	0.38	0.046
10	33.77	31.47	2.814	2.622	0.5470	4.100	1.826	0.24	0.029
12	40.05	37.70	3.370	3.140	0.7850	5.870	1.273	0.17	0.021
14	47.12	44.76	3.930	3.722	1.0690	7.030	1.067	0.14	0.017
16	53.41	51.52	4.440	4.310	1.3920	9.180	0.814	0.11	0.013
18	56.55	53.00	4.712	4.420	1.5530	11.120	0.644	0.09	0.010
20	62.83	59.09	5.236	4.920	1.9250	14.400	0.517	0.07	0.008

Table 2-11(M) Dimensional and Capacity Data—Schedule 40 Steel Pipe

Diameter			Wall thickness (mm)	Cross-sectional area (10 <sup>3</sup> mm <sup>2</sup> )			Weight per meter (kg)		
Nominal (in.)	Actual inside (mm)	Actual outside (mm)		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
1/8	6.8	10.3	1.7	0.083	0.037	0.047	0.37	0.04	0.41
1/4	9.3	13.7	2.2	0.148	0.067	0.081	0.64	0.07	0.71
3/8	12.5	17.2	2.3	0.231	0.123	0.108	0.85	0.12	0.97
1/2	15.8	21.3	2.8	0.357	0.196	0.161	1.28	0.20	1.48
3/4	20.9	26.7	2.9	0.559	0.344	0.215	1.7	0.35	2.05
1	26.7	33.4	3.4	0.876	0.557	0.319	2.5	0.56	3.06
1 1/4	35.1	42.2	3.6	1.396	0.965	0.432	3.4	0.97	4.37
1 1/2	40.9	48.3	3.7	1.829	1.314	0.516	4.05	1.31	5.36
2	52.5	60.3	3.9	2.859	2.165	0.694	5.45	2.17	7.62
2 1/2	62.7	73.0	5.2	4.188	3.089	1.099	8.64	3.09	11.73
3	77.9	88.9	5.5	6.207	4.77	1.437	11.29	4.77	16.06
3 1/2	90.1	101.6	5.7	8.108	6.379	1.729	13.57	6.39	19.96
4	102.3	114.3	6.0	10.26	8.213	2.047	16.09	8.22	24.31
5	128.2	141.3	6.6	15.68	12.91	2.777	21.9	12.92	34.82
6	154.1	168.3	7.1	22.24	18.64	3.603	28.3	18.65	46.95
8	202.7	219.1	8.2	37.69	32.28	5.417	42.6	32.29	74.89
10	254.5	273.1	9.3	58.57	50.87	7.677	60.33	50.88	111.21
12	303.2	323.9	10.3	82.37	72.96	10.17	79.84	72.24	152.08
14	333.4	355.6	11.1	99.32	87.31	12.01	94.29	87.34	181.63
16	381.0	406.4	12.7	129.72	114.01	15.71	123.33	114.07	237.4
18	428.7	457.2	14.3	164.17	144.31	19.87	156.4	144.38	300.78
20	477.9	508.0	15.1	202.68	179.36	23.32	183.21	179.43	362.64

Nominal Diam. (in.)	Circumference (mm)		M <sup>2</sup> of surface per Meter		Contents of Tube per Lineal Meter		Lineal Meters to Contain		
	Outside	Inside	Outside	Inside	(L)	(L)	1 L	1 L	1 kg of Water
1/8	32.26	21.34	0.032	0.021	0.037	0.037	27.27	27.28	23.98
1/4	42.93	28.96	0.043	0.029	0.065	0.062	14.9	14.9	14.92
3/8	53.85	39.37	0.054	0.039	0.121	0.124	8.12	8.12	8.09
1/2	67.31	49.53	0.067	0.051	0.195	1.199	5.1	5.1	5.09
3/4	83.57	65.53	0.084	0.066	0.344	0.348	2.91	2.91	2.89
1	104.9	83.57	0.105	0.084	0.576	0.559	1.79	1.79	1.79
1 1/4	132.33	109.98	0.133	0.11	0.966	0.956	1.04	1.04	1.03
1 1/2	151.38	128.52	0.152	0.129	1.31	1.316	0.76	0.76	0.76
2	189.48	164.85	0.19	0.165	2.165	2.161	0.46	0.46	0.46
2 1/2	229.36	196.85	0.23	0.199	3.084	3.08	0.32	0.32	0.32
3	278.38	244.6	0.279	0.245	4.775	4.756	0.21	0.21	0.21
3 1/2	319.02	282.96	0.319	0.283	6.336	6.37	0.16	0.16	0.16
4	358.9	321.06	0.359	0.321	8.213	8.196	0.12	0.12	0.12
5	443.74	402.34	0.444	0.402	12.91	12.92	0.08	0.08	0.08
6	528.57	483.87	0.529	0.483	18.67	18.63	0.05	0.05	0.05
8	688.09	636.78	0.688	0.637	32.33	32.29	0.03	0.03	0.03
10	857.76	799.34	0.858	0.799	50.82	50.91	0.02	0.02	0.02
12	1017.27	957.58	1.027	0.957	72.93	72.89	0.013	0.014	0.014
14	1196.85	1136.9	1.198	1.135	99.31	87.3	0.011	0.011	0.011
16	1356.61	1308.61	1.353	1.314	129.32	114.0	0.009	0.009	0.009
18	1436.37	1346.2	1.436	1.347	144.28	138.09	0.007	0.007	0.007
20	1595.88	1500.89	1.596	1.5	178.84	178.82	0.006	0.006	0.006

Table 2-12 Dimensional and Capacity Data—Schedule 80 Steel Pipe

Diameter (in.)			Wall thickness (in.)	Cross-sectional area (sq. in.)			Weight per foot (lb)		
Nominal (in.)	Actual inside	Actual outside		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
1/8	0.215	0.405	0.091	0.129	0.036	0.093	0.314	0.016	0.330
1/4	0.302	0.540	0.119	0.229	0.072	0.157	0.535	0.031	0.566
3/8	0.423	0.675	0.126	0.358	0.141	0.217	0.738	0.061	0.799
1/2	0.546	0.840	0.147	0.554	0.234	0.320	1.087	0.102	1.189
3/4	0.742	1.050	0.154	0.866	0.433	0.433	1.473	0.213	1.686
1	0.957	1.315	0.179	1.358	0.719	0.639	2.171	0.312	2.483
1 1/4	1.278	1.660	0.191	2.164	1.283	0.881	2.996	0.555	3.551
1 1/2	1.500	1.900	0.200	2.835	1.767	1.068	3.631	0.765	4.396
2	1.939	2.375	0.218	4.431	2.954	1.477	5.022	1.280	6.302
2 1/2	2.323	2.875	0.276	6.492	4.238	2.254	7.661	1.830	9.491
3	2.900	3.500	0.300	9.621	6.605	3.016	10.252	2.870	13.122
3 1/2	3.364	4.000	0.318	12.568	8.890	3.678	12.505	3.720	16.225
4	3.826	4.500	0.337	15.903	11.496	4.407	14.983	4.970	19.953
5	4.813	5.563	0.375	24.308	18.196	6.112	20.778	7.940	28.718
6	5.761	6.625	0.432	34.474	26.069	8.405	28.573	11.300	39.873
8	7.625	8.625	0.500	58.426	45.666	12.750	43.388	19.800	63.188
10	9.564	10.750	0.593	90.79	71.87	18.92	64.400	31.130	95.530
12	11.376	12.750	0.687	127.67	101.64	26.03	88.600	44.040	132.640
14	12.500	14.000	0.750	153.94	122.72	31.22	107.000	53.180	160.180
16	14.314	16.000	0.843	201.06	160.92	40.14	137.000	69.730	206.730
18	16.126	18.000	0.937	254.47	204.24	50.23	171.000	88.500	259.500
20	17.938	20.000	1.031	314.16	252.72	61.44	209.000	109.510	318.510

Nominal Diam. (in.)	Circumference (in.)		Ft <sup>2</sup> of Surface per Lineal Foot		Contents of Tube per Lineal Foot		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	Ft <sup>3</sup>	Gal	1 Ft <sup>3</sup>	1 Gal	1 Lb of Water
1/8	1.27	0.675	0.106	0.056	0.00033	0.0019	3070	527	101.01
1/4	1.69	0.943	0.141	0.079	0.00052	0.0037	1920	271	32.26
3/8	2.12	1.328	0.177	0.111	0.00098	0.0073	1370	137	16.39
1/2	2.65	1.715	0.221	0.143	0.00162	0.0122	616	82	9.80
3/4	3.29	2.330	0.275	0.194	0.00300	0.0255	334	39.2	4.69
1	4.13	3.010	0.344	0.251	0.00500	0.0374	200	26.8	3.21
1 1/4	5.21	4.010	0.435	0.334	0.00880	0.0666	114	15.0	1.80
1 1/2	5.96	4.720	0.497	0.393	0.01230	0.0918	81.50	10.90	1.31
2	7.46	6.090	0.622	0.507	0.02060	0.1535	49.80	6.52	0.78
2 1/2	9.03	7.320	0.753	0.610	0.02940	0.220	34.00	4.55	0.55
3	10.96	9.120	0.916	0.760	0.0460	0.344	21.70	2.91	0.35
3 1/2	12.56	10.580	1.047	0.882	0.0617	0.458	16.25	2.18	0.27
4	14.13	12.020	1.178	1.002	0.0800	0.597	12.50	1.675	0.20
5	17.47	15.150	1.456	1.262	0.1260	0.947	7.95	1.055	0.13
6	20.81	18.100	1.734	1.510	0.1820	1.355	5.50	0.738	0.09
8	27.09	24.000	2.258	2.000	0.3180	2.380	3.14	0.420	0.05
10	33.77	30.050	2.814	2.503	0.5560	4.165	1.80	0.241	0.03
12	40.05	35.720	3.370	2.975	0.7060	5.280	1.42	0.189	0.02
14	47.12	39.270	3.930	3.271	0.8520	6.380	1.18	0.157	0.019
16	53.41	44.970	4.440	3.746	1.1170	8.360	0.895	0.119	0.014
18	56.55	50.660	4.712	4.220	1.4180	10.610	0.705	0.094	0.011
20	62.83	56.350	5.236	4.694	1.7550	13.130	0.570	0.076	0.009

Table 2-12(M) Dimensional and Capacity Data—Schedule 80 Steel Pipe

Diameter			Wall thickness (mm)	Cross-sectional area (10 <sup>3</sup> mm <sup>2</sup> )			Weight per foot (kg)		
Nominal (in.)	Actual inside (mm)	Actual outside (mm)		Outside	Inside	Metal	of tube alone	of water in tube	of tube and water
1/8	5.46	10.29	2.41	0.083	0.023	0.06	0.468	0.024	0.492
1/4	7.67	13.72	3.02	0.148	0.047	0.101	0.797	0.046	0.843
3/8	10.74	17.15	3.2	0.231	0.091	0.14	1.099	0.091	1.19
1/2	13.87	21.34	3.73	0.357	0.151	0.207	1.619	0.152	1.771
3/4	18.85	26.67	3.91	0.559	0.279	0.279	2.194	0.317	2.511
1	24.31	33.4	4.55	0.876	0.464	0.412	3.234	0.465	3.698
1 1/4	32.46	42.16	4.85	1.396	0.828	0.569	4.463	0.827	5.289
1 1/2	38.1	48.26	5.08	1.829	1.14	0.689	5.408	1.14	6.548
2	49.25	60.33	5.54	2.859	1.906	0.953	7.48	1.907	9.386
2 1/2	59	73.03	7.01	4.188	2.734	1.454	11.411	2.726	14.137
3	73.66	88.9	7.62	6.207	4.261	1.946	15.27	4.275	19.545
3 1/2	85.45	101.6	8.08	8.108	5.736	2.373	18.626	5.541	24.167
4	97.18	114.3	8.56	10.26	7.417	2.843	22.317	7.403	29.72
5	122.25	141.3	9.53	15.683	11.739	3.943	30.949	11.827	42.776
6	146.33	168.28	10.97	22.241	16.819	5.423	42.56	16.831	59.391
8	193.68	219.08	12.7	37.694	29.462	8.232	64.627	29.492	94.119
10	242.93	273.05	15.06	58.574	46.368	12.206	95.924	46.368	142.292
12	288.95	323.85	17.45	82.368	65.574	16.794	131.97	65.598	197.568
14	317.5	355.6	19.05	99.316	79.174	20.142	159.377	79.212	238.588
16	363.58	406.4	21.41	129.716	103.819	25.897	204.062	103.863	307.925
18	409.6	457.2	23.8	164.174	131.768	32.406	254.705	131.821	386.526
20	455.63	508	26.19	202.684	163.045	39.639	311.306	163.115	474.421

Nominal Diam. (in.)	Circumference (mm)		M <sup>2</sup> of surface per Meter		Contents of Tube per Lineal Meter		Lineal Feet to Contain		
	Outside	Inside	Outside	Inside	(L)	(L)	1 L	1 L	1 kg of Water
1/8	32.26	17.15	0.032	0.017	0.031	0.024	33.05	42.44	67.82
1/4	42.93	23.95	0.043	0.024	0.048	0.046	20.67	21.82	21.66
3/8	53.85	33.73	0.054	0.034	0.091	0.091	14.75	11.03	11
1/2	67.31	43.56	0.067	0.044	0.151	0.152	6.63	6.6	6.58
3/4	83.57	59.18	0.084	0.059	0.279	0.317	3.6	3.16	3.15
1	104.9	76.45	0.105	0.077	0.465	0.464	2.15	2.16	2.16
1 1/4	132.33	101.85	0.133	0.102	0.818	0.827	1.23	1.21	1.21
1 1/2	151.38	119.89	0.152	0.12	1.143	1.14	0.88	0.88	0.88
2	189.48	154.69	0.19	0.155	1.914	1.906	0.54	0.53	0.52
2 1/2	229.36	185.93	0.23	0.186	2.731	2.732	0.37	0.37	0.37
3	278.38	231.65	0.279	0.232	4.274	4.272	0.23	0.23	0.24
3 1/2	319.02	268.73	0.319	0.269	5.732	5.687	0.18	0.18	0.18
4	358.9	305.31	0.359	0.305	7.432	7.414	0.14	0.14	0.13
5	443.74	384.81	0.444	0.385	11.706	11.76	0.09	0.09	0.09
6	528.57	459.74	0.529	0.46	16.909	16.826	0.06	0.06	0.06
8	688.09	609.6	0.688	0.61	29.543	29.555	0.03	0.03	0.03
10	857.76	763.27	0.858	0.763	51.654	51.721	0.02	0.02	0.02
12	1017.27	907.29	1.027	0.907	65.59	65.567	0.015	0.015	0.014
14	1196.85	997.46	1.198	0.997	79.154	79.227	0.013	0.013	0.013
16	1356.61	1142.24	1.353	1.142	103.773	103.814	0.01	0.01	0.009
18	1436.37	1286.76	1.436	1.286	131.737	131.755	0.008	0.008	0.007
20	1595.88	1431.29	1.596	1.431	163.046	163.048	0.006	0.006	0.006

electrofused from 1½ inches to 30 inches (38.1 mm to 762 mm) in diameter.

HDPE is not a fixed, rigid, or perfectly straight pipe—it bends. When designing systems with HDPE, expansion must be preplanned, and best efforts should be made to determine what direction it will take (e.g., bury the pipe in an S or snake pattern to let it expand or contract.)

Both pipe and tubing (IPS and CTS) are manufactured using a SDR series. The operating temperature limit is 160°F, but as always, the manufacturer of the product should be consulted on temperature versus pressure.

The color is typically black for HDPE, which according to ASTM means that 2 percent carbon black has been blended with the resin to provide the minimum 50-year life span at full pressure in direct sunlight. Two unique properties of HDPE pipe are that it swells and does not break if it freezes and it floats in water since its specific gravity is 0.95. This is why HDPE pipe can be preassembled, and thousands of feet can be floated to a certain position and then sunk with concrete collars.

### Cross-Linked Polyethylene

Cross-linked polyethylene tubing has been used extensively in Europe for many years for hot and cold potable water distribution systems.

A specially controlled chemical reaction takes place during the manufacturing of the polyethylene pipe to form PEX. Cross-linked molecular structur-




Figure 2-12 Plastic Pipe Fittings

Table 2-13 Plastic Pipe Data

Material	Schedule Numbers	Pipe Sizes (in.)	Fitting Sizes (in.)	Temperature Limit (°F)	Joining Methods
PVC I	40, 80, 120 SDR	¼–20	¼–8	150	Solvent weld, thread, flange, thermal weld
PVC II <sup>a</sup>	40, 80, 120 SDR	¼–20	¼–8	130	Solvent weld, thread, flange, thermal weld
Polypropylene	40–80	½–8	½–8	150	Thermal fusion, flange, thread, compression
CPVC	40–80	½–8	½–8	210	Solvent weld, thread, flange
Poyethylene	40, 80 SDR	½–6	½–6	120–140	Thermal fusion, compression
ABS	40, 80 SDR	½–12	½–6	160	Solvent weld, thread, flange
Polybutylene	SDR	¼–6	¼–6	210	Thermal fusion, flare, compression, insert

<sup>a</sup> The usage of PVC II is limited to electrical conduit.

Table 2-13(M) Plastic Pipe Data

Material	Schedule Numbers	Pipe Sizes (in.)	Fitting Sizes (mm)	Temperature Limit (°C)	Joining Methods
PVC I	40, 80, 120 SDR	¼–20	6.4 to 203.2	65.6	Solvent weld, thread, flange,
PVC II <sup>a</sup>	40, 80, 120 SDR	¼–20	6.4 to 203.2	54.4	Solvent weld, thread, flange,
Polypropylene	40–80	½–8	12.7 to 203.2	65.6	Thermal fusion, flange, thread,
CPVC	40–80	½–8	12.7 to 203.2	98.9	Solvent weld, thread, flange
Poyethylene	40, 80 SDR	½–6	12.7 to 152.4	48.9 to 60	Thermal fusion, compression
ABS	40, 80 SDR	½–12	3.2 to 152.4	71.1	Solvent weld, thread, flange
Polybutylene	SDR	¼–6	6.4 to 152.4	98.9	Thermal fusion, flare,

<sup>a</sup> The usage of PVC II is limited to electrical conduit.



ing gives the pipe greater resistance to rupture over a wider range of temperatures and pressures than other polyolefin piping (PB, PE, and PP).

Because of the unique molecular structure and heat resistance of PEX pipe, heat fusion is not permitted as a joining method. Being a member of the polyolefin plastic family, PEX is resistant to solvents and cannot be joined by solvent cementing. Mechanical connectors and fittings for PEX piping systems are proprietary in nature and must be used only with the pipe for which they have been designed. A number of mechanical fastening techniques have been developed to join PEX pipe. The pipe manufacturer's installation instructions should be consulted to properly identify the authorized fittings for the intended system use.

PEX pipe is flexible, allowing it to be bent. It is bent by two methods: hot and cold bending. See the manufacturer's instructions for the exact requirements for bending. The tubing can be bent to a minimum radius of six times the outside diameter for cold bending and a minimum of 2½ times the outside diameter for hot bending.

PEX is available in nominal pipe size (NPS) ¼ inch through 2 inches (6.4 mm through 51 mm).

### **Cross-Linked Polyethylene, Aluminum, Cross-Linked Polyethylene**

PEX-AL-PEX is a composite pipe made of an aluminum tube laminated with interior and exterior layers of cross-linked polyethylene. The layers are bonded with an adhesive.

The cross-linked molecular structuring described above and the addition of the aluminum core make the pipe resistant to rupture. Therefore, along with other system usages, the pipe is suitable for hot and cold water distribution. The pipe is rated for 125 pounds per square inch (psi) at 180°F (862 kPa at 82°C). It is available in nominal pipe size ¼ inch through 1 inch (6.4 mm through 25 mm).

Mechanical joints are the only methods currently available to join PEX-AL-PEX pipe. A number of mechanical compression-type connectors have been developed for joining this type of pipe material to permit transition to other types of pipe and fittings. The installation of any fitting shall be in accordance with the manufacturer's installation instructions.

Although it is partially plastic, PEX-AL-PEX pipe resembles metal tubing in that it can be bent by hand or with a suitable bending device while maintaining its shape without fittings or supports. The minimum radius is five times the outside diameter.

### **Polyethylene/Aluminum/Polyethylene**

PE-AL-PE is identical to the PEX-AL-PEX composite pipe except for the physical properties of the polyethylene.

Polyethylene does not display the same resistance to temperature and pressure as the cross-linked polyethylene. Therefore, this type of pipe is limited to cold water applications or applications with other suitable fluids up to 110°F at 150 psi (43°C at 1,034 kPa).

It is available in nominal pipe size ¼ inch through 1 inch (6.4 mm through 25 mm). The method of joining is mechanical (barbed joints and compression fittings).

### **Polyvinyl Chloride**

Polyvinyl chloride is rigid, pressure- or drainage-type pipe that resists chemicals and corrosion. PVC is used for water distribution, irrigation, storm drainage, sewage, laboratory and hospital wastes, chemical lines, chilled water lines, heat pumps, underground FM Global-approved fire mains, animal rearing facilities, hatcheries, graywater piping, and ultra-pure water. PVC water service piping is a different material than PVC drainage pipe, although both pipe materials are white in color. Two types are available: Schedule 40 and Schedule 80.

For pressure, SDR 21 (200 psi) or SDR 26 (160 psi) is used. The working pressure varies with the temperature: as the temperature increases, tensile strength decreases. The maximum working pressure is continuously marked on the pipe along with the manufacturer's name, ASTM or CSA standard, and the grade of PVC material. Temperature should be limited to 140° (60°C). The joints are solvent welded or threaded. Schedule 40 PVC cannot be threaded, and it can be used only with socket fittings. Schedule 80 can be threaded through the 4-inch (101.6-mm) size and used with either socket or threaded fittings. However, it also can be installed with mechanical grooved couplings or bell and gasket (underground only and thrust blocked).

The pipe classifications and dimensional information are:

- DWV: 1¼ inches to 24 inches (31.75 mm to 609.6 mm)
- Schedule 40: ½ inch to 30 inches (3.2 mm to 762 mm)
- Schedule 80: ½ inch 30 inches (3.2 mm to 762 mm)
- SDR 21: ¾ inch to 24 inches (22 mm to 609.6 mm), except ½-inch SDR (13.5 mm)
- SDR 26: 1¼ inches to 24 inches (32 mm to 609.6 mm)

The maximum temperature rating for PVC is 140°F (60°C). The coefficient of linear expansion is  $2.9 \times 10^{-5}$  inch/inch/°F. The specific gravity of PVC is  $1.40 \pm 0.02$ .

**Table 2-14 Physical Properties of Plastic Piping Materials**

Material	Specific Gravity	Tensile Strength (psi at 73°F)	Modulus of Elasticity in Tension (psi at 73°F × 10 <sup>5</sup> )	Compressive Strength (psi)	Strength Flexural (psi)	Resistance to Heat (continuous) (°F)	Coefficient of Expansion (in./in.°F × 10 <sup>-6</sup> )	Thermal Conductivity (Btu/h ft <sup>2</sup> /°F/in.)	Burning Rate	Heat Distortion Temp (°F at 264 psi)	Water Absorption at (%/24 hr/73°F)	Izod Impact (73°F ft lb/in. notch)
PVC	Type I	7,940	4.15	9,600	14,500	140	3.0	1.2	Self Extinguishing	160	.05	.65
	Type II <sup>a</sup>	6,000	3.5	8,800	11,500	140	5.55	1.35	Self Extinguishing	155	.07	2-15
	Type IV	8,400	4.2	—	15,600	210	3.8	.95	Self Extinguishing	221	.05	—
Polyethylene	Type I	1,750	1.9-.35	—	1,700	120	10.0	2.3	Slow	NA	.01	16
	Type III	2,800	1.5	—	2,000	120	7.3	3.5	Slow	NA	0.0	3.0
Polypropylene	Type I	4,900	1.5	8,500	—	160-212	3.8	1.3	Slow	150	0.03	2.1
	Type II	5,300	3.0	7,000	8,000	160	6.0	1.9	Slow	197	.20	5-9
ABS	Type I	8,000	—	10,000	12,000	170	3.8	2.5	Slow	225	.20	4
	Fluoride (PDVF)	7,000	1.2	10,000	—	200-250	8.5	1.05	Self Extinguishing	195	.04	3.0
Polybutylene	.93	4,800	.38	—	—	—	7.1	1.5	Slow	NA	<.01	no break

Notes: 1. Above data compiled in accordance with ASTM test requirements.  
 2. NA = Not Applicable.  
 a The usage of PVC II is limited to electrical conduit.

**Table 2-14(M) Physical Properties of Plastic Piping Materials**

Material	Specific Gravity	Tensile Strength (MPa at 22.8°C)	Modulus of Elasticity in Tension (10 <sup>3</sup> kPa at 22.8°C × 10 <sup>5</sup> )	Compressive Strength (MPa)	Strength Flexural (MPa)	Resistance to Heat (continuous) (°C)	Coefficient of Expansion (10 <sup>-5</sup> mm/mm/°C)	Thermal Conductivity (W/m <sup>2</sup> °K)	Burning Rate	Heat Distortion Temp (°C at 1.82 MPa)	Water Absorption at (%/24h at 22.8°C)	Izod Impact (J/mm notch at 22.8°C)
PVC	Type I	48.26	28.61	66.19	99.98	65.6	127.0	5.96	Self Extinguishing	73.9	0.07	0.04
	Type II <sup>a</sup>	41.37	24.13	60.67	79.29	60.0	251.73	7.56	Self Extinguishing	68.3	0.07	0.53-0.80
CPVC	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
	Type I	12.07	131.0-2.41	—	11.72	48.9	453.57	13.06	Slow	—	-0.01	0.85
Polyethylene	Type III	13.79	10.34	—	13.79	48.9	331.11	19.87	Slow	—	0	0.16
	Type I	33.79	10.34	58.61	—	71.1-100	172.36	7.38	Slow	65.6	0.03	0.11
ABS	Type I	36.54	20.68	48.26	55.16	71.1	272.14	10.79	Slow	91.7	0.20	0.27-0.48
	Type II	55.16	—	68.95	82.74	76.7	172.36	14.20	Slow	107.2	0.20	0.21
Polyvinylidene Fluoride (PDVF)	—	48.26	8.27	68.95	—	93.3-121.1	385.54	5.96	Self Extinguishing	90.6	0.04	0.16
	Polybutylene	33.10	2.62	—	—	—	180.34	8.51	Slow	NA	<.01	no break

Notes: 1. Above data compiled in accordance with ASTM test requirements.  
 2. NA = Not applicable.  
 a The usage of PVC II is limited to electrical conduit.

### Chlorinated Polyvinyl Chloride

The higher-temperature version of PVC is CPVC, which is commonly used as an alternative to copper and PEX. CPVC is available in a variety of pressure applications in CTS or IPS, Schedule 40 or Schedule 80. Copper tube size CPVC is rated at 180°F, and the working pressure varies with the temperature: as the temperature increases, tensile strength decreases. Because of its size ranges—CTS: ½ inch to 2 inches (12.7 mm to 50.8 mm), Schedule 80: ¼ inch to 24 inches (6.3 mm to 609.6 mm)—it can be used in a wide variety of hot or cold water systems. CPVC also has been used extensively in wet fire protection systems in hotels, motels, residences, office buildings, and dormitories (all applications that fall under NFPA 13, 13D, and 13R). Pipe sizes for fire protection systems are ¾ inch to 3 inches (19 mm to 76.2 mm) and are ideally suited for the retrofit market.

CPVC is joined using solvent welding, threads, flanges, compression fittings, O-rings, transition fittings, bell rings, and rubber gaskets.

In recent years, CPVC corrosive waste drainage systems have gained acceptance as a viable alternative to the traditional polypropylene systems. Some of these systems are now certified to meet the CSA plenum rating and are working to pass ASTM E84 as well. Standard pipe sizes available for CPVC chemical waste systems are 1½ inches to 24 inches (48.3 mm to 609.6 mm).

Note: PVC and CPVC piping systems are not recommended for compressed air or compressed gas lines. Compensation for both thermal expansion and contraction must be taken into account.

### Acrylonitrile-Butadiene-Styrene

ABS is manufactured in Schedules 40 and 80 and in special dimensions for main sewers and utility conduits and in SDR for compressed air. It is commonly used for DWV plumbing (in the color black), main sanitary and storm sewers, underground electrical conduits, and applications in the chemical and petroleum industries. Schedule 40 is available in 1½, 2, 3, 4, and 6 inches (38.1, 50, 63, 90, 110, and 160 mm), with the appropriate fittings, and Schedule 80 is available in 1½, 2, 3, 4, and 6 inches (38.1, 50, 63, 90, 110, and 160 mm), with the appropriate fittings. The joints are solvent welded for Schedule 40 and welded or threaded for Schedule 80.

For industrial applications, ABS piping is gray for low temperatures (-40°F to 176°F [-72°C to 80°C]) and pressure up to 230 psi in sizes ½ inch to 8 inches (12.7 mm to 203.2 mm). It is joined only by solvent cementing. The coefficient of linear expansion is  $5.6 \times 10^{-5}$  inch/inch/°F. Fittings are available for pressure only. The outside diameter of the pipe is nominal IPS, and a second product in the industrial area is air line, which is designed to be used in delivering

compressed air for machine tools from 0.63 inch to 4 inches (16 mm to 101 mm).

### Polypropylene

PP is manufactured for a wide variety of systems. The DWV systems are for chemicals, special waste, or acid waste in both buried and aboveground applications. Pipe is available in Schedule 40 or Schedule 80 black (underground) or flame retardant (FR) for aboveground installation. Polypropylene systems for acid waste installed aboveground must utilize FR pipe and fittings. PP also is used for a wide range of industrial liquids, salt water disposal, and corrosive waste systems.

Double containment of polypropylene systems has gained popularity in the DWV acid waste market. Double-containment polypropylene systems are typically nonflame pipe (NFPP) for underground and flame-retardant pipe (FRPP) for aboveground applications. Double-containment polypropylene can be installed with or without leak-detection systems.

Polypropylene acid waste (AW) pipe systems come with either mechanical joints (1½, 2, 3, 4, and 6 inches [50, 63, 90, 110, and 160 mm]) or with an internal wire heat fused (1½, 2, 3, 4, 6, 8, 10, 12, 14, 16, and 18 inches [50, 63, 90, 110, 160, 200, 250, 300, 315, and 350 mm]), molded (1½ inches to 6 inches [50 mm to 160 mm], and fabricated (8 inches to 18 inches [200 mm to 450 mm])). Pipe is available in 10-foot and 20-foot (3.05-m and 6.1-m) lengths.

Glue cannot be used to join any polypropylene piping system. Joints are made mechanically or by heat fusion (electric coil socket fusion, butt fusion, IR welding, bead, and crevice-free welding, see Figure 2-13). Fittings are made in both pressure-type and DWV configurations. Small-diameter (½ inch to 2 inches [12.7 mm to 50.8 mm]) polypropylene may be joined by threading with a greatly reduced pressure rating,



Figure 2-13 Fusion Lock Process in Operation

or certain manufacturers have molded fittings with stainless steel rings to restrain or help strengthen the threads for full pressure ratings.

### **Polyvinylidene Fluoride**

PVDF is manufactured in Schedules 40 and 80, as well as SDR for the deionized/ultra-pure water market. Polyvinylidene fluoride is a strong, tough, abrasion-resistant fluoropolymer material. It is used widely in high-purity electronic or medical-grade water or chemical piping systems that need to remain pure but function at high temperatures. Other uses include a wide range of industrial liquids, saltwater disposal, and corrosive waste systems, again where high-temperature performance is required. It also is often used for corrosive waste applications in return air plenum spaces. Certain PVDF resins offer excellent flame- and smoke-resistant characteristics. Other benefits are its ability to withstand high temperatures for elevated-temperature cleaning, its noncontaminating qualities, and its smooth surface finish.

The coefficient of thermal expansion is  $7.9 \times 10^{-5}$  inch/inch/°F. PVDF is available in metric and IPS sizes ranging from 0.37 inch to 12 inches (9.5 mm to 304.8 mm). Pipe is available in 10-foot (3.04-m) lengths.

The color is normally natural, and the resin is not affected by ultraviolet (UV) light. However, if the media being transported within the PVDF piping system is subject to degradation by UV light, a red pigmentation is added to the resin, resulting in a red-colored piping system that protects the flow stream.

Fittings are made in both pressure and DWV configurations. It must be noted that a special flame and smoke package is added to the PVDF resin when used to manufacture DWV pipe and fittings for return and supply plenum acid waste applications. Only these special PVDF pipe and fittings meet the requirements for plenum installations of UL 723/ASTM E84. The joints cannot be solvent welded. Joints are made mechanically or by heat fusion (electric coil or socket fusion).

### **Polypropylene-Random**

PP-R is the high temperature and pressure version of PP and is manufactured for a wide variety of pressure-type systems, including potable water (hot and cold water distribution and water service), reclaimed water, rainwater, chilled water, condenser water, hydronic/heating water, geothermal systems, swimming pool piping, RO/DI water, and chemical or special waste systems, in both buried and aboveground applications. PP-R is one of the most environmentally friendly piping materials from cradle to cradle in terms of energy consumption and air, soil, and water pollution, and it has a low carbon footprint. PP-R is compatible with the POE oils used with modern refrigerants, making it suitable for use in HVAC systems.

Pipe is available in SDR 11, SDR 7.3, or SDR 6 wall thicknesses. The methods of joining are heat fusion using socket fusion fittings, butt fusion joints, electrofusion fittings, and mechanical fittings for transition to other materials and union joints. PP-R cannot be solvent welded. PP-R pipe systems with socket fusion joints come in diameters of  $\frac{1}{2}$ ,  $\frac{3}{4}$ , 1,  $1\frac{1}{4}$ ,  $1\frac{1}{2}$ , 2,  $2\frac{1}{2}$ , 3,  $3\frac{1}{2}$ , and 4 inches (20, 25, 32, 40, 50, 63, 75, 90, 110, and 125 mm) and with butt fusion connections in diameters of 6, 8, 10, and 12 inches (160, 200, 250, and 315 mm). Pipe is available in 13-foot (4-m) lengths. Fittings are made in both pressure-type and DWV configurations.

PP-R pipe is manufactured to metric outside diameters but usually is referenced to by the nominal diameter. Transition fittings are available in both metric and NPT thread sizes, groove steel, and ASME and metric flange connections.

Where thermal expansion is a concern, PP-R can be extruded with an internal fiberglass layer that reduces thermal expansion by 75 percent. When NSF-listed for potable water and food grade applications, it typically comes in green and may have a dark green stripe to indicate the fiber layer. For reclaimed and rainwater applications, the pipe is offered in a purple color. The nonpotable water pipe usually has blue and green stripes.

### **Teflon (PTFE)**

Teflon, or polytetrafluoroethylene (PTFE), has outstanding resistance to chemical attack by most chemicals and solvents. It has a temperature range of -200°F to 500°F (-128.9°C to 260°C). Teflon typically is considered tubing; however, it can be joined by threading in pipe sizes 0.13 inch to 4 inches (3.2 mm to 101.6 mm). Teflon piping is well suited for low-pressure—not to exceed 15 psi—laboratory or process industry applications. If higher pressures or hotter temperatures are needed, Teflon-lined steel pipe generally is used. Lined steel pipe is 1 inch to 12 inches (25.4 mm to 304.8 mm) and can handle corrosive chemicals as well as high-pressure applications.

### **Low-Extractable PVC**

Low-extractable PVC provides a very economical solution compared to stainless steel, PVDF, or PP for the engineering of ultra-pure water loops for use in healthcare, laboratory, micro-electronics, pharmaceutical, and various other industrial applications. Tests performed validate that resistivity can be maintained at levels greater than 18 megaohms, and online total oxidizable carbon can average less than 5 parts per billion on properly designed and maintained systems. Pipe and fittings with valves are joined by a special low-extractable one-step solvent cement. Fluids being conveyed cannot exceed 140°F (60°C). The pipe comes in Schedule 80 wall thickness and  $\frac{1}{2}$ -inch

to 6-inch (20-mm to 160-mm) diameters. The reference standards are ASTM D1785 and ASTM D2467.

### Fiberglass and Reinforced Thermosetting Resin

Fiberglass piping systems are manufactured and joined using epoxy, vinyl ester, or polyester resins. These three resins offer a very distinct price/performance choice varying from strongest/most expensive to weakest/least expensive. They typically are used in a pressure pattern mode and have good chemical resistance as well as excellent stability in the upper temperature limit of 275°F (135°C). It is especially helpful in resisting attacks from the various oils used in the petroleum industry. However, it should be noted that the chemical resistance of such systems is provided exclusively by the resin-rich liner on the inside diameter of the pipe. If the liner is worn down, cracked, or compromised in any way, putting the process in direct contact with the glass fibers, leaks will result. Depending on the manufacturer, these systems also can be joined mechanically with bell and spigot, plain, or butt and wrap methods. The pipe is manufactured in sizes of 1 inch to 48 inches (25.4 mm to 1,219 mm) and can be custom made in much larger diameters. The coefficient of linear thermal expansion is  $1.57 \times 2^{-5}$  inch/inch/°F.

Different products require different approvals. Some must meet American Petroleum Institute (API), Underwriters Laboratories (UL), or military (MIL) specifications. For potable water, they must meet NSF/ANSI Standard 14 per ASTM D2996 or NSF/ANSI Standard 61 for drinking water.

### VITRIFIED CLAY PIPE

Vitrified clay pipe is used in a building sewer starting outside of the building and connecting to the main sewer. It also is used for industrial waste because of its outstanding corrosion and abrasion resistance.

Vitrified clay pipe is extruded from a suitable grade of shale or clay and fired in kilns at approximately 2,000°F (1,100°C). Vitrification takes place at this temperature, producing an extremely hard and dense, corrosion-resistant material. Clay pipe is suitable for most gravity-flow systems and is not intended for pressure service. Available sizes include 3-inch to 48-inch (75-mm to 1,220-mm) diameters and lengths up to 10 feet (3.05 m) in standard or extra-strength grades as well as perforated (see Tables 2-15 and 2-16). Pipe and fittings are joined with prefabricated compression seals.

### HIGH SILICON IRON PIPE

High silicon iron pipe is manufactured of a 14.5 percent silicon iron makeup that possesses almost universal corrosion resistance. For nearly a century, high silicon iron pipe and fittings have provided a durable and reliable means of transporting corrosive

waste safely. Over the last few decades, however, thermoplastics (such as PVC, PP, and PVDF) have replaced this product in most laboratory, school, and hospital applications because of their even greater inertness to many chemicals, light weight, and ease of installation.

The material is available with hub-and-spigot pipe and fittings (see Figure 2-14) in sizes from 2 inches to 15 inches, which are installed using traditional plumbing techniques. Mechanical joint pipe and fittings are available from 1½ inches to 4 inches and offer ease of installation through the use of couplings.

The bell-and-spigot joint is made using conventional plumbing tools, virgin lead, and a special acid-resistant caulking yarn. The caulking yarn is packed into the bell of the joint, and a small amount of lead is poured over the yarn to fill the hub. The caulking yarn, not the lead, seals the joint. Care must be taken to not overheat the lead used in making the joint. The iron material is very brittle, and fittings are subject to stress cracking and breakage during fabrication if the lead is poured while too hot, especially in cold-weather installations.

The mechanical joints are designed for fast and easy assembly through the use of the two-bolt mechanical coupling. A calibrated ratchet is necessary to complete the joint. The nuts are tightened to 10 feet per pound 24 hours prior to testing.

Piping systems manufactured of high silicon iron pipe are similar to cast iron hub-and-spigot pipe and fittings. The pipe has a hub into which the spigot (plain end) of a pipe or fitting is inserted. Hub-and-spigot pipe and fitting sizes include 2-inch to 15-inch diameters and 5-foot or 10-foot (1.5-m or 3.1-m) lengths.




Figure 2-14 (A) Duriron Pipe and (B) Duriron Joint

Source: Courtesy of Duriron

## SPECIAL-PURPOSE PIPING MATERIALS

Stainless steel and aluminum are the most common special-purpose piping materials used for a wide range of applications where performance requirements outweigh costs. Stainless steel and aluminum require specialized skills in design and fabrication. Many alloys are available for specific applications.

### Aluminum

Aluminum is extruded or drawn in a variety of alloys. Its uses include cryogenic systems with temperatures as low as -423°F (-252.8°C), process systems,

heat transfer, and pressure lines. The joints can be brazed or welded, but it should be noted that special techniques often are required, depending on the type of alloy. Aluminum is available in 8-inch to 48-inch diameters, depending on the type.

### Stainless Steel

The designation “stainless steel” applies to a number of alloys with different properties. Common to all stainless steels is the fact that they contain at least 12 percent chromium. Stainless steel is manufactured in three basic types: martensitic (hardenable, straight chromium alloy), ferritic (straight chromium, for

**Table 2-15 Dimensions of Class 1 Standard Strength Perforated Clay Pipe**

Size (in.)	Laying length		Maximum difference in length of two opposite sides (in.)	Outside diameter of barrel (in.)		Inside diameter of socket at ½ in. above base, (in.) Min.	Rows of perforations	Perforations per row				Depth of socket (in.)		Thickness of barrel (in.)		Thickness of socket at ½ in. from outer end (in.)	
	Min.	Limit of minus variation (in. per ft. of length)		Min.	Max.			2 ft.	3 ft.	4 ft.	5 ft.	Nominal	Min.	Nominal	Min.	Nominal	Min.
4	2	¼	⅝	4⅞	5⅞	5¾	4	7	9	11	13	1¾	1½	½	⅞	⅞	⅜
6	2	¼	¾	7⅞	7⅞	8⅞	4	7	9	11	13	2¼	2	⅝	⅞	½	⅞
8	2	¼	⅞	9¼	9¼	10½	4	7	9	11	13	2½	2¼	¾	1⅞	⅞	½
10	2	¼	⅞	11½	12	12¾	6	7	9	11	13	2⅝	2⅝	⅞	1⅞	⅞	⅞
12	2	¼	⅞	13¾	14⅞	15⅞	6	—	—	—	—	2¾	2½	1	1⅞	¾	1⅞
15	3	¼	½	17⅞	17⅞	18⅞	6	—	10	14	17	2⅞	2⅞	1¼	1⅞	1⅞	⅞
18	3	¼	½	20⅞	21⅞	22¼	8	—	10	14	17	3	2¾	1½	1⅞	1⅞	1⅞
21	3	¼	⅞	24⅞	25	25⅞	8	—	10	14	17	3¼	3	1¾	1⅞	1⅞	1⅞
24	3	⅜	⅞	27½	28½	29⅞	8	—	10	14	17	3⅝	3⅝	2	1⅞	1½	1⅞

Source: Table from ASTM Specification C700.

**Table 2-15(M) Dimensions of Class 1 Standard Strength Perforated Clay Pipe**

Size (in.)	Laying Length		Maximum Difference in Length of 2 Opposite Sides (mm)	Outside Diameter of Barrel (mm)		Inside Diameter of Socket at 12.7 mm Above Base (mm)
	Minimum (m)	Limit of Minus Variation (mm/m)		Minimum	Maximum	
4	0.61	20.8	7.94	123.83	130.18	146.05
6	0.61	20.8	9.53	179.39	188.91	207.96
8	0.61	20.8	11.11	234.95	247.65	266.70
10	0.61	20.8	11.11	292.10	304.80	323.85
12	0.61	20.8	11.11	349.25	363.54	348.18
15	0.94	20.8	12.70	436.56	452.44	473.08
18	0.94	20.8	12.70	523.88	544.51	565.15
21	0.94	20.8	14.29	612.78	635.00	657.23
24	0.94	31.3	14.29	698.50	723.90	746.13

Size (in.)	Rows of Perforations	Perforations per Row				Depth of Socket (mm)		Thickness of Barrel (mm)		Thickness of Socket at 12.7 mm from Outer End (mm)	
		0.61 m	0.91 m	1.22 m	1.52 m	Nominal	Minimum	Nominal	Minimum	Nominal	Minimum
4	4	7	9	11	13	44.45	38.10	12.70	11.11	11.11	9.53
6	4	7	9	11	13	57.15	50.80	15.88	14.29	12.70	11.11
8	4	7	9	11	13	63.50	57.15	19.05	17.46	14.29	12.70
10	6	7	9	11	13	66.68	60.33	22.23	20.64	15.88	14.29
12	6	—	—	—	—	69.85	63.50	25.40	23.81	19.05	17.46
15	6	—	10	14	17	73.03	66.68	31.75	28.58	23.81	22.23
18	8	—	10	14	17	76.20	69.85	38.10	34.93	28.58	26.99
21	8	—	10	14	17	82.55	76.20	44.45	41.28	33.34	30.16
24	8	—	10	14	17	85.73	79.38	50.80	48.63	38.10	34.93

Source: Table from ASTM Specification C700

**Table 2-16 Dimensions of Class 1 Extra Strength Clay Pipe**

Size (in.)	Laying length		Maximum difference in length of two opposite sides (in.)	Outside diameter of barrel (in.)		Inside diameter of socket at ½ in. above base, (in.)	Depth of socket (in.)		Thickness of barrel (in.)		Thickness of socket at ½ in. from outer end (in.)	
	Min.	Limit of minus variation (in. per ft. of length)		Min.	Max.		Nominal	Min.	Nominal	Min.	Nominal	Min.
4	2	¼	5/16	4 7/8	5 1/8	5 3/4	1 3/4	1 1/2	5/8	9/16	7/16	3/8
6	2	¼	3/8	7 1/16	7 7/16	8 3/16	2 1/4	2	1 1/16	9/16	1/2	7/16
8	2	¼	7/16	9 1/4	9 3/4	10 1/2	2 1/2	2 1/4	7/8	3/4	9/16	1/2
10	2	¼	7/16	11 1/2	12	12 3/4	2 5/8	2 3/8	1	7/8	5/8	9/16
12	2	¼	7/16	13 3/4	14 9/16	15 1/8	2 3/4	2 1/2	1 3/16	1 1/16	3/4	1 1/16
15	3	¼	1/2	17 3/16	17 13/16	18 5/8	2 7/8	2 5/8	1 1/2	1 3/8	15/16	7/8
18	3	¼	1/2	20 5/8	21 1/16	22 1/4	3	2 3/4	1 7/8	1 3/4	1 1/8	1 1/16
21	3	¼	9/16	24 1/8	25	25 7/8	3 1/4	3	2 1/4	2	1 5/16	1 3/16
24	3	3/8	9/16	27 1/2	28 1/2	29 3/8	3 3/8	3 1/8	2 1/2	2 1/4	1 1/2	1 3/8
27	3	3/8	5/8	31	32 1/2	33	3 1/2	3 1/4	2 3/4	2 1/2	1 1/16	1 9/16
30	3	3/8	5/8	34 3/8	35 5/8	36 1/2	3 5/8	3 3/8	3	2 3/4	1 7/8	1 3/4
33	3	3/8	5/8	37 5/8	38 13/16	39 1/8	3 3/4	3 1/4	3 1/4	3	2	1 3/4
36	3	3/8	1 1/16	40 3/4	42 1/4	43 1/4	4	3 3/4	3 1/2	3 1/4	2 1/16	1 7/8

Source: Table from ASTM Specification C700.

**Table 2-16(M) Dimensions of Class 1 Extra Strength Clay Pipe**

Size (in.)	Laying Length		Maximum Difference in Length of 2 Opposite Sides (mm)	Outside Diameter of Barrel (mm)		Inside Diameter of Socket at 12.7 mm Above Base (mm)
	Minimum (m)	Limit of Minus Variation (mm/m)		Minimum	Maximum	
4	0.61	20.8	7.94	123.83	130.18	146.05
6	0.61	20.8	9.53	179.39	188.91	207.96
8	0.61	20.8	11.11	234.95	247.65	266.70
10	0.61	20.8	11.11	292.10	304.80	323.85
12	0.61	20.8	11.11	349.25	363.54	384.18
15	0.91	20.8	12.70	436.56	452.44	473.08
18	0.91	20.8	12.70	523.88	544.51	565.15
21	0.91	20.8	14.29	612.78	635.00	657.23
24	0.91	31.3	14.29	698.50	723.90	746.13
27	0.91	31.3	15.88	787.40	815.98	838.20
30	0.91	31.3	15.88	873.13	904.88	927.10
33	0.91	31.3	15.88	955.68	989.01	1012.83
36	0.91	31.3	17.46	1035.05	1073.15	1098.55

Size (in.)	Depth of Socket (mm)		Thickness of Barrel (mm)		Thickness of Socket at 12.7 mm from Outer End (mm)	
	Nominal	Minimum	Nominal	Minimum	Nominal	Minimum
4	44.45	38.10	15.88	14.29	11.11	9.53
6	57.15	50.80	17.46	14.29	12.70	11.11
8	63.50	57.15	22.23	19.05	14.29	12.70
10	66.68	60.33	25.40	22.23	15.88	14.29
12	69.85	63.50	30.16	26.99	19.05	17.46
15	73.03	66.68	38.10	34.93	23.81	22.23
18	76.20	69.85	47.63	44.45	28.58	26.99
21	82.55	76.20	57.15	50.80	33.34	30.16
24	85.73	79.38	63.50	57.15	38.10	34.93
27	88.90	82.55	69.85	63.50	42.86	39.69
30	92.08	85.73	76.20	69.85	47.63	44.45
33	95.25	88.90	82.55	76.20	50.80	44.45
36	101.60	95.25	88.90	82.55	52.39	47.63

Source: Table from ASTM Specification C700

Note: There is no limit for plus variation.

corrosive service where nickel steel is undesirable), and austenitic (18 percent chromium and 8 percent nickel, for general corrosive service). The joints can be butt welded, socket welded, screwed, or flanged. Pipe and fittings are available in 1/8-inch through 48-inch diameters.

Stainless steel is a clean, durable, corrosion-resistant, and long-lasting material. Products are chemically descaled (acid pickled) to enhance the natural corrosion resistance and to provide a uniform, aesthetically pleasing matte-silver finish.

Stainless steel is used where sanitation and product contamination resistance are critical (dairies, food processing, etc.). In processing systems, stainless steel is used to resist corrosion. All stainless steels have inherent corrosion resistance, but the austenitic group of stainless steels has the greatest resistance to many different chemical products and most detergents. Austenitic steels also have an excellent ability to resist impacts and shocks at all temperatures. Hard blows to the material may cause dents in certain cases, but it is very difficult to actually damage the steel.

Other uses include applications in the food industry, shipbuilding, pharmaceutical industry, breweries and dairies, industrial kitchens, and institutions. When increased acid resistance is required and spot and crevice corrosion may occur, molybdenum-alloyed chromium-nickel steels may be used. These acid-resistant steels resist a number of organic and inorganic acids. However, acid-proof steels are only partially resistant to solutions containing chlorides.

Stainless steel cannot burn and consequently is classified as nonflammable. This means that pipes and drains made of stainless steel may penetrate floor partitions without the need for special fire insulation. Likewise, no harmful fumes or substances are released from the steel in the event of fire.

Due to their very low heat expansion coefficient, drain products in stainless steel are not in any way influenced by temperatures occurring in drain installations. Furthermore, drain products need not be stored or installed at specific temperatures. Neither heat nor cold affects stainless steel.

Stainless steel piping is manufactured in two different grades: 304, which is suitable for most environments, and 316, which is suitable for corrosive environments. Piping is available in single hub and in eight lengths: 0.5, 0.8, 1.6, 3.3, 4.9, 6.6, 9.8, and 16.4 feet (150, 250, 500, 1,000, 1,500, 2,000, 3,000, and 5,000 mm) and 2 inches to 6 inches (50.8 mm to 152.4 mm).

It is necessary to determine the lengths required between fitting location points and to select the pipe lengths that best minimize waste and eliminate field cuts when possible. A stainless steel piping system

is lightweight and easy to install. A pipe joint can be made in a few seconds.

### Corrugated Stainless Steel Tubing

Corrugated stainless steel tubing (CSST) is a flexible gas piping system made from 300 series stainless steel. The tubing is suitable for natural gas and propane. It can be used for both aboveground and underground installations. (See specific manufacturer's recommendations for underground use and installation.) The tubing is protected with a fire-retardant polyethylene jacket. It is manufactured in 3/8-inch to 2-inch (9.52-mm to 50.8-mm) sizes and in coils of up to 1,000 feet (304.8 m) based on pipe sizes.

Mechanical joints are the only methods currently available to join CSST tubing. A number of mechanical compression-type connectors have been developed for joining CSST to permit transition to other types of pipe and fittings. The installation of any fitting shall be in accordance with the manufacturer's installation instructions.

Manufacturers have specific protective devices and termination fittings for their products. The designer should consult with the manufacturer for all required accessories.

### DOUBLE CONTAINMENT

Double containment (DC) is the practice of putting a second walled enclosure around a single-wall pipe to protect people and the environment from harm if the pipe fails. It is used both underground and aboveground for a multitude of purposes, such as to prevent corrosive chemicals from getting into soils or spilling from a single-wall overhead pipe onto people below. It is available in both drainage and pressure systems.

Double containment is most commonly available in PVC DWV × PVC DWV, PVC Schedule 40/80 × PVC DWV, PVC 40/80 × PVC 40/80, CPVC 80 × PVC 80, DWV PP × DWV PE, FRP × FRP, PE × PE, PP × PVDF, and PVDF × PVDF as well as all metals and a limitless combination of dissimilar materials (both plastics and metals mixed together). It can be ordered with or without leak detection, which can be a continuous cable (single use or reusable), point of collections, or non-wetted sensors.

DC currently is not governed by plumbing standards; however, the standards for the single-wall piping components that make up the DC system do apply.

When planning for DC, the designer should leave plenty of space. Labor costs are five to seven times those for installing single-wall pipe. Therefore, the designer should ask the system manufacturer to provide, if possible, manifolded sections that can save installation time. The designer should also consider the differential in rates of expansion that can occur within a carrier pipe as opposed to the container



pipe and make the necessary allowances in layout flexibility. Again, working with a system manufacturer is highly recommended in such cases.

When testing DC, the designer should follow the manufacturer's requirements for the proper procedures for the inner and outer pipe. Testing should be performed on the inner and outer piping segments independently.

A simple DC size variation is 6 inches inner diameter and 10 inches outer diameter, so a great difference in size exists. A typical 6-inch trap may take up 15 inches to 18 inches, and a 6-inch by 10-inch trap may need 48 inches of space. Thus, maintaining pitch requires a very different site plan and pitch elevation plan. The designer should ensure that all buried piping drawings clearly show the finished floor elevation, slab thickness, and inverts at several intervals along the piping run. Also note whether the inverts are shown for the inner or outer piping.

## PIPE JOINING PRACTICES

### Mechanical Joints

Mechanical joints include transition (flanged), compression, and threaded joints. Mechanical joints shall incorporate a positive mechanical system for axial restraint in addition to any restraint provided by friction. All internal grab rings shall be manufactured from corrosion-resistant steel. Polyethylene sealing rings shall be Type 1 (LDPE) compound. Mechanical joints for chemical, special, or acid waste should never be installed where not accessible for routine maintenance (e.g., behind walls, buried, or above ceilings).

### Compression Joints

Compression-type gaskets have been used in pressure pipe joints for years. The compression joint uses hub-and-spigot pipe and fittings (as does the lead and oakum joint). The major difference is the one-piece neoprene rubber gasket. When the spigot end of the pipe or fitting is pulled or drawn into the gasketed hub, the joint is sealed by displacement and compression of the neoprene gasket. The resulting joint is leak free, and it absorbs vibration and can be deflected up to 5 degrees without leaking or failing.

Gaskets are precision molded of durable neoprene. Service gaskets must be used with service weight pipe and fittings. Extra-heavy gaskets must be used with extra-heavy pipe and fittings. The standard specification for rubber gaskets for joining cast iron soil pipe and fittings is ASTM C564.

Neoprene does not support combustion, and gasket materials can be used safely up to 212°F. Maximum deflection should not exceed ½ inch per foot of pipe. This allows 5 inches of deflection for a 10-foot piece of pipe and 2½ inches for 5 feet of pipe. For more than 5 degrees of deflection, use fittings.

### Lead and Oakum Joints (Caulked Joints)

Hub-and-spigot cast iron soil pipe and fitting joints can be made with oakum fiber and molten lead, which provides a leak-free, strong, flexible, and root-proof joint. The waterproofing characteristics of oakum fiber have long been recognized by the plumbing trades, and when molten lead is poured over the oakum in a cast iron soil pipe joint, it completely seals and locks the joint. This is because the hot lead fills a groove in the bell end of the pipe or fitting, firmly anchoring the lead in place after cooling.

To make a caulked joint, the spigot end of a pipe or fitting is placed inside the hub of another pipe or fitting. Oakum is placed around the spigot in the hub using a yarning tool, and then the oakum is packed to the proper depth using a packing tool. Molten lead is then poured into the joint, ensuring that the lead is brought up near the top of the hub. After the lead has cooled sufficiently, it is caulked with a caulking tool to form a solid lead insert. The result is a lock-tight soil pipe joint with excellent flexural characteristics. If horizontal joints are being made, a joint runner must be used to retain the molten lead. Customary safety precautions should be taken when handling molten lead.

### Shielded Hubless Coupling

The shielded hubless coupling system typically uses a one-piece neoprene gasket, or a shield of stainless steel retaining clamps. The hubless coupling is manufactured in accordance with CISPI 310 and ASTM C1277.

The advantage of the system is that it permits joints to be made in limited-access areas. 300 series stainless steel is always used with hubless couplings because it offers resistance to corrosion, oxidation, warping, and deformation, rigidity under tension with substantial tension strength, and sufficient flexibility. The shield is corrugated to grip the gasket sleeve and to give maximum compression distribution to the joint.

The stainless steel worm gear clamps compress the neoprene gasket to seal the joint. The neoprene gasket absorbs shock and vibration and completely eliminates galvanic action between the cast iron and the stainless steel shield. Neoprene does not support combustion and can be used safely up to 212°F. The neoprene sleeve is completely protected by a nonflammable stainless steel shield, and as a result, a fire rating is not required.

Joint deflection using a shielded hubless coupling has a maximum limit of up to 5 degrees. Maximum deflection should not exceed ½ inch per foot of pipe. This allows 5 inches of deflection for a 10-foot piece of pipe. For more than 5 degrees of deflection, fittings should be used.

### Mechanically Formed Tee Fittings for Copper Tube

Mechanically formed tee fittings (see Figure 2-15) shall be formed in a continuous operation consisting of drilling a pilot hole and drawing out the tube surface to form a tee having a height of not less than three times the thickness of the branch tube wall to comply with the American Welding Society’s lap joint weld. The device shall be fully adjustable to ensure proper tolerance and complete uniformity of the joint.

The branch tube shall be notched to conform to the inner curve of the run tube and have two dimple/depth stops pressed into the branch tube, one ¼ inch (6.4 mm) atop the other to serve as a visual point of inspection. The bottom dimple ensures that the penetration of the branch tube into the tee is of sufficient depth for brazing and that the branch tube does not obstruct the flow in the main line tube. Dimple/depth stops shall be in line with the run of the tube.

Mechanically formed tee fittings shall be brazed in accordance with the Copper Development Association’s *Copper Tube Handbook* using BCuP series filler metal.

Note that soldered joints are not permitted. Mechanically formed tee fittings shall conform to ASTM F2014 and ANSI/ASME B31.9.

### Mechanical Joining of Copper Tube

#### Press Connect and Push Connect

Press-connect and push-connect copper joining systems provide fast and clean installations for both aboveground and belowground applications. The systems do not require heat, which offers faster and safer installation. Joints made using these systems are capable of withstanding pressure and temperature ranges common to residential and commercial plumbing systems.

#### Roll Groove

Roll groove is another form of mechanical joining that does not require heat. Many manufacturers provide pipe and fittings already roll grooved for faster installation.

#### Brazing

Brazing is a process in which the filler metals (alloys) melt at a temperature greater than 840°F, and the base metals (tube and fittings) are not melted. The most commonly used brazing filler metals melt at temperatures from 1,150°F to 1,550°F.

#### Soldering

Soldering is a process wherein the filler metal (solder) melts at a temperature of less than 840°F, and the base metals (tube and fittings) are not melted. The most commonly used leak-free solders melt at tempera-




Figure 2-15 Copper Pipe Mechanical T-joint  
Source: Courtesy of T-Drill




Figure 2-16 Typical Welding Fittings



Figure 2-17 Types of Welded Joints

tures from 350°F to 600°F. Lead-free solders must contain less than 0.2 percent lead.

Soldered joints should be installed in accordance with the requirements, steps, and procedures outlined in ASTM B828 and the *Copper Tube Handbook*. Fluxes used for the soldering of copper and copper alloys shall meet the requirements of ASTM B813.

### Joining Plastic Pipe

#### PEX

PEX connections are made using PEX press stainless steel sleeves or PEX crimp rings. The connection must meet or exceed the requirement of ASTM F877 or the appropriate fitting standard.

#### Vinyls and ABS

Schedule 80 plastic piping systems can be solvent welded or threaded. Schedule 40 can only be solvent welded.

The use of cleaners is not always a must. However if dirt, grease, oil, or surface impurities are present on the areas to be jointed, a cleaner must be used. Cleaners must be allowed to evaporate completely before proceeding.

Primers are used to prepare (soften) the surfaces of the pipe and fitting so the fusion process can occur. Unlike with the cleaner, the primer must be wet when the cement is applied. Specially formulated one-step cements (no primer required) are also available. Most primers are pigmented with either a




Figure 2-18 Anchors and Inserts




Figure 2-18 Anchors and Inserts (continued)

purple or an orange color because most model codes require visual evidence of their use. Clear primers containing an ultraviolet-sensitive ingredient also are available; under UV light they reveal their purple color, which allows the visual evidence to be verified while maintaining a clean look to the fabricated results. The specifier should confirm that the clear primer is approved for use in the jurisdiction. Use of this primer should in no way relieve the contractor's responsibility for cleanliness. Spills should be avoided and cleaned just as if the primer were colored.

Cements must be material specific and must be selected based on the application (pressure, non-pressure, chemicals, sizes, temperatures, etc.).

**Assembling Flanged Joints**

The face of the flange should be cleaned with a solvent-soaked rag to remove any rust-preventive grease. Any dirt should be cleaned from the gasket. The pipe and the flanges should be aligned to eliminate any strain on the coupling. The gasket should be coated with graphite and oil or some other recommended lubricant, inserted, and then bolted. Thread lubricant should be applied to the bolts, and the bolts should be evenly tightened with a wrench. The nuts should be hand tightened. When tightening the bolts, care should be exercised that they are diametrically opposed; adjacent bolts never should be tightened. Special care is needed when assembling plastic flanges because no solvents or lubricants can be used on the gaskets or bolts. The bolts should be diametrically tightened in 5 foot-pound increments and should not exceed the recommended torque rating of the flange.

**Making Up Threaded Pipe**

Male and female threads should be cleaned with a wire brush. Pipe dope should be applied only to the male thread. (If dope is applied to the female thread, it will enter the system.) The pipe and coupling should be aligned and hand tightened and then finished by turning with a wrench. A few imperfect threads should be left exposed. Sections of the assembled piping should be blown out with compressed air before being placed in the system. Special care is needed when assembling plastic-threaded fittings; a proper thread make-up can be achieved by first assembling the fittings finger-tight, followed by one to two turns of an appropriate strap wrench.

The use of an appropriate paste or tape thread sealant is recommended, but they must not be used together. If tape is used, a TFE sealant with a minimum thickness of 2.5 mm is advised. Always cover the end of the fitting at the start to prevent the thread from seizing prior to proper joint makeup. Wrap the tape in the direction of the threads (e.g., clockwise for a right-hand thread). For head adapters, use only

two to three wraps of tape and tighten to the specified torque. For female adapter transitions to metal pipe, use only five wraps of tape.

### **Thread Cutting**

The pipe should be cut with a pipe cutter and clamped in a vise, where the pipe stock and die are engaged with short jerks. The pipe should be protected when clamped. When the cutter catches, it should be pulled slowly with a steady movement using both hands. Enough cutting oil should be used during the cutting process to keep the die cool and the edges clean. The die should be backed off frequently to free the cutters, and the follower should be watched when reversing the dies to prevent jumping threads, cross-threading, or stripping threads.

Only PVC and CPVC Schedule 80, or heavier wall pipe, are suitable for threading. Either standard hand pipe tools or a pipe-threading machine shall be used. Dies must be sharp and clean and should not be used to cut materials other than plastic pipe. A 5- to 10-degree negative front rake angle is preferable when cutting threads by hand. Care should be taken to center the die on the pipe and align the thread to prevent reducing the wall excessively on one side. A tapered plug should be tapped firmly into the end of the pipe to prevent distortion. This also provides additional support. Use only lubricants compatible with the plastic material to be threaded. Leaky threaded joints are usually caused by faulty or improper lubricants.

### **Welding**

Basic welding processes include electric arc, oxyacetylene, and gas shielded. Commercial welding fittings are available with ends designed for butt welding or for socket-joint welding. The type of joint used depends on the type of liquid, pressure in the system, pipe size and material, and applicable codes. The butt joint frequently is used with a liner (backing ring). (See Figures 2-16 and 2-17.)

#### ***Electric Arc Welding***

Electric arc welding is used for standard, extra-heavy, and double extra-heavy commercial steel pipe. ASTM A53 grades of low-carbon steel butt-welded pipe are the most weldable.

#### ***Oxyacetylene Welding***

In this welding process, the flame develops a temperature to 6,300°F (3,482.2°C), completely melting commercial metals to form a bond. The use of a rod increases strength and adds extra metal to the seam. This process is used with many metals (iron, steel, stainless steel, cast iron, copper, brass, aluminum, bronze, and other alloys) and can be used to join dissimilar metals. When cut on site, the pipe ends must be beveled for welding. This can be accomplished with an oxyacetylene torch.

### ***Gas-Shielded Arcs***

This process is good for nonferrous metals since flux is not required, producing an extremely clean joint. The two types of gas-shielded arc are tungsten inert gas (TIG) and metallic inert gas (MIG). Gas-shielded arcs are used for aluminum, magnesium, low-alloy steel, carbon steel, stainless steel, copper nickel, titanium, and others.

### **Joining Glass Pipe**

Glass pipe joints are either bead to bead or bead to plain end. The bead-to-bead coupling is used for joining factory-beaded or field-beaded-end pipe and fittings. The bead-to-plain-end coupling is used to join a pipe section or fitting that has a beaded end to a pipe section that has been field cut to length and is not beaded.

### **Bending Pipe and Tubing**

Bending pipe or tubing is easier and more economical than installing fittings. Bends reduce the number of joints (which could leak) and also minimize friction loss through the pipe.

Pipe bending (cold or hot method) typically is done with a hydraulic pipe bender. The radius of the bend should be large enough to free the surface of cracks or buckles (see ANSI/ASME B31.1). Some bends are designed specifically to be creased or corrugated. Corrugated bends are more flexible than conventional types and may have smaller radii. Straight sections of pipe sometimes are corrugated to provide flexibility.

Copper tube typically is bent with a spring tube bender, grooved wheel and bar, bending press, or machine. Sharp bends are made by filling the pipe with sand or other material to prevent flattening or collapsing.

### **Electrofusion Joining**

Electrofusion is a heat-fusion joining process wherein a heat source is an integral part of the fitting. Where an electric current is applied, heat is produced, which melts and joins the components. Fusion occurs when the joint cools below the melting temperature of the material. When the cycle is completed there is no delineation between the pipe and the fitting. The applicable standard is ASTM F1290.

### **Socket Fusion Joining**

Socket fusion requires the use of a heater plate fitted with properly sized heater bushings and spigots. The pipe end and fitting are inserted into the bushings for a set time as defined by the manufacturer. Both handheld and bench machines are available for use in this joining method. Socket fusion typically is used in pure water and DWV systems.

### **Infrared Butt Fusion Joining**

This joining method utilizes infrared radiant heat to fuse the system components. The materials being

joined never make contact with the heating surface, thus ensuring a clean, uncontaminated joint, typically used for pure water systems.

**Beadless Butt Fusion Joining**

This fusion process does not produce any seams or beads on the inner wall of the pipes and/or fittings being joined. It is used in ultra-pure water applications where any beads or crevices on the interior pipe wall could lead to the buildup of contaminants within the flow stream. It also is used where the end user requires the ability to completely drain the piping system.

**ACCESSORIES AND JOINTS**

**Anchors**

Anchors are installed to secure piping systems against expansion or contraction and to eliminate pipe variation. During the installation of anchors, damage to building walls or steel must be prevented. Common anchor materials are strap steel, cast iron, angles, steel plate, channels, and steel clamps (see Figure 2-18).

**Dielectric Unions and Flanges**

Dielectric unions and flanges (see Figure 2-19) are installed between ferrous and nonferrous piping to prevent corrosion and to prevent electric currents from flowing from one part of the pipe to another. The spacer should be suitable for the system pressure and temperature.

**Expansion Joints and Guides**

Expansion joints and guides (see Figure 2-20) are designed to permit free expansion and contraction and to prevent excessive bending at joints, hangers, and connections to the equipment caused by heat expansion or vibration. Expansion guides should be used where the direction of the expansion is critical.




Figure 2-19 Dielectric Fittings




Figure 2-20 Expansion Joints and Guides




Figure 2-21 Compression Fittings

### Ball Joints

Ball joints are used in hydronic systems, where pipe flexibility is desired, for positioning pipe, and where rotary or reciprocal movement is required. Ball joints are available with threaded, flanged, or welded ends of stainless steel, carbon steel, bronze, or malleable iron.

### Flexible Couplings (Compression or Slip)

Flexible couplings (see Figure 2-21) do not require the same degree of piping alignment as flanges and threaded couplings. They provide 1/4 inch to 3/8 inch (6 mm to 9.5 mm) of axial movement because of the elasticity in the gaskets. These couplings should not be used as slip-type expansion joints or as replacements for flexible expansion joints.

### Gaskets (Flanged Pipe)

Gaskets must withstand pressure, temperature, and attack from the fluid in the pipe. Gaskets typically should be as thin as possible. ANSI/ASME B16.21 designates the dimensions for nonmetallic gaskets.

### Mechanical Couplings

Mechanical couplings (see Figure 2-22) are self-centering, lock-in-place grooves or shouldered pipe and pipe fitting ends. The fittings provide some angular pipe deflection, contraction, and expansion. Mechanical couplings often are used instead of unions, welded flanges, screwed pipe connections, and soldered tubing connections. Mechanical couplings are available for a variety of piping materials, including steel and galvanized steel, cast iron, copper tubing, and plastics. Bolting methods are standard and vandal resistant. The gasketing material varies based on the fluid in the piping system.

### Pipe Supports

Pipe can be supported using hangers, clamps, or saddles (see Figure 2-23). Pipe should be securely




Figure 2-22 Mechanical Joint




Figure 2-23 Hangers, Clamps, and Supports



supported with an ample safety factor, and the supports should be spaced according to the following guidelines:

- Less than 3/4-inch pipe: On 5-foot (1.5-m) centers
- 1-inch and 1 1/4-inch pipe: On 6-foot (1.8-m) centers
- 1 1/2-inch to 2 1/2-inch pipe: On 10-foot (3.1-m) centers
- 3-inch and 4-inch pipe: On 12-foot (3.7-m) centers
- 6-inch and larger pipe: On 15-foot (4.6-m) centers

Horizontal suspended pipe should be hung using adjustable pipe hangers with bolted, hinged loops or turnbuckles. Chains, perforated strap irons, and flat steel strap hangers are not acceptable. Pipes 2 inches in diameter and smaller (supported from the side wall) should have an expansion hook plate. Pipes 2 1/2 inches in diameter and larger (supported from the side wall) should have brackets and clevis hangers. Rollers should be provided wherever necessary. Trapeze hangers, holding several pipes, may be preferred over individual pipeline hangers. For individual hangers of pipes 2 inches in diameter and smaller, clevis hangers should be used.

Where hangers are attached to concrete slabs, the slabs should have more concrete-reinforcing rods at the point of support. The risers can be supported vertically using approved methods such as resting on the floor slab with an elbow support, resting on the floor sleeve with a clamp, or anchoring to the wall.

Pipes installed in finished trenches or tunnels should rest on a suitable sidewall or floor supports.

Consideration must be given to seismic conditions when designing pipe supports. The designer should consult with local, state, and all other governing agencies for specific requirements.

**Hangers and Supports for Copper Piping**

In addition to the following instructions, the designer should consult the local plumbing, mechanical, or building code for unique hanger spacing requirements. First, install hangers for horizontal piping with the maximum spacing and minimum rod sizes as




Figure 2-24 Pipe Union

Table 2-17 Maximum and Minimum Rod Sizes for Copper Piping

Nominal Tube Size, in.	Copper Tube Maximum Span, ft	Minimum Rod Diameter, in.
Up to 3/4	5	3/8
1	6	3/8
1 1/4	7	3/8
1 1/2	8	3/8
2	8	3/8
2 1/2	9	1/2
3	10	1/2
3 1/2	11	1/2
4	12	1/2
5	13	1/2
6	14	5/8
8	16	3/4
10	18	3/4
12	19	3/4

Table 2-18 Pipe Union Dimensions

Pipe Size (in.)	Standard								Normal Engagement	
	A		B		C		L		(in.)	(mm)
	(250 lb) (in.)	(113.5 kg) (mm)	(250 lb) (in.)	(113.5 kg) (mm)	(250 lb) (in.)	(113.5 kg) (mm)	(250 lb) (in.)	(113.5 kg) (mm)		
1/8	0.505	12.8	0.935	23.8	1.080	27.4	1.484	37.7	1/4	6.4
1/4	0.638	16.2	1.113	28.3	1.285	32.6	1.641	41.7	3/8	9.5
3/8	0.787	20.0	1.264	32.1	1.460	37.1	1.766	44.9	3/8	9.5
1/2	0.950	24.1	1.456	37.0	1.681	42.7	2.000	50.8	1/2	12.7
3/4	1.173	29.8	1.718	43.6	1.985	50.4	2.141	54.4	9/16	14.3
1	1.440	36.6	2.078	52.8	2.400	61.0	2.500	63.5	11/16	17.5
1 1/4	1.811	46.0	2.578	65.5	2.978	75.6	2.703	68.7	11/16	17.5
1 1/2	2.049	52.1	2.890	73.4	3.338	84.8	2.875	73.0	11/16	17.5
2	2.563	65.1	3.484	88.5	4.025	102.2	3.234	82.1	3/4	19.1
2 1/2	3.109	79.0	4.156	105.6	4.810	122.2	3.578	90.9	15/16	23.8
3	3.781	96.0	4.969	126.2	5.740	145.8	3.938	100.0	1	25.4

shown in Table 2-17. Then, support vertical copper tube, copper pipe, or brass pipe at each floor. Finally, in areas where excessive moisture is anticipated, either the piping or the support shall be wrapped with an approved tape or otherwise isolated to prevent contact between dissimilar metals and to inhibit galvanic corrosion of the supporting member.

**Pipe Unions (Flanged Connections)**

Pipe unions (see Figure 2-24) are installed at several locations to facilitate dismantling. They typically are installed near control valves, regulators, water heaters, meters, check valves, pumps, compressors, and boilers so equipment can be readily disconnected for repair or replacement. See Table 2-18 for dimensions.










Figure 2-25 Sleeves

### Pipe Sleeves

For pipes passing through walls, sleeves (see Figure 2-25) should extend completely through the construction, flush with each surface. The sleeves should be caulked with graphite packing and a suitable plastic waterproof caulking compound. Pipe sleeves in rated walls are to be installed to suit the specific manufacturer's hourly fire rating. Packing and sealing compounds shall be the required thickness to meet the specific hourly ratings assembly.

Sleeves in bearing walls should be of steel, cast iron, or terra-cotta pipe. Sleeves in other masonry structures may be of sheet metal, fiber, or other suitable material. Sleeves for 4-inch pipe and smaller should be at least two pipe sizes larger than the pipe passing through. For larger pipes, sleeves should be at least one pipe size larger than the enclosed pipe. The inside diameter of pipe sleeves should be at least  $\frac{1}{2}$  inch (12.7 mm) larger than the outside diameter of the pipe or covering.

### Service Connections (Water Piping)

Hand-drilled, self-tapping saddle, or cut-in sleeves should be used for water service connections. Two types of cut-in sleeves are available: for pressures to 50 psi

(344.7 kPa) and for pressures to 250 psi (1,727.7 kPa). Tapping valves are for working pressures of 175 psi (1,206.6 kPa) for 2-inch to 12-inch (50.8-mm to 304.8-mm) pipe and 150 psi (1,034.2 kPa) for 16-inch pipe.

### EXPANSION AND CONTRACTION

Piping subjected to changes in temperature expands (increases in length) and contracts (decreases in length), and each material has its own expansion and contraction characteristics. Piping expands as the temperature increases and contracts as the temperature decreases. The coefficient of expansion (CE) of a material is the material's characteristic unit increase in length per 1°F (0.56°C) temperature increase. CE values for various materials are given in *Marks' Standard Handbook for Mechanical Engineers* and manufacturer literature.

If the piping is restrained, it will be subject to compressive (as the temperature increases) and tensile (as the temperature decreases) stresses. The piping usually withstands the stresses; however, failures may occur at the joints and fittings. Common methods to absorb piping expansion and contraction are the use of expansion joints, expansion loops, and offsets.

## APPENDIX 2-A

### PIPE AND FITTINGS REFERENCE STANDARDS

The following list includes the most common standards encountered regarding plumbing pipe and fittings materials. As standards are always being developed, revised, and withdrawn, consult the authority having jurisdiction for the applicable standards in the local area.

#### Cast Iron Soil Pipe

ASTM A74: *Standard Specification for Cast Iron Soil Pipe and Fittings*

ASTM A888: *Standard Specification for Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications*

ASTM C564: *Standard Specification for Rubber Gaskets for Joining Cast Iron Soil Pipe and Fittings*

ASTM C1540: *Standard Specification for Heavy-Duty Shielded Couplings Joining Hubless Cast Iron Soil Pipe and Fittings*

CISPI 301: *Standard Specification for Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications*

CISPI 310: *Specification for Coupling for Use in Connection with Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications*

#### Ductile Iron Water and Sewer Pipe

ANSI/AWWA C104: *Cement-Mortar Lining for Ductile Iron Pipe and Fittings*

ANSI/AWWA C105: *Polyethylene Encasement for Ductile Iron Pipe Systems*

ANSI/AWWA C110: *Ductile Iron and Gray Iron Fittings*

ANSI/AWWA C111: *Rubber Gasket Joints for Ductile Iron Pressure Pipe and Fittings*

ANSI/AWWA C115: *Flanged Ductile Iron Pipe with Ductile Iron or Gray Iron Threaded Flanges*

ANSI/AWWA C116: *Protective Fusion-Bonded Epoxy Coatings for the Interior and Exterior Surfaces of Ductile Iron and Gray Iron Fittings for Water Supply Service*

ANSI/AWWA C150: *Thickness Design of Ductile Iron Pipe*

ANSI/AWWA C151: *Ductile Iron Pipe, Centrifugally Cast, for Water*

ANSI/AWWA C153: *Ductile Iron Compact Fittings*

ANSI/AWWA C600: *Installation of Ductile Iron Water Mains and Their Appurtenances*

AWWA C651: *Disinfecting Water Mains*

ASTM A716: *Standard Specification for Ductile Iron Culvert Pipe*

ASTM A746: *Standard Specification for Ductile Iron Gravity Sewer Pipe*

#### Concrete

ASTM C14: *Standard Specification for Nonreinforced Concrete Sewer, Storm Drain, and Culvert Pipe*

ASTM C76: *Standard Specification for Reinforced Concrete Culvert, Storm Drain, and Sewer Pipe*

ASTM C443: *Standard Specification for Joints for Concrete Pipe and Manholes, Using Rubber Gaskets*

ASTM C655: *Standard Specification for Reinforced Concrete D-Load Culvert, Storm Drain, and Sewer Pipe*

#### Copper

ASME B16.18: *Cast Copper Alloy Solder Joint Pressure Fittings*

ASME B16.22: *Wrought Copper and Copper Alloy Solder Joint Pressure Fittings*

ASME B16.23: *Cast Copper Alloy Solder Joint Drainage Fittings: DWV*

ANSI/ASME B16.29: *Wrought Copper and Wrought Copper Alloy Solder Joint Drainage Fittings: DWV*

ASTM B75: *Standard Specification for Seamless Copper Tube*

ASTM B88: *Standard Specification for Seamless Copper Water Tube*

ASTM B280: *Standard Specification for Seamless Copper Tube for Air-Conditioning and Refrigeration Field Service*

ASTM B306: *Standard Specification for Copper Drainage Tube (DWV)*

ASTM B584: *Standard Specification for Copper Alloy Sand Castings for General Applications*

ASTM B819: *Standard Specification for Seamless Copper Tube for Medical Gas Systems*

ASTM B837: *Standard Specification for Seamless Copper Tube for Natural Gas and Liquefied Petroleum (LP) Gas Fuel Distribution Systems*

NFPA 99: *Health Care Facilities Code*

#### Glass

ASTM C601: *Standard Test Method for Pressure Test on Glass Pipe*

ASTM C1053: *Standard Specification for Borosilicate Glass Pipe and Fittings for Drain, Waste, and Vent (DWV) Applications*

ASTM C1509: *Standard Specification for Beaded Process Glass Pipe and Fittings*

### **Steel**

ASTM A53: *Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless*

ASTM A106: *Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service*

ASTM A135: *Standard Specification for Electric-Resistance-Welded Steel Pipe*

ASTM A795: *Standard Specification for Black and Hot-Dipped Zinc-Coated (Galvanized) Welded and Seamless Steel*

ASME B16.11: *Forged Fittings, Socket-Welding and Threaded Pipe for Fire Protection Use*

ANSI/ASME B16.9: *Factory-Made Wrought Steel Buttwelding Fittings*

ANSI/ASME B16.28: *Wrought Steel Buttwelding Short Radius Elbows and Returns*

### **Polybutylene**

ASTM D2581: *Standard Specification for Polybutylene (PB) Plastics Molding and Extrusion Materials*

ASTM D2657: *Standard Practice for Heat Fusion Joining of Polyolefin Pipe and Fittings*

ASTM F1668: *Standard Guide for Construction Procedures for Buried Plastic Pipe*

CSA B137.8: *Polybutylene (PB) Piping for Pressure Applications*

### **Polyethylene**

ASTM D2239: *Standard Specification for Polyethylene (PE) Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter*

ASTM D2609: *Standard Specification for Plastic Insert Fittings for Polyethylene (PE) Plastic Pipe*

ASTM D2737: *Standard Specification for Polyethylene (PE) Plastic Tubing*

ASTM D3035: *Standard Specification for Polyethylene (PE) Plastic Pipe (DR-PR) Based on Controlled Outside Diameter*

ASTM D3350: *Standard Specification for Polyethylene Pipe and Fittings Materials*

ASTM F771: *Standard Specification for Polyethylene (PE) Thermoplastic High-Pressure Irrigation Pipeline Systems*

ASTM F810: *Standard Specification for Smoothwall Polyethylene (PE) Pipe for Use in Drainage and Waste Disposal Absorption Fields*

ASTM F894: *Standard Specification for Polyethylene (PE) Large Diameter Profile Wall Sewer and Drain Pipe*

CAN/CSA B137 Series: *Thermoplastic Pressure Piping*

### **PEX**

ASTM F876: *Standard Specification for Crosslinked Polyethylene (PEX) Tubing*

ASTM F877: *Standard Specification for Crosslinked Polyethylene (PEX) Hot- and Cold-Water Distribution Systems*

CAN/CSA B137 Series: *Thermoplastic Pressure Piping*

### **PEX-AL-PEX**

ASTM F1281: *Standard Specification for Crosslinked Polyethylene/Aluminum/Crosslinked Polyethylene (PEX-AL-PEX) Pressure Pipe*

### **PE-AL-PE**

ASTM F1282: *Standard Specification for Polyethylene/Aluminum/Polyethylene (PE-AL-PE) Composite Pressure Pipe*

CAN/CSA B137 Series: *Thermoplastic Pressure Piping*

### **PVC**

ASTM D1785: *Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120*

ASTM D2241: *Standard Specification for Poly(Vinyl Chloride) (PVC) Pressure-Rated Pipe (SDR Series)*

ASTM D2464: *Standard Specification for Threaded Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80*

ASTM D2466: *Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40*

ASTM D2467: *Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80*

ASTM D2564: *Standard Specification for Solvent Cements for Poly(Vinyl Chloride) (PVC) Plastic Piping Systems*

ASTM D2665: *Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Drain, Waste, and Vent Pipe and Fittings*

ASTM D2672: *Standard Specification for Joints for IPS PVC Pipe Using Solvent Cement*

ASTM D2680: *Standard Specification for Acrylo-*

*nitrile-Butadiene-Styrene (ABS) and Poly(Vinyl Chloride) (PVC) Composite Sewer Piping*

ASTM D2729: *Standard Specification for Poly(Vinyl Chloride) (PVC) Sewer Pipe and Fittings*

ASTM F477: *Standard Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe*

ASTM F1760: *Standard Specification for Coextruded Poly(Vinyl Chloride) (PVC) Non-Pressure Plastic Pipe Having Reprocessed-Recycled Content*

CAN/CSA B137 Series: *Thermoplastic Pressure Piping*

### **CPVC**

ASTM D2846/D2846M: *Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Hot- and Cold-Water Distribution Systems*

ASTM F437: *Standard Specification for Threaded Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 80*

ASTM F438: *Standard Specification for Socket-Type Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 40*

ASTM F439: *Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 80*

ASTM F441/F441M: *Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe, Schedules 40 and 80*

ASTM F442/F442M: *Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe (SDR-PR)*

ASTM F2618: *Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Pipe and Fittings for Chemical Waste Drainage Systems*

CAN/CSA B137 Series: *Thermoplastic Pressure Piping*

### **ABS**

ASTM D1527: *Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe, Schedules 40 and 80*

ASTM D2235: *Standard Specification for Solvent Cement for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe and Fittings*

ASTM D2661: *Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) Schedule 40 Plastic Drain, Waste, and Vent Pipe and Fittings*

ASTM D2680: *Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) and Poly(Vinyl Chloride) (PVC) Composite Sewer Piping*

ASTM D2751: *Standard Specification for Acrylo-*

*nitrile-Butadiene-Styrene (ABS) Sewer Pipe and Fittings*

ASTM F628: *Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) Schedule 40 Plastic Drain, Waste, and Vent Pipe With a Cellular Core*

CAN/CSA B137 Series: *Thermoplastic Pressure Piping*

### **Polypropylene**

ASTM D2122: *Standard Test Method for Determining Dimensions of Thermoplastic Pipe and Fittings*

ASTM D4101: *Standard Specification for Polypropylene Injection and Extrusion Materials*

ASTM F1055: *Standard Specification for Electrofusion Type Polyethylene Fittings for Outside Diameter Controlled Polyethylene and Crosslinked Polyethylene (PEX) Pipe and Tubing*

ASTM F1056: *Standard Specification for Socket Fusion Tools for Use in Socket Fusion Joining Polyethylene Pipe or Tubing and Fittings*

ASTM F1290: *Standard Practice for Electrofusion Joining Polyolefin Pipe and Fittings*

ASTM F1412: *Standard Specification for Polyolefin Pipe and Fittings for Corrosive Waste Drainage Systems*

ASTM F2389: *Standard Specification for Pressure-Rated Polypropylene (PP) Piping Systems*

### **PVDF**

ASTM D635: *Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position*

ASTM D3222: *Specification for Unmodified Poly(Vinylidene Fluoride) (PVDF) Molding Extrusion and Coating Materials*

ASTM F1673: *Standard Specification for Polyvinylidene Fluoride (PVDF) Corrosive Waste Drainage Systems*

FDA CFR 21.177.1520: *Olefin Polymer*

USP 25 Class VI (for pure water applications)

### **PP-R**

ASTM D2657: *Standard Practice for Heat Fusion Joining of Polyolefin Pipe and Fittings*

ASTM D4101: *Standard Specification for Polypropylene Injection and Extrusion Materials*

ASTM F1056: *Standard Specification for Socket Fusion Tools for Use in Socket Fusion Joining Polyethylene Pipe or Tubing and Fittings*

ASTM F1290: *Standard Practice for Electrofusion Joining Polyolefin Pipe and Fittings*

ASTM F2389: *Standard Specification for Pressure-Rated Polypropylene (PP) Piping Systems*

### **Vitrified Clay Pipe**

ASTM C12: *Standard Practice for Installing Vitrified Clay Pipe Lines*

ASTM C301: *Standard Test Methods for Vitrified Clay Pipe*

ASTM C425: *Standard Specification for Compression Joints for Vitrified Clay Pipe and Fittings*

ASTM C700: *Standard Specification for Vitrified Clay Pipe, Extra Strength, Standard Strength, and Perforated*

ASTM C828: *Standard Test Method for Low-Pressure Air Test of Vitrified Clay Pipe Lines*

ASTM C896: *Standard Terminology Relating to Clay Products*

ASTM C1091: *Standard Test Method for Hydrostatic Infiltration Testing of Vitrified Clay Pipe Lines*

ASTM C1208: *Standard Specification for Vitrified Clay Pipe and Joints for Use in Microtunneling, Sliplining, Pipe Bursting, and Tunnels*

### **High-Silicon Iron**

ASTM A518/A518M: *Standard Specification for Corrosion-Resistant High-Silicon Iron Castings*

ASTM A861: *Standard Specification for High-Silicon Iron Pipe and Fittings*

The more you use it, the smarter you get.

NEW

# leonardvalve.com

Water temperature control made easy



Built for your busy schedule, leonardvalve.com has made it easier to access Leonard when and where you need it.

- Easy navigation
- Straightforward product details
- Direct link to experts
- Personalized project details
- Leonard exclusive CASPAK® sizing software

Stay connected and boost your support of water tempering requirements with the brand you know and the service you demand: Leonard Valve. Visit the new leonardvalve.com and bookmark it today.



Experience the NEW leonardvalve.com today!



# 3 Valves

Valves serve the purpose of controlling the fluids in building service piping. They come in many shapes, sizes, design types, and materials to accommodate different fluids, piping, pressure ranges, and types of service. Proper selection is important to ensure the most efficient, cost-effective, and long-lasting systems. No single valve is best for all services. (Note: This chapter is limited to manually operated valves that start, stop, regulate, and prevent the reversal of flow.)

The following organizations publish standards and guidelines governing the use of valves:

- Manufacturers Standardization Society (MSS) of the Valve and Fittings Industry
- Underwriters Laboratories (UL)
- FM Global
- American Petroleum Institute (API)

## TYPES OF VALVES

When selecting a valve, the following service conditions should be taken into consideration:

- Pressure
- Temperature
- Type of fluid: liquid, gas (steam or air), dirty or abrasive (erosive), corrosive
- Flow: on-off, throttling, need to prevent flow reversal, concern for pressure drop, velocity
- Operating conditions: orientation, frequency of operation, accessibility, overall space available, manual or automated control, need for bubble-tight shutoff, concerns about body joint leaks, fire-safe design, speed of closure

Multi-turn valves include gate, globe, angle, and end connection. Quarter-turn

types include ball, butterfly, plug, and end connection. Check type valves include swing, list, silent or non-slam, and end connection.

## Gate Valve

With starting and stopping flow as its prime function, the gate valve is intended to operate either fully open or fully closed. The components of a gate valve are shown in Figure 3-1.

The gate valve uses a gate-like disc actuated by a stem screw and hand wheel that moves up and down at right angles to the path of flow and seats against two faces to shut off flow. Since the disc of the gate valve presents a flat surface to the oncoming flow, this valve should never be used to regulate or throttle flow. Flow through a partially open gate valve cre-




Figure 3-1 Gate Valve

ates vibration and chattering and subjects the disc and seat to inordinate wear.

Bypass valves should be provided where the differential pressure exceeds 200 pounds per square inch (psi) (1,378 kilopascals [kPa]) on valves sized 4 to 6 inches (101.6 to 152.4 mm) and 100 psi (689 kPa) on valves 8 inches (203.2 mm) and larger. Bypass valves should be  $\frac{1}{2}$  inch (12.7 mm) for 4-inch (101.6-mm) valves and  $\frac{3}{4}$  inch (19.1 mm) for 5-inch (127-mm) and larger valves.

### ***Disc and Seat Designs***

Many different seats and discs suit the conditions under which the valve operates. For relatively low pressures and temperatures and for ordinary fluids, bronze and iron valves are preferred. Bronze and iron valves usually have bronze or bronze-faced seating surfaces; iron valves may be all iron. Stainless steel is used for high-pressure steam and erosive media. Nonmetallic composition discs are available for tight seatings or hard-to-hold fluids, such as air and gasoline.

Gate discs can be classified as solid-wedge discs, double discs, or split-wedge discs. In the solid-wedge design, a single tapered disc, thin at the bottom and thicker at the top, is forced into a similarly shaped seat. In the double and split-wedge disc designs, two discs are employed back to back, with a spreading device between them. As the valve wheel turns, the gate drops into its seat (as with any other gate valve), but on the final turns of the wheel, the spreader forces the discs outward against the seats, effecting tight closure.


Metal-to-metal seating is not the best choice for frequent operation. Bubble-tight seating should not be expected with the metal-to-metal design.

Another type, resilient wedge, is a rubber-encapsulated metal wedge that seals against an epoxy-coated body. The resilient wedge design is limited to cold water applications.

### **Globe Valve**

The globe valve (see Figure 3-2), which is named for the shape of its body, is much more resistant to flow than the gate valve, as can be seen by examining the path of flow through it. Its main advantages over the gate valve are its use as a throttling valve to regulate flow, positive bubble-tight shutoff when equipped with a resilient seating, and its ease of repair. It also is good for frequent operation. On the negative side, the flow path causes a significant pressure drop, and globe valves are typically more expensive than other valves.

Because all contact between the seat and the disc ends when flow begins, the effects of wire drawing (seat erosion) are minimized. The valve can operate



**Figure 3-2 Globe Valve**


just barely open or fully open with little change in wear. Also, because the disc of the globe valve travels a relatively short distance between fully open and fully closed, with fewer turns of the wheel required, an operator can gauge the rate of flow by the number of turns of the wheel.

### ***Disc and Seat Designs***

As with the gate valve, many disc and seat arrangements are available. These are classified as conventional disc, plug type, and composition disc. The conventional disc is relatively flat, with beveled edges. On closure, it is pushed down into a beveled, circular seat. Plug-type discs differ only in that they are far more tapered, thereby increasing the contact surface between the disc and the seat. This characteristic has the effect of increasing their resistance to the cutting effects of dirt, scale, and other foreign matter. The sliding action of the semi-plug disc assembly permits the valve to serve as a shutoff valve, throttling valve, or check valve.

The composition disc differs from the others in that it does not fit into the seat opening, but over it—much as a bottlecap fits over the bottle opening. This seat adapts the valve to many services, including use with hard-to-hold substances such as compressed air, and makes it easy to repair.

Resilient (soft) seat discs are preferred over metal to metal, except where temperature, very close throttling, or abrasive flow makes all-metal seating a better choice. Stainless steel trim is available for medium-to high-pressure steam and abrasive applications. Tetrafluoroethylene (TFE) is the most resilient disc material for most services, although rubber's softness



**Figure 3-3 Angle Valve**

provides good performance in cold water. TFE is good up to 400°F (204.4°C). Nitrile rubber (Buna-N) is good up to 200°F (93.3°).

### Angle Valve

Akin to the globe valve, the angle valve (see Figure 3-3) can decrease piping installation time, labor, and materials by serving as both a valve and a 90-degree elbow. It is less resistant to flow than the globe valve, as flow must change direction twice instead of three times. It is also available with conventional, plug type, and composition discs.

### Ball Valve

The ball valve derives its name from the drilled ball that swivels on its vertical axis and is operated by a handle. Its advantages are its straight-through flow, minimum turbulence, low torque, bubble-tight closure, and compactness. Also, a quarter turn of the handle makes it a quick-closing or quick-opening valve. Reliability, ease of maintenance, and durability have made the ball valve popular in industrial, chemical, and gas transmission applications. On the downside, the cavity around the ball traps media

and does not drain entrapped media. Ball valves are susceptible to freezing, expansion, and increased pressure due to increased temperature.

### Body Styles

Ball valves are available in one-, two-, and three-piece body types, as shown in Figure 3-4. The one-piece body is machined from a solid bar of stock material or is a one-piece casing. The ball is inserted in the end for assembly, and the body insert that acts as the seat ring is threaded in against the ball. One-piece valves have no potential body leak path, but they do have a double-reduced port; thus, significant pressure drop occurs. Not repairable, they are used primarily by chemical and refining plants.

The two-piece body is the same as the one-piece valve, except that the body insert is larger and acts as an end bushing. Two-piece end entries are used most commonly in building services. They are the best value valves and are available in full- or standard-port balls. They are recommended for on/off or throttling service and are not recommended to be repaired.

The three-piece body consists of a center body section containing the ball that fits between two body end pieces. Two or more bolts hold the assembly together. Three-piece valves are costly but are easy to disassemble and offer the possibility of inline repair. They are available in full- or standard-port balls.

### Port Size

Full-port ball valves provide a pressure drop equal to the equivalent length of the pipe, slightly better than gate valves.

Standard-port (conventional) balls are up to one pipe size smaller than the nominal pipe size but still have significantly better flow characteristics than globe valves.

Reduced-port ball valves have greater than one pipe size flow restriction and are not recommended in building service piping, but rather are used for process piping for hazardous material transfer.

### Handle Extensions

Insulated handle extensions or extended handles should be used to keep insulated piping systems intact.



**Figure 3-4 Ball Valves**



**Figure 3-5** Butterfly Valves

### Butterfly Valve

The butterfly valve (see Figure 3-5) is the valve most commonly used in place of a gate valve in cases where absolute, bubble-free shutoff is required. It offers quick, 90-degree open and close and is easier to automate than multi-turn valves.

In addition to its tight closing, one of the valve's advantages is that it can be placed in a very small space between pipe flanges. It is available with several types of motorized and manual operators and a variety of component material combinations. A broad selection of trim materials is available to match different fluid conditions. Butterfly valves are very cost-effective compared to alternative valve choices, and they offer a long cycle life.

Butterfly valves cannot be used with steam, and gear operators are needed for 8-inch and larger valves to aid in operation and to protect against operating too quickly and causing destructive line shock.

### Body Styles

The two most common body types are the wafer body and lug body. The wafer body is placed between pipe flanges, and the flange bolts surround the valve body. They are easy to install but cannot be used as isolation valves.

Lug-style valves have wafer bodies with tapped lugs matching the bolt circles of class 125/150-pound flanges. They are easily installed with cap screws from either side. Screwed-lug valves can be provided so that equipment may be removed without draining down the system.

Groove butterfly valves directly connect to pipe using iron pipe size, grooved couplings. While more costly than wafer valves, grooved valves are easier to install.

### Check Valve

Swing checks and lift checks (see Figure 3-6) are the most common types of check valve. Both are designed to prevent reversal of flow in a pipe. The swing check permits straight-through flow when open and is, therefore, less resistant to flow than the lift check.

When installed in vertical installations and to ensure immediate closure upon reversal of flow, the check valve should be of the spring-loaded (non-slammng) type. If reverse flow is not stopped immediately, the backflow velocity could increase to a point that when closure occurs, the resulting shock could cause serious damage to the valve and system.


The lift check is primarily used with gases or compressed air or in fluid systems where pressure drop is not critical.

### Design Details

Swing-type check valves offer the least pressure drop and simple automatic closure. When fluid flow stops, gravity and flow reversal close the valve. Many bronze valves offer a Y-pattern body with an angle seat for improved performance. Resilient Teflon seating is preferred for tight shutoff.

Lift checks come in an inline or globe-style body pattern. Both cause greater pressure drop than the swing type, with the horizontal pattern similar in restriction to globe valves.

Some styles are spring actuated and center guided for immediate closure when flow stops. The inline,



**Figure 3-6** Check Valves

spring-actuated lift check is also referred to as the silent check because the spring closes the valve before gravity and fluid reversal can slam the valve closed. Resilient seating is recommended.

Double-disc check valves have twin discs on a spring-loaded center shaft. These valves have better flow characteristics than lift checks and most often use a wafer body for low cost and easy installation. Resilient seating is recommended.

### Plug Valve

The plug valve has a quarter-turn design similar to a ball valve, with the ball replaced by a plug. The plug can be round, diamond, or rectangular (standard). The plug valve typically requires a higher operating torque for closure, meaning specialized wrenches or expensive automation packages are required. However, it has a mechanism for power operation or remote control of any size and type to operate with air, oil, or water.

Plug valves offer bubble-tight shutoff from a stem seal of reinforced Teflon as well as quick, 90-degree open and close. Flow through the valve can be straight through, unobstructed, bidirectional, three way, or four way. Plug valves offer a long cycle life and an adjustable stop for balancing or throttling service.

Plug valves are available in lubricated, non-lubricated, and eccentric types. The lubricated, sealed check valve and combination lubricant screw and button head fitting prevent foreign matter from being forced into the lubrication system. However, the temperature and pressure ranges are limited by the type of lubricant sealant and ANSI standard rating. The non-lubricating type eliminates periodic lubrication and ensures that the valve's lubrication does not contaminate the process media or affect any downstream instrumentation. The eccentric type is basically a valve with the plug cut in half. The eccentric design allows a high achieved seating force with minimal friction encountered from the open to closed positions.

## VALVE MATERIALS

A valve may be constructed of several materials. For example, it may have a bronze body, monel seat, and an aluminum wheel. Metallic materials include brass, bronze, cast iron, malleable iron, ductile iron, steel, and stainless steel. Nonmetallic materials are typically thermoplastics. Material specifications depend on the operating conditions.

### Brass and Bronze

Brass usually consists of 85 percent copper, 5 percent lead, 5 percent tin, and 5 percent zinc. Bronze has a higher copper content, ranging from 86 percent to 90 percent, with the remaining percentage divided

among lead, tin, and zinc. Due to lead-free legislation in many states and the federal government, manufacturers are decreasing or eliminating the amount of lead in their products that are used in systems conveying water meant for human consumption.

Under certain circumstances, a phenomenon known as dezincification occurs in valves or pipes containing zinc. The action is a result of electrolysis; in effect, the zinc is actually drawn out and removed from the brass or bronze, leaving a porous, brittle, and weakened material. A higher zinc content leads to greater susceptibility to dezincification. To slow or prevent the process, tin, phosphorus antimony, and other inhibitors are added.

Brass valves should not be used for operating temperatures above 450°F (232.2°C). The maximum operating temperature for bronze is 550°F (287.8°C).

### Iron

Iron used in valves usually conforms to ASTM A126-04: *Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings*. Although iron-bodied valves are manufactured in sizes as small as ¼-inch (6.4-mm) nominal diameter, they are most commonly stocked in sizes of 2 inches (50.8 mm) and above. In these larger sizes, they are considerably less expensive than bronze.

The higher weight of iron valves, as compared to bronze valves, should be considered when determining hanger spacing and loads. A typical 2-inch (50.8-mm) bronze screwed globe valve rated at 125 psi (861.3 kPa) weighs about 13 pounds (5.9 kg). The same valve in iron weighs 15 pounds (6.8 kg) and, if specified with a yoke bonnet, about 22 pounds (10 kg).

### Malleable Iron

Malleable iron valves are stronger, stiffer, and tougher than iron-bodied valves and hold tighter pressures. Its toughness is most valuable for piping subjected to stresses and shocks.

### Stainless Steel

For highly corrosive fluids, stainless steel valves provide the maximum corrosion resistance, high strength, and good wearing properties. Seating surfaces, stems, and discs of stainless steel are suitable where foreign materials in the fluids handled could have adverse effects.

### Thermoplastic

Many different types of thermoplastic materials are used for valve construction. Plastic valves generally are limited to a maximum temperature of 250°F (121.1°C) and a maximum pressure of 150 psi (1,035 kPa).




Figure 3-7 Valve Stems

## VALVE RATINGS

Most valve manufacturers rate their products in terms of saturated steam pressure, pressure of non-shock cold water, oil, or gas (WOG), or both. These ratings usually appear on the body of the valve. For instance, a valve with the markings “125” with “200 WOG” will operate safely at 125 psi (861.3 kPa) of saturated steam or 200 psi (1,378 kPa) of cold water, oil, or gas.

The engineer should be familiar with the markings on the valves specified and should keep them in mind during construction inspection. A ruptured valve can do much damage.

## VALVE COMPONENTS

### Stems

Stem designs fall into four basic categories: rising stem with outside screw, rising stem with inside screw, nonrising stem with inside screw, and sliding stem (see Figure 3-7).

#### *Rising Stem with Outside Screw*

This design is ideal where the valve is used infrequently and the possibility of sticking constitutes a hazard, such as in a fire protection system. In this arrangement, the screws are not subject to corrosion or elements in the line fluid that might cause damage

because they are outside the valve body. Also, being outside, they can be lubricated easily.

As with any other rising stem valve, sufficient clearance must be allowed to enable a full opening.

#### ***Rising Stem with Inside Screw***

This design is the simplest and most common stem design for gate, globe, and angle valves. The position of the hand wheel indicates the position of the disc, opened or closed.

#### ***Nonrising Stem***

These are ideal where headroom is limited, but they generally are limited to use with gate valves. In this type, the screw does not raise the stem, but rather raises and lowers the disc. As the stem only rotates and does not rise, wear on packings is lessened slightly.

#### ***Sliding Stem***

These are applied where quick opening and closing are required. A lever replaces the hand wheel, and stem threads are eliminated.

#### **Bonnets**

In choosing valves, the service characteristics of the bonnet joint should not be overlooked. Bonnets and bonnet joints must provide a leak-proof closure. Many modifications are available, but the three most common types are screwed-in bonnet, screwed union-ring bonnet, and bolted bonnet.

#### ***Screwed-in Bonnet***

This is the simplest and least expensive construction, frequently used on bronze gate, globe, and angle valves and recommended where frequent dismantling is not needed. When properly designed with running threads and carefully assembled, the screwed-in bonnet makes a durable, pressure-tight seal that is suitable for many services.

#### ***Screwed Union-Ring Bonnet***

This construction is convenient where valves need frequent inspection or cleaning and also for quick renewal or changeover of the disc in composition disc valves. A separate union ring applies a direct load on the bonnet to hold the pressure-tight joint with the body. The turning motion used to tighten the ring is split between the shoulders of the ring and bonnet. Hence, the point-of-seal contact between the bonnet and the body is less subject to wear from frequent opening of the joint.

Contact faces are less likely to be damaged in handling. The union ring gives the body added strength and rigidity against internal pressure and distortion.

While ideal on small valves, the screwed union-ring bonnet is impractical on large sizes.

#### ***Bolted Bonnet Joint***

A practical and commonly used joint for large valves or for high-pressure applications, the bolted bonnet joint has multiple boltings with small-diameter bolts that permit equalized sealing pressure without the excessive torque needed to make large threaded joints. Only small wrenches are needed.

#### **End Connections**

Valves are available with screwed, welded, brazed, soldered, flared, flanged, hub, and press-fitted ends.

#### ***Screwed End***

The most widely used type of end connection is the screwed end. It is found in brass, iron, steel, and alloy piping materials. It is suited for all pressures but usually is confined to small pipe sizes. It is more difficult to make the screwed joint with larger pipe sizes.

#### ***Welded End***

Welded ends are available only in steel valves and fittings and is mainly for high-pressure and high-temperature services. It is recommended for lines not requiring frequent dismantling. The two welded-end types are butt and socket welding. Butt-welding valves and fittings come in all sizes; socket-welding ends are limited to small sizes.

#### ***Brazed End***

Brazed ends are available in brass materials because the ends of such materials are specially designed for the use of brazing alloys to make the joint. When the equipment and brazing material are heated with a welding torch to the temperature required by the alloy, a tight seal is formed between the pipe and the valve or fitting. While made in a manner similar to a solder joint, a brazed joint can withstand higher temperatures due to the brazing materials used.

#### ***Soldered Joint***

Soldered joints are used with copper tubing for plumbing and heating lines and for many low-pressure industrial services. The joint is soldered by applying heat. Because of the close clearance between the tubing and the socket of the fitting or valve, the solder flows into the joint by capillary action. The use of soldered joints under high temperatures is limited because of the low melting point of the solder. Silver solder or sil-fo (silver-copper-phosphorus) is used for high pressures and temperatures.

#### ***Flared End***

The flared end is commonly used on valves and fittings for metal and plastic tubing up to 2 inches (50.8 mm) in diameter. The end of the tubing is skirted or flared, and a ring nut is used to make a union-type joint.

#### ***Flanged End***

Flanged ends generally are used when screwed or soldered ends become impractical because of cost, size,

or the strength of the joint. They typically are used for large-diameter lines due to their ease of assembly and dismantling. Flanged facings are available in various designs depending on the service requirements. One important rule is to match facings. When bolting iron valves to forged steel flanges, the facing should be of the flat face design on both surfaces.

### **Hub End**

The hub end generally is limited to valves for water-supply and sewage piping. The joint is assembled on the socket principle, with the pipe inserted in the hub end of the valve or fitting.

### **Press-Fitted End**

The press-fitting method involves crimping the ends with a crimping tool around an ethylene propylene diene monomer (EPDM) seal to form a water-tight connection.

## **WATER PRESSURE REGULATORS**

A pressure regulator is an automatic valve controlled by an inner valve connected to a diaphragm or piston or both. The diaphragm, held in the extreme travel (open) position by a preloaded spring, is positioned in the downstream portion of the valve and closes the valve when the desired pressure has been reached.

The effectiveness of the diaphragm and the amount of preloading must be related to allow the diaphragm to move the inner valve to the extreme opposite travel (closed) position immediately after the pressure on the diaphragm passes the desired operating pressure. To change the operating pressure, tension on the diaphragm is increased or decreased by turning the adjusting screw.

A regulator typically does not go from closed to fully open or from open to fully closed immediately, but moves between these extreme positions in response to system requirements. The regulator adjusts to a fully open position instantaneously only if maximum system demand is imposed quickly, which is not a common occurrence unless the regulator is undersized. The degree of valve opening, therefore, depends entirely on the regulator's ability to sense and respond to pressure changes.

A reducing pressure change that causes a valve to open is known as a reduced pressure fall-off, or droop, and is an inherent characteristic of all self-operated or pilot-operated regulators. Technically, fall-off is expressed as the deviation in pressure from the set value that occurs when a regulator strokes from the minimum flow position to a desired flow position. The amount of fall-off necessary to open a valve to its rated capacity varies with different types of valves.

It is important to realize that the installation of a regulator sets up a closed system; therefore, it is

necessary to install a relief valve and expansion tank to eliminate any excessive pressure caused by thermal expansion of the water in the water heater or hot water storage tank.

Every manufacturer makes regulators with an integral bypass to eliminate relief valve dripping caused by thermal expansion. During normal operation, the bypass is held closed by high initial pressure. However, when thermal expansion pressure equals initial pressure, the bypass opens, passing the expanded water back into the supply line. The effectiveness of this feature is limited to systems where initial pressure is less than the pressure setting of the relief valve. The integral bypass is not a replacement for the relief valve. It is used only to eliminate excessive drip from the relief valve.

### **Regulator Selection and Sizing**

Selection of the correct type of regulator depends entirely on the accuracy of regulation required. The valve plug in oversized valves tends to remain close to the seat, causing rapid wire drawing and excessive wear. Unfortunately, no set standard for rating a pressure-regulating valve or for sizing it to the system capacity exists. The many methods proposed for selecting the proper valve are often a cause of confusion to the engineer.

The capacity rating of a pressure-regulating valve usually is expressed in terms of some single value. This value, to be useful, must specify all of the conditions under which the rating was established. Otherwise, it is impossible to adapt it to different system conditions.


Manufacturers attempt to recognize the inherent characteristics of their own design and to stipulate those factors that, in their opinion, must be considered in sizing the valve to the system. Some stress the importance of the difference between initial and reduced pressure—the differential pressure. Set pressure and allowable reduced pressure fall-off are very important factors in sizing a valve. A fall-off of 15 to 17 psi (103.4 to 117.1 kPa) is considered reasonable for the average residential installation and, in well-designed valves, produces a good rating.

Another procedure for establishing valve performance is based on flow rate, with a reduced pressure fall-off of 15 to 17 psi (103.4 to 117.1 kPa) below the reduced lockup or no-flow pressure. For general use, this approach provides an adequate means of valve selection. However, it is not specific enough to enable the selection of the valve best suited to the particular conditions.


Other manufacturers rate their valves based on a stipulated flow rate at a specific pressure differential, with the valve open to the atmosphere, without regard to changes in pressure drop when the system demand is zero. This method does not provide ample



# CONSISTENCY IN SERVICE




Hydronic Manifolds



Gate, Globe & Check Valves



Ball Valves



Engineered Valves

# VARIETY IN SELECTION

- Unbeatable Performance
- Same Day Shipping
- Over 99% Order Accuracy
- Guaranteed for Life


## Webstone

VALVE INNOVATION

Learn more:

[www.webstonevalves.com](http://www.webstonevalves.com)

(800) 225-9529



information for proper judgment of valve behavior and capability, which could result in the selection of a valve that, under no-demand conditions, permits a reduction in pressure great enough to damage equipment in the system. The maximum pressure permitted under no-flow conditions is a very important factor, for both physical and economic reasons, and should be stipulated in the specification.

The rule of thumb frequently employed is a size-to-size selection—that is, using a valve with the same connection size as the pipeline in which it will be installed. This is a gamble inasmuch as the actual capacities of many valves are inadequate to satisfy the service load specified for a pipeline of corresponding size. Consequently, the system may be starved, and the equipment may operate in an inconsistent manner.

The only sound valve selection procedure to follow is to capacity size a valve on the basis of known performance data related to system requirements.

### **Common Regulating Valves**

#### ***Direct Acting, Diaphragm Actuated***

This valve is simple in construction and operation, requiring minimum attention after installation. The direct-acting, diaphragm-actuated pressure regulator does not regulate the delivery pressure with extreme accuracy.

#### ***Pilot Operated***

The pilot-controlled valve operates efficiently because the pilot magnifies the control valve travel for a given change in control pressure.

The pilot-type regulator consists of a small, direct-acting, spring-loaded valve and a main valve. The pilot valve opens just enough to supply the necessary pressure to operate the main valve. Extreme accuracy is affected as a constant load exists on the adjusting spring, and variations in initial pressure have little effect.

#### ***Direct Acting, Balanced Piston***

This valve is a combination piston and diaphragm and requires little attention after installation. With the dependability of the diaphragm and the simplicity of direct action, this valve is only slightly affected by variations in initial pressure.

#### ***Booster Pump Control***

This is a pilot-operated valve designed to eliminate pipeline surges caused by the starting and stopping of a booster pump. The pump starts against a closed valve, and after the pump starts a solenoid valve is energized, slowly opening the valve and allowing the line pressure to gradually increase to full pumping head. When the pump shuts off, the solenoid is de-energized, and the valve slowly closes as the pump

continues to run. When the valve is fully closed, the pump stops.

#### ***Level Control***

This non-modulating valve is used to accurately control the liquid level in a tank. The valve opens fully when a preset liquid low point is reached and closes drip tight when the preset high point is reached. This is a hydraulically operated diaphragm valve with the pilot control and float mechanism mounted on the cover.

### **Common Types of Regulator Installations**

#### ***Single Regulator in Supply Line***

This type of installation is most common in domestic service and is self-explanatory.

#### ***Two Regulators in Series in Supply Line***

This type of installation provides extra protection when the main pressure is so excessive that it must be reduced to two stages to prevent high-velocity noise in the system.

#### ***Multiple Regulators Used as a Battery in Supply Line***

In many instances, a battery installation is preferable to the use of a single valve, as it provides more precise regulation over a wide demand variation.

This type of installation consists of a group of parallel regulators, all receiving water from a common manifold. After flowing through the battery of valves, water enters a common manifold of sufficient size to service the system at the reduced pressure. The battery installation is advantageous because it allows maintenance work to be performed without the necessity of turning off the entire system. It also provides better performance where demands vary from one extreme to the other.

For example, at a school with a 3-inch (76.2-mm) service, demand on drinking fountains during classes may be approximately 6 to 7 gallons per minute (gpm) (22.7 to 26.5 lpm). However, between classes, when all services are in use, the demand may be at a maximum. With a single 3-inch (76.2-mm) regulator in the system, when the faucet is turned on, the regulator must open to allow a small draw. Each time this is done, it cuts down on the service life of the large regulator.

In comparison, with a battery installation of two or three regulators set at a graduated pressure, with the smallest valve set 2- to 3-psi (13.8- to 20.7-kPa) higher than the larger ones, the system is more efficient. For a small demand, only the smallest valve opens. As the demand increases, the larger valves also open, providing the system with the capacity of all valves in the battery.

## VALVE SIZING AND PRESSURE LOSSES

Valve size and valve pressure losses can be determined utilizing a flow coefficient ( $C_V$ ), which is the number of gallons per minute (lpm) that will pass through a valve with a pressure drop of 1 psi (6.9 kPa).  $C_V$  is determined by physically counting the number of gallons (liters) that pass through a valve with 1-psi (6.9-kPa) applied pressure to the valve inlet and zero pressure at the outlet. The  $C_V$  coefficient for specific valves can be obtained from the valve manufacturer. Since the  $C_V$  factor varies in relation to valve size, the  $C_V$  can be used to determine the proper size valve for the amount of flow at a given pressure drop or, conversely, the pressure drop at a given flow. The formulas for this are:

### Equation 3-1a

$$Q = C_V \sqrt{P/G}$$

### Equation 3-1b

$$C_V = \frac{Q}{\sqrt{\Delta P/G}}$$

### Equation 3-1c

$$\Delta P = [Q/C_V]^2 G$$

where

- G = Specific gravity of the fluid
- $\Delta P$  = Pressure drop across the valve
- Q = Flow through the valve
- $C_V$  = Valve flow coefficient

## HOT AND COLD DOMESTIC WATER SERVICE VALVE SPECIFICATIONS

### Gate Valves 2 Inches and Smaller

Valves 2 inches and smaller shall be class 125, rated 125-psi SWP and 200-psi nonshock CWP, and have a rising stem. The body, union bonnet, and solid wedge shall be of ASTM B62 cast bronze with soldered ends. Stems shall be of dezincification-resistant silicon bronze (ASTM B371) or low-zinc alloy (ASTM B99). Packing glands shall be bronze (ASTM B62), with aramid fiber nonasbestos packing and malleable hand wheel. Valves shall comply with MSS SP-80.

### Gate Valves 2½ Inches and Larger

Valves 2½ inches and larger shall be class 125, rated 100-psi SWP and 150-psi nonshock CWP, and have an iron body and bronze-mounted outside screw and yoke (OS&Y). The body and bolted bonnet shall conform to ASTM A126 class B cast iron, with flanged ends, aramid fiber nonasbestos packing, and two-piece packing gland assembly. Valves shall comply with MSS SP-70.

All domestic water valves 4 inches and larger that are buried in the ground shall be of iron body and bronze fitted, with an O-ring stem seal. They shall have epoxy coating (AWWA C550) inside and outside and a resilient-seated gate valve with non-rising stem and mechanical joint or flanged ends as required. All valves furnished shall open left. All internal parts shall be accessible without removing the valve body from the line. Valves shall conform to ANSI/AWWA C509.

### Ball Valves 2 Inches and Smaller

Valves 2 inches and smaller shall be rated 150-psi SWP and 600-psi nonshock CWP and have two-piece, cast brass bodies, replaceable reinforced Teflon seats, ¼-inch to 1-inch full port or 1¼-inch to 2-inch conventional port, blowout-proof stems, chrome-plated brass ball, and threaded, soldered, or press-fit ends. Valves shall comply with MSS SP-110. Provide extended stems for valves in insulated piping.

### Globe Valves 2 Inches and Smaller

Valves 2 inches and smaller shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. The body and bonnet shall be of ASTM B62 cast bronze composition with threaded or soldered ends. Stems shall be of dezincification-resistant silicon bronze (ASTM B371) or low-zinc alloy (ASTM B99). Packing glands shall be bronze (ASTM B62), with aramid fiber nonasbestos packing and malleable hand wheel. Valves shall comply with MSS SP-80.

### Globe Valves 2½ Inches and Larger

Valves 2½ inches and larger shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have an iron body, bronze mounted, and OS&Y, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, aramid fiber nonasbestos packing, and two-piece packing gland assembly. Valves shall comply with MSS SP-85.

### Butterfly Valves 2½ Inches and Larger

Valves 2½ inches and larger shall be rated 200-psi nonshock CWP and have a lug or IPS grooved-type body with a 2-inch extended neck for insulating. They shall be cast or ductile iron (ASTM A536 or ASTM A126) with an aluminum bronze disc, 416 stainless steel stem, EPDM O-ring stem seals, and resilient, EPDM cartridge-lined seat.

Sizes 2½ inches to 6 inches shall be lever operated with a 10-position throttling plate.

Sizes 8 inches to 12 inches shall have gear operators. Sizes 14 inches and larger shall have worm gear operators only. They are suitable for use as bidirectional isolation valves and, as recommended by the manufacturer, on dead-end service at full pressure without the need for downstream flanges.

Valves shall comply with MSS SP-67.

Note: Butterfly valves in dead-end service require both upstream and downstream flanges for proper shutoff and retention or must be certified by the manufacturer for dead-end service without downstream flanges.

### **Check Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have threaded or soldered ends, with the body and cap conforming to ASTM B62 cast bronze composition and a Y-pattern swing-type disc. Valves shall comply with MSS SP-80

Note: Class 150 valves meeting the above specifications may be used where system pressure requires. For class 125 seat discs, specify Buna-N for WOG service and TFE for steam service. For class 150 seat discs, specify TFE for steam service.

### **Check Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have an iron body, bronze mounted, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, swing-type disc, and nonasbestos gasket. Valves shall comply with MSS SP-71.

Alternative check valves (2½ inches and larger) shall be class 125/250 iron body, bronze mounted, wafer check valves, with ends designed for flanged-type connection, aluminum bronze disc, EPDM seats, 316 stainless steel torsion spring, and hinge pin.

A spring-actuated check valve is to be used on pump discharge. A swing check with outside lever and spring (not center guided) is to be used on sewage ejectors or storm water sump pumps.

## **COMPRESSED AIR SERVICE VALVE SPECIFICATIONS**

### **Ball Valves 2 Inches and Smaller**

Main line valves 2 inches and smaller shall be rated 150-psi SWP and 600-psi nonshock CWP. They shall have two-piece, cast bronze bodies, with reinforced Teflon seats, a full port, blowout-proof stems, chrome-plated brass ball, and threaded or soldered ends. Valves shall comply with MSS SP-110.

Branch line valves 2 inches and smaller shall be rated 150-psi SWP and 600-psi nonshock CWP and have two-piece, cast bronze (ASTM B584) bodies with reinforced Teflon seats. Full-port ¼-inch to 1-inch valves and conventional-port 1¼-inch to 2-inch valves require blowout-proof stems, a chrome-plated brass ball with a safety vent hole on the downstream side, threaded or soldered ends, and lockout/tagout handles, which must meet the requirements of Occupational Safety and Health Administration (OSHA)

29 CFR Section 1910.147. Valves shall comply with MSS SP-110.

### **Butterfly Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be rated 200-psi nonshock CWP. Valves shall be lug or IPS, grooved-type body and shall be cast or ductile iron (ASTM A536) with a Buna-N seat, ductile iron, aluminum bronze disc, ASTM A582 Type 416 stainless steel stem, and Buna-N O-ring stem seals.

Sizes 2½ inches to 6 inches shall be lever operated with a 10-position throttling plate.

Sizes 8 inches to 12 inches shall have gear operators. Lever-operated valves shall be designed to be locked in the open or closed position. Butterfly valves on dead-end service or valves needing additional body strength shall be lug type conforming to ASTM A536 ductile iron, drilled and tapped, with other materials and features as specified above.

Valves shall comply with MSS SP-67.

Note: Dead-end service requires lug-pattern or grooved-type bodies. For dead-end service, flanges are required upstream and downstream for proper shutoff and retention, or valves must be certified by the manufacturer for dead-end service without downstream flanges. Ductile iron bodies are preferred; however, cast iron may be acceptable.

### **Check Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be of class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have threaded ends, with the body and cap conforming to ASTM B62 cast bronze composition, Y-pattern, swing-type with TFE seat disc, or spring-loaded lift type with resilient seating. Valves shall comply with MSS SP-80.

### **Check Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 125, rated 200-psi nonshock CWP, and have a maximum temperature of 200°F. They shall have an ASTM A126 class B cast iron body, wafer-check valve with ends designed for flanged-type connections, Buna-N resilient seats molded to the body, bronze disc, 316 stainless steel torsion spring, and a hinge pin. Valves shall conform to ANSI B16.10.

Note: If the compressor is the reciprocating type, check valves shall be downstream of the receiver tank.

## **VACUUM SERVICE VALVE SPECIFICATIONS**

### **Ball Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be rated 150-psi SWP and 600-psi nonshock CWP. They shall have two-piece, cast brass bodies, reinforced Teflon seats, a full port, blowout-proof stems, a chrome-plated brass ball, and

threaded or soldered ends. Valves shall comply with MSS SP-110.

### **Butterfly Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be rated 200-psi nonshock CWP. Valves shall be lug or IPS grooved-type body with a 2-inch extended neck for insulating and shall be cast or ductile iron (ASTM A536) with a Buna-N seat, ductile iron, aluminum bronze disc (ASTM A582), type 416 stainless steel stem, and Buna-N O-ring stem seals.

Sizes 2½ inches to 6 inches shall be lever operated with a 10-position throttling plate.

Sizes 8 inches to 12 inches shall have gear operators. Lever-operated valves shall be designed to be locked in the open or closed position.

For butterfly valves on dead-end service or requiring additional body strength, valves shall be lug type, conforming to ASTM A536 ductile iron, drilled and tapped, with other materials and features as specified above.

Valves shall comply with MSS SP-67.

Note: Dead-end service requires lug-pattern or grooved-type bodies. For dead-end service, flanges are required upstream and downstream for proper shutoff and retention, or valves must be certified by the manufacturer for dead-end service without downstream flanges. Ductile iron bodies are preferred; however, cast iron may be acceptable.

## **MEDICAL GAS SERVICE VALVE SPECIFICATIONS**

### **Ball Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be rated 600-psi nonshock CWP and 200 psi for medical gas. They shall have three-piece, cast bronze (ASTM B584) bodies, replaceable reinforced TFE seats, a full port, blowout-proof stems, a chrome-plated brass/bronze ball, and brazed ends. Valves shall be provided by the manufacturer cleaned and bagged for oxygen service. Valves shall comply with MSS SP-110.

### **Ball Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be rated 600-psi nonshock CWP and 200 psi for medical gas. They shall have three-piece, cast bronze (ASTM B584) bodies, replaceable reinforced TFE seats, a full port, blowout-proof stems, a chrome-plated brass/bronze ball, and brazed ends. Valves shall be provided by the manufacturer cleaned and bagged for oxygen service. Valves shall comply with MSS SP-110.

Note: Where piping is insulated, ball valves shall be equipped with 2-inch extended handles of a non-thermal, conductive material. Also, a protective sleeve that allows operation of the valve without breaking the vapor seal or disturbing the insulation should be provided.

## **LOW-PRESSURE STEAM AND GENERAL SERVICE VALVE SPECIFICATIONS**

This includes service up to 125 psi (861.8 kPa) saturated steam to 353°F (178°C).

### **Butterfly Valves**

Butterfly valves are not allowed in steam service unless stated as acceptable for the application by the manufacturer.

### **Gate Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 125, rated 125-psi SWP and 200-psi nonshock CWP, and have a rising stem. The body, union bonnet, and solid wedge shall be of ASTM B62 cast bronze with threaded ends. Stems shall be of dezincification-resistant silicon bronze (ASTM B371) or low-zinc alloy (ASTM B99). Packing glands shall be bronze (ASTM B62), with aramid fiber nonasbestos packing and malleable hand wheel.

Class 150 valves meeting the above specifications may be used where pressures approach 100 psi.

Valves shall comply with MSS SP-80.

### **Gate Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 125 and rated 100-psi SWP and 150-psi nonshock CWP. They shall have an iron body, bronze-mounted, and OS&Y, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, aramid fiber nonasbestos packing, and two-piece packing gland assembly.

Class 250 valves meeting the above specifications may be used where pressures approach 100 psi.

Valves shall comply with MSS SP-70.

### **Ball Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be 150-psi SWP and 600-psi nonshock CWP, WOG. They shall have two-piece, cast bronze bodies, reinforced Teflon seats, a full port, blowout-proof stems, an adjustable packing gland, a stainless steel ball and stem, and threaded ends. Valves shall comply with MSS SP-110.

Note: A standard port may be used where pressure drop is not a concern. For on/off service, use ball valves with stainless steel balls. For throttling, use globe valves.

### **Globe Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 125, rated 125-psi SWP and 200-psi nonshock CWP, and have a body and bonnet of ASTM B62 cast bronze composition, with threaded ends. Stems shall be of dezincification-resistant silicon bronze (ASTM B371) or low-zinc alloy (ASTM B99). Packing glands shall be of bronze (ASTM B62), with aramid fiber nonasbestos

tos packing and malleable hand wheel. Valves shall comply with MSS SP-80.

### **Globe Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have an iron body, bronze-mounted, and OS&Y, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, aramid fiber nonasbestos packing, and two-piece packing gland assembly.

Class 250 valves meeting the above specifications may be used where pressures approach 100 psi.

Valves shall comply with MSS SP-85.

### **Check Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have threaded ends with the body and cap conforming to ASTM B62 cast bronze composition, Y-pattern swing type with TFE seat disc, or spring-loaded lift type with resilient seating. Valves shall comply with MSS SP-80.

Note: Class 150 valves meeting the above specifications may be used where system pressure requires them. For class 150 seat discs, TFE for steam service should be specified.

### **Check Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 125 and rated 125-psi SWP and 200-psi nonshock CWP. They shall have an iron body, bronze mounted, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, a swing-type disc, and nonasbestos gasket. Valves shall comply with MSS SP-71.

## **MEDIUM-PRESSURE STEAM SERVICE VALVE SPECIFICATIONS**

This includes up to 200-psi (1,379 kPa) saturated steam to 391°F (201°C).

### **Butterfly Valves**

Butterfly valves are not allowed in steam service unless stated as acceptable for the application by the manufacturer.

### **Gate Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 200 and rated 200-psi SWP and 400-psi nonshock CWP. They shall have a rising stem, and the body and union bonnet shall be of ASTM B61 cast bronze, with threaded ends, ASTM B584 solid wedge, silicon bronze ASTM B371 stem, bronze ASTM B62 or ASTM B584 packing gland, aramid fiber nonasbestos packing, and malleable hand wheel. Valves shall comply with MSS SP-80.

### **Gate Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 250 and rated 250-psi SWP and 500-psi nonshock CWP. They shall have an iron body and bronze-mounted OS&Y, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, aramid fiber nonasbestos packing, and two-piece packing gland assembly. Valves shall comply with MSS SP-70.

### **Globe Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 200, rated 200-psi SWP and 400-psi nonshock CWP. They shall have a rising stem, body and union bonnet of ASTM B61 cast bronze, threaded ends, ASTM A276 type 420 stainless steel plug-type disc and seat ring, silicon bronze ASTM B371 alloy stem, bronze ASTM B62 or ASTM B584 packing gland, aramid fiber nonasbestos packing, and malleable iron hand wheel. Valves shall comply with MSS SP-80.

### **Globe Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 250, rated 250-psi SWP and 500-psi nonshock CWP. They shall have an iron body and bronze-mounted OS&Y, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends, aramid fiber nonasbestos packing, and two-piece packing gland assembly.

Where steam pressure approaches 150 psi or 366°F, gray iron or ductile iron shall be used.

Valves shall comply with MSS SP-85.

### **Check Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 200, rated 200-psi SWP and 400-psi nonshock CWP. They shall have threaded ends with the body and cap conforming to ASTM B61 cast bronze composition and a Y-pattern swing-type disc. Valves shall comply with MSS SP-80.

### **Check Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 250, rated 250-psi SWP and 500-psi nonshock CWP. They shall have an iron body, bronze mounted, with the body and bolted bonnet conforming to ASTM A126 class B cast iron, with flanged ends and a swing-type disc assembly.

Where steam pressure approaches 150 psi or 366°F, gray iron or ductile iron shall be used.

Valves shall comply with MSS SP-71.

## **HIGH-PRESSURE STEAM SERVICE VALVE SPECIFICATIONS**

This includes up to 300-psi (2,068.4-kPa) saturated steam to 421°F (216°C).

### **Gate Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 300 and rated 300-psi SWP. They shall have a rising stem,

and the body and union bonnet shall be of ASTM B61 cast bronze composition, with threaded ends, bronze ASTM B61 disc, bronze ASTM B371 stem, stainless steel ASTM A276 type 410 seat rings, bronze packing gland, aramid fiber nonasbestos packing, and malleable hand wheel. Valves shall comply with MSS SP-80.

#### **Gate Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 300, rated 300-psi SWP, and have a cast carbon steel (ASTM A216) wrought-carbon grade B (WCB) body and bolted bonnet. The disc and stem shall be ASTM A217 grade CA 15, cast 12–14 percent chromium stainless steel, with stellite-faced seat rings, flanged ends, and two-piece packing gland assembly. Valves shall comply with MSS SP-70.

#### **Globe Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 300, rated 300-psi SWP. They shall have a body and union bonnet of ASTM B61 cast bronze composition, threaded ends, stainless steel ASTM A276 hardened plug-type disc and seat ring, silicon bronze ASTM B371 stem, bronze ASTM B62 or ASTM B584 packing gland, aramid fiber nonasbestos packing, and malleable hand wheel. Valves shall comply with MSS SP-80.

#### **Globe Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 300, rated 300-psi SWP. They shall have a cast carbon steel ASTM A216 grade WCB body and bolted bonnet. The disc, stem, and seat rings shall be ASTM A217 grade CA 15, cast 12–14 percent chromium stainless steel, with flanged or welded ends and two-piece packing gland assembly. Valves shall comply with MSS SP-85.

#### **Check Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be class 300, rated 300-psi SWP. They shall have threaded ends with the body and cap conforming to ASTM B61 cast bronze composition and a Y-pattern swing-type disc. Valves shall comply with MSS SP-80.

#### **Check Valves 2½ Inches and Larger**

Valves 2½ inches and larger shall be class 300, rated 300-psi SWP. They shall have a cast carbon steel, ASTM A216 grade WCB body and bolted bonnet. The disc and seat ring shall be ASTM A217 grade CA 15, cast 12–14 percent chromium stainless steel, with flanged or welded ends. Valves shall comply with MSS SP-71.

### **HIGH-TEMPERATURE HOT WATER SERVICE VALVE SPECIFICATIONS**

This includes service to 450°F (232.2°C).

### **Nonlubricated Plug Valves**

Valves shall be ANSI class 300, 70 percent port, with nonlubricated wedge plug and bolted bonnet. The body, bonnet, and packing gland flange shall be cast carbon steel (ASTM A216) grade WCB.

The plug shall be cast from high-tensile, heat-treated alloy iron with two Teflon O-rings inserted into dovetail-shaped grooves machined into the plug face. The O-rings shall provide double seating and ensure vapor-tight shutoff on both the upstream and downstream seats. Valves are to be seated in both the open and closed positions to protect the body seats.

The stem shall be high-strength alloy steel conforming to American Iron and Steel Institute (AISI) 4150 and sulphurized, with face-to-face dimensions to meet ANSI B16.10.

Each valve shall be provided with a position indicator for visual indication of the 90-degree rotation of the plug. Valves are to be equipped with a provision for bypass connections.

For valves 3 inches and smaller, the operator shall be a hand wheel or wrench. Valves 4 inches and larger shall have an enclosed gear with a hand wheel.

Each valve shall be certified to have passed the following minimum test requirements: 1,100-psi hydrostatic shell test and 750-psi hydrostatic (both sides to be tested) and 100-psi air underwater (both sides to be tested) seat test.

### **GASOLINE AND LPG SERVICE VALVE SPECIFICATIONS**

#### **Plug Valves**

Valves shall be ANSI class 150, 70 percent port, with nonlubricated tapered plug and bolted bonnet. Valve body shall be ASTM A216 grade WCB steel with a drain plug suitable for double block and bleed service.

The plug seals shall be two Teflon O-rings inserted into dovetail-shaped grooves machined into the plug face. The plug shall lift clear of the seats before rotating 90 degrees.

End connections shall be ANSI class 150 raised face and flanged. Face-to-face dimensions are to meet ANSI B16.10.

### **FIRE PROTECTION SYSTEM VALVE SPECIFICATIONS**

#### **Gate Valves 2 Inches and Smaller**

Valves 2 inches and smaller shall be of class 175-psi water working pressure (WWP) or greater, and the body and bonnet shall conform to ASTM B62 cast bronze composition, with threaded ends, OS&Y, and solid disc. They shall be listed by UL, be FM approved, and be in compliance with MSS SP-80.

### Gate Valves 2½ Inches and Larger

Valves 2½ inches and larger shall be rated 175-psi WWP or greater. They shall have an iron body, bronze mounted or with resilient rubber-encapsulated wedge, and the body and bonnet shall conform to ASTM A126 class B cast iron, with OS&Y and class 125 flanged or grooved ends. If of the resilient-wedge design, the interior of the valve is to be epoxy coated. Valves shall meet or exceed AWWA C509. Valves are to be UL listed, FM approved, and in compliance with MSS SP-70.

### Valves 4 Inches and Larger for Underground Bury

These shall be rated 200-psi WWP or greater, and the body and bonnet shall conform to ASTM A126 class B cast iron, bronze mounted, resilient-seated gate valve with nonrising stem, with O-ring stem seal, epoxy coating (AWWA C550) inside and outside, and flanged or mechanical joint ends as required. All valves furnished shall open left. All internal parts shall be accessible without removing the valve body from the line. Valves shall conform to AWWA C509. Valves shall come with a mounting plate for an indicator post and be UL listed, FM approved, and in compliance with MSS SP-70.

When required, a vertical indicator post may be used on underground valves. Posts must provide a means of knowing if the valve is open or closed. Indicator posts must be UL listed and FM approved.

## HIGH-RISE SERVICE VALVE SPECIFICATIONS

### Gate Valves 2½ Inches to 12 Inches

Gate valves 2½ inches to 10 inches shall be rated 300-psi WWP or greater. 12 inches shall be rated 250-psi WWP. They shall have an iron body, bronze mounted, with the body and bonnet conforming to ASTM A126 class B cast iron, OS&Y, and flanged ends for use with class 250/300 flanges. They shall be UL listed, FM approved, and in compliance with MSS SP-70.

### Check Valves 2½ Inches to 12 Inches

Check valves 2½ inches to 10 inches shall be rated 300-psi WWP or greater. 12 inches shall be rated 250-psi WWP. They shall have an iron body, bronze mounted, with a horizontal swing check design, and the body and bonnet shall conform to ASTM A126 class B cast iron, with flanged ends for use with class 250/300 flanges. They shall be UL listed, FM approved, and in compliance with MSS SP-71.

Note: In New York City, valves are to be approved by the New York City Materials and Equipment Acceptance Division (MEA) in addition to the above specifications.

### Ball Valves 2 Inches and Smaller

Valves 2 inches and smaller shall be constructed of commercial bronze (ASTM B584) and rated 175-psi WWP or higher, with reinforced TFE seats. Valves shall have a gear operator with a raised position indicator and two internal supervisory switches. Valves shall have threaded or IPS grooved ends and shall have blowout-proof stems and chrome-plated balls. They shall be UL listed, FM approved, and in compliance with MSS SP-110 for fire protection service.

### Butterfly Valves 4 Inches to 12 Inches

Butterfly valves may be substituted for gate valves where appropriate. Valves shall be rated for 250-psi WWP and 175-psig working pressure, UL listed, FM approved, and in compliance with MSS SP-67.

Valves furnished shall have a ductile iron (ASTM A536) body and may have ductile iron (ASTM A395) (nickel-plated) discs or aluminum bronze discs, depending on local water conditions. In addition, the wafer style for installation between class 125/150 flanges or the lug style or grooved body may be specified depending on the system's needs.

Valves shall be equipped with weatherproof gear, operator rated for indoor and outdoor use with hand wheel, and have a raised position indicator with two internal supervisory switches.

### Check Valves

Valves 2½ inches and larger shall be 500-psi WWP and have a bolted bonnet, and the body and bonnet shall conform to ASTM A126 class B cast iron, with flanged end composition Y-pattern, horizontal swing-type disc. They shall be UL listed, FM approved, and in compliance with MSS SP-71 type 1 for fire protection service.

## GLOSSARY

**Ball valve** A valve consisting of a single drilled ball that is operated by a handle attached to the vertical axis of the ball, which permits fluid flow in a straight-through direction. The ball within the valve body may be rotated fully opened or fully closed by a one-quarter turn of the handle.

**Body** The part of a valve that attaches to the pipeline or equipment—with screwed ends, flanged ends, or soldered/welded joint ends—and encloses the working parts of the valve.

**Bolted bonnet** A type of bonnet constructed so that it attaches to the valve body by means of a flanged, bolted connection. The whole bonnet assembly, including the hand wheel, stem, and disc, may be quickly removed by unscrewing the nuts from the bonnet stud bolts.

**Bonnet** The part of the valve housing through which the stem extends. It provides support and



protection to the stem and houses the stem packing. It may be screwed or bolted to the body.

**Butterfly valve** A type of valve consisting of a single disc that is operated by a handle attached to the disc, which permits fluid flow in a straight-through direction. The valve is bidirectional. The disc within the valve body may be rotated fully open or fully closed by a one-quarter turn of the handle.

**Cap** The top part of the housing of a check valve (equivalent to the bonnet of a gate or globe valve), which may be either screwed or bolted onto the main body.

**Check valve** An automatic, self-closing valve that permits flow in only one direction. It automatically closes by gravity when liquid ceases to flow in that direction.

**Clapper** A common term that is used to describe the disc of a swing-type check valve.

**Disc** The disc-shaped device that is attached to the bottom of a valve stem and is brought into contact with or lifted off the seating surfaces to close or open a globe valve or butterfly valve.

**Full port** A term meaning that the area through the valve is equal to or greater than the area of standard pipe.

**Gate valve** A valve that is used to open or close off the flow of fluid through a pipe. It is so named because of the wedge (gate) that is either raised out of or lowered into a double-seated sluice to permit full flow or completely shut off flow. The passageway through a gate valve is straight through, uninterrupted, and the full size of the pipeline into which the valve is installed.

**Gland bushing** A metal bushing installed between the packing nut and the packing to transmit the force exerted by the packing nut against the packing.

**Globe valve** A valve that is used for throttling or regulating flow through a pipe. It is so named because of the globular shape of the body. The disc is raised off a horizontal seating surface to permit flow or lowered against the horizontal seating surface to shut off flow. The disc may be lifted completely to permit full flow or lifted only slightly to throttle or regulate flow. The flow through a globe valve has to make two 90-degree turns.

**Hand wheel** The wheel-shaped turning device by which a valve stem is rotated, thus lifting or lowering the disc or wedge.

**Hinge pin** The valve part that the disc or clapper of a check valve swings.

**Lift check valve** A check valve using a disc that lifts off the seat to allow flow. When flow decreases, the disc starts closing and seals before reverse flow occurs.

**Outside screw and yoke (OS&Y)** A type of bonnet so constructed that the operating threads of the stem are outside the valve housing, where they may be lubricated easily and do not come into contact with the fluid flowing through the valve.

**Packing** A general term describing any yielding material used to affect a tight joint. Valve packing is generally jam packing, or pushed into a stuffing box and adjusted from time to time by tightening a packing gland or packing nut.

**Packing gland** A device that holds and compresses the packing and provides additional compression by manual adjustment of the gland as wear of the packing occurs. A packing gland may be screwed or bolted in place.

**Packing nut** A nut that is screwed into place and presses down on a gland bushing, which transmits the force exerted by the packing nut to the packing. It serves the same purpose as the packing gland.

**Rising stem** A threaded component that is unscrewed or screwed through the valve bonnet to open or close a valve. The hand wheel may rise with the stem, or the stem may rise through the hand wheel.

**Screwed bonnet** A type of bonnet so constructed that it attaches to the valve body by means of a screwed joint. A bonnet may be attached to the body by screwing over the body or inside the body or by means of a union-type screwed connection.

**Solid wedge** A wedge consisting of one solid piece into which the valve stem is attached, so it seals against the valve seating surfaces to ensure a tight seal when the valve is closed.

**Split wedge** A wedge consisting of two pieces into which the valve stem is screwed, so it expands the two pieces against the valve seating surfaces to ensure a tight seal when the valve is closed.

**Standard port** A term meaning that the area through the valve is less than the area of standard pipe.

**Stem** The usually threaded shaft to which the hand wheel is attached at the top and the disc or wedge at the lower end. The stem also may be called the spindle.

**Stopplug** An adjusting screw that extends through the body of a check valve. It adjusts and controls the extent of movement of the disc or clapper.

**Swing check valve** A check valve that uses a hinged disc or clapper to limit the direction of flow. The pressure exerted by the fluid flowing through the valve forces the disc away from the seating surface. When the flow ceases, the clapper falls to its original position, preventing flow in the opposite direction.

**Union** A coupling fitting consisting of three parts (shoulder piece, thread piece, and ring) that is used for coupling the ends of pipe sections. Adjoining faces of shoulder and thread pieces are lapped together to form a tight joint. Unions permit easy disconnection for repair and replacement of piping and fittings.

**Union bonnet** A type of bonnet so constructed that the whole bonnet assembly, including the hand wheel, stem, and disc assembly, may be removed quickly by unscrewing the bonnet union ring from the valve body.

**Union ring** A large nut-like component that secures the union thread and the union shoulder together. It slips over and against the shoulder piece and screws onto the union thread piece.

**Union shoulder piece** The part of the union fastened to the pipe that retains the union ring.

**Union threaded piece** The part of the union that is fastened to the pipe and has external threads over which the union ring is screwed to effect a coupling.

**Wedge** The wedge-shaped device that fits into the seating surfaces of a gate valve and is drawn out of contact with the seating surfaces to permit flow or is pushed down into contact with the seating surfaces to close off flow with the valve. (See also disc.)

# 4 Pumps

The most common type of pump used in plumbing systems is the centrifugal pump, although some applications require other types. For plumbing, the centrifugal pump stands out because of its simple design and suitable head (pressure). Further, its rotational speed matches that of commonly available electric motors; drive belts or gears are rarely employed. With small sizes, the motor shaft is typically coupled directly to the pump impeller, resulting in a compact design and a simple installation, even for fire pumps.

This chapter focuses on centrifugal pumps, but pumps in general are explored, including differences in pump types, performance characteristics, applications, installation, and environmental issues.

## APPLICATIONS

Pump applications in plumbing include specialty pumps for liquid supplies, pressure boosters for domestic water supply, similar supply pumps for fire suppression, water circulation for temperature maintenance, and elevation increases for drainage systems. Except for the circulation application, pump systems theoretically are open systems, meaning that the liquid is transferred from one reservoir to another of a higher elevation. The applications vary in the nature of the liquid, the duty—whether for daily use or for rare firefighting use—and the magnitude of elevation changes.

## PUMP BASICS

Machines that move water, or any liquid, are called turbomachines. Commonly referred to as pumps, these machines add energy to the liquid, resulting in a higher pressure downstream. This added energy is called head, which refers back to the days of dams and water wheels. The descent of water was expressed as a level of energy per pound of water. The water descended adjacent to the dam through the water wheel, and the vertical distance between the water levels on either side of the dam was measured. In contrast to

water wheels, all pumps add energy, but the amount is expressed in the same terminology.

In theory, if a sufficiently tall, open-top vertical pipe is mounted on a pipe both downstream and upstream of a pump, the liquid level in both can be observed. The level downstream will be higher than the level upstream. This difference in elevation between the two levels is called the total head for the pump. Another element of pump head is the difference in elevation between the upstream pipe and the pump; a distinction is made if the upstream elevation is above or below the elevation of the pump inlet.


## Pump Types and Components

For all pumps, the basic parts consist of a passage and a moving surface. The passage is simply referred to as the pump casing. A prime mover, such as an electric motor but sometimes an engine, adds torque to the moving surface. Other parts include shaft bearings and various seals, such as the shaft seal.

Pumps may be categorized as positive displacement, centrifugal, axial, or mixed flow. Positive-displacement pumps deliver energy in successive isolated quantities whether by a moving plunger, piston, diaphragm, or rotary element. Clearances are minimized between the moving and unmoving parts, resulting in only insignificant leaks past the moving parts. Common rotary elements include vanes, lobes, and gears.

When a pump with a rotating surface has significant clearance between itself and the stationary passage, the pump does not have positive displacement. If the direction of discharge from the rotating surface, called the impeller, radiates in a plane perpendicular to the shaft, the pump is a centrifugal pump. If the direction is inline with the shaft, the pump is axial. If the direction is partly radial and partly axial, the pump is mixed flow. Examples of a centrifugal pump, an axial pump, and a positive-displacement pump, respectively, include an automobile water pump, a boat propeller, and the human heart.

Compared to positive-displacement pumps, centrifugal and axial pumps are simple and compact



**Figure 4-1** Portion of a Close-Coupled Centrifugal Pump With an End-Suction Design



**Figure 4-2** Inline Centrifugal Pump with a Vertical Shaft  
Photo courtesy of Peerless Pump Co.

and do not have flow pulsations. Centrifugal pumps provide greater total head than similarly sized axial pumps, but they provide lower flow. The operation of a centrifugal pump includes the outward, radial projection of the liquid from the impeller as it rotates. In addition, if a gradual expanding passage is provided after the impeller, the high velocity is converted to a high static pressure. This idea follows the law of conservation of energy and is quantified in Bernoulli's equation. If the expanding passage wraps around the impeller, it is called a volute.

The quantity and angle of the blades on the impeller and the shape of the blades vary. They may be two straight blades positioned radially, many curved blades angled forward, or more commonly, many blades angled backward to the direction of rotation. While forward blades theoretically impart greater velocity, the conversion to pressure is unstable except within a narrow speed range.

Pipes generally connect to pumps with standard flanges, but they may also connect by pipe threads or solder joints. The centerline of the inlet pipe may be aligned with the pump shaft. Figure 4-1 shows this type; it is referred to as an end-suction design. The outlet generally falls within the plane of the impeller. If the inlet and outlet connections align as if in a continuation of the pipe run, as shown in Figure 4-2, the pump is referred to as inline.

Casing materials are generally cast iron and, for domestic water supply, cast bronze. Other materials include stainless steel and various polymers. Impeller materials also include cast iron, bronze, and various polymers. Pump bearings and motor bearings vary between traditional sleeves and roller elements such as steel ball bearings. Bearings on each side of the impeller minimize shaft stresses compared to a pair of bearings on one side. At the other extreme, the pump itself has no bearings, and all hydraulic forces are applied to the motor bearings. The combination of these materials, design features, and array of pump sizes results in pumps being the most varied of the world's manufactured products.

The greatest pressure in any pumped system is within the pump casing, which includes the shaft seal. Another concern with this seal occurs when the pump is not operating, when a stored supply of pressure applies continuous static head against the seal. This seal traditionally has been designed with a flexible composite material stuffed around a clearance between the shaft and the hub portion of the pump casing, referred to as a stuffing box. A mechanical arrangement applies pressure to the flexible material through routine adjustments. Some leakage is deliberately required, so provisions for the trickle flow must be included, such as with the installation of a floor drain.

Another seal design consists of a simple O-ring. More advanced seals include the mechanical seal and the wet rotor design. In a mechanical seal, the interface of two polished surfaces lies perpendicular to the shaft. One is keyed and sealed to the shaft, and the other is keyed and sealed to the pump casing. Both are held together by a spring and a flexible boot. Some pumps include two sets of these seals, and the space between them is monitored for leakage. Often, a special flow diversion continuously flushes the seal area.

In the wet rotor design, the rotor winding of the motor and the motor bearings are immersed in the water flow and are separated from the dry stator by a thin, stationary, stainless steel shield called a canister. The shield imparts a compromise in the magnetic flux from the stator to the rotor, so these pumps are limited to small sizes.

### DETERMINING PUMP EFFICIENCY

High efficiency is not the only characteristic to examine in selecting a pump. It is explored here, nonetheless, to demonstrate the impact of alternatives when various compromises are considered.

An ideal pump transfers all of the energy from a shaft to the liquid; therefore, the product of torque and rotational speed equals the product of mass flow and total head. However, hydraulic and mechanical losses result in performance degradation. Hydraulic losses result from friction within the liquid through the pump, impeller exit losses, eddies from sudden changes in diameter, leaks, turns in direction, or short-circuit paths from high-pressure sections to low-pressure sections. Mechanical losses include friction in bearings and seals. The amount of hydraulic and mechanical losses is from 15 percent to 80 percent in centrifugal pumps and lesser amounts for positive-displacement pumps.

Design features in centrifugal pumps that minimize hydraulic losses include a generous passage diameter to reduce friction, an optimal impeller design, a gradual diameter change and direction change, placement of barriers against short-circuits, and optimal matches of impeller diameters to pump casings. The design of a barrier against short-circuits includes multiple impeller vanes, seals at the impeller inlet, and minimal space between the impeller and the pump casing. The seals at the impeller inlet are commonly in the form of wear rings. Enclosed impellers, as shown in Figure 4-3, achieve higher heads because of the isolation of the inlet pressure from the liquid passing through the impeller; thus, the original efficiencies are maintained over the pump's useful life.

Equation 4-1 illustrates the relationship between flow, total head, efficiency, and input power for pumps with cold water. For other liquids, the equation is appropriately adjusted.

#### Equation 4-1

$$P = \frac{Q \times h}{3,960 \times e} \left[ \frac{Q \times h \times 9.81}{e} \right]$$

where

P = Power through the pump shaft, horsepower (W)

Q = Flow, gallons per minute (gpm) (L/s)

h = Total head, feet (meters)

e = Efficiency, dimensionless



Figure 4-3 Enclosed Impeller




Figure 4-4 Centrifugal Pump with a Double-Suction Inlet Design

Impellers with diameters significantly smaller than an ideal design generally compromise efficiency. The efficiency of centrifugal pumps varies greatly with head and flow. Hence, a pump with 85 percent efficiency at one flow may be only 50 percent at one-third of that flow.

Axial flow directed into the impeller of a centrifugal pump may come from one side only (single-suction pump, refer back to Figure 4-1) or both sides (double-suction pump, see Figure 4-4). The single-suction design creates axial forces on the pump shaft. The double-suction design balances those forces. In addition, double-suction pumps have a slower inlet velocity, which helps prevent cavitation.

Since most pumps are driven by electric motors, a complete review of pump efficiency should include

consideration of motor efficiency, which varies with torque, type of motor, speed, type of bearings, and quality of electricity. Many fractional-horsepower, single-phase motors experience a dramatic loss of efficiency at light loads. A three-phase motor achieves peak efficiency at slightly less than full load. High-speed motors and large motors offer greater efficiencies than slower or smaller motors. Polyphase, permanent split-capacitor, and capacitor-start/capacitor-run motors are more efficient than split-phase, capacitor-start/induction-run, and shaded pole motors.

A centrifugal pump's first cost can be minimized by designing for the best efficiency points (BEP) of the operating flow and head. A lower total head also results in less bearing and shaft stresses, leading to a longer expected pump life.

An appreciation of the benefits of investing in efficiency in a plumbing system can be realized by identifying the magnitude of power in various parts of a building. For example, a domestic water heater's energy input may be 1,000,000 British thermal units per hour (Btuh) (293 kW), while its circulation pump may be 700 Btuh (205 W). Hence, in this situation an inefficient pump is of little consequence. Excessive circulation increases standby losses, but a more efficient heat exchanger in the water heater will provide the most tangible benefit. While the importance of a fire pump for fire suppression is paramount, efficiency invested there is less important than a reliable pump design.

## CENTRIFUGAL PUMP CHARACTERISTICS

The characteristics of centrifugal pumps can be reduced to two coefficients and one value referred to as the specific speed. The coefficients and a set of relationships, called affinity laws, allow similarly shaped centrifugal pumps to be compared. In general, the coefficients also apply to axial and mixed-flow pumps, as well as turbines and fans.

Deriving the coefficients starts with the law of conservation of momentum. That is, the summation of forces on the surface of any fixed volume equals the aggregate of angular-momentum vectors multiplied by the flows at each of those vectors. Since the applied energy into the liquid on the fixed volume around the impeller is only the tangential movement of the impeller, only the tangential velocity vectors are considered. For constant density and for radial and tangential velocities at the inlet and outlet of an impeller, the momentum equation becomes:

### Equation 4-2

$$T = d_2 \times r_2 \times v_{t2} \times Q_2 - d_1 \times r_1 \times v_{t1} \times Q_1$$

where

T = Torque, foot-pounds (N-m)

$d_2$  = Density at the outlet, pounds per cubic foot ( $\text{kg}/\text{m}^3$ )

$r_2$  = Radius at the outlet, inches (mm)

$v_{t2}$  = Tangential velocity at the outlet, feet per second (fps) (m/s)

$Q_2$  = Flow at the outlet, gpm (L/s)

$d_1$  = Density at the inlet, pounds per cubic foot ( $\text{kg}/\text{m}^3$ )

$r_1$  = Radius at the inlet, inches (mm)

$v_{t1}$  = Tangential velocity at the inlet, fps (m/s)

$Q_1$  = Flow at the inlet, gpm (L/s)

From Bernoulli's equation of an ideal flow through any type of pump, total head is a measure of power per flow and per specific weight. Since power is the product of torque and rotational speed, the above equation can be related to the Bernoulli equation. For steady-state conditions, the inlet flow equals the outlet flow. The relation becomes:

### Equation 4-3

$$h = \frac{P}{d \times g \times Q} = \frac{(r_2 \times v_{t2} - r_1 \times v_{t1}) \times n}{g}$$

where

h = Total head created by the pump, feet (m)

P = Power, horsepower (W)

n = Rotational speed, revolutions per minute (rpm) (radians per second)

g = Gravity constant

With the velocity of the tip of a rotating surface at its outside radius designated as U, the equation is:

### Equation 4-4

$$h = \frac{U_2 \times v_{t2} - U_1 \times v_{t1}}{g}$$

For centrifugal pumps, flow is proportional to the outlet radial velocity. In addition,  $v_{t1} = 0$  since inlet flow generally is moving in an axial direction and not in a tangential direction. Thus:

### Equation 4-5

$$h = \frac{U_2 \times v_{t2}}{g}$$

Figure 4-5 shows the velocity vectors of the flow leaving the impeller. Vector  $v_{r2}$  represents the velocity of the water in a radial direction, Vector X represents the velocity of the water relative to the impeller blade, and Vector Y represents the sum of X and U. Thus, it is possible to resolve these vectors into tangential components and derive the following:

### Equation 4-6a

$$v_{t2} = U_2 - v_{r2} \cot B = U_2 [1 - (v_{r2}/U_2) \cot B]$$

### Equation 4-6b

$$h = \frac{U_2 \times U_2 [1 - (v_{r2}/U_2) \cot B]}{g}$$

**Equation 4-6c**

$$h = \frac{U_2^2 [1 - (C_Q) \cot B]}{g}$$

For a given flow, the  $v_{r2}/U_2$  ratio is constant and is defined as a capacity coefficient,  $C_Q$ . For a given impeller design,  $C_Q$  and Angle B are constant. Hence,  $[1 - (v_{r2}/U_2) \cot B]$  is constant and is defined as a head coefficient,  $C_H$ . Equation 4-7 shows the relationship between this coefficient, the head, and the impeller's tip velocity.

**Equation 4-7**


$$C_H = \frac{h \times g}{U_2^2}$$

With the various constants identified in Equation 4-6c, the total head is directly proportional to the square of the impeller's tip velocity,  $U_2$ . Recall that the tip velocity is a product of the impeller's rotational speed and the impeller's radius. Thus, the total head is proportional to the square of the impeller's radius or of its diameter, and it is proportional to the square of the impeller's rotational speed, in rpm (radians per second). This is the second pump affinity law.

Additionally, since flow is directly proportional to area and velocity at any section through a pump, at a particular section the flow is proportional to the velocity of the impeller's tip. Hence, flow is proportional to the rotational speed of the impeller and to the diameter of the impeller. This is the first pump affinity law.

**Table 4-1 Centrifugal Pump Affinity Laws**

Function	Tip Velocity	Rotational Speed, rpm (radians/sec)	Impeller Radius (or Diameter), in. (mm)
Flow	U	n	R
Head	U <sup>2</sup>	n <sup>2</sup>	R <sup>2</sup>
Power	U <sup>3</sup>	n <sup>3</sup>	R <sup>3</sup>



**Figure 4-5 Net Fluid Movement From an Impeller Represented by Vector Y**

Since power is the product of flow and head, power is directly proportional to the cube of the velocity. This is the third pump affinity law.

Table 4-1 summaries the three pump affinity laws. Each function is directly proportional to the corresponding value in the other columns.


In addition, it is customary to combine flow and head with the rotational speed and set exponentials, so this speed appears to the first power. The result,  $nQ^{0.5}/h^{0.75}$ , is called the specific speed of the pump.

When the flow rate, head, and a given pump speed are known, the specific speed can be derived, and the design of an economical pump can be identified, whether centrifugal, axial, or mixed flow. Specific speed also allows a quick classification of a pump's efficient operating range with a mere observation of the shape of the impeller.

The affinity laws allow easy identification of pump performance when the speed changes or the impeller diameter changes. For example, doubling the speed or impeller diameter doubles the flow, increases the head by four, and increases the required motor power by eight.

**PERFORMANCE CURVES**

Since centrifugal pumps do not supply a nearly constant flow rate like positive-displacement pumps, characteristic pump curves are provided by manufacturers to aid in selecting a pump. Under controlled conditions, such as with water at a certain temperature, these curves are created from measurements of impeller speed, impeller diameter, electric power, flow, and total head. The standard conditions are created by such groups as the Hydraulic Institute. As can be observed, the shape of the curve in Figure 4-6 agrees with Equation 4-6c. This pump curve represents a particular impeller diameter measured at a constant speed, with its total head varied and its resulting flow recorded. Efficiency is plotted on many of these



**FLOW CAPACITY**

**Figure 4-6 Typical Pump Curve Crossing a System Curve**

curves, and the BEP is sometimes marked. Additional curves usually include shaft input power, measured in horsepower (W), efficiency, and net positive suction head (NPSH).

While a curve is plotted for a given pump and with a given diameter impeller, a pump in operation under a constant head and speed has one particular flow. The point on the pump curve of this flow and head is referred to as the duty point or system balance point. The pump will provide that flow if that head applies.

In plumbing, a particular flow may be required for a sump pump or hot water circulation pump. In domestic water and fire suppression supply systems, the head varies with the quantity of open faucets,

outlets, hose streams, or sprinkler heads. Further, the quantity of such open outlets varies with time. Thus, the duty point rides left and right along the curve with time.

Another curve that represents the building's distribution piping at peak demand can be plotted on a pump curve. This second curve, called the system head curve or building system curve, is shown in Figure 4-6. Equation 4-8 represents this familiar curve, where  $p_1$  represents a pressure gauge reading at the pump inlet and  $p_2$  and  $h_2$  represent pressure and elevation head respectively at a particular system location such as at a remote fixture. The last term represents the entire friction head in the piping between the two points including control valves, if any, at the pump.

The curve's shape is parabolic. This curve is applicable to any liquid that has a constant absolute viscosity over a wide flow range (a Newtonian fluid).

**Equation 4-8**


$$h_p = (p_2 - p_1)/d + h_2 + f(L/D)(v^2/2g)$$

At no flow, the friction term becomes zero since velocity is zero, and the point where this curve crosses the vertical axis is the sum of the remaining terms.


To select a pump, determine the peak flow and use Equation 4-8 to calculate the required pump head. The flow and head identify the duty point. Most catalogues from pump manufacturers offer a family of centrifugal pumps in one diagram. Separate graphs, one for each pump housing and shaft speed, show the pump performance for each of several impellers. Figure 4-7 illustrates such a graph for a pump measured at 1,750 rpm (183 radians per second). Pick a pump impeller that at least includes the duty point. An optimal pump is one whose pump curve crosses this point. However, with most pump selections, the pump curve crosses slightly above the point.

For example, if the duty point is 100 gpm at 30 feet of head (6.31 L/s at 9.14 m of head), the impeller number 694 in Figure 4-7 is a suitable choice because its pump curve (the solid line matched to 694) crosses above the duty point. Power requirements are marked

**Figure 4-7 Typical Pump Curves and Power Requirements**



**Figure 4-8 Blade Shape and Quantity Versus Performance Curve**



Source: Figures 4-7 and 4-8 courtesy of Weil Pump Company Inc.



in dashed lines in Figure 4-7. The pump's motor size, in horsepower or kilowatts, is identified by the dashed line above and to the right of the duty point. A more precise motor required can be estimated at 1.6 hp (1.2 kW), but engineers typically pick the 2-hp (1.5-kW) motor size. Select the motor with a nominal 1,800-rpm (188 radians per second) rotational speed. The pump's efficiency can be estimated if efficiency curves are included on the chart. Comparing the efficiencies of several pumps can lead to an ideal choice. Alternatively, the flow and head of the duty point can determine the ideal power requirement. A pump's efficiency is found by dividing the ideal power, from Equation 4-1, by the graphically shown power. With this example, the efficiency is  $0.758/1.6 = 47$  percent.

The shape of a pump curve varies with the impeller design. A rapidly dropping head due to increasing flow is characterized by a steep curve. Flat curves represent a slight variation from no flow to BEP, often defined as 20 percent. The latter is preferred in most plumbing applications that employ one pump because of the nearly uniform head. Figure 4-8 shows steep and flat curves and the corresponding blade designs.

A pump with a steep curve is advantageous when a high head is required in an economical pump design and the flow is of less consequence. For example, a sump pump, which has a sump to collect peak flows into its basin, may have a high static head. With a generous volume in the sump, the total time to evacuate the sump is secondary; therefore, the pump's flow is of less concern than its head. Further, as the inlet flow increases and the water level rises, the head reduces and the pump flow increases.

A pump design with some slope in its curve is desired for parallel pump configurations. The sum of the flows at each head results in a more flat curve. For control, the drop in head as the demand increases may serve as an indicator to stage the next pump.

A pump with nearly vertical steepness is desired for drainage pumps that are part of a system of pumps that discharge into a force main. This performance character-

istic allows a nearly uniform flow for a wide variation of heads. Some centrifugal and all positive-displacement pumps exhibit this characteristic.

## STAGING

To obtain greater total head, two pumps can be connected in series; that is, the discharge of one pump becomes the inlet of the other. As a convenience, pump manufacturers have created multistage pumps in which two or more centrifugal pumps are joined in a series by combining all of the impellers on a common shaft and arranging the casing to direct the flow of a volute into the eye of the next impeller (see Figure 4-9).

Another way to obtain greater head is by using a regenerative turbine pump. Unlike other centrifugal pumps, the outer edge of the impeller and its volute are intentionally employed with higher velocities by using recirculation of a portion of the flow from the volute to pass just inside the tip of the impeller. The close dimensions of these pumps limit their use to clean liquids.

Applications of high-head pumps include water supplies in high-rise buildings, deep water wells, and fire pumps for certain automatic stand-pipe systems.

## SPECIALTY PUMPS

To select a specialty pump, the following must be considered: pressure increase, range of flow, nature of the energy source (electricity, air, manual, etc.), whether the liquid contains particulates, whether pulses are tolerable, accuracy in dispensing, self-priming requirement, whether the pump is submerged, and if the pump requires an adaptation to its supply container.

### Domestic Booster Pumps

A domestic booster pump system typically uses multiple parallel centrifugal pumps to increase municipal water pressure for the building's domestic water distribution. Particular design issues such as sizing, pump redundancy, pressure-reducing valves, other pump controls, adjustable-frequency drives, high-rise buildings, and break tanks are described in *Plumbing Engineering Design Handbook*, Volume 2, Chapter 5: "Cold Water Systems." The same issues apply for private water systems that require a well pump.



**Figure 4-9 Multistage or Vertical Lineshaft Turbine Pump**

Photo courtesy of Peerless Pump Co.

## Fire Pumps

The water supply for fire suppression requires a pump that is simple and robust. In addition, the slope of the performance curve is limited by fire pump standards. NFPA 20: *Standard for the Installation of Stationary Fire Pumps for Fire Protection* limits the curve to not less than 65 percent of the rated total head for 150 percent of the rated flow. A variety of listing agencies monitor pump manufacturing to certify compliance with one or more standards. The design of a single-stage or multistage centrifugal pump generally qualifies. A double-suction centrifugal pump with enclosed impeller, horizontal shaft, wear rings, stuffing-box shaft seals, and bearings at both ends historically has been used. The pump inlet connection generally is in line with the outlet connection.

A recent variation, for small fire pumps, includes a vertical shaft and a single-suction design with the impeller fastened directly to the motor shaft. Pump bearings, shaft couplings, and motor mounts are eliminated in this compact design.

In applications for tank-mounted fire pumps, the impeller is suspended near the bottom of the tank, and the motor or other prime mover is located above the cover. Between the two is a vertical shaft placed within a discharge pipe. NFPA calls these pumps vertical lineshaft turbine pumps. Flexibility in their design includes multistaging, a wide range of tank depths, and several types of prime movers.

## Water Circulation Pumps

Maintaining adequate water temperature in plumbing is achieved through circulation pumps. Applicable generally for hot water, but equally effective for chilled water to drinking fountains served by a remote chiller, the circulation pump maintains a limited temperature change. Heat transfer from hot water distribution piping to the surrounding space is quantified for each part of the distribution network. For a selected temperature drop from the hot water source to the remote ends of the distribution, an adequate flow in the circulation can be determined from Equation 4-9. Since the nature of circulation is as if it were a closed system, pump head is simply the friction losses associated with the circulation flow.

### Equation 4-9

$$Q = \frac{q}{500 \times T} \left[ \frac{q}{4,187 \times T} \right]$$

where

Q = Flow, gpm (L/s)

q = Heat transfer rate, Btuh (W)

T = Temperature difference, °F (°C)

For example, if it is determined that 1,000 Btuh transfers from a length of hot water piping and no more than 8°F is acceptable for a loss in the hot wa-

ter temperature, the flow is determined to be 1,000/(500 × 8) = 0.250 gpm. In SI, if it is determined that 293 W transfers from a length of hot water piping and no more than 4.4°C is acceptable for a loss in the hot water temperature, the flow is determined to be 293/(4,187 × 4.4) = 0.0159 L/s.

## Drainage Pumps

Where the elevation of the municipal sewer is insufficient or if another elevation shortfall occurs, pumps are added to a drainage system. The issue may apply only to one fixture, one floor, or the entire building. Elevation issues usually apply to subsoil drainage, so this water is also pumped. Lastly, if backflow is intolerable from floor drains in a high-value occupancy, pumps are provided for the floor drains.

The terminology varies to describe these pumps, but typical names include sewage pump, sump pump, sewage ejector, lift station pump, effluent pump, bilge pump, non-clog pump, drain water pump, solids-handling sewage pump, grinder pump, dewatering pump, and wastewater pump.

Drainage pumps generally have vertical shafts, cylindrical basins, and indoor or outdoor locations. Some pumps are designed to be submerged in the inlet basin, others in a dry pit adjacent to the basin, and in others the motor is mounted above with only the pump casing and impeller submerged. In any design, provision is required for air to enter or leave the basin as the water level varies.

The nature of solids and other contaminants in the water through these pumps necessitates several types of pump designs. For minimal contaminants, the design may be with an enclosed impeller, wear rings, and clearance dimensions that allow 3/4-inch (19-mm) diameter spheres to pass through. Such a pump may be suitable for subsoil drainage or for graywater pumping.

For drainage flows from water closets and similar fixtures, manufacturers provide pumps of two designs. One design uses an open recessed impeller, no wear rings, and clearance dimensions that allow 2-inch (50-mm) diameter spheres to pass through. The other, referred to as a grinder pump (see Figure 4-10), places a set of rotating cutting blades upstream of the impeller inlet, which slice solid contaminants as they pass through a ring that has acute edges. Efficiency is compromised in both types for the sake of effective waste transport, in the latter more so than in the former, but with the benefit of a reduced pipe diameter in the discharge piping. Grinder pumps are available in centrifugal and positive-displacement types.

The installation of a pump in a sanitary drain system includes a sealed basin and some vent piping to the exterior or to a vent stack. In some cases, the pump can be above the water level, but only if a

reliable provision is included in the design to prime the pump prior to each pumping event.

## PUMP MAINTENANCE

The selection of a pump includes factors such as the need to monitor, repair, or replace the pump. Pumps in accessible locations can readily be monitored. Sensors on remote pumps, such as seal leak probes and bearing vibration sensors, assist in pump monitoring to prevent a catastrophic pump failure.

Pump maintenance can be facilitated when disassembly requires minimal disturbance of piping or wiring. Disassembly may be with the casing split horizontally along a horizontal shaft or with the casing split perpendicularly to the shaft. The latter allows impeller replacement without disturbing the pipe connection to the pump body.

Complete pump replacement can be facilitated with adequate access, shutoff valves, nearby motor disconnects, minimal mounting fasteners, direct mounting of the motor on the pump housing (close-coupled pump), and pipe joints with bolted fasteners. A simpler arrangement, commonly used for submersible drainage pumps, allows removal of the pump from the basin by merely lifting a chain to

extract it. The lift or return is facilitated by special guide rails, a discharge connection joint held tight by the weight of the pump, and a flexible power cable.

## ENVIRONMENTAL CONCERNS

In addition to any concerns about how a pump may affect the environment, the environment may affect the design requirement for a pump. An example of the former is a provision in an oil-filled submersible pump to detect an oil leak, such as a probe in the space between the shaft seals that signals a breach of the lower seal. Another example is vibration isolation for a pump located near sensitive equipment.

The external environment can affect a pump in many ways. For instance, a sewage ejector may be subjected to methane gas, causing a potential explosion hazard. Loss of power is a common concern, as are abrasive or corrosive conditions. The former can be prevented with the inclusion of a parallel pump powered by a separate battery, and correct material selection can help prevent the latter. Other examples include the temperature of the water through the pump, the temperature of the air around the pump, and the nature of any contaminants in the water. Sand and metal shavings are a concern with grinder pumps as they can erode the blades.

## PUMP CONTROLS


Pump controls vary with the application. A small simplex sump pump may have a self-contained motor overload control, one external float switch, an electric plug, and no control panel. A larger pump may have a control panel with a motor controller, run indicator light, hand-off auto switch, run timer, audio/visual alarm for system faults, and building automation system interface.

A control panel should be certified as complying with one or more safety standards, and the panel housing should be classified to match its installation environment. Motor control generally includes an electric power disconnect and the related control wiring, such as power-interrupting controls against motor overload, under-voltage, or over-current.

The largest pumps often include reduced-voltage starters. Duplex and triplex pump arrangements include these control features for each pump as well as an alternator device that alternates which pump first operates on rising demand. A microprocessor may be economically chosen for applications involving at least a dozen sensor inputs.

A booster pump has additional controls such as low flow, low suction pressure, high discharge pressure, a time clock for an occupancy schedule and possibly a speed control such as a variable-frequency drive.

A circulation pump may include a temperature sensor that shuts down the pump if it senses high



**Figure 4-10** Cross-Section of a Grinder Pump with Cutting Blades at the Inlet

Photo courtesy of Ebara.

temperature in the return flow, which presumably indicates adequate hot water in each distribution branch. A time clock for an occupancy schedule shuts down the pump during off hours.

The controls for a fire pump may include an automatic transfer between two power sources, engine control if applicable, and pressure maintenance through a secondary pump, which is called a jockey pump. The control of a drainage pump includes one or more float switches and possibly a high water alarm.

## INSTALLATION

Pumping effectiveness and efficiency require uniform velocity distribution across the pipe diameter or basin dimensions at the pump inlet. An elbow, increaser with a sudden diameter change, check valve, and any other flow disturbance at the pump inlet create an irregular velocity profile that reduces the flow and possibly the discharge head. To avoid air entrapment, eccentric reducers with the straight side up are used on inlet piping rather than concentric reducers.

In addition to shutoff valves, pump installations may include drain ports, pressure gauges, automatic or manual air release vents, and vibration isolation couplings. Pressure gauges upstream and downstream of the pump allow easy indication of the rated pump performance. Check valves are provided for each pump of duplex and similar multiple-pump arrangements, fire pumps, and circulation pumps.

A fire pump includes provisions for periodic flow testing. Fire pumps also may include a pressure relief valve if low flows create high heads that exceed pipe material ratings.

A pump requires a minimum pressure at its inlet to avoid cavitation. Destructive effects occur when a low absolute pressure at the entry to the impeller causes the water to vaporize and then collapse further into the impeller. The resulting shock wave erodes the impeller, housing, and seals and overloads the bearings and the shaft. The pockets of water vapor also block water flow, which reduces the pump's capacity. Cavitation can be avoided by verifying Equation 4-10.

### Equation 4-10

$$h_r \leq h_a - h_v + h_s - h_f$$

where

$h_r$  = Net positive suction head required (obtained from the pump manufacturer), feet (m)

$h_a$  = Local ambient atmospheric pressure converted to feet (m) of water

$h_v$  = Vapor pressure of water at applicable temperature, feet (m)

$h_s$  = Suction head (negative value for suction lift), feet (m)

$h_f$  = Friction head of piping between pump and where  $h_s$  is measured, feet (m)

Increasing  $h_s$  resolves most issues regarding cavitation, generally by mounting the pump impeller as low as possible. Note that  $h_r$  varies with flow and impeller diameter:  $h_a = 33.96$  feet (10.3 m) for an ambient of 14.7 pounds per square inch (psi) (101 kPa) and  $h_v = 0.592$  feet (0.180 m) for water at 60°F (15.5°C). Suction head,  $h_s$ , may be the inlet pressure converted to head, but it also may be the vertical distance from the impeller centerline to the surface of the water at the inlet. The ambient head,  $h_a$ , also may need adjusting for sewage pumps, with the basin connected to an excessively long vent pipe. Reciprocating positive-displacement pumps have an additional acceleration head associated with keeping the liquid filled behind the receding piston.

Submergence is a consideration for pumps joined near or in a reservoir or basin. A shallow distance from the pump inlet to the surface of the water may create a vortex formation that introduces air into the pump unless the reservoir exit is protected by a wide plate directly above. In addition to lost flow capacity, a vortex may cause flow imbalance and other harm to the pump. To prevent these problems, the basin can be made deeper to mount the pump lower, and the elevation of the water surface can be unchanged to keep the same total head.

Redundancy can be considered for any pump application. The aggregate capacity of a set of pumps may exceed the peak demand by any amount; however, the summation for centrifugal pumps involves adding the flow at each head to create a composite performance curve. Discretion is further made to the amount of redundancy, whether for each duplex pump at 100 percent of demand or each triplex pump at 40 percent, 50 percent, or 67 percent. For efficiency's sake, a mix may be considered for a triplex, such as 40 percent for two pumps and 20 percent for the third pump.

## GLOSSARY

**Available net positive suction head** The inherent energy in a liquid at the suction connection of a pump.

**Axial flow** When most of the pressure is developed by the propelling or lifting action of the vanes on the liquid. The flow enters axially and discharges nearly axially.

**Bernoulli's theorem** When the sum of three types of energy (heads) at any point in a system is the same in any other point in the system, assuming no friction losses or the performance of extra work.

**Brake horsepower (BHP)** The total power required by a pump to do a specified amount of work.

**Capacity coefficient** The ratio of the radial velocity of a liquid at the impeller to the velocity of the impeller's tip.

**Churn** The maximum static head of a pump—typically the head when all flow is blocked.

**Design working head** The head that must be available in the system at a specified location to satisfy design requirements.

**Diffuser** A point just before the tongue of a pump casing where all the liquid has been discharged from the impeller. It is the final outlet of the pump.

**Flat head curve** When the head rises slightly as the flow is reduced. As with steepness, the magnitude of flatness is a relative term.

**Friction head** The rubbing of water particles against each other and against the walls of a pipe, which causes a pressure loss in the flow line.

**Head** The energy of a fluid at any particular point of a flow stream per weight of the fluid, generally measured in feet (meters).

**Head coefficient** Pump head divided by the square of the velocity of the impeller tip.

**Horsepower** The power delivered while doing work at the rate of 500 foot-pounds per second or 33,000 foot-pounds per minute.

**Independent head** Head that does not change with flow, such as static head and minimum pressure at the end of a system.

**Mechanical efficiency** The ratio of power output to power input.

**Mixed flow** When pressure is developed partly by centrifugal force and partly by the lift of the vanes on the liquid. The flow enters axially and discharges in an axial and radial direction.

**Multistage pumps** When two or more impellers and casings are assembled on one shaft as a single unit. The discharge from the first stage enters the suction of the second and so on. The capacity is the rating of one stage, and the pressure rating is the sum of the pressure ratings of the individual stages, minus a small head loss.

**Net positive suction head (NPSH)** Static head, velocity head, and equivalent atmospheric head at a pump inlet minus the absolute vapor pressure of the liquid being pumped.

**Packing** A soft semi-plastic material cut in rings and snugly fit around the shaft or shaft sleeve.

**Potential head** An energy position measured by the work possible in a decreasing vertical distance.

**Pumps in parallel** An arrangement in which the head for each pump equals the system head and the sum of the individual pump capacities equals the system flow rate at the system head.

**Pumps in series** An arrangement in which the total head/capacity characteristic curve for two pumps in series can be obtained by adding the total heads of the individual pumps for various capacities.

**Pump performance curve** A graphical illustration of head horsepower, efficiency, and net positive suction head required for proper pump operation.

**Radial flow** When pressure is developed principally by centrifugal force action. Liquid normally enters the impeller at the hub and flows radially to the periphery.

**Required NPSH** The energy in a liquid that a pump must have to operate satisfactorily.

**Shutoff BHP** One-half of the full load brake horsepower.

**Slip** A loss in delivery due to the escape of liquid inside a pump from discharge to suction.

**Specific speed** An index relating pump speed, flow, and head used to select an optimal pump impeller.

**Standpipe** A theoretical vertical pipe placed at any point in a piping system so that the static head can be identified by observing the elevation of the free surface of the liquid in the vertical pipe. The connection of the standpipe to the piping system for a static head reading is perpendicular to the general flow stream.

**Static head** The elevation of water in a standpipe relative to the centerline of a piping system. Any pressure gauge reading can be converted to static head if the density of the liquid is known.

**Static pressure head** The energy per pound due to pressure. The height a liquid can be raised by a given pressure.

**Static suction head** The vertical distance from the free surface of a liquid to the pump datum when the supply source is above the pump.

**Static suction lift** The vertical distance from the free surface of a liquid to the pump datum when the supply source is below the pump.

**Steep head curve** When the head rises steeply and continuously as the flow is reduced.

**Suction head** The static head near the inlet of a pump above the pump centerline.

**Suction lift** In contrast to suction head, this vertical dimension is between the pump centerline and a liquid's surface that is below the pump.

**System head curve** A plot of system head versus system flow. System head varies with flow since friction and velocity head are both a function of flow.

**Total discharge head** The sum of static head and velocity head at a pump discharge.

**Utility horsepower (UHP)** Brake horsepower divided by drive efficiency.

**Total head** The total head at the pump discharge minus suction head or plus suction lift.

**Variable-speed pressure booster pumps** A pump used to reduce power consumption to maintain a constant building supply pressure by varying pump speeds through coupling or mechanical devices.

**Velocity head** The velocity portion of head with its units converted to an equivalent static head.

**Water horsepower** The power required by a pump motor for pumping only.

# 5

## Piping Insulation

Insulation and its ancillary components are major considerations in the design and installation of the plumbing and piping systems of modern buildings. Insulation is used for the following purposes:

- Retard heat or cooling temperature loss through pipe
- Eliminate condensation on piping
- Protect personnel by keeping the surface temperature of pipes low enough to touch
- Improve the appearance of pipe where aesthetics are important
- Protect pipe from abrasion or damage from external forces
- Reduce noise from a piping system

### TERMINOLOGY

To ensure an understanding of the mechanism of heat, the following definitions are provided.

**British thermal unit (Btu)** The heat required to raise the temperature of 1 pound of water 1°F.

**Conductance** Also known as conductivity, the measurement of the flow of heat through an arbitrary thickness of material, rather than the 1-inch thickness used in thermal conductivity. (See also thermal conductivity.)

**Convection** The large-scale movement of heat through a fluid (liquid or gas). It cannot occur through a solid. The difference in density between hot and cold fluids produces a natural movement of heat.

**Degree Celsius** The measurement used in international standard (SI) units found by dividing the ice point and steam point of water into 100 divisions.

**Degree Fahrenheit** The measurement used in inch-pound (IP) units found by dividing the ice point and steam point of water into 180 divisions.

**Heat** A type of energy that is produced by the movement of molecules. More movement produces more heat. All heat (and movement) stops at absolute zero. It flows from a warmer body to a cooler body. It is calculated in such units as Btu, calories, or watt-hours.

**Kilocalorie (kcal)** The heat required to raise 1 kilogram of water 1°C.

**Thermal conductivity** The ability of a specific solid to conduct heat. This is measured in British thermal units per hour (Btuh) and is referred to as the k-factor. The standard used in the measurement is the heat that will flow in one hour through a 1-inch-thick material, with a temperature difference of 1°F over an area of 1 square foot. The metric equivalent is watts per square meter per degree Kelvin ( $W/m^2/°K$ ). As the k-factor increases, so does the flow of heat.

**Thermal resistance** Abbreviated R, the reciprocal of the conductance value. (See conductance.)

**Thermal transmittance** Known as the U-factor, the rate of flow, measured in thermal resistance, through several different layers of materials taken together as a whole. It is measured in Btuh per square foot per degree Fahrenheit ( $Btuh/ft^2/°F$ ).

### THE PHYSICS OF WATER VAPOR TRANSMISSION

Water vapor is present in the air at all times. A water vapor retarder does not stop the flow of water vapor. Rather, it serves as a means of controlling and reducing the rate of flow and is the only practical solution to the passage of water vapor. Its effectiveness depends on its location within the insulation system, which is usually as close to the outer surface of the insulation as practical. Water vapor has a vapor pressure that is a function of both temperature and relative humidity. The effectiveness of an insulation system is best when it is completely dry.

The water vapor transmission rate is a measure of water vapor diffusion into or through the total insulation system and is measured in perms. A perm is the weight of water, in grains, that is transmitted through 1 square foot of 1-inch-thick insulation in one hour. A generally accepted value of 0.10 perms is considered the maximum rate for an effective vapor retarder. A formula for the transmission of water vapor diffusing through insulation systems is given in Equation 5-1.

#### Equation 5-1

$$W = \mu A T \Delta P \frac{P}{L}$$

where

- W = Total weight of vapor transmitted, grains (7,000 grains = 1 pound of water)
- $\mu$  = Permeability of insulation, grains/ft<sup>2</sup>/h/in. Hg  $\Delta P$ /in.
- A = Area of cross-section of the flow path, square feet
- T = Time during which the transmission occurred, hours
- $\Delta P$  = Difference of vapor pressure between ends of the flow path, inches of mercury (in. Hg)
- L = Length of flow path, inches

## TYPES OF INSULATION

Insulation manufacturers give their products different trade names. The discussions that follow use the generic names for the most often used materials in the plumbing and drainage industry. The insulation properties are based on the following conditions:

- All materials have been tested to ASTM, NFPA, and UL standards.
- The temperature at which the thermal conductivity and resistance were calculated is 75°F (24°C).

Insulation used for the chemical, pharmaceutical, and

food-processing industries (for example) must be able to withstand repeated cleaning by various methods. This is provided by the application of the proper jacketing material (discussed later), which shall be resistant to organism growth, smooth and white, resistant to repeated cleaning by the method of choice by the owner, and nontoxic.

As with other building materials, insulation may contribute to a fire by either generating smoke (if the product is incombustible) or supporting combustion. Code limits for these factors have been established. These ratings are for complete insulation systems tested as a whole and not for individual components.




Figure 5-1 Insulating Around a Split Ring Hanger

1. Pipe
2. Insulation—shown with factory-applied, non-metal jacket
3. Overlap at longitudinal joints—cut to allow for hanger rod
4. Tape applied at butt joints—pipe covering section at hanger should extend a few inches beyond the hanger to facilitate proper butt joint sealing
5. Insulation altered to compensate for projections on split ring hangers—if insulation thickness is severely altered and left insufficient for high-temperature applications or condensation control, insulate with a sleeve of oversized pipe insulation
6. Insulation applied in like manner around rod on cold installations

Source: MICA



The code requirements for insulation are a flame spread index of not more than 25 and a smoke-developed index of not more than 50. The standards governing the testing of materials for flame spread and smoke developed are ASTM E84, NFPA 255, and UL 723.

### Fiberglass

Fiberglass insulation shall conform to ASTM C547. It is manufactured from glass fiber bonded with a phenolic resin. The chemical composition of this resin determines the highest temperature rating of this insulation. (Consult the manufacturer for exact figures.)

This insulation is tested to fall below the index of 25 for flame spread and 50 for smoke developed. It has low water absorption and very limited to no combustibility. It has poor abrasion resistance.

Fiberglass is the most commonly used insulation for the retardation of heat loss from plumbing lines and equipment. The recommended temperature range is from 35°F to 800°F (1.8°C to 422°C), with ratings depending on the binder. It is available as pre-molded pipe insulation, boards, and blankets. Typical k-factors range from 0.22 to 0.26, and R values range from 3.8 to 4.5. Its density is about 3–5 pounds per cubic foot (48–80 kilograms per cubic meter).

Fiberglass by itself is not strong enough to stay on a pipe or piece of equipment, prevent the passage of water vapor, or present a finished appearance. Because of this, a covering or jacket must be used.

### Elastomeric

Elastomeric insulation, commonly called rubber, shall conform to ASTM C534. This is a flexible, expanded foam made of closed-cell material manufactured from nitrile rubber and polyvinyl chloride resin. This insulation depends on its thickness to fall below a specific smoke-developed rating. All thicknesses have a flame spread index of 25. It can absorb 5 percent of its weight in water and has a perm rating of 0.10. Its density ranges between 3 pounds per cubic foot and 6 pounds per cubic foot.

The recommended temperature range is from -297°F to 220°F (-183°C to 103°C). A typical k-factor is 0.27, and a typical R value is 3.6. It is recommended as preformed insulation for pipe sizes up to 6 inches (DN 150) in ½-inch, ¾-inch, and 1-inch thicknesses. It is also available in 48-inch (1,200-mm) wide rolls and in sheet sizes of 36 × 48 inches (900 × 1,200 mm). An adhesive must be used to seal the seams and joints and adhere the insulation to the equipment.

Rubber insulation can be painted without treatment. It is widely used in mechanical equipment rooms and pipe, and the ease of application makes it less costly. The recommended temperature range is from -297°F to 220°F (-183°C to 103°C)




Figure 5-2 Insulating Around a Clevis Hanger

1. Pipe
2. Insulation—type specified for the line
3. High-density insulation insert—extend beyond the shield to facilitate proper butt joint sealing
4. Factory-applied vapor-retarder jacket securing two insulation sections together—cold application
5. Jacketing—field-applied metal shown
6. Metal shield
7. Wood block or wood dowel insert

Source: MICA

### Cellular Glass

Cellular glass shall conform to ASTM C552. This insulation is pure glass foam manufactured with hydrogen sulfide and has closed-cell air spaces. The smoke-developed rating is zero, and the flame spread is 5. The recommended application temperature is between -450°F and 450°F (-265°C and 230°C), with the adhesive used to secure the insulation to the pipe or equipment being the limiting factor. It has no water retention and poor surface abrasion resistance.

Cellular glass is rigid and strong and commonly used for high-temperature installations. It generally is manufactured in blocks and must be fabricated by the contractor to make insulation for pipes or equipment. A saw is used for cutting. It has a typical k-factor of 0.37 and an R value of 2.6. Its density is 8 pounds per cubic foot.

It is resistant to common acids and corrosive environments. It shall be provided with a jacket of some type.

### Foamed Plastic

Foamed plastic insulation is a rigid, closed-cell product, which shall conform to the following standards depending on the material. Polyurethane shall conform to ASTM C591; polystyrene shall conform to ASTM C578; and polyethylene shall conform to ASTM C1427. It is made by the expansion of plastic beads or granules in a closed mold or using an extrusion process. The fire spread index varies among manufacturers, but its combustibility is high. Additives can be used to improve fire retardancy. It is available molded into boards or pre-molded into pipe insulation.

Foamed plastic is most commonly used in 3-inch or 4-inch thickness to insulate cryogenic piping. The recommended temperature range for installation is from cryogenic to 220°F (103°C). The density varies from 0.7 pound per cubic foot to 3 pounds per cubic foot. The k-factor varies between 0.32 and 0.20 depending on the density and age of the material. The average water absorption is 2 percent.

### Calcium Silicate

Calcium silicate shall conform to ASTM C533. It is a rigid granular insulation composed of calcium silicate, asbestos-free reinforcing fibers, and lime. This material has a k-factor of 0.38 and an R value of 2.

A mineral fiber commonly referred to as calsil, it is used for high-temperature work and does not find much use in the plumbing industry except as a rigid insert for installation at a hanger to protect the regular insulation from being crushed by the weight of the pipe.

### Insulating Cement

Insulating cement is manufactured from fibrous and/or granular material and cement mixed with water to form a plastic substance. Sometimes referred to as mastic, it has typical k-factors ranging between 0.65 and 0.95 depending on the composition. It is well suited for irregular surfaces.

### JACKET TYPES

A jacket is any material, except cement or paint, that is used to protect or cover insulation installed on a pipe or over equipment. It allows the insulation to function for a long period by protecting the underlying

**Table 5-1 Heat Loss in Btu/h/ft Length of Fiberglass Insulation, ASJ Cover 150°F Temperature of Pipe**

		Horizontal																								
NPS		1/2		3/4		1		1 1/4		1 1/2		2		2 1/2		3		4		5		6		8		
THK	HL																									
BARE		36		44		54		67		75		92		110		131		165		200		235		299		
1/2"		10	92	10	90	13	93	20	98	18	94	20	93	23	94	30	95	36	95	43	95	53	97	68	97	
1"		7	86	8	87	9	86	11	88	11	87	13	87	15	88	18	88	22	88	27	89	32	89	38	89	
1 1/2"		5	84	6	84	7	84	8	84	9	85	10	85	10	84	14	85	17	86	20	86	23	86	28	8	
2"		5	82	5	83	6	83	7	83	7	83	9	83	9	83	11	84	14	84	16	84	18	84	23	85	

		Vertical																							
		1/2		3/4		1		1 1/4		1 1/2		2		2 1/2		3		4		5		6		8	
THK	HL																								
BARE		32		40		49		61		69		84		100		120		152		185		217		277	
1/2"		9	92	10	90	13	93	19	99	18	95	20	94	23	94	30	96	35	96	43	96	52	97	67	98
1"		7	86	8	87	9	86	11	88	11	87	13	88	15	88	18	89	22	89	26	89	31	90	38	89
1 1/2"		5	84	6	84	7	84	8	84	9	85	10	85	10	84	14	86	16	86	20	86	23	87	28	8
2"		5	83	5	83	6	83	7	83	7	83	9	83	9	83	11	84	14	84	16	85	18	85	23	85

Source: Courtesy of Owens/Corning. HL = heat loss (BTU/h/ft length)  
 Notes: 80° ambient temperature, ST = surface temperature (°F)  
 0 wind velocity, Bare = bare pipe, iron pipe size  
 0.85 bare surface emittance, THK = thickness  
 0.90 surface emittance

ing material and extending its service life. The jacket is used for the following purposes:

- As a vapor retarder to limit the entry of water into the insulation system
- As a weather barrier to protect the underlying insulation from exterior conditions
- To prevent mechanical abuse due to accidents
- Corrosion and additional fire resistance
- Appearance
- Cleanliness and disinfection

**Table 5-2 Heat Loss from Piping**

Insulation Type	Insulation Factor	Heat Loss per Inch Thickness, Based on K Factor @ 50°F Mean Temp. (Btu/h • °F • ft <sup>2</sup> )
Glass fiber (ASTM C547)	1.00	0.25
Calcium silicate (ASTM C533)	1.50	0.375
Cellular glass (ASTM C552)	1.60	0.40
Rigid cellular urethane (ASTM C591)	0.66	0.165
Foamed elastomer (ASTM C534)	1.16	0.29
Mineral fiber blanket (ASTM C553)	1.20	0.30
Expanded perlite (ASTM C610)	1.50	0.375

Insulation Thickness (in.)	ΔT, °F	IPS												
		½	¾	1	1¼	1½	2	2½	3	4	6	8	10	12
		Tubing Size (in.)												
		¾	1	1¼	1½									
0.5	10	0.5	0.6	0.7	0.8	0.9	1.1	1.3	1.5	1.8	2.6	3.3	4.1	4.8
	50	2.5	2.9	3.5	4.1	4.8	5.5	6.5	7.7	9.6	13.5	17.2	21.1	24.8
	100	5.2	6.1	7.2	8.6	9.9	11.5	13.5	15.9	19.9	28.1	35.8	43.8	51.6
	150	8.1	9.5	11.2	13.4	15.5	17.9	21.0	24.8	31.9	43.8	55.7	68.2	80.2
	200	11.2	13.1	15.5	18.5	21.4	24.7	29.0	34.3	42.7	60.4	76.9	94.1	110.7
	250	14.6	17.1	20.2	24.1	27.9	32.2	37.8	44.7	55.7	78.8	100.3	122.6	144.2
1.0	10	0.3	0.4	0.4	0.5	0.6	0.6	0.7	0.8	1.0	1.4	1.8	2.2	2.6
	50	1.6	1.9	2.2	2.5	2.9	3.2	3.7	4.4	5.4	7.4	9.4	11.4	13.4
	100	3.4	3.9	4.5	5.2	5.9	6.8	7.8	9.1	11.2	15.5	19.5	23.8	27.8
	150	5.3	6.1	7.0	8.2	9.3	10.5	12.2	14.2	17.4	24.1	30.4	37.0	43.3
	200	7.4	8.4	9.7	11.3	12.8	14.6	16.8	19.6	24.0	33.4	42.0	51.2	59.9
	250	9.6	11.0	12.6	14.8	16.7	19.0	22.0	25.6	31.4	43.6	54.9	66.9	78.2
1.5	10	0.3	0.3	0.3	0.4	0.4	0.5	0.5	0.6	0.8	1.0	1.3	1.4	1.8
	50	1.3	1.5	1.7	1.9	2.2	2.4	2.8	3.2	3.9	5.3	6.6	8.0	9.3
	100	2.7	3.1	3.5	4.0	4.5	5.1	5.8	6.7	8.1	11.1	13.8	16.7	19.5
	150	4.3	4.8	5.5	6.3	7.1	7.9	9.1	10.4	12.6	17.2	21.5	26.0	30.3
	200	5.9	6.7	7.6	8.7	9.8	11.0	12.5	14.5	17.5	23.8	29.7	36.0	41.9
	250	7.8	8.7	9.9	11.4	12.8	14.4	16.4	18.9	22.8	31.1	38.9	47.1	54.8
2.0	10	0.2	0.2	0.3	0.3	0.4	0.4	0.4	0.5	0.6	0.8	1.0	1.2	1.4
	50	1.1	1.3	1.4	1.6	1.8	2.0	2.3	2.6	3.1	4.2	5.2	6.3	7.3
	100	2.4	2.7	3.0	3.4	3.8	4.2	4.8	5.5	6.5	8.8	10.9	13.1	15.2
	150	3.7	4.2	4.7	5.3	5.9	6.6	7.5	8.5	10.2	13.7	17.0	20.4	23.6
	200	5.2	5.8	6.5	7.4	8.2	9.1	10.3	11.8	14.1	19.0	23.5	28.2	32.7
	250	6.8	7.5	8.5	9.6	10.7	11.9	13.5	15.4	18.5	24.8	30.7	36.9	42.7
2.5	10	0.2	0.2	0.2	0.3	0.3	0.3	0.4	0.4	0.5	0.7	0.8	1.0	1.2
	50	1.0	1.1	1.3	1.4	1.6	1.8	2.0	2.3	2.7	3.6	4.4	5.2	6.0
	100	2.2	2.4	2.7	3.0	3.3	3.7	4.1	4.7	5.6	7.7	9.1	10.9	12.6
	150	3.4	3.7	4.2	4.7	5.2	5.8	6.5	7.3	8.7	11.5	14.2	17.0	19.6
	200	4.7	5.2	5.8	6.5	7.2	8.0	9.0	10.2	12.1	16.0	19.6	23.5	27.1
	250	6.1	6.8	7.5	8.5	9.4	10.4	11.7	13.3	15.8	20.9	25.7	30.7	35.4
3.0	10	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.4	0.5	0.6	0.7	0.9	1.0
	50	1.0	1.1	1.2	1.3	1.4	1.6	1.8	2.0	2.4	3.1	3.8	4.5	5.2
	100	2.0	2.2	2.4	2.7	3.0	3.3	3.7	4.2	4.9	6.5	7.9	9.4	10.8
	150	3.1	3.4	3.8	4.3	4.7	5.2	5.8	6.6	7.7	10.1	12.3	14.7	16.8
	200	4.3	4.8	5.3	5.9	6.5	7.2	8.0	9.0	10.7	14.0	17.0	20.3	23.3
	250	5.7	6.2	6.9	7.7	8.5	9.4	10.5	11.8	13.9	18.3	22.3	26.5	30.5

### All-Service Jacket

Known as ASJ, the all-service jacket is a lamination of brown (kraft) paper, fiberglass cloth (skrim), and a metallic film. A vapor retarder also is included. This jacket also is called an FSK jacket because of the fiberglass cloth, scrim, and kraft paper. It most often is used to cover fiberglass insulation.

The fiberglass cloth is used to reinforce the kraft paper. The paper is generally a bleached, 30-pound (13.5-kg) material, which actually weighs 30 pounds per 30,000 square feet (2,790 m<sup>2</sup>). The metallic foil is aluminum. This complete jacket gives the fire rating for the insulation system.

The jacket is adhered to the pipe with either self-sealing adhesive or staples. The butt joint ends are sealed with adhesive, placed together, and then covered with lap strips during installation. Staples are used when the surrounding conditions are too dirty or corrosive to use self-sealing material. The staple holes shall be sealed with adhesive.

### Aluminum Jacket

Aluminum jackets shall conform to ASTM B209. They are manufactured as corrugated or smooth and are available in various thicknesses ranging from 0.010 inch to 0.024 inch, with 0.016 inch being the most common. The corrugated version is used where expansion and contraction of the piping may be a problem.

Aluminum jackets also are made in various tempers and alloys. A vapor retarder material can be applied to protect the aluminum from any corrosive ingredient in the insulation. Fittings are fabricated in the shop.

Aluminum jackets may be secured by one of three methods: by straps on 9-inch (180-mm) centers, by a proprietary S or Z shape, or by sheet metal screws.

### Stainless Steel Jacket

Stainless steel jackets shall conform to ASTM A240. They are manufactured as corrugated or smooth and are available in various thicknesses ranging from 0.010 inch to 0.019 inch, with 0.016 inch being the most common. They are also available in various alloy types conforming to ASTM A304 and can be obtained in different finishes. A vapor retarder material can be applied, although it is not required for corrosive environments except where chlorine or fluorides are present.

Stainless steel jackets are used for hygienic purposes and are adhered in a manner similar to that used for aluminum.

### Plastic and Laminates

Plastic jackets are manufactured from polyvinyl chloride (PVC), polyvinylidene fluoride (PVDF), acrylonitrile butadiene styrene (ABS), polyvinyl acetate (PVA), and acrylics. Thicknesses range from 3 mils to 35 mils. The local code authority shall be consulted prior to their use.

Laminates are manufactured as a composite that is alternating layers of foil and polymer. Thicknesses range from 3 to 25 mils. The local code authority shall be consulted prior to their use.

Both are adhered by the use of an appropriate adhesive.

### Wire Mesh

Wire mesh is available in various wire diameters and widths. Materials for manufacture are Monel, stainless steel, and Inconel. Wire mesh is used where a strong, flexible covering that can be removed easily is needed. It is secured with lacing hooks or stainless steel wire that must be additionally wrapped with tie wire or metal straps.

**Table 5-3 Insulation Thickness - Equivalent Thickness (in.)**

DN	NPS	½		1		1½		2		2½		3	
		L <sub>1</sub>	A	L <sub>1</sub>	A	L <sub>1</sub>	A	L <sub>1</sub>	A	L <sub>1</sub>	A	L <sub>1</sub>	A
15	½	0.76	0.49	1.77	0.75	3.12	1.05	4.46	1.31				
20	¾	0.75	0.56	1.45	0.75	2.68	1.05	3.90	1.31				
25	1	0.71	0.62	1.72	0.92	2.78	1.18	4.02	1.46	—	—	—	—
32	1¼	0.63	0.70	1.31	0.92	2.76	1.31	3.36	1.46				
40	1½	0.60	0.75	1.49	1.05	2.42	1.31	4.13	1.73				
50	2	0.67	0.92	1.43	1.18	2.36	1.46	3.39	1.73	4.43	1.99	—	—
65	2½	0.66	1.05	1.38	1.31	2.75	1.73	3.71	1.99	4.73	2.26		
80	3	0.57	1.18	1.29	1.46	2.11	1.73	2.96	1.99	3.88	2.26	4.86	2.52
90	3½	0.92	1.46	1.67	1.73	2.46	1.99	3.31	2.26	4.22	2.52	5.31	2.81
100	4	0.59	1.46	1.28	1.73	2.01	1.99	2.80	2.26	3.65	2.52	4.68	2.81
115	4½	0.94	1.74	1.61	1.99	2.35	2.26	3.15	2.52	4.11	2.81	5.02	3.08
125	5	0.58	1.74	1.20	1.99	1.89	2.26	2.64	2.52	3.54	2.81	4.40	3.08
150	6	0.54	2.00	1.13	2.26	1.79	2.52	2.60	2.81	3.36	3.08	4.17	3.34
	7	—	—	1.11	2.52	1.84	2.81	2.54	3.08	3.27	3.34	4.25	3.67
200	8	—	—	1.18	2.81	1.81	3.08	2.49	3.34	3.39	3.67	4.15	3.93
	9	—	—	1.17	3.08	1.79	3.34	2.62	3.67	3.32	3.93	4.06	4.19
250	10	—	—	1.09	3.34	1.85	3.67	2.50	3.93	3.18	4.19	3.90	4.45
300	12	—	—	1.22	3.93	1.82	4.19	2.45	4.45	3.10	4.71	3.79	4.97
350	14	—	—	1.07	4.19	1.65	4.45	2.26	4.71	2.90	4.97	3.57	5.24
400	16	—	—	1.06	4.71	1.63	4.97	2.23	5.24	2.86	5.50	3.50	5.76
450	18	—	—	1.05	5.24	1.62	5.50	2.21	5.76	2.82	6.02	3.45	6.28
500	20	—	—	1.05	5.76	1.61	6.02	2.19	6.28	2.79	6.54	3.41	6.81
600	24	—	—	1.04	6.81	1.59	7.07	2.16	7.33	2.74	7.59	3.35	7.85

Source: Owens/Corning.

DN = nominal diameter

NPS = nominal pipe size

L<sub>1</sub> = equivalent thickness (in.)

L<sub>1</sub> = r<sub>2</sub> ln (r<sub>2</sub>/r<sub>1</sub>)

where

r<sub>1</sub> = inner radius of insulation (in.)

r<sub>2</sub> = outer radius of insulation (in.)

ln = log to the base e (natural log)

A = square feet of pipe insulation surface per lineal foot of pipe

**Table 5-4 Dewpoint Temperature**

Dry Bulb Temp. (°F)	Percent Relative Humidity																		
	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100
5	-35	-30	-25	-21	-17	-14	-12	-10	-8	-6	-5	-4	-2	-1	1	2	3	4	5
10	-31	-25	-20	-16	-13	-10	-7	-5	-3	-2	0	2	3	4	5	7	8	9	10
15	-28	-21	-16	-12	-8	-5	-3	-1	1	3	5	6	8	9	10	12	13	14	15
20	-24	-16	-11	-8	-4	-2	2	4	6	8	10	11	13	14	15	16	18	19	20
25	-20	-15	-8	-4	0	3	6	8	10	12	15	16	18	19	20	21	23	24	25
30	-15	-9	-3	2	5	8	11	13	15	17	20	22	23	24	25	27	28	29	30
35	-12	-5	1	5	9	12	15	18	20	22	24	26	27	28	30	32	33	34	35
40	-7	0	5	9	14	16	19	22	24	26	28	29	31	33	35	36	38	39	40
45	-4	3	9	13	17	20	23	25	28	30	32	34	36	38	39	41	43	44	45
50	-1	7	13	17	21	24	27	30	32	34	37	39	41	42	44	45	47	49	50
55	3	11	16	21	25	28	32	34	37	39	41	43	45	47	49	50	52	53	55
60	6	14	20	25	29	32	35	39	42	44	46	48	50	52	54	55	57	59	60
65	10	18	24	28	33	38	40	43	46	49	51	53	55	57	59	60	62	63	65
70	13	21	28	33	37	41	45	48	50	53	55	57	60	62	64	65	67	68	70
75	17	25	32	37	42	46	49	52	55	57	60	62	64	66	69	70	72	74	75
80	20	29	35	41	46	50	54	57	60	62	65	67	69	72	74	75	77	78	80
85	23	32	40	45	50	54	58	61	64	67	69	72	74	76	78	80	82	83	85
90	27	36	44	49	54	58	62	66	69	72	74	77	79	81	83	85	87	89	90
95	30	40	48	54	59	63	67	70	73	76	79	82	84	86	88	90	91	93	95
100	34	44	52	58	63	68	71	75	78	81	84	86	88	91	92	94	96	98	100
110	41	52	60	66	71	77	80	84	87	90	92	95	98	100	102	104	106	108	110
120	48	60	68	74	79	85	88	92	96	99	102	105	109	109	112	114	116	118	120
125	52	63	72	78	84	89	93	97	100	104	107	109	111	114	117	119	121	123	125

**Table 5-5 Insulation Thickness to Prevent Condensation, 50°F Service Temperature and 70°F Ambient Temperature Relative Humidity (%)**

DN	Nom. Pipe Size (in.)	20			50			70			80			90			
		THK	HG	ST	THK	HG	ST	THK	HG	ST	THK	HG	ST	THK	HG	ST	
15	0.50	Condensation control not required for this condition	0.5	2	66	0.5	2	66	0.5	2	66	0.5	2	66	1.0	2	68
20	0.75		0.5	2	67	0.5	2	67	0.5	2	67	0.5	2	67	0.5	2	67
25	1.00		0.5	3	66	0.5	3	66	0.5	3	66	0.5	3	66	1.0	2	68
32	1.25		0.5	3	66	0.5	3	66	0.5	3	66	0.5	3	66	1.0	3	67
40	1.50		0.5	4	65	0.5	4	65	0.5	4	65	0.5	4	65	1.0	3	67
50	2.00		0.5	5	66	0.5	5	66	0.5	5	66	0.5	5	66	1.0	3	67
65	2.50		0.5	5	65	0.5	5	65	0.5	5	65	0.5	5	65	1.0	4	67
75	3.00		0.5	7	65	0.5	7	65	0.5	7	65	0.5	7	65	1.0	4	67
90	3.50		0.5	8	65	0.5	8	65	0.5	8	65	0.5	8	65	1.0	4	68
100	4.00		0.5	8	65	0.5	8	65	0.5	8	65	0.5	8	65	1.0	5	67
125	5.00		0.5	10	65	0.5	10	65	0.5	10	65	0.5	10	65	1.0	6	67
150	6.00		0.5	12	65	0.5	12	65	0.5	12	65	0.5	12	65	1.0	7	67
200	8.00		1.0	9	67	1.0	9	67	1.0	9	67	1.0	9	67	1.0	9	67
250	10.00		1.0	11	67	1.0	11	67	1.0	11	67	1.0	11	67	1.0	11	67
300	12.00		1.0	12	67	1.0	12	67	1.0	12	67	1.0	12	67	1.0	12	67

Source: Courtesy Certainteed.

Notes: 25 mm = 1 in.

THK = Insulation thickness (in.).

HG = Heat gain/lineal foot (pipe) 28 ft (flat) (Btu). ST = Surface temperature (°F).

### Lagging

Lagging is the covering of a previously insulated pipe or piece of equipment with a cloth or fiberglass jacket. It is used where appearance is the primary consideration, since this type of jacket offers little or no additional insulation protection. This material also is used as a

combination system that serves as a protective coat and adhesive.

This jacket typically is secured to the insulation with the use of lagging adhesive and/or sizing. It is available in a variety of colors and may eliminate the need for painting.

## INSTALLATION TECHNIQUES

### Insulation for Valves and Fittings

The fittings and valves on a piping system require specially formed or made-up sections of insulation to complete the installation.

One type of insulation is the pre-formed type that is manufactured by specific size and shape to fit over any particular fitting or valve. Such insulation is available in two sections that are secured with staples, adhesive, or pressure-sensitive tape depending on the use of a vapor retarder. This is the quickest method of installation, but the most costly.

Another system uses a pre-formed plastic jacket the exact size and shape of the fitting or valve. A fiberglass blanket or sheet is cut to size and wrapped around the bare pipe, and then the jacket is placed over the insulation. The exposed edges are tucked in, and the jacket is secured with special tacks with a barb that prevents them from pulling apart. The ends are sealed with pressure-sensitive tape.

For large piping, it is common to use straight lengths of fiberglass by mitering the ends and securing them with a fiberglass jacket (lagging).

### Insulation for Tanks

Where fiberglass is specified, tanks are insulated using 2×4-foot boards in the thickness required. The boards are placed on the tank in a manner similar to brick laying. They are secured with metal bands. Wire is placed over the bands as a foundation for insulating cement applied over the tank to give a finished appearance.

Where rubber is specified, the tank is coated with adhesive, and the rubber sheets are placed on the tank. The edges are coated with adhesive to seal it. Painting is not required.

### Insulation Around Pipe Supports

As the installation on a project progresses, a contractor must contend with different situations regarding the vapor retarder. Since the insulation system selected shall be protected against the migration of water vapor into the insulation, the integrity of the vapor retarder must be maintained. Where a hanger is installed directly on the pipe, the insulation must be placed over both the pipe and the hanger. Figure 5-1 illustrates a split-ring hanger attached directly on the pipe.

Since low-density insulation is the type most often used, a situation arises wherein the primary considerations are keeping the vapor retarder intact and preventing the weight of the pipe from crushing the insulation. Figure 5-2 illustrates several high-density insert solutions for a clevis hanger supporting an insulated pipe.

The jacketing method shown in both figures can be used interchangeably with any type of insulation for which it is suited.

## SELECTING INSULATION THICKNESS

Selecting the proper insulation thickness is affected by the reason for using insulation:

1. Controlling heat loss from piping or equipment
2. Condensation control
3. Personnel protection
4. Economics

### Controlling Heat Loss

Increased concern about conservation and energy use has resulted in the insulation of piping to control heat loss becoming one of the primary considerations in design. Heat loss is basically an economic consideration, since the lessening of heat loss produces a more cost-efficient piping system. The proper use of insulation can have dramatic results.

The insulation installed on domestic hot water, hot water return, and chilled drinking water systems is intended to minimize heat loss from the water. Since fiberglass insulation is the type most often used, Table 5-1 is provided to give the heat loss through vertical and horizontal piping as well as the heat loss through bare pipe. Table 5-2 is given for piping intended to be installed outdoors.

When calculating the heat loss from round surfaces such as a pipe, the plumbing engineer should remember that the inside surface of the insulation has a different diameter than the outside. Therefore, a means must be found to determine the equivalent thickness that shall be used. This is done by the use of Table 5-3. To read this table, enter with the actual pipe size and insulation thickness, and then find the equivalent thickness of the insulation.

Software endorsed by the U.S. Department of Energy and distributed by the North American Insulation Manufacturers Association (NAIMA) that will calculate heat loss, condensation control, and environmental emissions is available at [pipeinsulation.org](http://pipeinsulation.org).

### Condensation Control

As mentioned, water vapor in the air condenses on a cold surface if the temperature of the cold surface is at or below the dewpoint. If the temperature is above the dewpoint, condensation does not form. The purpose of a vapor retarder is to minimize or eliminate such condensation. For this to be accomplished, the joints and overlaps must be sealed tightly. This is done through one of three methods:

**Table 5-6 Insulation Thickness for Personnel Protection, 120°F Maximum Surface Temperature, 80°F Ambient Temperature**

**Service Temperature**

Nom. Pipe Size (in.)	250				350				450				550			
	TH	HL		ST	TH	HL		ST	TH	HL		ST	TH	HL		ST
		LF	SF			LF	SF			LF	SF			LF	SF	
0.50	0.5	25	51	109	1.0	30	40	104	1.0	48	64	118	1.5	55	52	113
0.75	0.5	25	41	104	0.5	42	68	120	1.5	45	43	107	1.5	64	61	118
1.00	0.5	34	55	112	1.0	37	40	105	1.0	60	66	120	1.5	69	58	117
1.25	0.5	37	49	109	1.0	47	51	112	1.5	55	42	107	1.5	77	59	118
1.50	0.5	46	61	117	1.0	48	46	109	1.5	62	47	110	2.0	70	40	106
2.00	0.5	50	55	114	1.0	56	47	110	1.5	70	48	111	2.0	84	48	112
2.50	0.5	59	56	115	1.5	45	26	97	1.5	72	41	107	1.5	102	59	119
3.00	0.5	75	64	120	1.0	76	52	114	1.5	93	53	115	2.0	110	55	117
3.50	1.0	43	25	96	1.0	71	41	107	1.5	93	46	111	2.0	112	49	113
4.00	0.5	89	61	119	1.0	90	52	114	1.5	112	56	117	2.0	131	58	119
5.00	1.0	67	33	102	1.0	110	55	117	1.5	134	59	120	2.5	131	46	112
6.00	1.0	79	35	103	1.0	130	57	119	2.0	124	44	110	2.5	150	48	114
8.00	1.0	95	33	103	1.0	157	55	118	2.0	153	45	112	2.5	177	48	114
10.00	1.0	121	36	105	1.5	136	37	106	2.0	179	45	112	2.5	215	51	117
12.00	1.0	129	32	103	1.0	212	54	118	2.0	207	46	113	2.5	248	52	118

Source: Certainteed.

Notes: TH = Thickness of insulation (in.)

HL = heat loss (Btu/h)

LF = Heat loss per lineal foot of pipe (Btu/h)

SF = Heat loss per square foot of outside insulation surface (Btu/h)

ST = Surface temperature of insulation (°F)

**Table 5-7 Time for Dormant Water to Freeze**

**Fiberglass Insulation**

Pipe or Tubing Size (in.)	Air Temp., °F (°C)	Water Temp., °F (°C)	Insulation Thickness, in. (mm)	Time to 32°F (0°C) DORMANT water (h)	Time to 32°F (0°C) Solid Ice (h) <sup>a</sup>	Flow <sup>b</sup>
½ OD CT	-10 (-23.3)	50 (10)	0.66 (N¾) (19.1)	0.30	3.10	0.33
1½ OD CT	-10 (-23.3)	50 (10)	0.74 (N¾) (19.1)	0.75	8.25	0.44
1½ OD CT	-10 (-23.3)	50 (10)	0.79 (N¾) (19.1)	1.40	14.75	0.57
3½ OD CT	-10 (-23.3)	50 (10)	0.88 (N¾) (19.1)	3.5	37.70	0.83
1 IPS	-10 (-23.3)	50 (10)	0.76 (N¾) (19.1)	0.75	8.25	0.48
2 IPS	-10 (-23.3)	50 (10)	0.85 (N¾) (19.1)	2.10	22.70	0.67
3 IPS	-10 (-23.3)	50 (10)	0.89 (N¾) (19.1)	3.60	38.40	0.90
5 IPS	-10 (-23.3)	50 (10)	0.95 (N¾) (19.1)	6.95	73.60	1.25

**Foamed Plastic Insulation**

Pipe or Tubing Size (in.)	Air Temp., °F (°C)	Water Temp., °F (°C)	Insulation Thickness, in. (mm)	Time to 32°F (0°C) DORMANT water (h)	Time to 32°F (0°C) Solid Ice (h) <sup>a</sup>	Flow <sup>b</sup>
½ OD CT	-10 (-23.3)	50 (10)	1 (25.4)	0.60	6.20	0.16
1½ OD CT	-10 (-23.3)	50 (10)	1 (25.4)	1.30	13.70	0.26
1½ OD CT	-10 (-23.3)	50 (10)	1 (25.4)	2.35	24.75	0.32
3½ OD CT	-10 (-23.3)	50 (10)	1 (25.4)	5.55	58.65	0.52
1 IPS	-10 (-23.3)	50 (10)	1 (25.4)	1.50	15.75	0.25
2 IPS	-10 (-23.3)	50 (10)	1 (25.4)	3.80	40.15	0.39
3 IPS	-10 (-23.3)	50 (10)	1 (25.4)	6.05	64.20	0.53
5 IPS	-10 (-23.3)	50 (10)	1 (25.4)	11.15	118.25	0.78

<sup>a</sup>No way to calculate slush. 32°F (0°C) ice value higher due to heat of fusion.

<sup>b</sup>Flow is expressed as gal/h/ft of pipe (12.4 Uhr-m).

Example: For 100 ft. (30.5m) pipe run, multiply value shown by 100. This is the minimum continuous flow to keep water from freezing.

OD CT = outside diameter, copper tube

IPS = iron pipe size

1. Rigid jackets such as metallic or plastic
2. Membranes such as laminated foils
3. Mastics applied over the pipe, either emulsion or solvent type

Table 5-4 shows the dry-bulb dewpoint temperature at which condensation forms. Table 5-5 is provided to indicate the thickness of fiberglass insulation needed to prevent condensation with water at 50°F (10°C).

**Personnel Protection**

When hot water flows through an uninsulated piping system, it is usually at a temperature that may scald any person touching the pipe. Insulation is used to lower the surface temperatures of hot water pipes to prevent such harm. A surface temperature of 120°F (49°C) has been shown to not burn a person who touches the pipe. Table 5-6 provides the thickness of fiberglass insulation and the surface temperature of the insulation. The thicknesses shown in this table

should be compared with those shown in Table 5-1 or 5-2 to see which thickness is greater. The larger thickness should be used.

**Economics**

The two economic factors involved are the cost of the insulation and the cost of energy. To calculate the energy savings in financial terms, the following are needed: service temperature of the surface, pipe size or surface dimensions, Btu difference between the air and the surface (linear feet or square feet), efficiency of heating equipment, annual operating hours, and the cost of fuel.

If the plumbing designer wishes to make an economic comparison among various insulation systems, many formulas and computer programs are available for the purpose. Discussion of these methods is beyond the scope of this chapter.




Figure 5-3 Temperature Drop of Flowing Water in a Pipeline



## **FREEZE PROTECTION**

No amount of insulation can prevent the freezing of water (or sewage) in a pipeline that remains dormant over a long period. Table 5-7 is provided as a direct reading table for estimating the time it takes for dormant water to freeze. For some installations, it is not possible for the water to remain dormant. If the water is flowing, as it does in a drainage line, use Figure 5-3, a nomogram that gives the temperature drop of flowing water. If the contents cannot be prevented from freezing, the plumbing engineer can add hot water to raise the temperature, heat trace the line, or provide sufficient velocity to keep the contents from freezing.

To calculate the flow of water in a line to prevent freezing, use Equation 5-2.

### **Equation 5-2**

$$\text{gpm} = \frac{A_1 \times A_2 \times (0.5TW - TA + 16)}{40.1 D^2 (TW - 32)}$$

where

gpm = Flow rate, gallons per minute

$A_1$  = Pipe flow area, square feet

$A_2$  = Exposed pipe surface area, square feet

TW = Water temperature, °F

TA = Lowest air temperature, °F

D = Inside diameter of pipe, feet

## **INSULATION DESIGN CONSIDERATIONS**

Following are some general items to consider when designing the insulation for a plumbing system.

1. Insulation attenuates sound from the flow of pipe contents. Where sound is a problem, such as in theaters, adding a mass-filled vinyl layer over the insulation can lessen the sound.
2. Protecting health and safety when storing and handling insulation and/or jacketing materials can be alleviated by proper adherence to established safe storage and handling procedures.
3. The rate of expansion affects the efficiency of the insulation over a long period. The difference between the expansion of insulation and the expansion of the pipe eventually leads to gaps after numerous flexings.
4. Protect the insulation against physical damage by adding a strong jacket or delaying installation on a piping system. It has been found that workmen walking on the pipe pose the greatest danger.
5. If the insulation is to be installed in a corrosive atmosphere, the proper jacket shall be installed to withstand the most severe conditions.
6. Union regulations should be reviewed to ensure that the insulation contractor installs a jacket. Some metal jackets above a certain thickness are installed by the general contractor.
7. Space conditions may dictate the use of one insulation system over another to fit in a confined space.

# ICC-ES PMG LISTING PROGRAM

## Did You Know

Product Certification is now required by  
Section 303.4 of the 2012 IPC, published by ICC



*Most widely accepted and trusted listing program for plumbing,  
mechanical and fuel gas products in U.S. and Canada.*



**CONTACT US TODAY**  
**1.800.423.6587 x7643 | [www.icc-es.org/pmg](http://www.icc-es.org/pmg)**

# 6

## Hangers and Supports

Piping system supports and hangers perform many functions—including supporting or anchoring piping systems, preventing pipe runs from sagging, allowing for motion to alleviate breakage, and providing an adequate slope to accommodate drainage or flow—and they are an integral part of the plumbing system. Choosing the correct supports and hangers is an important aspect of the design of a plumbing system, as improper specification can lead to failure of the entire system. The designer must consider a multitude of environmental and physical characteristics that may interact with and affect the overall system, such as the quantity and composition of the fluid expected to flow through the system, structural components, chemical interactions, metal fatigue analysis, acoustics, and even electric current transference. The specification must go beyond the support types and hanger distances prescribed in the plumbing codes. In fact, the designer may need to consult with other engineering disciplines and with the pipe and pipe support manufacturers for the correct materials to specify for particular applications.

### HANGER AND SUPPORT CONSIDERATIONS

The most common hanger and support detail specified on plans is a simple statement: “the piping shall be supported in a good and substantial manner in accordance with all local codes and ordinances.” However, the codes typically provide little help to the plumbing engineer. Their requirements are simple:

- All water piping shall be adequately supported to the satisfaction of the administrative authority.
  - Piping shall be supported for the weight and the design of the material used.
  - Supports, hangers, and anchors are devices for properly supporting and securing pipe, fixtures, and equipment.
  - Suspended piping shall be supported at intervals not to exceed those shown in Table 6-1.
- All piping shall be supported in such a manner as to maintain its alignment and prevent sagging.
  - Hangers and anchors shall be of sufficient strength to support the weight of the pipe and its contents.
  - Piping shall be isolated from incompatible materials.

A technical specification or performance characteristic regarding piping support is an often-overlooked part of the plumbing system design. In addition to following the basic code requirements, the plumbing engineer must study, evaluate, and analyze the piping layout in relation to the structure and equipment, as well as consider the totality of the piping systems that will be utilized and the surrounding environmental and physical characteristics that will come to bear on the overall performance of the completed system. Given the wide variety of environmental and physical characteristics around which projects are designed, it is not possible to provide an exhaustive listing of potential areas that need evaluation. However, some basic considerations include the following.

### Loads

What will the total load of the piping system be? First and foremost, basic engineering requires a performance and load calculation to be conducted to determine the physical amount and weight of all specific piping system elements. In this initial determination, the engineer considers not only the weight of the piping itself, but also that of all associated elements including valves, fittings, the bulk weight and flow characteristics of the substance to flow through or be carried within the pipe, and thermal or acoustical insulation or other pipe-covering material.

Depending on the piping system’s location, other natural and manmade forces that may create an additional load on the piping system, such as rain, ice, and snow for piping systems exposed to natural weather conditions, also must be considered. When a portion of the piping system will be exposed and rel-

actively easy to reach, the engineer should give some consideration to the potential for unintended uses, such as people hanging from pipes or using them as supports for various items (e.g., plants, lights).

The chosen hanger, support, and anchor system must, at a minimum, accommodate the piping system load. Moreover, the plumbing engineer needs to work closely with the structural engineer to ensure that the building's structure will be able to support the load created by the attachment of the piping system. This load calculation also may incorporate other elements as indicated below.

**Thermal Stresses**

What stresses and accompanying limitations will be imposed on the piping system? Many external, internal, and thermal stresses and the accompanying movements that can occur need to be accommodated by the hangers, supports, and anchors of a piping system. Hangers and supports must provide for

flexibility and axial (twisting), latitudinal, and longitudinal motions.

Thermal events subject the piping system to both internal and external influences resulting in contractions and expansions, which can be gradual or sudden in their movements. Here again, natural and manmade environments must be taken into account. Whenever the piping system and its surrounding environment are subject to any heating or cooling events, the hangers and supports must be able to accommodate the contraction and expansion effects. In addition, the hangers must be able to accommodate the effects of heating and cooling events that affect the substances being carried within the piping system (e.g., certain liquids flow at different velocities under different temperatures).

Even in a piping system with thermal considerations accounted for by design elements such as expansion loops, the accompanying lateral movement

**Table 6-1 Maximum Horizontal Pipe Hanger and Support Spacing**

Nominal Pipe or Tube Size	1	2	3	4	5	6	7	8	9	10
	Std Wt Steel Pipe		Copper Tube		Fire Protection	Ductile Iron Pipe	Cast Iron Soil	Glass	Plastic	Fiberglass Reinforced
	Water Service	Vapor Service	Water Service	Vapor Service						
in (mm)	ft (m)	ft (m)	ft (m)	ft (m)						
¼ (6)	—	—	5(1.5)	5(1.5)	Follow requirements of the National Fire Protection Association.	20 ft (6.1 m) max spacing; min of one (1) hanger per pipe section close to the joint behind the bell and at change of direction and branch connections. For pipe sizes six (6) in. (150 mm) and under, installed on ASME B31 projects, that are subject to loading other than weight of pipe and contents, the span should be limited to the maximum spacing for water service steel pipe.	10 ft (3.0 m) max spacing; min of one (1) hanger per pipe section close to joint on the barrel, also at change of direction and branch connections.	8 ft (2.4 m) max spacing; follow pipe manufacturer's recommendations.	Follow pipe manufacturer's recommendations for material and service condition.	Follow pipe manufacturer's recommendations for material and service condition.
⅜ (10)	7(2.1)	8(2.4)	5(1.5)	6(1.8)						
½ (15)	7(2.1)	8(2.4)	5(1.5)	6(1.8)						
¾ (20)	7(2.1)	9(2.7)	5(1.5)	7(2.1)						
1 (25)	7(2.1)	9(2.7)	6(1.8)	8(2.4)						
1¼ (32)	7(2.1)	9(2.7)	7(2.1)	9(2.7)						
1½ (40)	9(2.7)	12(3.7)	8(2.4)	10(3.0)						
2 (50)	10(3.0)	13(4.0)	8(2.4)	11(3.4)						
2½ (65)	11(3.4)	14(4.3)	9(2.7)	13(4.0)						
3 (80)	12(3.7)	15(4.6)	10(3.0)	14(4.3)						
3½ (90)	13(4.0)	16(4.9)	11(3.4)	15(4.6)						
4 (100)	14(4.3)	17(5.2)	12(3.7)	16(4.9)						
5 (125)	16(4.9)	19(5.8)	13(4.0)	18(5.5)						
6 (150)	17(5.2)	21(6.4)	14(4.3)	20(6.1)						
8 (200)	19(5.8)	24(7.3)	16(4.9)	23(7.0)						
10 (250)	22(6.7)	26(7.9)	18(5.5)	25(7.6)						
12 (300)	23(7.0)	30(9.1)	19(5.8)	28(8.5)						
14 (350)	25(7.6)	32(9.8)								
16 (400)	27(8.2)	35(10.7)								
18 (450)	28(8.5)	37(11.3)								
20 (500)	30(9.1)	39(11.9)								
24 (600)	32(9.8)	42(12.8)								
30 (750)	33(10.1)	44(13.4)								

Notes:

- a. For spacing supports incorporating type 40 shields, see ANSI/MSS SP-58-2009, Table A3.
- b. This table does not apply where span calculations are made or where there are concentrated loads between supports, such as flanges, valves, and specialties, etc. or changes in direction requiring additional supports.
- c. Unbalanced forces of hydrostatic or hydrodynamic origin (thrust forces) unless restrained externally can result in pipe movement and separation of joints if the joints of the system are not of a restrained joint design. See ANSI/MSS SP-58-2009 Section 7.5.3

Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc. Note: The SP-58-2009 "comprehensive" edition integrates the content of a revised MSS SP-58 with ANSI/MSS SP-69-2003, MSS SP-77-1995 (R 2000), MSS SP-89-2003, and MSS SP-90-2000 into a single source document, enabling the user to specify a minimum level of acceptance for pipe hanger design and performance, in addition to defining the types of hangers and supports. The aforementioned SP-69 will not be revised, and SP-77, 89, and 90 were withdrawn in 2010. The SP-58-2009 edition can officially be utilized and referenced in place of the aforementioned Standard Practices.

should be accommodated by buttressing with the proper hangers and supports.

### **Pressure Fluctuations**

Just as with thermal stresses, pressure fluctuations that occur because of the substance being transported within the piping system are accompanied by contraction and expansion effects that need to be accommodated by the proper hangers and supports. These pressure fluctuations are often complex, as they involve the conduct of fluids, gases, and semisolids being transported in an enclosed environment.

Changes in pressure can create unrealized stresses on the hangers and supports for the piping system. For instance, water hammer can cause movement and vibration within pipes that may cause the piping system to fail if it is too firmly or rigidly anchored. Water hammer can occur within any piping system carrying liquids when a significant fluctuation of flow volume or pressure occurs or when a contaminant substance, such as air, enters the piping.

The plumbing engineer must design a piping hanger and support system to handle extreme pressure fluctuations and also to ensure that the building's structure can handle the applied loads created by the movement of the piping system.

### **Structural Stresses**

Perhaps the most obvious of all external influences on a piping system is the structure to which the piping system must be attached and pass through. Every natural and manmade material is subject to contraction and expansion due to internal and external effects. Many of these structural stresses must be accommodated by the plumbing engineer within the design of the hangers and supports for the piping system. Every building must be engineered to handle the stresses of the basic structural components.

Anchors and supports of piping systems that initially are attached to vertical metal structural components and transition to horizontal attachments to concrete structural components must contend with the contraction and expansion of the piping system materials as well as the expansion and contraction of the structural elements. For example, the diameter of the metal dome of the U.S. Capitol in Washington, D.C. is known to expand by up to 6 inches when heated by the sun during the summer.

### **Natural Environmental Conditions**

The susceptibility of a piping system to natural conditions must be accounted for within the piping system and the accompanying hangers, supports, and anchors. The major effect of these natural environmental conditions is on the basic building structure. However, within structures designed to handle extreme natural phenomena, the piping system itself must be hardened or conditioned.

Typical natural phenomena consist of seismic forces and sustained periods of high winds, including hurricanes and typhoons, which create major stresses and loads on a building's structure. For instance, an extreme high-rise building, such as the Empire State Building in New York City, is known to move 4 to 12 inches laterally in high winds. In zones of known natural phenomena, such as areas susceptible to earth movement, the plumbing engineer must design the piping and support systems to sustain the shocks, stresses, and loads inherent with and applied by these extreme forces. The engineer must refer to applicable building codes to determine the seismic design category for any mandated piping system support requirements.

While a plumbing system may not be expected to survive the complete destruction of a building's structure, it is expected to survive intact and working in the event that the building structure itself survives.

### **Reactivity and Conductivity**

The hangers and supports vital to providing piping system integrity often must also provide protection from unexpected natural and manmade activities, events, and phenomena totally unrelated to structure, stresses, loads, and similar engineering events. Just as the engineer must consider the makeup of the interior surfaces of the piping material, he also must consider the exterior components of the piping system that will be subject to environmental and manmade conditions. The hangers and supports must be factored into this reactive equation.

Reactive conditions can consist of chemical reactions between unlike materials or the introduction of a reactive substance or electrical conductivity that can occur between different materials due to electrical "leakage" onto a piping system. These reactive and conductivity concerns can be unobtrusive and unexpected. Regardless, they can be the cause of unexpected failure in the hangers or supports of the piping system.

This type of failure can be especially acute in unexpected areas. Chemical fumes, salt water, and cleaning liquids can cause a chemical reaction between a hanger or support and a pipe of differing metals. Initial indicators of potential failure can be seen in corrosion or in the compounds produced by chemical reaction that attach to the hangers and supports in inhospitable environments such as boiler rooms or specialty gas and liquid systems.

It is vital that such reactive conditions be considered and that the engineer specify compatible pipe and support materials or provide for protective coatings or materials. It is especially important to ensure that the interior portions of hangers, supports, and clamps that come in contact with piping also are subject to the protective coatings; otherwise, they

will be prone to failure as the material is destroyed from the inside out.

Similarly, electrical current seepage or leakage can cause unexpected but known effects between two dissimilar materials. The plumbing engineer may need to evaluate the potential for this electrical leakage, especially in common raceways where piping and conduit are placed side by side, and provide suitable protection via the hangers and supports. A common example of this is the galvanic corrosion that occurs in copper pipe when steel hangers are used.

### Acoustics

For certain structures, the engineer may need to consider various acoustical aspects related to piping systems. In general, two significant types of acoustical annoyances must be considered. The first is noise such as the sound of liquid rushing through a pipe or a harmonic resonance that makes a pipe “ring.” In these instances, the engineer must ensure that the piping system and the accompanying supports receive proper insulation.

The second type of acoustic effect that must be considered is that created by vibration and movement within the piping system. This acoustic anomaly requires a hanger and support system that offers a combination of three-dimensional flexibility to account for lateral, longitudinal, and axial movements of the piping system and a sound- and vibration-insulating material or anchor integrated into the hanger.

### Manmade Environmental Conditions

The plumbing engineer also should be cognizant of any manmade environmental conditions that can affect the piping system. These created conditions can cause uncalculated stresses and loads on the system and lead to premature failure. Created environmental conditions that can result in resonance or vibration affecting interior structural systems include major highway arteries with significant automotive and truck traffic; airport takeoff and landing patterns; nearby construction; underground digging; and underground traffic such as subways and railroad tunnels.

## HANGER AND SUPPORT SELECTION AND INSTALLATION

The old adage “the whole is only as strong as its individual parts” applies directly to piping hangers and supports. Countless environmental and physical conditions as discussed above can be considered when choosing the correct hanger, support, or anchor. Nothing, however, substitutes for experience and knowledge. The engineer should work directly with the pipe manufacturer regarding the proper spacing criteria and hanging methods for the pipe that is to be specified. While the number of variables that can be examined in choosing hangers and supports

for a plumbing system has no limits, practicality and resource limitations also must be taken into consideration.

### Hanger Types

Hangers, supports, and clamps come in a wide variety of materials, shapes, and sizes (see Figure 6-1). While the major purpose of the hangers shown is to support the loads and stresses imposed on a piping system, specification of the correct hanger is a vital component for the overall structural integrity of the building itself. The structure must be able to handle the loads and stresses of the piping system, and the hanger and support system must be engineered to provide flexibility, durability, and structural strength.

### Selection Criteria

To ensure proper hanger and support selection, the plumbing engineer must determine or be cognizant of the degrees of freedom that will be necessary within the piping system due to its operating characteristics. These degrees of freedom need to be considered in a three-dimensional space to account for lateral, horizontal, vertical, and axial movements and fluctuations.

The most typical selection criterion used is the one most closely associated with the type of pipe material and the temperature fluctuations within the system. This simple selection process requires the correct hanger choice to be made from Table 6-2. Then, based on that hanger choice and the temperature of the overall piping system, Table 6-3 can be used to select the appropriate hanger.

However, this selection process relies on averages and standards. It does not take into account all of the three-dimensional fluctuations and movements that, depending on the structure and the associated or potential stresses and loads, will affect the overall plumbing system.

Tables 6-2 and 6-3 should be used as guidelines for selecting the most suitable type of hanger for the support requirement at each incremental step of the design process. These tables offer the basics of hanger selection—a variety of hanger choices and the material composition most suited for the temperature characteristics that will affect the piping

**Table 6-2 Pipe Classification by Temperature**

System	Class	Temperature Rating, °F (°C)
Hot	A-1	120 to 450 (49 to 232)
Hot	A-2	451 to 750 (233 to 399)
Hot	A-3	Over 750 (over 400)
Ambient	B	60 to 119 (16 to 48)
Cold	C-1	33 to 59 (1 to 15)
Cold	C-2	–20 to 32 (–29 to 0)
Cold	C-3	–39 to –20 (–39 to –29)
Cold	C-4	–40 and below (–40 and below)

Table 6-3 Hanger and Support Selections

To find recommended hanger or support components.


1. Locate the system temperature and insulation condition in the two columns at left.
2. Read across the column headings for the type of component to be used.
3. Numbers in boxes refer to those types shown in Figure 6-1.

System	Horizontal Pipe Attachments										Vertical Pipe Attachments					Hanger Rod Fixtures					Building Structure Attachments				
	Temp. Range, °F (°C)	Insulation	Steel Clips A	Malleable Iron Rings B	Steel Bands C	Steel Clamps D	Cast Iron Hanging Rolls E	Cast Iron G	Steel Trapezes G	Steel Protection Saddles & Shields H	Steel or Cast Iron Stanchions I	Steel Welded Attachments J	Riser Clamps 2 bolt K	Steel Riser Clamps 4 bolt L	Steel Welded Attachments Steel M	Turn Buckles N	Swing Eyes O	Clevises P	Inserts Q	C-Clamps R	Beam Clamps S	Welded Attachments T	Brackets U		
HOT A-1	COVERED*	24 W/39	NONE	1, 5, 7, 9, 10 W/39 OR 40	2, 3	41, 43 W/39 OR 40	44, 45, 46 W/39 OR 40	59 W/39 OR 40	39, 40	36, 37, 38 W/39 OR 40	35°	8	42°	°	20, 21, 25, 27	13, 15, 16, 17	14	18°	19, 23	20, 21, 25, 27	22, 57, 58°	31, 32, 33, 34			
120 (49) to 450 (232)	BARE	24, 26	6, 11, 12	1, 5, 7, 9, 10	3, 4	41, 43	44, 45, 46	59	NONE	36, 37, 38															
HOT A-2	COVERED*	24 W/39	NONE	1 W/39 OR 40	3	41 W/39 OR 40	44, 45, 46 W/39 OR 40	59 W/39 OR 40	39, 40	36, 37, 38 W/39 OR 40	35°	NONE	42°	°	20, 21, 25, 27, 28, 29, 30	13, 15, 16, 17	14	18°	NONE	20, 21, 25, 27, 28, 29, 30	22, 57, 58°	31, 32, 33			
451 (233) to 750 (399)	BARE	NONE	NONE	NONE	3, 4	NONE	NONE	°	NONE	NONE															
HOT A-3	COVERED*	NONE	NONE	1 W/40	ALLOY 2, 3	41, 43 W/40 OR ALLOY 39	44, 45, 46 W/40 OR ALLOY 39	59 W/40 OR ALLOY 39	40 ALLOY 39	36, 37, 38 W/40 OR ALLOY 39	ALLOY 35°	NONE	ALLOY 42°	ALLOY 39°	20, 21, 25, 27, 28, 29, 30	13	14	°	NONE	20, 21, 25, 27, 28, 29, 30	22, 57, 58°	31, 32, 33			
OVER 750 (399)	BARE	NONE	NONE	NONE	ALLOY 2, 3, 4	NONE	NONE	°	NONE	NONE															
AMBIENT B	COVERED*	24, 26	NONE	1, 5, 7, 9, 10 W/39 OR 40	3, 4	41, 43 W/39 OR 40	44, 45, 46 W/39 OR 40	59 W/39 OR 40	39, 40	36, 37, 38 W/39 OR 40	35°	8	42°	°	20, 21, 25, 27, 28, 29, 30	13, 15, 16, 17	14	18°	19, 23	20, 21, 25, 27, 28, 29, 30	22, 57, 58°	31, 32, 33, 34			
60 (16) to 119 (48)	BARE	24, 26	6, 11, 12	1, 5, 7, 9, 10	3, 4	41, 43	44, 45, 46	59	NONE	36, 37, 38															
COLD C-1	COVERED*	26 W/40	NONE	1, 5, 7, 9, 10 W/40	3, 4	41, 43 W/40	44, 45, 46 W/40	59 W/40	40	36, 37, 38 W/40	°	8	42°	°	20, 21, 25, 27, 28, 29, 30	13, 15, 16, 17	14	18°	19, 23	20, 21, 25, 27, 28, 29, 30	22, 57, 58°	31, 32, 33			
33(1) to 59 (15)	BARE	24, 26	6, 11, 12	1, 5, 7, 9, 10	3, 4	41, 43	44, 45, 46	°	NONE	36, 37, 38															
COLD C-2	COVERED*	NONE	NONE	1, 5, 7, 9, 10 W/40	NONE	41, 43 W/40	44, 45, 46 W/40	° <sup>c,d</sup> W/40	40	36, 37, 38 W/40															
-19(-28) to 32 (0)	BARE	NONE	NONE	1, 5, 7, 9, 10	3, 4	41, 43	44, 45, 46	°	NONE	36, 37, 38															
COLD C-3 & C4	COVERED*	NONE	NONE	1, 5, 7, 9, 10 W/40	NONE	41, 43 W/40	44, 45, 46 W/40	° <sup>b,c,d</sup> W/40	40	36, 37, 38 W/40	°	8	42°	°	20, 21, 25, 27, 28, 29, 30	13, 15, 16, 17	14	18°	19, 23	20, 21, 25, 27, 28, 29, 30	22, 57, 58°	31, 32, 33, 34			
BELOW -19 (-28)	BARE	NONE	NONE	NONE	° <sup>b,c</sup>	NONE	NONE	° <sup>b,c</sup>	NONE	NONE															

Notes:

- a. Hangers on insulated systems shall incorporate protection saddles, shields, pipe clamps, or welded lugs which project through the insulation to provide external attachment.
- b. The selection of type and material shall be made by the piping design engineer.
- c. The design shall be in accordance with MSS SP-58 or as specified by the piping design engineer.
- d. For shields used with rollers or subject to point loading, see MSS SP-58 Table A3.
- e. Continuous inserts, embedded plates, anchor bolts, and concrete fasteners may be used as specified by the piping design engineer.
- f. The need to maintain a vapor barrier may be required because of ambient dew point considerations.


Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc.



**Figure 6-1 Types of Hangers and Supports**

Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc.





**Figure 6-1 Types of Hangers and Supports (continued)**

Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc.

system. What these tables cannot do is substitute for the engineering and design processes that determine the proper hanger selection based on the environmental and physical influences that will affect the different elements of the piping system under varying conditions. The most instructive aspect of Table 6-3 is found in the notes at the end of the table (see notes b, c, and e).

### Hanger and Support Spacing

After the appropriate hanger components have been selected for the type of piping system and the type of building or structural support available, the plumbing engineer must identify the spacing appropriate to the type of pipe used. Table 6-1 provides support criteria for some of the most common pipe materials. However, the plumbing engineer must ensure that the design criteria is in compliance with local code requirements.

**Table 6-4 Recommended Minimum Rod Diameter for Single Rigid Rod Hangers**

Nominal Pipe or Tubing Size	Types of Pipe	
	Steel Water Service Steel Vapor Service Ductile Iron Pipe Cast Iron Soil	Copper Water Service Copper Vapor Service Glass, Plastic Fiberglass Reinforced
	Nominal Rod Diam.	Nominal Rod Diam.
in. (mm)	in. (mm)	in. (mm)
¼ (6)	⅜ (M10)	⅜ (M10)
⅜ (10)	⅜ (M10)	⅜ (M10)
½ (15)	⅜ (M10)	⅜ (M10)
¾ (20)	⅜ (M10)	⅜ (M10)
1 (25)	⅜ (M10)	⅜ (M10)
1¼ (32)	⅜ (M10)	⅜ (M10)
1½ (40)	⅜ (M10)	⅜ (M10)
2 (50)	⅜ (M10)	⅜ (M10)
2½ (65)	½ (M12)	½ (M12)
3 (80)	½ (M12)	½ (M12)
3½ (90)	½ (M12)	½ (M12)
4 (100)	⅝ (M16)	½ (M12)
5 (125)	⅝ (M16)	½ (M12)
6 (150)	¾ (M20)	⅝ (M16)
8 (200)	¾ (M20)	¾ (M20)
10 (250)	⅞ (M20)	¾ (M20)
12 (300)	⅞ (M20)	¾ (M20)
14 (350)	1 (M24)	
16 (400)	1 (M24)	
18 (450)	1 (M24)	
20 (500)	1¼ (M30)	
24 (600)	1¼ (M30)	
30 (750)	1¼ (M30)	

**Notes:**

- For calculated loads, rod diameters may be sized in accordance with MSS SP-58 Tables 2 and 2M provided Table 1 and Section 7.2.1 of MSS SP-58 are satisfied.
- Rods may be reduced one size for double rod hangers. Minimum rod diameter shall be ⅜ in. (M10).

Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc.

Just as with Table 6-3, it needs to be noted that Table 6-1 provides guidelines only based on piping systems under ideal circumstances with little environmental or physical influences. Therefore, these spacing guidelines are at the upper end of the specifications. That is, they should be considered the maximum spacing for hangers and supports.

For proper hanger spacing, the engineer must evaluate and take into account the three-dimensional fluctuations and movements as well as the environmental and physical influences that will affect the entirety of the plumbing system. Proper spacing is a function of stress, vibration, and the potential for misuse (e.g., exposed piping used as a ladder, scaffolding, or exercise equipment). Spacing depends on pipe direction changes, structural attachment material and anchor points, additional plumbing system loadings—such as valves, flanges, filters, access ports, tanks, motors, pipe shielding, insulation, and drip, splash, and condensate drainage—and other specialty design requirements.

**Table 6-5 Load Ratings of Carbon Steel Threaded Hanger Rods**

Nominal Rod Diameter	Root Area of Thread	Max. Safe Load at Rod Temp. of 650°F (343°C)
in. (mm)	in. <sup>2</sup> (mm <sup>2</sup> )	lb (kg)
⅜ (9.6)	0.068 (43.8)	730 (3.23)
½ (12.7)	0.126 (81.3)	1,350 (5.98)
⅝ (15.8)	0.202 (130.3)	2,160 (9.61)
¾ (19.0)	0.302 (194.8)	3,230 (14.4)
⅞ (22.2)	0.419 (270.3)	4,480 (19.9)
1 (25.4)	0.551 (356.1)	5,900 (26.2)
1¼ (31.8)	0.890 (573.5)	9,500 (42.4)
1½ (38.1)	1.29 (834.2)	13,800 (61.6)
1¾ (44.4)	1.74 (1125)	18,600 (82.8)
2 (50.8)	2.30 (1479)	24,600 (109)
2¼ (57.2)	3.02 (1949)	32,300 (144)
2½ (63.5)	3.72 (2397)	39,800 (177)
2¾ (69.8)	4.62 (2980)	49,400 (220)
3 (76.2)	5.62 (3626)	60,100 (267)
3¼ (82.6)	6.72 (4435)	71,900 (320)
3½ (88.9)	7.92 (5108)	84,700 (377)
3¾ (95.2)	9.21 (5945)	98,500 (438)
4 (101.6)	10.6 (6844)	114,000 (505)
4¼ (108.0)	12.1 (7806)	129,000 (576)
4½ (114.3)	13.7 (8832)	146,000 (652)
4¾ (120.6)	15.4 (9922)	165,000 (733)
5 (127.0)	17.2 (11074)	184,000 (819)

**Notes:**

- For materials other than carbon steel, see requirements of ANSI/MSS SP-58-2009, Section 4.8 and Table A2.
- Tabulated loads are based on a minimum actual tensile stress of 50 ksi (345 MPa) divided by a safety factor of 3.5, reduced by 25%, resulting in an allowable stress of 10.7 ksi. (The 25% reduction is to allow for normal installation and service conditions.)
- Root areas of thread are based on the following thread series: diam. 4 in. and below: coarse thread (UNC); diam. above 4 in.: 4 thread (4-UN).

Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc.

## ANCHORING

The strength, safety, and integrity of a plumbing system depend on the hangers or supports that are specified. However, it is not enough to simply specify a hanger or support—another important consideration is how it is anchored. A hanger or support will perform only up to the capability of its attachment to a structural element. At a minimum, the plumbing engineer needs to ensure close coordination between the plumbing system design and that of the other design engineers, including iron and concrete structural engineers, to ensure properly spaced and applied hangers and supports and their anchors.

Anchoring hangers and supports requires different methods depending on the structural elements, transitions from vertical and horizontal

surfaces, and differing materials (e.g., from steel to concrete). Perhaps the most difficult hanger and support attachment requirement is that to concrete in an existing structure. It might be necessary for the plumbing engineer to contact the original concrete designer or supplier or involve an experienced hanger manufacturer or contractor for the proper anchoring of the hangers and supports.

The extent of detail required within the plumbing system design depends on the project's parameters and the practicality and responsibility of the engineer to the overall building assembly. It might be in the plumbing engineer's scope to establish loading, shear, and stress specifications for the hanger and support anchoring structure. Depending on the structure, the requirements and specifications for the hanger and support anchors vary widely. For instance, anchoring to wood involves a significantly different process than anchoring to steel. In the latter case, welding specifications may need to be included and bonding material compatibility ensured. Anchoring to concrete requires the use of implanted anchors during the pouring of the concrete or subsequent attachment using anchor bolts and plates.

### Anchor Types

Figure 6-2 shows some common materials and devices often used for anchoring hangers and supports; however, a wide variety of anchor bolts, screws, washers, nuts, rods, plates, and strengtheners is available. Figure 6-3 shows additional supports that might be preferred by the engineer in very particular circumstances.

Table 6-4 shows the pipe hanger rod size for a single rigid rod hanger; however, care should be taken to observe the loading associated with special conditions that may induce a load beyond the hanger rod strength. Moreover, lateral stress and axial tension affect the choice of rod size and material. See Table 6-5 for load ratings of threaded hanger rods and Table 6-6 for minimum design load ratings for rigid pipe hanger assemblies. These tables show acceptable standards for hanger materials, but it is important to check a particular manufacturer's specifications as well. See Table 6-7 for sample design load tables for a manufacturer's concrete inserts. In the overall engineered design, load and stress calculations for multiple hanger and support assemblies and the use of multiple anchor assemblies (such as concrete rod inserts) require additional evaluation and analysis to properly incorporate the effects of a distributed load.

## SLEEVES

Pipes often must pass through walls, floors, and other penetrations. If unlike materials come into contact, the potential chemical reactions between them can

**Table 6-6 Minimum Design Load Ratings for Pipe Hanger Assemblies** (applicable to all components of complete assembly, including pipe attachment, rod, fixtures, and building attachment)

Nominal Pipe or Tube Size	Min. Design Load Ratings at Normal Temp. Range <sup>b</sup>
in. (mm)	lb (kg)
3/8 (10)	150(0.67)
1/2 (15)	150(0.67)
3/4 (20)	150(0.67)
1 (25)	150(0.67)
1 1/4 (32)	150(0.67)
1 1/2 (40)	150(0.67)
2 (50)	150(0.67)
2 1/2 (65)	150(0.67)
3 (80)	200(0.89)
3 1/2 (90)	210(0.93)
4 (100)	250(1.11)
5 (125)	360(1.60)
6 (150)	480(2.14)
8 (200)	760(3.38)
10 (250)	1120(4.98)
12 (300)	1480(6.58)
14 (350)	1710(7.61)
16 (400)	2130(9.47)
18 (450)	2580(11.48)
20 (500)	3060(13.61)
24 (600)	3060(13.61)
30 (750)	3500(15.57)

#### Notes:

- See MSS SP-58-2009 Section 4 for allowable stresses and temperatures.
- Normal temperature range is  $-20$  to  $650^{\circ}\text{F}$  ( $-29$  to  $343^{\circ}\text{C}$ ) for carbon steel,  $-20$  to  $450^{\circ}\text{F}$  ( $-29$  to  $231^{\circ}\text{C}$ ) for malleable iron, and  $-20$  to  $400^{\circ}\text{F}$  ( $-29$  to  $204^{\circ}\text{C}$ ) for gray iron.
- See MSS SP-58-2009 Section 7.2.1 for minimum rod diameter restrictions.
- For loads greater than those tabulated, hanger component load ratings shall be established by the manufacturer. Design shall be in accordance with all criteria as outlined in MSS SP-58-2009.
- Pipe attachment ratings for temperature ranges between  $650$  and  $750^{\circ}\text{F}$  ( $343$  and  $398^{\circ}\text{C}$ ) shall be reduced by the ratio of allowable stress at service temperature to the allowable stresses at  $650^{\circ}\text{F}$  ( $343^{\circ}\text{C}$ ).
- For services over  $750^{\circ}\text{F}$  ( $398^{\circ}\text{C}$ ), attachments in direct contact with the pipe shall be designed to allowable stresses listed in MSS SP-58-2009, Tables A2 and A2M.

Extracted from ANSI/MSS SP-58-2009 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry Inc.

**Table 6-7(A) Sample Design Load Tables for Manufacturer’s Concrete Inserts**

Design Load Chart for 3000 psi Hard Rock Concrete											
Rod Size (in.)	Design Load Vertical (psi)				Design Load Shear (psi)				Design Load 45° (psi)		
	A	B	C	De° (in.)	A	B	C	De° (in.)	A	B	C
3/8	1207	457	457	1	675	675	675	2	612	364	385
1/2	2043	496	496	1.4	912	912	912	2	892	454	454
5/8	1690	532	532	1.7	1148	1148	1148	2	967	514	514
3/4	2321	567	567	2	1368	1368	1368	2.5	1217	567	567
7/8	2321	878	878	4	1596	1596	1596	3	1338	801	801


Design Load Chart for Lightweight Concrete											
Rod Size (in.)	Design Load Vertical (psi)				Design Load Shear (psi)				Design Load 45° (psi)		
	A	B	C	De° (in.)	A	B	C	De° (in.)	A	B	C
3/8	905	343	343	7/8	590	590	590	2	547	307	321
1/2	1632	372	372	7/8	590	590	590	2	828	323	374
5/8	1268	399	399	7/8	590	590	590	2	852	337	419
3/4	1741	426	426	7/8	590	590	590	2 1/2	1084	350	459
7/8	1741	656	656	7/8	590	590	590	3	1178	439	654

**Table 6-7(B) Sample Design Load Tables for Manufacturer’s Concrete Inserts**

Rod Size (in.)	Design Load Vertical (psi)		Design Load Shear (psi)		Design Load 45° (psi)		"E" Embedment Depth (in.)	De° min. (in.)
	Hard Rock	Lt. Wt.	Hard Rock	Lt. Wt.	Hard Rock	Lt. Wt.		
3/8	1255	753	978	733	777	525	3 1/2	2
1/2	2321	1392	978	733	980	679	3 1/2	2
5/8	780	468	1278	958	688	445	4	2
3/4	1346	806	1278	958	927	619	4	2 1/2
7/8	2321	1392	1278	958	1166	803	4	6

Source: Table 6-7(A) and (B) courtesy of Tolco

\*De = distance to the edge of the concrete that must be maintained for the rod to meet the design load.



**Figure 6-2 Types of Hanger and Support Anchors**

Source: Anchor details courtesy of TOLCO®.

damage the pipe, structure, or both. Likewise, when a pipe passes through a penetration, what happens if the structure collapses on or damages the pipe? For this reason, the plumbing engineer must provide protection of the pipes using pipe sleeves. Pipe sleeves can be constructed of a variety of materials that should be selected based on the application as well as the materials of the structure and the pipe.

### HANGER, SUPPORT, AND ANCHOR MATERIALS

An almost unlimited variety of materials can be used for producing hangers, supports, and anchors. With the increased use of plastic, fiberglass, and other lightweight and corrosion-resistant pipe materials has come an increased availability of matching hangers and supports. The plumbing engineer must match and coordinate the various materials available. Due to possible chemical reactions and galvanic effects, it is very important to match the composition of the hanger, support, and anchor materials to the composition of the piping system material.

### GLOSSARY

**Acceleration limiter** A device—hydraulic, mechanical, or spring—used to control acceleration, shock, and sway in piping systems.

**Access channel** A conduit or channel cast in place within concrete structural elements that provides for the passing through of pipe. It is placed horizontally throughout a concrete structure to facilitate future access.

**Access opening** An opening or conduit cast in place within concrete structural elements that provides for the passing through of pipe. The most typical usage is for short vertical conduit in concrete slabs to eliminate the subsequent drilling of core holes.

**Accumulator** A container, used in conjunction with a hydraulic cylinder or rotating vane device for the control of shock or sway in piping systems, that is used to accommodate the difference in fluid volume displaced by the piston. It also serves as a continuous supply of reserve fluid.




Figure 6-2 Types of Hanger and Support Anchors (continued)




Figure 6-2 Types of Hanger and Support Anchors (continued)


**Adjustable** Mechanical or automated movement providing for linear adjustment capability (regardless of the plane or dimension). Adjustment may be mechanical, such as a threaded rod, or assisted with vacuum or air pressure.

**Adjustment device** A component that provides for adjustability. (See adjustable.)

**After cold pull elevation** The mechanical drawing view incorporating additional piping elements during installation that will be necessary for thermal fluctuations once the piping system is hot.

**Alloy** A chrome-moly material (often less than 5 percent chrome) used to resist the effects of high temperatures (750°F to 1,100°F [399°C to 593°C]). Alloys are used as pipe, hanger, support, and anchor materials.

**Anchor** To fasten or hold a material or device to prevent movement, rotation, or displacement at the point of application. Also an appliance used in conjunction with piping systems to fasten hangers and supports to prevent movement, rotation, or displacement.



**Figure 6-3 Hanger and Support Anchors for Particular Applications**

Source: Support details courtesy of Holdrite®

**Anchor bolt** A fastener (e.g., bolt or threaded rod) that is used to attach or connect materials, devices, or equipment. Often refers to the bolt that is embedded in concrete or passed through an opening in steel that is used to attach a hanger or support to a concrete or steel structure.

**As built** The actual installation of construction or configuration placement.

**Assembly** A pre-formed arrangement or a gathered collection of various appliances and components used to carry, hold, and/or restrain devices, equipment, or a piping system load in tension.

**Auxiliary stop** A supplemental restraint that temporarily locks or holds in place movable parts. Often used in conjunction with spring devices, such as a spring hanger, to provide for a fixed position enabling a load to be transferred to a supporting structure in a desired placement during construction or installation.

**Axial brace** An assembly or bracket device used to resist twisting or to restrain a piping run in the axial direction.

**Band or strap hanger** An appliance or device used as a hanger or support for pipe that provides for vertical adjustment. It also is used to connect pipe to a hanger assembly.

**Base support** A device that carries a load from beneath and is used to carry a load's weight in compression.

**Beam clamp** A mechanical device used to connect, as a hanger or support, or to hold part of a piping system to a structural beam element (typically a steel beam). A clamp firmly holds multiple materials or devices together and does not require welding.

**Bearing plate** See slide plate and roll plate.

**Bent** An assembly or frame consisting of two vertical members joined by one or more horizontal members used for the support of a piping system to a structural element.

**Bolting** The use of bolts, studs, and nuts as fasteners.

**Brace, brace assembly** A pre-formed appliance or assembly consisting of various components that, depending on its location, is used to hold and/or restrain a piping system from horizontal, vertical, and lateral forces.

**Brace, hanger, or support drawing** The mechanical drawing detailing the elements and components of an assembly or frame structure that incorporates a bill of material, load and movement data, and both general and specific identification.

**Bracket** A pre-formed support or fastener, usually constructed in a cantilevered manner, with or without additional diagonal structural members for load stability, designed to withstand a gravity load and horizontal and vertical forces.

**C clamp** A pre-formed appliance in a C shape that attaches to a flange or other part of a structural member and acts as an anchor for a hanger, support, or other device such as a threaded rod.

**Cable** A component used to brace structural assemblies and piping systems (also called wire rope).

**Cable sway brace** Components added to a standard pipe support or hanger system to limit sway during movement such as during a seismic event. The components include cable, pipe attachments, and attachment to the structure. Cable bracing requires two attachment locations as it works under tension only and not tension and compression like rigid bracing.

**Cantilever** A projecting structural element or member supported at only one end.

**Center beam clamp** A jaw-type mechanical device used to connect, as a hanger or support, or used to hold part of a piping system to a structural beam element (typically a steel beam). It is used with I beams and wide flange beams to provide a centered beam connection.

**Channel clamp** A mechanical device with a channel adapter and hook rod that provides an off-center attachment to the bottom flange of a channel beam for a hanger, support, or other part of a piping system.

**Clamp** A mechanical device used to connect, as a hanger or support, or hold part of a piping system to a structural beam element. (A clamp firmly holds multiple materials or devices together and does not require welding.) See beam clamp, C clamp, channel clamp, double bolt pipe, three-bolt clamp, double-bolt riser, riser clamp, and pipe clamp.

**Clevis** A connector device or metal shackle with drilled ends to receive a pin or bolt that is used for attaching or suspending parts.

**Clevis hanger** A support device providing vertical adjustment consisting of a clevis-type top bolted to a formed steel bottom strap.

**Cold elevation** See design elevation and after cold pull elevation.

**Cold hanger location** The location of the pipe hangers, supports, and assemblies of the installed piping system in reference to the building's structure and structural elements prior to the invoking of an operating environment.



**Cold load** The stress or loading put on a piping system prior to the occurrence of a normal or steady-state operating environment (as measured at ambient temperature). The cold load equals the operating load plus or minus load variations.

**Cold setting** The position at which a mechanical control device indicator, such as that on a spring hanger, is set to denote the proper nonoperating position installation setting of the unit.

**Cold shoe** A T-section hanger or support with integrated insulation that has been designed for cold temperature piping system application.

**Cold spring** The act of pre-stressing a piping system during installation to condition it for minimal fluctuations, expansions, and other reactions when the finished piping system and related equipment are used in the designed operating environment.

**Colored finish** A generic term to describe various color finishes that are used as an identifier for product compatibility. For example, a copper-colored finish on connectors or piping denotes that the product was sized for copper tubing.

**Commercial piping system** A piping system located in a commercial building structure that generally includes fire protection, plumbing, heating, and cooling piping systems.

**Component** Any individual item, appliance, or device that is combined with others to create an assembly or is part of a whole.

**Concrete fastener** A device installed in or attached to concrete by various means (often pre-cast, drilled, or epoxied) to which a pipe hanger or support can be attached.

**Concrete insert, concrete insert box** An anchor device cast in place in concrete and provides for a hanger, support, rod, or similar attachment. The insert provides load assistance to a piping system and has nominal lateral adjustment.

**Continuous insert** An anchoring device in the form of a channel (which can be of varying lengths) that is cast in place in a concrete structure and provides for multiple hangers, supports, rods, or similar attachments. The insert provides load assistance to a piping system and has the capability for lateral adjustments.

**Constant support hanger** A mechanical spring-coil device that provides constant support for a piping system while permitting some dimensional movement.

**Constant support hanger indicator** A device attached to the movable arm of a constant support hanger that measures vertical pipe movement.

**Copper plating** See plating.

**Corrosion** The process that describes the oxidation of a metal that is weakened or worn down by chemical action.

**Cut short** The shortening or lengthening of a section of pipe to provide for reduced fluctuations, expansions, and other reactions when the finished piping system and related equipment are used in the designed operating environment.

**DWV** Drain, waste, and venting.

**Deadweight load** The combination of all stress or loading put on a piping system that takes into consideration only the weight of the piping system, including the pipe, hangers, supports, insulation, and pipe contents.

**Design elevation** The overall mechanical drawing view of the piping system as designed.

**Design load** The combination of all stress or loading put on a piping system as defined in the engineered drawing or as part of the engineered design specification.

**Deviation** A measurement of difference often expressed as a percentage. It often is used to describe the accuracy difference between actual and specified performance criteria.

**Double acting** A descriptor for a mechanical device that provides resistance in both tension and compression cycles.

**Double-bolt pipe clamp** See three-bolt pipe clamp.

**Drag** The retarding force that acts on a portion of a hydraulic or mechanical device as it moves through fluid, gas, or other friction-generating substances. It also refers to the force required to extend and retract a hydraulic or mechanical element of a hanger or support device during activation at low velocity.

**Dual-use brace** A single brace that can be used as both a longitudinal and lateral brace in a single location.

**Dynamic force or dynamic loading** The additional loading and stress conditions that must be taken into consideration over and above a steady-state condition.

**Dynamic load** The temporary stress or loading put on a piping system as the result of internal or external forces that create movement or motion in the system.

**Elbow lug** An elbow-shaped device with a pipe connector welded to it for use as an attachment.

**Electrogalvanized** A protective coating of electroplated zinc. (See also galvanized.)

**Electroplated** Plating by using an electro-deposition process. (See also plating.)

**Electrolysis** The producing of chemical changes due to the differences in electrical potential between dissimilar materials in the presence of moisture. (See also corrosion.)

**Elevation** A mechanical drawing view that is a geometrical projection as seen on a vertical plane.

**Embedded** A device or fastener that is cast in place in a concrete structure.

**Engineered drawing** A mechanical drawing that details the elements and components of a piping system and incorporates a bill of material, load and movement data, location information, and both general and specific identification.

**Engineered hanger assembly** A mechanical drawing that details the elements and components of a hanger assembly and incorporates a bill of material, load and movement data, location information, and both general and specific identification. (See also semi-engineered hanger assembly.)

**Erected elevation** See design elevation.

**Extension riser clamp** An attachment device for the support of vertical piping that provides for the transfer of the piping load to the bearing surface to which the clamp is attached.

**Eye rod** A bolt or rod with a circular or pear-shaped end that permits other components or devices to be attached by means of a bolt or pin. The eye may be forged, welded, or nonwelded.

**Eye socket** An appliance that provides for the attachment of a threaded bolt or rod to the bolt or rod of another component or device.

**Fabrication** A term used to refer to a part constructed or manufactured out of standard parts or raw materials.

**Fabricated steel part** A component that is constructed from standard shapes of steel plate.

**Fabricator** A business engaged in the fabrication of parts.

**Forged clevis** A connector device, a clevis, that has been formed as one piece (i.e., forged).

**Four-way brace** An assembly consisting of lateral and longitudinal bracing that is designed to control back-and-forth movement in four directions.

**Framing steel** A structural steel member, normally less than 10 feet in length, used between existing

members as a means of providing for the attachment of a hanger or support for a piping system.

**Friction load** The stress or loading put on a piping system as the result of frictional forces that exist between different surfaces that are in contact with each other, such as moving or sliding surfaces.

**Galvanized** A zinc coating applied to steel to protect against oxidation and other chemical actions.

**Gang hanger** A hanger assembly utilizing a common cross-member to provide support for parallel runs or banks of piping.

**Guide** A device used to permit pipe movement in a predetermined direction while restraining movement in other directions.

**Hanger** A device that is suspended from a structure and used to carry or support a load.

**Hanger assembly** A general term used to describe a series of assembled components that make up a device that is connected to or suspended from a structure and is used to carry or support a load in tension or carry a load under compression. The device may be designed to prevent, resist, or limit movement, or it may be used to permit movement in a predetermined direction while restraining movement in other directions.

**Hanger drawing** See brace, hanger, or support drawing.

**Hanger loads** See pipe hanger loads.

**Hanger rod** A round steel bar, normally threaded, used to connect components for hangers and supports.

**Heavy bracket** A bracket used for the support of heavy loads. (See bracket.)

**Hinged pipe clamp** Also known as a split ring, a hinged attachment device that permits installation before or after piping is in place and used primarily on noninsulated piping.

**Horizontal traveler** A hanger or support device that accommodates horizontal piping movement.

**Hot-dip galvanized** A corrosion protection coating of zinc applied to steel or other metals.

**Hot elevation** The mechanical drawing view of a piping system as it will appear in its full operating environment.

**Hot hanger location** The location of the pipe hangers, supports, and assemblies of the installed piping system in reference to the building's structure and structural elements within the operating environment.

**Hot load** The stress or loading put on a piping system as the result of a normal or steady-state operating environment. (See operating load.)

**Hot setting** The position at which a mechanical control device indicator, such as that on a spring hanger, is set to denote the proper operating position setting of the unit.

**Hot shoe** A T-section hanger or support with integrated insulation that has been designed for hot temperature piping system application.

**HVAC** Heating, ventilation, and air-conditioning.

**Hydraulic snubber** See hydraulic sway brace.

**Hydraulic sway brace** A hydraulic cylinder or rotating vane device used to control shock or sway in piping systems, while allowing for normal thermal expansion.

**Hydrostatic load** The stress or loading put on a piping system as the result of hydrostatic testing. (See hydrostatic test load.)

**Hydrostatic lock** The condition wherein a supplemental restraint temporarily locks or holds in place moveable parts during a hydrostatic test. It often is used in conjunction with spring devices, such as a spring hanger, to provide for a fixed position enabling a load to be transferred to a supporting structure in a desired placement during construction or installation.

**Hydrostatic test** A pre-operational test whereby the piping system is subjected to a pressurized fluid in excess of the specified operational pressure to ensure the integrity of the system.

**Hydrostatic test load** The temporary loading condition consisting of the total load weight of the piping (gravitational load), insulation, and test fluid for piping systems subjected to hydrostatic tests.

**Industrial piping system** A piping system located in an industrial complex that generally includes fire protection, plumbing, heating, and cooling piping systems and also incorporates process, vacuum, air, steam, or chemical piping systems.

**Insert** An anchor device that is cast in place in a concrete structure and provides for a hanger, support, rod, or similar attachment. Inserts provide load assistance to a piping system and have nominal lateral adjustment.

**Insert box** See concrete insert.

**Insert nut** A female threaded anchor device that is locked into position as part of an insert and that receives a threaded rod or bolt.

**Institutional piping system** A piping system located in an institutional environment or building structure that generally includes fire protection, plumbing, heating, and cooling piping systems, as well as process, vacuum, air, or chemical gas piping systems.

**Insulated pipe support** A hanger or support with an integrated insulation insert designed for use with insulated pipe.

**Insulation protection saddle** A device used to prevent damage to the insulation on a pipe at the support point.

**Integral attachment** When connector pieces and devices have been welded together as hangers and supports or an assembly.

**Intermediate anchor** An attachment point used to control the distribution, loading, and movement on a flexible piping system.

**Invert** A drawing elevation view from the bottom or underneath.

**Jacket** A metal covering placed around the insulation on a pipe to protect it against damage.

**Knee brace** A diagonal structural member used to transfer load or provide stability.

**Lateral brace** A brace designed to restrain a piping system against transverse loads.

**Lateral stability** The state or degree of control of a piping system transverse to the run of the pipe.

**Light bracket** A bracket used for the support of light loads. (See bracket.)

**Limit stop** An internal device built into a mechanical device to prevent the overstressing of a spring coil, overtravel, or release of a load.

**Liner** Material placed between hangers, supports, or an assembly to protect a piping system from damage or other undesirable effects.

**Load adjustment scale** A scale used on a mechanical device to indicate the load adjustment.

**Load bolt or pin** A bolt or pin used to support the weight or load carried by a hanger or assembly.

**Load coupling** An adjustment device used to connect hanger and support components.

**Load indicator** A pointer, dial, or gauge for reading or determining the settings and changes of a device.

**Load rated** The rating of a particular size of component or assembly to withstand a specified force with a safety factor applied.

- Load scale** A measurement pointer, dial, or gauge attached to a device to provide a means of determining the static or dynamic aspects of a supported load.
- Load variation** The difference in the elevations at a support point between the time of installation (cold) and actual operating (hot) environment.
- Load** See pipe hanger load.
- Location** See pipe hanger location.
- Lock up** The operational period when a hydraulic, mechanical, or spring device used to control shock and sway in piping systems is actuated.
- Longitudinal brace** A brace designed to restrain a piping system against axial loads.
- Lug** A welded appliance to provide an attachment point to a structural member or piping.
- Mechanical snubber** See mechanical sway brace.
- Mechanical sway brace** A mechanical device used to control shock or sway in piping systems, while allowing for normal thermal expansion.
- Medium bracket** A bracket used for the support of moderate loads. (See bracket.)
- Metric hanger** A hanger or support that conforms to metric measurements and, where appropriate, contains a metric threaded connection.
- Mill galvanized** A corrosion-protection coating of zinc applied at the point of fabrication.
- Multiple support** See gang hanger.
- Negligible movement** The calculated minimum movement at a support point for the portion of a piping system with inherent flexibility.
- Nominal size** The identified size, which may vary from the actual size.
- Nonintegral attachment** When connector pieces and devices do not require being welded together as hangers and supports or an assembly.
- Nut, insert** See insert nut.
- Offset** A relative displacement between a structural attachment point and a piping system that is incorporated into the design to accommodate movement.
- Operating load** The stress or loading put on a piping system as the result of a normal or steady-state operating environment.
- OSHPD** California Office of Statewide Health Planning and Development, which provides services that include the efficient processing of approvals for health facility construction. OSHPD is a national leader in seismic restraint guidelines and requirements.
- Pipe attachment** Any component or device used to connect a pipe to a hanger, support, or assembly.
- Pipe brace** See brace.
- Pipe channel** A conduit or channel cast in place within concrete structural elements that provides for the passing through of pipe. It is placed horizontally throughout a concrete structure to facilitate future access.
- Pipe clamp** A bolted clamp attachment that connects a pipe to a hanger, support, assembly, or structural element.
- Pipe clip** An attachment appliance used to connect a pipe directly to a structural element, also referred to as a strap or pipe clamp.
- Pipe covering protection saddle** A protective covering used to prevent damage to insulation surrounding a pipe at hanger and support points.
- Pipe elevation** See design elevation, erected elevation, after cold pull elevation, and cold elevation.
- Pipe hanger** An appliance or device attached to or suspended from a structural element that is used to support a piping system load in tension.
- Pipe hanger assembly** An assembly of hangers used to hold a piping system.
- Pipe hanger drawing** A mechanical drawing that details the elements and components of a piping system and incorporates a bill of material, load and movement data, location information, and both general and specific identification. (See also engineered drawing and semi-engineered drawing.)
- Pipe hanger load** See specific load types: cold load, deadweight load, design load, dynamic load, friction load, hot load, hydrostatic load, operating load, seismic load, thermal load, thrust load, trip-out load, water hammer load, and wind load.
- Pipe hanger location** See location types: cold hanger location and hot hanger location.
- Pipe hanger plan** and **pipe hanger plan location** The engineered design and elevations that fully detail the hangers, supports, and anchors of a piping system. Mechanical drawings include appropriate offsets as a result of movement and displacement expectations.
- Pipe insulation shield** A rigid insert appliance designed to protect pipe insulation passing through hangers, supports, and assemblies.
- Pipe load** See specific load types: cold load, deadweight load, design load, dynamic load, friction load,

hot load, hydrostatic load, operating load, seismic load, thermal load, thrust load, trip-out load, water hammer load, and wind load.

**Pipe opening** An opening, conduit, or channel cast in place within concrete structural elements that provides for the passing through of pipe. The most typical usage is for short vertical conduit in concrete slabs to eliminate the subsequent drilling of core holes.

**Pipe rack** A structural frame that is used to support piping systems. (See assembly.)

**Pipe roll** A pipe hanger or support that utilizes a roller or bearing device to provide the ability for lateral axial movement in a piping system.

**Pipe saddle support** A pipe support that utilizes a curved section for cradling the pipe.

**Pipe shoe** A hanger or support (typically T shaped) attached to a pipe to transmit the load or forces to adjacent structural elements.

**Pipe size** Nominal pipe size, unless otherwise specified.

**Pipe sleeve** An opening, conduit, or channel cast in place within concrete structural elements that provides for the passing through of pipe. The most typical usage is for short vertical conduit in concrete slabs to eliminate the subsequent drilling of core holes. However, conduit or channel may be placed horizontally throughout a concrete structure to facilitate future access.

**Pipe sleeve, pipe sleeve hanger or support** An appliance or device that surrounds a pipe and connects to a hanger or support to provide for alignment and limited movement.

**Pipe slide** A hanger or support that incorporates a slide plate to accommodate horizontal pipe movement.

**Pipe strap** An attachment appliance used to connect a pipe directly to a structural element. (See pipe clip and pipe clamp.)

**Pipe support** A device or stanchion by which a pipe is carried or supported from beneath. In this position, the pipe load is in compression.

**Pipe system load** See specific load types: cold load, deadweight load, design load, dynamic load, friction load, hot load, hydrostatic load, operating load, seismic load, thermal load, thrust load, trip-out load, water hammer load, and wind load.

**Plate lug** See lug.

**Plating** An electroplating process whereby a metallic coating (e.g., copper, chrome, or zinc) is deposited on a substrate.

**Point loading** The point of application of a load between two surfaces. It typically describes the load point between a curved and a flat surface.

**Preset** Prior installation adjustment of hangers, supports assemblies, equipment, and devices.

**Protection saddle** A saddle that provides a protective covering or coating to prevent damage to pipe or to the insulation surrounding a pipe at hanger and support points.

**Protection shield** An appliance, which may be rigid or flexible, designed to protect pipe or insulation at contact points with hangers and supports.

**Random hanger** A hanger or support that requires field fabrication and the exact location, shape, and type of which are left to the discretion of the installer.

**Reservoir** An attachment or separate container used in conjunction with a fluid- (or gas-) using device (e.g., hydraulic) that provides a means to store or hold a supply of liquid (or gas) to provide for a reserve or otherwise ensure for an adequate or continuous supply of fluid (or gas).

**Restraint** An appliance, device, or equipment that prevents, resists, or limits unplanned or random movement.

**Restraining control device** A hydraulic, mechanical, spring, or other rigid or flexible hanger, support, or device used to control movement.

**Resilient support** A hanger, support, or device that provides for vertical, horizontal, lateral, or axial movement.

**Retaining strap** An appliance or device used in conjunction with clamps and other components to secure hangers and supports to structural elements.

**Rigid sway brace** Components added to a standard pipe support or hanger system to limit sway during movement such as a seismic event. The components include solid strut or pipe, pipe attachments, and attachment to the structure. Rigid bracing only requires one attachment per location because it works under tension and compression.

**Rigid hanger** A hanger or support that controls or limits vertical and horizontal movement.

**Rigid support** See rigid hanger.

**Rigging** Devices, including chain, rope, and cable, used to erect, support, and manipulate.

**Ring band** An appliance or device consisting of a strap (steel, plastic, or other material) formed in a circular shape with an attached knurled swivel nut used for vertical adjustment.

**Riser** An upright or vertical member, structural or otherwise.

**Riser clamp** An appliance or device used to provide connections to and support for upright or vertical members, structural or otherwise.

**Riser hanger** A hanger or support used in conjunction with a riser.

**Rod** A slender bar typically considered to have a circular cross-section, available in a variety of materials. (See threaded rod.)

**Rod coupling** An appliance or device used to join two rods. (See threaded rod coupling.)

**Rod hanger** A hanger or support that has an integrated rod as part of its construction.

**Rod stiffener** An appliance or device used to provide additional rigidity to a rod.

**Roll stand** A pipe roll mounted on a stand and used for support.

**Roll and plate** A combination of a pipe roll and a slide plate used for minimal lateral and axial movement where minimal or no vertical adjustment is required.

**Roll hanger** An appliance or device that utilizes a pipe roll for lateral and axial movement when used to carry a load in suspension or tension.

**Roll plate** A flat appliance, typically a steel or alloy plate, that permits movement and/or facilitates a sliding motion. (See slide plate.)

**Roll trapeze** A combination device utilizing a pipe roll and a trapeze hanger.

**Saddle** A curved appliance or device designed to cradle a pipe and used in conjunction with a hanger or support.

**Safety factor** The ultimate strength of a material divided by the allowable stress. It also refers to the ultimate strength of a device divided by the rated capacity.

**Scale plate** A device attached to hangers, supports, and assemblies to detect changes in load or movement.

**Seismic control device** An appliance or device used to provide structural stability in the event of a change in the steady-state environment affecting a building's structure, such as would occur with a natural event such as an earthquake or other violent action.

**Seismic load** The temporary stress or loading put on a piping system as the result of a change in the steady-state environment affecting a building's structure, such as would occur with a natural

event such as an earthquake or other violent action.

**Semi-engineered drawing** A mechanical drawing that details the elements and components of a piping system and incorporates a bill of material, load and movement data, and other general identification.

**Semi-engineered hanger assembly** A mechanical drawing that details the elements and components of a hanger assembly and incorporates a bill of material, load and movement data, and other general identification.

**Service conditions** Description of the operating environment and operating conditions, including operating pressures and temperatures.

**Shear lug** An appliance or device used primarily to transfer axial stress (shear stress) and load to a support element.

**Shield** See protection shield.

**Side beam bracket** A bracket designed to be mounted in a vertical position by attachment to a structural element. This bracket provides mounting capability for a hanger or support.

**Side beam clamp** A beam clamp that provides for an off-center attachment to the structural element.

**Significant movement** The calculated movement at a proposed support point for a hanger or support.

**Single acting** A descriptor for a mechanical device that provides resistance in either tension or compression cycles, but not both. (See double acting.)

**Single pipe roll** A pipe roll used in a trapeze hanger.

**Sleeper** A horizontal support, usually located at grade.

**Slide plate** A flat appliance, typically a steel or alloy plate, which permits movement and/or facilitates a sliding motion.

**Sliding support** An appliance or device that provides for frictional resistance to horizontal movement.

**Slip fitting** An appliance or device used to help align and provide for limited movement of a pipe. This device is used as an assembly component.

**Snubber** A hydraulic, mechanical, or spring device used to control shock and sway; a shock absorber.

**Special component** An appliance or device that is designed and fabricated on an as-required basis.

**Spider guide** An appliance or device used with insulated piping to maintain alignment during axial expansion and contraction cycles.

**Split ring** See hinged pipe clamp.

**Spring cushion hanger** A simple, noncalibrated, single-rod spring support used to provide a cushioning effect.

**Spring cushion roll** A pair of spring coils with retainers for use with a pipe roll.

**Spring hanger** An appliance or device using a spring or springs to permit vertical movement.

**Spring snubber** See spring sway brace.

**Spring sway brace** A spring device used to control vibration or shock or to brace against sway.

**Stanchion** A straight length of structural material used as a support in a vertical or upright position.

**Stop** An appliance or device used to limit movement in a specific direction.

**Strap** An attachment appliance used to connect a pipe directly to a structural element. (See pipe clip and pipe clamp.)

**Stress analysis** An analytical report that evaluates material, structural, or component stress levels.

**Strip insert** See continuous insert.

**Structural attachment** An appliance or device used to connect a hanger, support, or assembly to a structural element.

**Strut** A rigid tension/compression member.

**Strut clamp** An appliance or device used to secure a pipe to a strut.

**Support** A device that attaches to or rests on a structural element to carry a load in compression.

**Support drawing** See brace, hanger, or support drawing.

**Suspension hanger** See pipe hanger.

**Sway brace** See lateral brace or restraining control device.

**Swivel pipe ring** See ring band.

**Swivel turnbuckle** An appliance or device that provides flexibility and linear adjustment capability used in conjunction with hangers and supports. (See turnbuckle.)

**Thermal load** The stress or loading put on or introduced to a piping system as the result of regular or abrupt changes in the steady-state temperature

of the pipe contents or the surrounding environment.

**Threaded rod** A steel, alloy, plastic, or other material rod threaded along its full length. Threads may be rolled or cut.

**Threaded rod coupling** An appliance or device used to join two threaded rods.

**Three-bolt pipe clamp** A pipe clamp normally used for horizontal insulated piping that utilizes bolts to attach the clamp to the pipe and a separate load bolt to transfer the piping weight to the remainder of the pipe hanger assembly from a point outside the insulation (previously known as a double-bolt pipe clamp).

**Top beam clamp** A mechanical device used to connect, as a hanger or support, or used to hold part of a piping system to the top of a structural beam element (typically a steel beam). A clamp firmly holds multiple materials or devices together and does not require welding.

**Thrust load** The temporary stress or loading put on a piping system as the result of a change in the steady-state operating environment of the pipe contents due to regular or abrupt changes associated with equipment or mechanical devices such as the discharge from a safety valve, relief valve, pump failure, or failure of some other mechanical device or element.

**Transverse brace** See lateral brace.

**Trapeze hanger** A pipe hanger consisting of parallel vertical rods connected at their lower ends by a horizontal member that is suspended from a structural element. This type of hanger often is used where an overhead obstruction is present or where insufficient vertical space is available to accommodate a more traditional hanger or support.

**Travel device** A hanger or support device that accommodates piping movement.

**Travel indicator** See constant support hanger indicator and variable spring hanger indicator.

**Travel scale** A device attached to a spring unit to measure vertical movement.

**Travel stop** A device that temporarily locks moveable parts in a fixed position, enabling a load to be transferred to a supporting structural element during installation and testing phases.

**Trip-out load** The temporary stress or loading put on a piping system as the result of a change in the steady-state flow of the pipe contents due to the change associated with equipment or mechanical devices such as a turbine or pump.

**Turnbuckle** A device with one left-hand female threaded end and one right-hand female threaded end, used to join two threaded rods and provide linear adjustment.

**Two-way brace** A brace designed to control movement in two directions. (See lateral brace and longitudinal brace.)

**U-bolt** A U-shaped rod with threaded ends that fits around a pipe and is attached to a structural element or a supporting member.

**Vapor barrier** An uninterrupted, nonpermeable material used as a cover for insulated pipe to exclude moisture from the insulation.

**Variability** The load variation of a variable-spring hanger divided by the hot load expressed as a percentage.

**Variable-spring hanger** A spring coil device that produces varying support while permitting vertical movement.

**Variable-spring hanger indicator** A device attached to a variable-spring hanger that measures vertical pipe movement.

**Velocity limited** A term relating to snubbers in which velocity is the means of control.

**Vibration control device** An appliance used to reduce and/or control the transmission of vibration to structural elements.

**Vibration isolation device** See vibration control device.

**Water hammer load** The temporary stress or loading put on a piping system as the result of a change, abrupt or otherwise, in the steady-state flow of the pipe contents.

**Welded beam attachment** A U-shaped, flat-bar appliance, normally welded to a steel beam, used to connect a hanger, support, or assembly.

**Welded pipe attachment** The use of a weld to attach a pipe to a hanger, support, or assembly.

**Weldless eye nut** A forged steel appliance that provides an attachment point for a threaded hanger rod to a bolt or pin connection.

**Wire hook** A type of hanger or support that is simply a bent piece of heavy wire.

**Wind load** The temporary or steady-state stress or loading put on or added to a piping system as the result of a change in environmental conditions such as increased steady state or alternating air movement. Usually refers to piping systems in environmentally exposed conditions.



# 7 Vibration Isolation

In modern commercial construction, due to space restrictions, HVAC and plumbing system-related equipment often is placed near occupied space, but such equipment generates noise and vibration while running that is irritating or unacceptable to tenants. In the past, a very critical installation on an upper floor could be achieved by allowing not more than 10 percent vibration transmission. Thick, stiff concrete floors and walls in old buildings could withstand and absorb such significant machinery vibration and noise. However, today's lighter structures are not as capable of shielding equipment vibration, and designs require a greater precision to allow no more than a 1 percent or 2 percent transmissibility. Installations that were satisfactory in the past are no longer acceptable by modern standards. Noise levels now must be controlled to the extent that equipment noise does not add to the noise level of any building area.

Tests have been conducted to establish acceptable noise criteria for different types of occupancies. These noise criteria (NC) curves take into consideration an individual's sensitivity to both the loudness and frequency of noise. This studied criteria is very prevalent in more sensitive environments such as schools, hospitals, and performance venues where the disturbance hinders the acceptable environment. A similar criterion in vibration analysis shows that in certain facilities, such disturbance has a dramatic effect on the neurological path-fire of tenants.

The only acceptable solution is to analyze the structure and equipment, not just as individual pieces, but as a total system during design. Every element must be carefully considered to ensure a satisfactory end product. It is impossible to separate vibration and noise issues, but taking a conscientious design approach can eliminate most problems.

## TERMINOLOGY

Following are some common factors found in vibration isolation theory formulas.

### Vibration Isolator

A vibration isolator is a pliant, or resilient, material that is placed between the equipment or machinery and the building structure to create a low, natural frequency support system for the equipment. Common materials are cork, elastomers, neoprene rubber, and steel springs.

### Static Deflection

Static deflection ( $d$ ) reflects how much the isolator deflects under the weight of the equipment. It is measured in inches (mm).

### Natural Frequency

Natural frequency ( $f_n$ ) is the frequency at which the vibration isolator naturally oscillates when compressed and released rapidly. It is measured in cycles per minute (cpm) (Hz).

### Disturbing Frequency

Generated by the equipment, disturbing frequency ( $f_d$ ) is the lowest frequency of vibration. It is measured in cycles per minute (cpm) (Hz).

### Resonant Amplification

Resonant amplification occurs when the natural frequency of the isolators and the disturbing frequency equal one another.

### Transmissibility

Also known as frequency or efficiency quotient ( $E_q$ ), transmissibility is the ratio ( $f_d/f_n$ ) of the maximum force to the supporting structure, due to the vibration of a machine, to the maximum machine force.

Percent transmissibility ( $T$ ) is the percentage of the maximum force given to the building's structure through the isolators.

### Damping

Damping is the capacity of a material to absorb vibration by essentially acting as the brakes for equipment mounted on isolators by reducing or stopping motion through friction or viscous resistance.

## THEORY OF VIBRATION CONTROL

A very simple equation is used to determine the transmission of steady-state vibration, the constantly repeating sinusoidal wave form of vibration generated by such equipment as compressors, engines, and pumps.

### Equation 7-1

$$T = \frac{F_t}{F_d} = \frac{1}{(f_d/f_n)^2 - 1}$$

where

T = Transmissibility

F<sub>t</sub> = Force transmitted through the resilient mountings

F<sub>d</sub> = Unbalanced force acting on the resiliently supported system

f<sub>d</sub> = Frequency of disturbing vibration, cpm (Hz)

f<sub>n</sub> = Natural frequency of the resiliently mounted system, cpm (Hz)

This equation is exact for steel springs because they have straight-line load deflection characteristics and negligible damping. When the equation is used for organic materials, the following corrections normally give conservative results: For rubber and neoprene, use 50 percent of the static deflection when calculating the natural frequency, and for cork, use 1.5 times the natural frequency determined by actual test.

The natural frequency of a resiliently mounted system is the frequency at which it will oscillate by itself if a force is exerted on the system and then released. The natural frequency of the resiliently mounted system can be calculated using the following equation.

### Equation 7-2

$$f_n = \frac{188}{(1/d)^{1/2}}$$

where

d = Static deflection of the resilient mounting, inches (mm)

When using Equation 7-2 in international standard (SI) units, the 188 multiplying factor should be changed to 947.5.

The static deflection can be obtained from the following expression.

### Equation 7-3

$$d = \frac{W}{k}$$

where

W = Weight on the mounting, pounds (kg)

k = Stiffness factor of the mounting of deflection, pounds per inch (kg/mm)

The natural frequency of a resiliently mounted system can be illustrated by suspending a weight from a very long rubber band. If the weight is pulled down slightly and released, it will oscillate up and down at the natural frequency of the system. A longer rubber band will produce more deflection than a shorter one. Systems with more deflection have lower natural frequencies than those with less deflection. The importance of this can be seen by examining Equation 7-1 rewritten in the following form.

### Equation 7-4

$$F_t = F_d \left[ \frac{1}{(f_d/f_n)^2 - 1} \right]$$

A system may have up to six natural frequencies. In the practical selection of machine mountings, if the vertical natural frequency of the system is decreased to allow for a low transmissibility, the horizontal and rotational natural frequencies generally will be lower than the vertical and can be disregarded, except for machines with very large horizontal, unbalanced forces or with large unbalanced moments, such as horizontal compressors and large two-, three-, and five-cylinder engines.

Obviously, the transmitted force should be minimized. Since the disturbing force is a function of the machine's characteristics and cannot be reduced, except by dynamic balancing of the machine—or by reducing the operating speed, which is seldom practical—the transmitted force can be reduced only by minimizing the function  $1/[(f_d/f_n)^2 - 1]$ .

This can be accomplished only by increasing the frequency ratio ( $f_d/f_n$ ). However, since the disturbing frequency is fixed for any given machine and is a function of the revolutions per minute (rpm), it seldom can be changed. The only remaining variable is the mounting natural frequency. Reducing the natural frequency by increasing the static deflection of the resilient mountings reduces the vibration transmission. This explains why the efficiency of machinery mountings increases as their resiliency and deflection increase.

Figure 7-1 shows the effect of varying frequency ratios on the transmissibility. Note that for frequency ratios less than two, the use of mountings actually increases the transmissibility above what would result if no isolation were used and the machine were bolted down solidly. In fact, if careless selection results in a mounting with the natural frequency equal to or nearly equal to the disturbing frequency, a very serious condition called resonance occurs. In Equation 7-4, the denominator of the transmissibility function becomes zero, and the transmitted force theoretically becomes infinite. As the frequency ratio

increases beyond two, the resilient mountings reduce the transmitted force.

Figure 7-2 shows a chart that can be used to select the proper resilient mountings when the following job characteristics are known: weight per mounting, disturbing frequency, and design transmissibility. The chart shows the limitations of the various types of isolation materials, data that is particularly helpful in selecting the proper media.

## TYPES OF VIBRATION AND SHOCK MOUNTINGS

### Cork

Cork is the original vibration and noise isolation material and has been used for this purpose for at least 100 years. The most widely used form of cork today is compressed cork, which is made of pure granules of cork without any foreign binder and is compressed and baked under pressure to an accurately controlled density. Cork can be used directly under machines, but its widest applications are under concrete foundations. It is not affected by oils, acids normally encountered, or temperatures between 0°F and 200°F (-17.8°C and 93.3°C) and does not rot under continuous cycles of moistening and dryness. However, it is attacked by strong alkaline solutions.

Cork under concrete foundations still giving good service after 20 years indicates that the material has a long, useful life when properly applied. Cork is fairly good as a low-frequency shock absorber, but its use as a

**Table 7-1 The Relative Effectiveness of Steel Springs, Rubber, and Cork in the Various Speed Ranges**

Range	RPM	Springs	Rubber	Cork
Low	Up to 1200	Required	Not recommended	Unsuitable except for shock <sup>a</sup>
Medium	1200–1800	Excellent	Fair	Not recommended
High	Over 1800	Excellent	Good	Fair to good for critical jobs

<sup>a</sup> For noncritical installations only; otherwise, springs are recommended.

vibration isolator is limited to frequencies above 1,800 cpm. Cork has good sound insulation characteristics. Because of the large amount of damping in cork, the natural frequency cannot be computed from the static deflection and must be determined in tests by vibrating the cork under different loads to determine the resonance frequency, which establishes the natural frequency of the material. The limiting values for cork given in Figure 7-2 were determined in this manner.

### Elastomers and Neoprene Rubber


Elastomers having very good sound insulation characteristics are acceptable for low-frequency shock absorption and are useful as vibration isolators for frequencies above 1,200 cpm. Static deflection typical to elastomers is from 0.05 inch to 0.15 inch (1 mm to 4 mm). Typical elastomer mountings are illustrated in Figure 7-3. The temperature range of natural rubber is 50°F to 150°F (10°C to 65.6°C), and that of neoprene is 0°F to 200°F (-17.8°C to 93.3°C).

Neoprene rubber is recommended for applications with continuous exposure to oil. Special elastomer compounds are available to meet conditions beyond those cited. Elastomers tend to lose resiliency as they age. The useful life of elastomer mountings is about seven years under nonimpact applications and about

five years under impact applications, though they retain their sound insulation value for much longer. Individual molded elastomer mountings generally are economical only with light- and medium-weight machines, since heavier capacity mountings approach the cost of the more efficient steel spring isolators. Pad-type elastomer isolation has no such limitations.

### Steel Spring Isolators

Steel spring isolators provide the most efficient method of isolating vibration and shock, approaching 100 percent effectiveness. The higher efficiency is due to the greater deflections they provide. Standard steel spring isolators, such as those shown in Figure 7-4, provide deflections up to 5 inches (127 mm) compared to about ½ inch (12.7 mm) maximum for rubber and other materials. Special steel spring isolators can provide deflections up to 10 inches (254 mm). Since the performance of steel springs fol-



**Figure 7-1 Transmissibility vs. Frequency Ratio**

Note: This curve applies to steel spring isolators and other materials with very little damping.

**SPRING DEFLECTION AND NATURAL FREQUENCY** — What deflection and natural frequency are obtained with a 300 lb. load on a spring whose constant is 280 lbs. per inch?  
 Answer: Vertical line from 280 on K scale intersects 300 lbs. weight diagonal line at B. Horizontal line from B intersects  $\delta$  scale at 1.1" deflection and  $f_N$  scale at 180 CPM.

**TRANSMISSIBILITY** — What is the transmissibility of a system having a natural frequency of 180 CPM and being disturbed by vibrations of 600 CPM frequency?  
 Answer: Vertical line from 600 on  $f_D$  scale, and horizontal line from 180 on  $f_N$  scale intersects at A on 10% transmissibility diagonal scale.

Here are typical problems which can be solved with this calculator.

**NATURAL FREQUENCY AND SPRING DEFLECTION** — What natural frequency and spring deflection are required to isolate a disturbing frequency of 600 CPM with a transmissibility of 10%?  
 Answer: Vertical line from 600 on  $f_D$  scale intersects 10% transmissibility diagonal line at A. Horizontal line from A intersects  $f_N$  scale at 180 CPM and  $\delta$  scale at 1.1" deflection.

**SPRING CONSTANT** — What spring constant is required to give a deflection of 1.1" for a load of 300 lbs.?  
 Answer: Horizontal line from 1.1" on  $\delta$  scale intersects 300 lbs. weight diagonal line at B. Vertical line from B intersects K scale at 280 LBS. PER INCH.




Figure 7-2 Calculator for Vibration Isolation

Here are typical problems which can be solved with this calculator.

**NATURAL FREQUENCY AND SPRING DEFLECTION** — What natural frequency and spring deflection are required to isolate a disturbing frequency of 600 CPM with a transmissibility of 10%?

**Answer:** Vertical line from 600 on  $f_D$  scale intersects 10% transmissibility diagonal line at A. Horizontal line from A intersects  $f_N$  scale at 180 CPM and  $\delta$  scale at 27.9 mm deflection.

**SPRING CONSTANT** — What spring constant is required to give a deflection of 27.9 mm for a load of 136.2 kg?

**Answer:** Horizontal line from 27.9 mm on  $\delta$  scale intersects 136.2 kg weight diagonal line at B. Vertical line from B intersects K scale at 5 kg/mm.

**SPRING DEFLECTION AND NATURAL FREQUENCY** — What deflection and natural frequency are obtained with a 136.2 kg load on a spring whose constant is 5 kg/mm?

**Answer:** Vertical line from 5 on K scale intersects 136.2 weight diagonal line at B. Horizontal line from B intersects  $\delta$  scale at 27.9 deflection and  $f_N$  scale at 180 CPM.

**TRANSMISSIBILITY** — What is the transmissibility of a system having a natural frequency of 180 CPM and being disturbed by vibrations of 600 CPM frequency?

**Answer:** Vertical line from 600 on  $f_D$  scale, and horizontal line from 180 on  $f_N$  scale intersects at A on 10% transmissibility diagonal scale.




Figure 7-2(M) Calculator for Vibration Isolation

lows the vibration control equations very closely, their performance can be predetermined very accurately, eliminating costly trial and error, which is sometimes necessary in other materials.

Steel spring isolators are available in static deflections from 0.75 inch to 6.0 in (19 to 152 mm), yielding natural frequencies from 4 Hz to 1.3 Hz with open steel spring isolators. (Restrained steel spring isolators have different capacity levels than open steel spring isolators.) Most steel spring isolators are equipped with built-in leveling bolts, which eliminates the need for shims when installing machinery. The more rugged construction possible in steel spring isolators provides for a long life, usually equal to that of the machine itself. Since high-frequency noises sometimes tend to bypass steel springs, rubber sound isolation pads usually are used under spring isolators to stop such transmission into the floor on critical installations.

Table 7-1 tabulates the useful ranges of cork, rubber, and steel springs for different equipment speeds.

## APPLICATIONS

Properly designed mountings permit the installation of heavy mechanical equipment in penthouses and on roofs directly over offices and sleeping areas. Such upper-floor installations offer certain operating economies and release valuable basement space for garaging automobiles. However, when heavy machinery is installed on upper floors, great care must be taken




Figure 7-4 Typical Steel Spring Mounting




Figure 7-3 Typical Elastomer and Elastomer-Cork Mountings: (A) Compression and Shear Elastomer Floor Mounting; (B) Elastomer Hanger for Suspended Equipment and Piping; (C) Elastomer/Cork Mounting; (D) Elastomer/Cork Mounting with Built-In Leveling Screw

to prevent vibration transmission, which often shows up many floors below when a wall, ceiling, or even a lighting fixture has the same natural frequency as the disturbing vibration. The result of such resonance vibration is a very annoying noise.

Efficient mountings permit lighter, more economical construction of new buildings and prevent difficulties when machinery is installed on concrete-filled, ribbed, metal deck floors. They also permit the installation of heavy machinery in old buildings that were not originally designed to accommodate such equipment.

Vibration and noise transmission through piping is a serious problem. When compressors are installed on resilient mountings, provision should be made for flexibility in the discharge and intake piping to reduce vibration transmission. This can be accomplished either through the use of flexible metallic hose (which must be of adequate length and very carefully installed in strict accordance with the manufacturer's specifications) or by providing for flexibility in the piping itself

by running the piping for a distance equal to 15 pipe diameters, both vertically and horizontally, before attaching the piping to the structure. Additional protection is provided by suspending the piping from the building on resilient mountings.

Effective vibration control for machines is usually quite inexpensive, seldom exceeding 3 percent of the equipment cost. In many cases, resilient mountings pay for themselves immediately by eliminating special machinery foundations or the need to bolt equipment to the floor. It is much cheaper to prevent vibration and structural noise transmission by installing mountings when the equipment is installed than it is to go back later and try to correct a faulty installation. Resilient machinery mountings should not be considered a panacea for noise transmission problems. They have a definite use in the overall solution of noise problems, and their intelligent use can produce gratifying results at low cost.





# 8 Grease Interceptors

The purpose of a grease interceptor is to intercept and collect grease from a commercial or institutional kitchen's wastewater passing through the device, thereby preventing the deposition of pipe-clogging grease in the sanitary drainage system and ensuring free flow at all times. Grease interceptors are installed in locations where liquid wastes contain grease. These devices are required to receive the drainage from fixtures and equipment with grease-laden wastes located in food preparation facilities such as restaurants, hotel kitchens, hospitals, school kitchens, bars, factory cafeterias, and clubs. Fixtures and equipment include pot sinks, soup kettles or similar devices, wok stations, floor drains or sinks into which kettles are drained, automatic hood wash units, pre-rinse sinks, and dishwashers without grinders. Residential dwellings seldom discharge grease in such quantities as to warrant a grease interceptor.

Grease interceptors typically come in one of two basic types. The first type is called a hydromechanical grease interceptor (HGI), previously referred to as a grease trap. These are prefabricated steel manufactured units, predominately located indoors at a centralized location in proximity to the fixtures served or at the discharging fixture point of use. They are relatively compact in size and utilize hydraulic flow action, internal baffling, air entrainment, and a difference in specific gravity between water and FOG (fats, oils, and grease) for the separation and retention of FOG from the fixture waste stream. The standard governing the installation, testing, and maintenance of HGIs is PDI G101: *Testing and Rating Procedure for Hydro Mechanical Grease Interceptors*.

The second type is the gravity grease interceptor (GGI). These are engineered, prefabricated, or field-formed concrete-constructed units that typically are located outside due to their large size and receive FOG discharge waste from all required fixtures within a given facility. These units essentially utilize gravity flow and retention time as the primary means of separating FOG from the facility waste stream prior to it entering the municipal drainage system. The

standard for the design and construction of gravity grease interceptors is IAPMO/ANSI Z1001: *Prefabricated Gravity Grease Interceptors*.

Other FOG retention and removal equipment can be categorized as grease removal devices (GRDs) and FOG disposal systems (FDSs).

Note: It is important for the plumbing engineer to understand that the topic of FOG retention and removal is a continuing and ever-changing evolution of both technology and the latest equipment available at the time. Types of interceptors currently on the market may be proprietary in nature and may include features specifically inherent to one particular manufacturer. The purpose of the equipment descriptions contained in this chapter is to expose the reader to the basic types of FOG treatment equipment presently available as they currently are defined and listed within model codes. The text is not intended to imply that any one particular type of device is superior to another for a given application. That being the case, the plumbing engineer must exercise care when proposing to specify FOG treatment equipment that could be considered proprietary, in conjunction with a government-controlled or publicly funded project that may prohibit the specifying of such equipment due to a lack of competition by other manufacturers.

## PRINCIPLES OF OPERATION

Most currently available grease interceptors operate on the principle of separation by flotation alone (GGI) or fluid mechanical forces in conjunction with flotation (HGI).

The performance of the system depends on the difference between the specific gravity of the water and that of the grease. If the specific gravity of the grease is close to that of the water, the globules will rise slowly. If the density difference between the grease and the water is larger, the rate of separation will be faster.

Since the grease globules' rise rate is inversely proportional to the viscosity of the wastewater, the rate of separation will be faster when the carrier

fluid is less viscous and vice versa. Grease globules rise more slowly at lower temperatures and more rapidly at higher temperatures. Grease, especially when hot or warm, has less drag, is lighter than water, and does not mix well with water. The final velocity for a spherical particle, known as its floating velocity, may be calculated using Newton's equation for the frictional drag with the driving force, shown in Equation 8-1.

**Equation 8-1**

$$\frac{C_d A p v^2}{2} = (p_1 - p) g V$$

This yields the following mathematical relationship:

**Equation 8-2**

$$v = \sqrt{\frac{4}{3} \frac{g}{C_d} \frac{p_1 - p}{p} D}$$

where

- $C_d$  = Drag coefficient
- $A$  = Projected area of the particle,  $pD^2/4$  for a sphere
- $v$  = Relative velocity between the particle and the fluid
- $p$  = Mass density of the fluid
- $p_1$  = Mass density of the particle
- $g$  = Gravitational constant, 32.2 ft/s/s
- $D$  = Diameter of the particle
- $V$  = Volume of the particle,  $13pr^3$  for a sphere ( $r$  = radius of the particle)

Experimental values of the drag coefficient have been correlated with the Reynolds number, a dimensionless term expressing the ratio of inertia and viscous forces. (Note: Equation 8-2 applies to particles with diameters 0.4 inch [10 mm] or smaller and involving Reynolds numbers less than 1. For larger diameters, there is a transition region; thereafter, Newton's law applies.) The expression for the Reynolds number,  $R = r v D/m$ , contains, in addition to the parameters defined above, the absolute viscosity. The drag coefficient has been demonstrated to equal  $24/R$  (Stokes' law). When this value is substituted for  $C_d$  in Equation 8-2, the result is the following (Reynolds number < 1):

**Equation 8-3**

$$v = \frac{g (p_1 - p) D^2}{18m}$$

The relationship in Equation 8-3, which identifies the principle of separation in a gravity grease interceptor, has been verified by a number of investigations for spheres and fluids of various

types. An examination of this equation shows that the vertical velocity of a grease globule in water depends on the density and diameter of the globule, the density and viscosity of the water, and the temperature of the water and FOG material. Specifically, the grease globule's vertical velocity is highly dependent on the globule's diameter, with small globules rising much more slowly than larger ones. Thus, larger globules have a faster rate of separation.

The effect of shape irregularity is most pronounced as the floating velocity increases. Since grease particles that need to be removed in sanitary drainage systems have slow floating velocities, particle irregularity is of small importance.

Figure 8-1 shows the settling velocities of discrete spherical particles in still water. The heavy lines are for settling values computed using Equation 8-3 and for drag coefficients depending on the Reynolds number. Below a Reynolds number of 1, the settlement is according to Stokes' law. As noted above, as particle sizes and Reynolds numbers increase, there is first a transition stage, and then Newton's law applies. At water temperatures other than 50°F (10°C), the ratio of the settling velocities to those at 50°F (10°C) is approximately  $(T + 10)/60$ , where  $T$  is the water temperature. Sand grains and heavy floc particles settle in the transition region; however, most of the particles significant in the investigation of water treatment settle well within the Stokes' law region. Particles with irregular shapes settle somewhat more slowly than spheres of equivalent volume. If the volumetric concentration of the suspended particles exceeds about 1 percent, the settling is hindered to the extent that the velocities are reduced by 10 percent or more.

Flotation is the opposite of settling insofar as the densities and particle sizes are known.




Figure 8-1 Rising and Settling Rates in Still Water




Figure 8-2 Cross-Section of a Grease Interceptor Chamber

### Retention Period

The retention period ( $P$ ) is the theoretical time that the water is held in the grease interceptor. The volume of the tank for the required retention period can be computed as follows:

#### Equation 8-4

$$V = \frac{QP}{7.48}$$

As an example of the use of Equation 8-4, for a retention period ( $P$ ) equal to two minutes and a flow rate ( $Q$ ) of 35 gallons per minute (gpm), the tank volume is:

$$V = (35 \times 2) / 7.48 = 9.36 \text{ ft}^3$$

Retention periods should be based on peak flows. In International Standard (SI) units, the denominator in Equation 8-4 becomes approximately unity (1).

### Flow-Through Period

The actual time required for the water to flow through an existing tank is called the flow-through period. How closely this flow-through period approximates the retention period depends on the tank. A well-designed tank should provide a flow-through period of at least equal to the required retention period.

### Factors Affecting Flotation in the Ideal Basin

When designing the ideal separation basin, four parameters dictate effective FOG removal from the water: grease/oil droplet size distribution, droplet velocity, grease/oil concentration, and the condition of the grease/oil as it enters the basin. Grease/oil can be present in five basic forms: oil-coated solids, free oil, mechanically emulsified, chemically emulsified, and dissolved. When designing the ideal basin, consider only free grease/oil.

The ideal separation basin is one that has no turbulence, short-circuiting, or eddies. The flow through the basin is laminar and distributed uniformly throughout the basin's cross-sectional area. The surface-loading rate is equal to the overflow rate. Free oil is separated due to the difference in specific gravity between the grease/oil globule and the water. Other factors affecting the design of an ideal basin are influent concentration and temperature.

It is important to evaluate and quantify a basin design both analytically and hydraulically. Figure 8-2 shows a cross-section of a basin chamber. The basin chamber is divided into two zones: liquid treatment zone and surface-loading area (grease/oil mat). The mat zone is that portion of the basin where the separated grease/oil is stored.  $L$  is the length of the chamber or basin, and  $D$  is the liquid depth or the maximum distance the design grease/oil globule must rise to reach the grease mat.  $V_h$  is the horizontal velocity of the water, and  $V_t$  is the vertical rise rate of the design grease/oil globule.

As noted, the separation of grease/oil from water by gravity differential can be expressed mathematically by Stokes' law, which can be used to calculate the rise rate of any grease/oil globule on the basis of its size and density and the density and viscosity of the water. (See Figure 8-1 for the rise rate versus globule size at a fixed design temperature.)

The primary function of a grease interceptor is to separate free-floating FOG from the wastewater. Such a unit does not separate soluble substances, and it does not break emulsions. Therefore, it never should be specified for these purposes. However, like any settling facility, the interceptor presents an environment in which suspended solids are settled coincident with the separation of the FOG in the influent.




Figure 8-3 Trajectory Diagram

The ability of an interceptor to perform its primary function depends on a number of factors. These include the type and state of FOG in the waste flow, the characteristics of the carrier stream, and the design and size of the unit. Due to the reliance on gravity differential phenomena, there is a practical limitation to interceptor effectiveness. In terms of grease/oil globule size, an interceptor will be effective over a globule diameter range having a lower limit of 0.015 centimeter (150 microns).

Gravity separation permits the removal of particles that exhibit densities different from their carrier fluid. Separation is accomplished by detaining the flow stream for a sufficient time to permit particles to separate out. Separation, or retention, time ( $T$ ) is the theoretical time that the water is held in the basin. A basin must be designed such that even if the grease/oil globule enters the chamber at the worst possible location (at the bottom), there will be enough time for the globule to rise the distance needed for capture (see Figure 8-3). If the grease/oil globule rate of rise ( $V_t$ ) exceeds the retention time required for separation, the basin will experience pass-through or short-circuiting. Retention time can be expressed as:

**Equation 8-5**

$$V = QT$$

where

- V = Volume of basin
- Q = Design flow
- T = Retention time

As previously noted, particles that rise to the surface of a liquid are said to possess rise rates, while particles that settle to the bottom exhibit settling rates. Both types obey Stokes' law, which establishes the theoretical terminal velocities of the rising and/or settling particles. With a value of 0.015 centimeter for the diameter ( $D$ ) of the globule, the rate of rise of oil globules in wastewater may be expressed in feet per minute as:

**Equation 8-6**

$$V_t = \frac{0.0241 (S_w - S_o)}{u}$$

where

- $V_t$  = Rate of rise of oil globule (0.015 centimeter in diameter) in wastewater, feet per minute
- $S_w$  = Specific gravity of wastewater at design temperature of flow
- $S_o$  = Specific gravity of oil in wastewater at design temperature of flow
- $u$  = Absolute viscosity of wastewater at design temperature, poises

**Grease Interceptor Design Example**

The following example illustrates the application of the above equations for the design of a grease interceptor.

Without additional data describing the distribution of oil droplets and their diameters within a representative wastewater sample, it is not possible to quantitatively predict the effect that increased interceptor size or reduced flow and subsequent increased retention time within the grease interceptor will have on the effluent concentration of the interceptor. However, experimental research on oil droplet rise time (see Table 8-1) illustrates the effect that increased interceptor size or reduced flow and subsequent increased retention time within the grease interceptor will have on oil droplet removal. Following the logic in Table 8-1 allows the designer to improve the grease interceptor by increasing the interceptor volume or reducing flow and subsequently lowering horizontal velocity and increasing retention time within the grease interceptor.

Other data for this example is as follows:

- Specific gravity of grease/oil in wastewater: 0.9 (average)
- Temperature of wastewater and oil mixture: 68°F (average)
- Rate of rise of oil globules in wastewater: use Equation 8-6

**Table 8-1 Droplet Rise Time**

Travel Time for 3-inch Distance at 688°F (hr:min:sec)	
Droplet Diameter (microns)	Oil (rise time) SG 0.85
300	0:00:12
150	0:00:42
125	0:01:00
90	0:01:54
60	0:04:12
50	0:06:18
40	0:09:36
30	0:17:24
20	0:38:46
15	1:08:54
10	2:35:02
5	10:02:09
1	258:23:53
Droplet Diameter (microns)	Oil (rise time) SG 0.90
300	0:00:15
150	0:01:03
125	0:01:27
90	0:02:54
60	0:06:36
50	0:09:18
40	0:14:24
30	0:25:48
20	0:58:08
15	1:43:22
10	3:52:33
5	15:30:14
1	387:35:49

- Dimensions of a typical 20-gpm capacity grease interceptor:

Capacity: 21.33 gallons

Dimensions: 22 inches long, 14 inches wide, 20 inches high

Fluid level: 16 inches

Flow rate: 20 gpm

Inlet/outlet: 2 inches

- Grease interceptors are to operate when completely full and when the interceptor is in a horizontal position.
- Inlet and outlet pipes are running full, and the interceptor is fully charged.
- Grease/oil globules must rise a minimum distance of 3 inches from a point at the bottom of the inlet head of the interceptor to a point directly below the interceptor effluent outlet.

#### *Solution*

First, determine the rate of rise of oil globules: 150 micron = 0:01:03 minutes.

Then determine the wastewater flow rate through a 20-gpm capacity grease interceptor:

- $V_h = L/T = 1.83 \text{ ft}^2/1.03 \text{ minutes} = 1.776 \text{ ft/min}$
- Wetted cross-sectional area of the separation basin:  $W \times H = 14 \text{ in.} \times 16 \text{ in.} = 224 \text{ in.}^2 \times 6.944 \times 10^{-3} = 1.55 \text{ ft}^2$
- Wastewater flow rate:  $1.55 \text{ ft}^2 \times 1.776 \text{ ft/min} = 2.76 \text{ ft}^3/\text{min} \times 7.48 = 20.66 \text{ gpm}$

This example proves the critical elements in designing the ideal basin. Grease/oil droplet size and velocity determine the minimum outlet elevation needed to capture the targeted grease/oil globule. This also establishes retention time as a key element in the design of a basin.

The hydraulic environment of the separation chamber of the grease interceptor induces the separation of grease/oil and the deposition of solids. Stokes' law governs the rise and fall rates of an oil droplet or solid particle in the fluid stream.

The principles of flotation discussed above are applicable strictly to particles that are separate and distinct. If the wastewater mixture contains variously sized grease/oil droplets and solid particles distributed throughout the mixture, each droplet will (in accordance with Stokes' law) rise toward the surface or fall to the bottom at a rate depending on its own diameter.

In strong concentrations of very small particles, as in turbid waters, hindered flotation takes place. This condition means that the faster-rising particles collide with the slower-rising particles with more or less agglomeration due to adhesion. The resulting larger particles float faster. These coalesce into larger droplets with a higher rate of rise. The odds of such a collision depend on the droplet size distribution and the quantity of droplets in the mixture. This condition is particularly noticeable where the suspended particles are highly flocculent (i.e., composed of masses of very finely divided material). Therefore, a tank that is deep enough to permit agglomeration will have a blanket (or mass) of flocculent material receiving the suspended solids from the material rising from below or from the currents passing through it. Thus, the tank will lose masses of the agglomerated solids to the storage space above.

While varying flotation rates among the particles are probably the most important factor in agglomeration, the varying liquid velocities throughout the tank have a similar effect, causing fast-moving particles to collide with slower-moving particles. Since flocculation can be assumed to continue throughout the entire flotation period, the amount of flocculation depends on the detention period. Accordingly, with a given overflow rate, a tank of considerable depth should be more efficient than a shallow unit. On the other hand,

a decrease in the overflow rate might have the same effect. A flotation test might determine the point of agglomeration for a known water sample.

**PRACTICAL DESIGN**


While acquaintance with the theory of flotation is important to the engineer, several factors have pre-

vented the direct application of this theory to the design of grease interceptors. Some turbulence is unavoidable at the inlet end of the tank. This effect is greatly reduced by good inlet design (including baffling) that distributes the influent as uniformly as practicable over the cross-section of the tank. There is also some interference with the streamline flow at


the outlet, but this condition is less pronounced than the inlet turbulence and is reduced only by using overflow weirs or baffles. Density currents are caused by differences in the temperature, the density of the incoming wastewater, and the interceptor's contents. Incoming water has more suspended matter than the partially clarified contents of the tank. Therefore, the influent tends to form a relatively rapid current along the bottom of the tank, which may extend to the outlet. This condition is known as short-circuiting and occurs even with a uniform collection at the outlet end.

Flocculation of suspended solids has been mentioned. Its effects, however, are difficult to predict.


In general, the engineer depends on experience as well as the code requirements of the various local health departments for the preferred retention and overflow rates. Depth already has been discussed as having some effect on the tank's efficiency. A smaller depth provides a shorter path for the rising particle to settle, which gives the basin greater efficiency as the surface-loading rates match the overflow rates based on a given retention time. The tank's inlets and outlets require careful consideration by the designer. The ideal inlet reduces the inlet velocity to prevent the pronounced currents toward the outlet, distributes the inlet water as uniformly as practical over the cross-section of the tank, and mixes the inlet water with the water already in the tank to prevent the entering water from short-circuiting toward the outlet.



(A)



(B)



(C)

**Figure 8-4 (A) Hydromechanical Grease Interceptor; (B) Timer-controlled Grease Removal Device; (C) FOG Disposal System**

**GREASE INTERCEPTOR TYPES**

**Hydromechanical Grease Interceptors**

For more than 100 years, grease interceptors have been used in plumbing drainage systems to prevent grease accumulations from clogging interconnecting sanitary piping and sewer lines. However, it wasn't until 1949 that a comprehensive standard for the basic testing and rating requirements for hydromechanical grease interceptors was developed. This standard is known as PDI G101. It has been widely recognized and is referenced in most plumbing codes, replicated in ASME A112.14.3: *Grease Interceptors*, referred to in manufacturers' literature, and included in the basic testing and rating requirements of Military Specification

MIL-T-18361. A specifying engineer or purchaser of a hydromechanical grease interceptor can be assured that the interceptor will perform as intended when it has been tested, rated, and certified in conformance with PDI G101, ASME A112.14.3, and ASME A112.14.4: *Grease Removal Devices*.

Conventional manually operated hydromechanical interceptors (see Figure 8-4A) are extremely popular and generally are available with a rated flow capacity up to 100 gpm (6.31 L/s) for most applications. For flow rates above 100 gpm (6.31 L/s), large capacity units up to 500 gpm (31.5 L/s) commonly are used. The internal designs of these devices are similar. The inlet baffles, usually available in various styles and arrangements, act to ensure at least 90 percent efficiency of grease removal through the HGI, per PDI G101 testing requirements for units of 100 gpm and less. Care should be taken to avoid long runs of pipe between the source and the interceptor to avoid FOG accumulation and mechanical emulsification prior to entering the interceptor.

Grease removal from manually operated hydromechanical grease interceptors is typically performed by opening the access cover and manually skimming the accumulated grease from the interior water surface (along with the removal of a perforated filter screen for cleaning if so equipped).

### **Semiautomatic Units**

Semiautomatic units are typically a hydromechanical interceptor design, with FOG accumulation on the surface of the water inside the interceptor. However, these types of HGIs are not used as widely as they once were due in part to advances in grease retention equipment technology. In addition, the FOG removal process involves the running of hot water through the interceptor to raise the water level and force the FOG into the draw-off recovery cone or pyramid and then out through the attached draw-off hose to a FOG disposal container until the running water becomes clear. As compared to the operational qualities of the interceptor types and technologies currently available, this process wastes potable water at a time when water conservation should be of critical concern to the plumbing engineer, especially in certain areas of the country where the cost of water may be at a premium for a facility owner.

### **Separators**

Grease separators are available from some manufacturers. They separate FOG-laden wastes discharged from fixtures via gravity action. These types of devices are similar to HGIs in their construction, function, and cleaning. Unlike HGIs, they are not PDI G101 certified and do not contain or rely on external flow control devices for proper functioning. Internally, they are constructed in such a way that there is no

straight-through travel of wastewater from inlet to outlet. Flow through the unit is directed in a specific pattern and/or use of components (engineered by the device manufacturer) as required to minimize flow velocities and allow for the proper separation of FOG material from the wastewater. Provided that the device has been properly sized and installed correctly, the inlet simply closes when the separator's holding capacity is reached if short-circuiting devices or methods have not been otherwise utilized. As such, this type of device has essentially a built-in flow control and needs no external flow control. These devices can be selected where allowable by local authorities and where the installation of a PDI G101-certified device is not required for approval.

### **Grease Removal Devices**

Grease removal devices are typically hydromechanical interceptors that incorporate automatic, electrically powered skimming devices within their design. The two basic variations of this type of interceptor are timer-controlled units and sensor-controlled units.

In timer-controlled units (see Figure 8-4B), FOG is separated by gravity flotation in the conventional manner, at which point the accumulated FOG is skimmed from the surface of the water in the interceptor by a powered skimming device and activated by a timer on a time- or event-controlled basis.

The skimmed FOG is essentially scraped or wiped from the skimmer surface and directed into a trough, from which it drains through a small pipe from the interceptor into a disposal container located adjacent to the interceptor. Most GRDs are fitted with an electric immersion heater to elevate the temperature in the interceptor to maintain the contained FOG in a liquid state for skimming purposes.

A variation of this type of interceptor utilizes a FOG removal pump that is positioned in a tray inside the interceptor and controlled from a wall unit that contains a timer device. The pump is attached to a small translucent tank with a drain outlet that is located adjacent to the interceptor.

To operate these units, a timer is set to turn on the skimmer or FOG removal pump within a selected period. In a short time, the accumulated FOG is drained into the adjacent container, to be disposed of in a proper manner.

Sensor-controlled units employ computer-controlled sensors or probes, which sense the presence of FOG and automatically initiate the draw-off cycle at a predetermined percentage level of the interceptor's rated capacity. FOG is then drawn from the top of the FOG layer in the interceptor. The draw-off cycle continues until the presence of water is detected by the sensor, which stops the cycle to ensure that only water-free FOG is recovered. If required, an immersion heater is activated automatically at the onset of

the draw-off cycle to liquefy FOG in the interceptor. In addition, if either the unit's grease collection reservoir (where the recovered grease is stored pending removal) or the interceptor itself is near capacity with potential overloading sensed, warning measures and unit shutdown are activated automatically.

When GRDs are considered for installation, the manufacturer should be consulted regarding electrical, service, and maintenance requirements. The plumbing engineer must coordinate these requirements with the appropriate trades to ensure a proper installation. Furthermore, owing to these requirements, it is essential that those responsible for operating GRDs be trained thoroughly in their operation.

### FOG Disposal Systems

A FOG disposal system is very similar to a hydro-mechanical interceptor in its operation. However, in addition to reducing FOG in effluent by separation, it automatically reduces FOG in effluent by mass and volume reduction, without the use of internal mechanical devices or manual FOG removal. This system is specifically engineered, and one type is configured to contain microorganisms that are used to oxidize FOG within the interceptor to permanently convert the FOG material into the by-products of digestion, a process otherwise referred to as bioremediation. (It should be noted that this is also the same process used by municipal wastewater treatment plants.) Other FOG disposal systems utilize thermal or chemical methods of oxidation.


Figure 8-4C is an example of a bioremediation type of interceptor. The interceptor is divided into two main chambers, separated by baffles at the inlet and outlet sides. The baffle located at the inlet side of the interceptor acts to distribute the inflow evenly across the horizontal dimension of the interceptor. However, unlike conventional HGIs, a media chamber is its main compartment, which contains a coalescing media that is engineered to cause FOG to rise along the vertical surfaces of the media structure, where it comes into contact with microorganisms inhabiting a biofilm attached to the media. A wall-mounted shelf located above the interceptor supports a metering pump, timer, controls, and a bottle filled with a bacteria culture provided by the system manufacturer.

As the FOG material collects in the biofilm, bacteria from the culture bottle

(injected by the metering pump) break the bonds between fatty acids and glycerol and then the bonds between the hydrogen, carbon, and oxygen atoms of both, thereby reducing FOG volume. Drainage continues through the media chamber around the outlet baffle, where it then is discharged to the sanitary system.

Though FOG disposal systems significantly reduce the need for manual FOG removal or the handling of mechanically removed FOG materials, the need for monitoring effluent quality, routine maintenance to remove undigested materials, and inspections to ensure all components are clean and functioning properly are required and should be performed on a regular basis.

Furthermore, it is essential that the plumbing engineer coordinate all electrical and equipment space allocation requirements with the appropriate trades to allow for the proper installation and functioning of a FOG disposal system.



**Figure 8-5 (A) Gravity Grease Interceptor; (B) Passive, Tank-Type Grease Interceptor**



## Gravity Grease Interceptors

Gravity grease interceptors commonly are made of 4-inch (101.6-mm) minimum thickness concrete walls, with interior concrete barriers that act to sectionalize the interior into multiple chambers that dampen flow and retain FOG by flotation. Figure 8-5A shows a typical installation. However, standards allow other materials such as fiberglass, plastic, and protected steel. Generally, these units are used outside buildings as inground installations rather than as inside systems adjacent to or within kitchen areas. These units generally do not include the draw-off or flow-control arrangements common to hydromechanical units.

The unit should be installed as close to the source of FOG as possible. If this cannot be achieved due to field conditions or other site constraints, a heat trace system can be installed along the drain piping that is routed to the inlet side of the GGI to help keep the FOG-laden waste from solidifying before it enters the interceptor. Increasing the slope of the drain piping to the interceptor also can be considered in lieu of heat tracing where allowable by local codes and authorities having jurisdiction.

If a unit is located in a traffic area, care must be taken to ensure that the access covers are capable of withstanding any possible traffic load. It is also important that the interceptor be located in such a way as to allow easy cleanout.

Prefabricated GGIs also tend to be internally and externally configured with unique, pre-installed features designed to meet the local jurisdictional requirements of any given project location. The plumbing engineer must verify the local requirements to which these units must conform to ensure proper unit selection.

Field-formed concrete gravity grease interceptors are basically identical to the prefabricated units as described above, with the exception that they usually are constructed at the project site. Though likely more expensive to install than a prefabricated unit, one reason for its installation could be unique project site constraints. For example, a GGI may need to be installed in a very tight area, too close to existing property lines or adjacent structures to allow hoisting equipment the necessary access to an excavated area that otherwise would be sufficient for a standard prefabricated GGI installation.

Following is a list of recommended installation provisions for prefabricated and field-formed GGIs located outside a building.

- The unit should be installed as close to the source of FOG as possible. If this cannot be achieved due to field conditions or other site constraints, a heat trace system can be installed along the drain piping that is routed to the inlet side of the GGI.

- The influent should enter the unit at a location below the normal water level or near the bottom of the GGI to keep the surface as still as possible.
- The inlet and the outlet of the unit should be provided with cleanouts for unplugging both the sewers and the dip pipes.
- The effluent should be drawn from near the bottom of the unit, via a dip pipe, to remove as much floating grease and solids as possible.
- A large manhole, or removable slab, should be provided for access to all chambers of the grease interceptor for complete cleaning of both the floating and the settled solids.
- The top, or cover, should be gas-tight and capable of withstanding traffic weight.
- A difference in elevation between the inlet and the outlet of 3 to 6 inches (76.2 to 152.4 mm) should be provided to ensure flow through the grease interceptor during surge conditions without the waste backing up in the inlet sewer. As the grease begins to accumulate, the top of the grease layer will begin to rise above the normal water level at a distance of approximately 1 inch (25.4 mm) for each 9 inches (228.6 mm) of grease thickness.
- After installation, testing of the GGI for leakage should be a specification requirement prior to final acceptance.

In addition to concrete GGIs, gravity grease interceptors in the form of prefabricated round, cylindrical protected steel tanks are also available (see Figure 8-5B). These units often are referred to as passive grease interceptors, but they fall into the same category as gravity grease interceptors because they operate in virtually the same manner. Interceptors of this type are available with single and multiple chambers (depending on local jurisdictional requirements), with internal baffles, vent connections, and manhole extensions as required to allow for proper operation. They are manufactured in single- and double-wall construction and can be incorporated with steam or electric heating systems to help facilitate FOG separation and extraction from the unit.

Protected steel tank GGIs are built to UL specifications for structural and corrosion protection for both the interior and the exterior of the interceptor. The exterior corrosion protection is a two-part, polyurethane, high-build coating with interior coating options of polyurethane, epoxy, or a proprietary material (depending on influent wastewater temperature, wastewater characteristics, etc.). When protected steel tank GGIs are considered for installation, the manufacturer should be consulted regarding venting and hold-down requirements for buoyancy considerations.

## INSTALLATION

Most local administrative authorities require in their jurisdictions' codes that spent water from food service fixtures and equipment producing large amounts of FOG discharge into an approved interceptor before entering the municipality's sanitary drainage system. These requirements (generally code and pretreatment regulations, with pretreatment coordinators having the final word) can include multi-compartment pot sinks, pre-rinse sinks, kettles, and wok stations, as well as area floor drains, grease-extracting hoods installed over frying or other grease-producing equipment, and dishwashing equipment.

If floor drains are connected to the interceptor, the engineer must give special consideration to other adjacent fixtures that may be connected to a common line with a floor drain upstream of the interceptor. Unless flow control devices are used on high-volume fixtures or multiple fixtures flowing upstream of the floor drain connection, flooding of the floor drain can occur. A common misapplication is the installation of a flow control device at the inlet to the interceptor that may restrict high-volume fixture discharge into the interceptor, but floods the floor drain on the common branch. Floor drains connected to an interceptor require a recessed (beneath the floor) interceptor design.

An acceptable design concept is to locate the interceptor as close to the grease-producing fixtures as possible. Under-the-counter or above-slab interceptor installations are often possible adjacent to the grease-producing fixtures. This type of arrangement often avoids the individual venting of the fixtures, with a common vent and trap downstream of the grease interceptor serving to vent the fixtures and the grease interceptor together. Therefore, a p-trap is not required on the fixture outlet. However, provided this particular arrangement is allowed by governing codes and local jurisdictions, special attention should be paid to air inlet sources for the air-injected flow control if no p-trap is attached to the fixture outlet to avoid circuiting the building vent to the fixture.

If the grease interceptor is located far from the fixtures it serves, the grease can cool and solidify in the waste lines upstream of the grease interceptor, causing clogging conditions or requiring more frequent cleaning of the waste lines. However, a heat trace system can be installed along the main waste line that is routed to the inlet side of the interceptor to help keep the FOG-laden waste from solidifying before it enters the interceptor. Long horizontal and vertical runs also can cause mechanical emulsification of entrained FOG, which makes it difficult to separate.

Some practical considerations are also important if an interceptor is to be located near the fixtures it serves. If the interceptor is an under-the-counter, above-the-slab device, the engineer should leave enough space above the cover to allow complete cleaning and FOG removal from the unit.

Some ordinances also require that interceptors not be installed where the surrounding temperatures under normal operating conditions are less than 40°F (4.4°C).

Some administrative authorities prohibit the discharge of food waste disposers through HGIs and GRDs because of the clogging effect of ground-up particles. Other jurisdictions allow this setup, provided that a solids interceptor or strainer basket is installed upstream of these devices to remove any food particulates prior to entering the interceptor. It is recommended that food waste disposers be connected to HGIs and GRDs (in conjunction with a solids strainer) when allowed by the authority having jurisdiction due to the fact that disposer waste discharge is a prime carrier of FOG-laden material.

The same situation is similar with respect to dishwashers. Some administrative authorities prohibit the discharge of dishwasher waste to HGIs and GRDs, while other jurisdictions allow it, provided that the dishwashers are without pre-rinse sinks. It is recommended that dishwashers not be connected to HGIs or GRDs. Although the high discharge waste temperature from a dishwasher may be beneficial to the FOG separation process by helping maintain the FOG in a liquid state, the detergents used in dishwashing equipment can inhibit the device's ability to separate FOG altogether, which allows FOG to pass through the device where it eventually can revert to its original state and cause problems within the municipal sanitary system.

## FLOW CONTROL

Flow control devices are best located at the outlet of the fixtures they serve. However, flow control fittings are not common for floor drains or for fixtures that would flood if their waste discharge was restricted (such as a grease-extracting hood during its flushing cycle).

A few precautions are necessary for the proper application of flow control devices. The engineer should be sure that enough vertical space is available if the flow control device is an angle pattern with a horizontal inlet and a vertical outlet. A common difficulty encountered is the lack of available height for an above-slab grease interceptor adjacent to the fixture served when the vertical height needed for the drain outlet elbow, pipe slope on the waste arm from the fixture, vertical outlet flow control fitting,

and height from the grease interceptor inlet to the floor are all compensated.

The air intake (vent) for the flow control fitting may terminate under the sink as high as possible to prevent overflow or terminate in a return bend at the same height on the outside of the building. When the fixture is individually trapped and back-vented, air intake may intersect the vent stack. All installation recommendations are subject to the approval of the code authority. The air intake allows air to be drawn into the flow control downstream of the orifice baffle, thereby promoting air-entrained flow at the interceptor's rated capacity. The air entrained through the flow control also may aid the flotation process by providing a lifting effect for the rising grease.

It is particularly important to install the grease interceptor near the grease-discharging fixture when flow control devices are used because of the lower flow in the waste line downstream of the flow control device. Such flow may not be enough to ensure self-cleaning velocities of 3 feet per second (fps) (0.9 m/s).

While flow control is necessary to ensure that an interceptor will meet PDI G101 standards and function as designed, it should be stated that they can also be problematic due to their nature and purpose. Along with the issues previously mentioned, these devices clog fairly rapidly if not maintained on a regular basis due to their construction. It is not uncommon for these devices to be removed entirely and discarded by facility maintenance personnel in an effort to alleviate clogging and minimize maintenance expenses. Whether legal or not, this defeats the purpose of having the device in the first place, resulting in an interceptor installation that may not function as intended.

An alternative to utilizing a flow control device may be to select an interceptor whose flow characteristics exceed the design flow rate established for a facility or fixture. In the case of a single fixture or point-of-use application, Equation 1-11 from *Plumbing Engineering Design Handbook, Volume 1* could be used to determine the actual flow rate of a fixture. The subsequent selection of an interceptor would then be of a capacity greater than that of the discharge flow rate of the fixture to ensure proper operation and removal of FOG. The same method or a central interceptor installation could be used for a group of fixtures, except that the Manning formula could then be used to determine the necessary influent flow rate. While either method typically results in the selection of an interceptor that is somewhat oversized, the elimination of a flow control device and longer durations between interceptor cleanings

could be achieved, thus offsetting initial installation cost over time.

## GUIDELINES FOR SIZING

The following recommended sizing procedure for grease interceptors may be used as a general guideline for the selection of these units. The engineer should always consult the local administrative authorities regarding variations in the allowable drain-down times acceptable under the approved codes. Calculation details and explanations of the decision-making processes have been included in full in the examples as an aid to the engineer using these guidelines in specific situations.

### Example 8-1

Assume an HGI or a GRD for a single-fixture installation with no flow control. Size the grease interceptor for a three-compartment pot (scullery) sink, with each compartment being 18 × 24 × 12 inches.

1. First, determine the sink volume:

$$\text{Cubic contents of one sink compartment} = 18 \times 24 \times 12 = 5,184 \text{ in.}^3$$

$$\text{Cubic contents of three sink compartments} = 3 \times 5,184 = 15,552 \text{ in.}^3$$

$$\text{Contents expressed in gallons} = 15,552 \text{ in.}^3 / 231 = 67.3 \text{ gallons}$$

2. Then add the total potable water supply that could be discharged independent of a fixture calculated above, including manufacturer-rated appliances such as water-wash exhaust hoods and disposers (if allowed to discharge to the interceptor).
3. Next, determine the fixture load. A sink (or fixture) seldom is filled to the brim, and dishes, pots, or pans displace approximately 25 percent of the water. Therefore, 75 percent of the actual fixture capacity should be used to establish the drainage load:

$$0.75 \times 67.3 \text{ gal} = 50.8 \text{ gal}$$

4. Calculate the flow rate based on drain time, typically one minute or two minutes. The flow rates are calculated using the following equation:

$$\text{Drainage load, in gallons} / \text{Drainage load, in minutes}$$

Therefore, the flow rate for this example would be:

$$50 \text{ gpm (3.15 L/s) for one-minute drainage or 25 gpm (1.58 L/s) for two-minute drainage.}$$

5. Last, select the interceptor. Choose between a hydromechanical interceptor with a rated capacity of 50 gpm for one-minute flow or 25 gpm for two-minute flow or a gravity interceptor

with a capacity of 1,500 gallons (50-gpm flow rate  $\times$  30-minute detention time).

Local administrative authorities having jurisdiction should be consulted as they may dictate a specific formula or sizing criteria that would ultimately determine the specific flow parameters for which the interceptor could be selected. It is extremely important to determine not only the governing model code requirements regarding specific interceptor criteria, but also local jurisdictional requirements promulgated by the pretreatment authority since they sometimes contradict each other, especially where local jurisdictions adopt certain amendments and regulations that may supersede any model code requirements.

Grease extraction water-wash hood equipment may be used. It should be noted that while these systems are used in some cases, grease hoods that incorporate troughs that entrap grease, which are sloped to drip cups at the ends of the hood, are used quite prevalently. These cup drains are removed by hand, and the FOG material contained is disposed of in a proper manner and never discharges to the interceptor. It is important to verify which types of systems will be used with respect to grease hood equipment prior to the selection of the interceptor so the proper capacity can be determined.

It also should be noted that the phrase “sizing an interceptor” is used throughout the industry quite loosely. However, grease interceptors are not sized. They are selected based on specific flow parameters and requirements as determined by the plumbing engineer during the design process for each individual facility. Furthermore, the design flow rates and pipe sizing criteria for food preparation facilities should not be determined by using the fixture unit method typically used for other types of facilities due to the fact that the probability of simultaneous use factors associated with fixture unit values do not apply in food preparation facilities where increased and continuous flow rates are encountered. Also, the facility determines the peak flows used to select the proper interceptor for the intended application, not the other way around (i.e., a single facility does not discharge at a multitude of different flow rates depending on which particular type of interceptor is being considered for installation.)

Lastly, in certain projects the plumbing engineer may be called on to select an interceptor in which the flow rates for a facility are not readily quantifiable at the time of design, such as for a future expansion, restaurant, or food court area within a new development. In this case, tables or formulas can be used in an effort to help quantify the maximum flow rate that will be encountered for a specific pipe size at a given slope and velocity that ultimately dis-

charges to the interceptor. This information can be used to select the proper interceptor capacity for the intended flow rates anticipated.

## CODE REQUIREMENTS

The necessity for the plumbing engineer to verify all state and local jurisdictional requirements prior to the start of any food service facility design cannot be emphasized enough. Although state and model plumbing codes provide information with respect to interceptor requirements and regulations, local health departments and administrative authorities having jurisdiction have likely established their own set of guidelines and requirements for an interceptor on a specific project and, therefore, also should be consulted at the start of the design. It is up to the plumbing engineer to pull together the various agency requirements in an effort to design a code-compliant system, while incorporating any additional governing requirements and regulations.

Following are itemized lists incorporating the major provisions of the model plumbing codes and are included herein as an abbreviated design guide for the engineer when specifying sizing. It is important to review the applicable code in effect in the area for any variation from this generalized list.

### UPC Requirements for Interceptors

1. Grease interceptors are not required in individual dwelling units or residential dwellings.
2. Water closets, urinals, and other plumbing fixtures conveying human waste shall not drain into or through any interceptor.
3. Each fixture discharging into an interceptor shall be individually trapped and vented in an approved manner.
4. Grease waste lines leading from floor drains, floor sinks, and other fixtures or equipment in serving establishments such as restaurants, cafes, lunch counters, cafeterias, bars, clubs, hotels, hospitals, sanitariums, factory or school kitchens, or other establishments where grease may be introduced into the drainage or sewage system shall be connected through an approved interceptor.
5. Unless specifically required or permitted by the authority having jurisdiction, no food waste disposal unit or dishwasher shall be connected to or discharge into any grease interceptor. Commercial food waste disposers shall be permitted to discharge directly into the building drainage system.
6. The waste discharge from a dishwasher may be drained into the sanitary waste system through a gravity grease interceptor when approved by the authority having jurisdiction.

7. Flow control devices are required at the drain outlet of each grease-producing fixture connected to a hydromechanical grease interceptor. Flow control devices having adjustable (or removable) parts are prohibited. The flow control device shall be located such that no system vent shall be between the flow control and the interceptor inlet. (Exception: Listed grease interceptors with integral flow controls or restricting devices shall be installed in an accessible location in accordance with the manufacturer's instructions.)
8. A vent shall be installed downstream of hydromechanical grease interceptors.
9. The grease collected from a grease interceptor must not be introduced into any drainage piping or public or private sewer.
10. Each gravity grease interceptor shall be so installed and connected that it shall be at all times easily accessible for inspection, cleaning, and removal of intercepted grease. No gravity grease interceptor shall be installed in any part of a building where food is handled.
11. Gravity grease interceptors shall be placed as close as practical to the fixtures they serve.
12. Each business establishment for which a gravity grease interceptor is required shall have an interceptor that shall serve only that establishment unless otherwise approved by the authority having jurisdiction.
13. Gravity grease interceptors shall be located so as to be readily accessible to the equipment required for maintenance and designed to retain grease until accumulations can be removed by pumping the interceptor.

### IPC Requirements for Hydromechanical Grease Interceptors

1. Grease interceptors are not required in individual dwelling units or private living quarters.
2. A grease interceptor or automatic grease removal device shall be required to receive the drainage from fixtures and equipment with grease-laden waste located in food preparation areas such as restaurants, hotel kitchens, hospitals, school kitchens, bars, factory cafeterias, and clubs. The fixtures include pre-rinse sinks, soup kettles or similar devices, wok stations, floor drains or sinks to which kettles are drained, automatic hood wash units, and dishwashers without pre-rinse sinks.
3. Where food waste disposal units are connected to grease interceptors, a solids interceptor shall separate the discharge before connecting to the interceptor. Solids interceptors and grease interceptors shall be sized and rated for the discharge of the food waste grinder.

4. Grease interceptors shall be equipped with devices to control the rate of water flow so that the water flow does not exceed the rated flow. The flow control device shall be vented and terminate not less than 6 inches above the flood rim level or be installed in accordance with manufacturer's instructions.
5. Hydromechanical grease interceptors shall have the minimum grease retention capacity for the flow-through rates indicated in Table 8-2.

### OPERATION AND MAINTENANCE

Operational methods can create problems for the engineer even if all of the design techniques for grease interceptors presented have been observed. Failing to scrape dinner plates and other food waste-bearing utensils into the food waste disposer prior to loading them into dishwasher racks means that the liquid waste discharged from the dishwasher to the grease interceptor also carries solid food particles into the grease interceptor unit. The grease interceptor is not a food waste disposer.

Another common problem is insufficient grease removal. The period between removals differs for each interceptor type and is best left to the experience of licensed professional cleaning services. However, if the flow rate of the unit is constantly exceeded (no flow control) with high-temperature water, such as a heavy discharge from a dishwasher, the grease in the unit may periodically be liquefied and washed into the drainage system downstream

**Table 8-2 Minimum Grease Retention Capacity**

Total Flow-Through Rating (gpm)	Grease Retention Capacity (pounds)
4	8
6	12
7	14
9	18
10	20
12	24
14	28
15	30
18	36
20	40
25	50
35	70
50	100
75	150
100	200

of the grease interceptor. In this case, the operator or cleaning service may never realize that the unit needs cleaning because it never reaches its grease storage capacity. The difficulty is that when the temperature of the grease/water mixture finally cools in the drainage system downstream of the grease interceptor, clogging ultimately occurs.

Adequate maintenance is critical to an efficient grease interceptor installation. One of the most

common problems is the disposal of the accumulated grease. The grease removed must be disposed of in various ways depending on local requirements. Grease should not be poured down any other drain or in any sewer line or buried in the ground. It should be disposed of via garbage pickup or some similar approved operation.

# 9

# Cross-Connection Control

Keeping a fluid isolated in a complex piping network in a modern building may seem like a straightforward proposition. However, such efforts fall short unless all details are addressed thoroughly. Plumbing conveys one of society's most cherished commodities, safe water, to be used for personal hygiene and consumption, for industry, for medical care, and for landscape irrigation. Thus, a clear and distinct barrier between potable water and pollution, toxic substances, or disease-causing microbes is required. Good plumbing practices also call for similar controls related to graywater.

A cross-connection control (CCC) is a piping design or device, often combined with frequent monitoring, that prevents a reverse flow of water at a cross-connection, or the point in the water supply where the water purity level is no longer known because of the transition from an enclosed streamline of water to another surface, basin, drain system, pipe system, or piping beyond the control of the water purveyor. Examples of potential cross-connections include plumbing fixtures, hose bibbs, appliance connections, hydronic water supply connections, fire sprinkler and standpipe water supply connections, water supply connections to industrial processes, laundries, medical equipment, food service equipment, HVAC equipment, swimming pool water makeup, water treatment backwash, trap primers, irrigation taps, dispensers that dilute their product with water, pressure-relief valve discharge piping, and drain-flushing water supply. However, a cross-connection is not necessarily hard piped. Rather, because of the nature of fluid mechanics, it also could be where the end of a water supply pipe is suspended below the rim of a fixture or floor drain.

## HYDROSTATIC FUNDAMENTALS

A cross-connection hazard is relative to the nature of the contaminants likely to be present in the environment of the cross-connection. To understand the hazards of cross-connections and the associated control methods, a knowledge of hydrostatics is essential since the pressure at any point in a static water

system is a function only of the water's depth. This relationship is understood by considering that at any point, the weight of water above it is the product of its volume and its specific weight. Specific weight is similar to density; however, it is defined as weight per unit volume rather than mass per unit volume. Like density, it varies slightly with temperature.

To derive the pressure relationship in a hydrostatic fluid, consider the volume of the fluid at a given depth and a horizontal area at that depth. The pressure is the weight divided by the area. Hence,

$$p = W / A, \text{ or}$$

### Equation 9-1

$$p = h \times w$$

where

p = Static gauge pressure, pounds per square inch (psi) (kPa)

W = Weight, pounds (N)

A = Area, square inches (square meters)


h = Static head, feet (meters)

w = Specific weight of water, pounds per cubic feet (N/m<sup>3</sup>)

If 1 cubic foot of water is 62.4 lb and 1 square foot of area is 144 in<sup>2</sup>, then  $p = h \times 62.4/144 = 0.433h$ .

For absolute pressure in a water supply, the local atmospheric pressure is added to the gauge pressure. For example, in Figure 9-1, if the local atmospheric pressure is 14.7 psi, the absolute pressure at the top of the column is found from  $[(0.433)(-23)] + 14.7 = 4.73$  psia. Note that atmospheric pressure is not constant. Rather, it varies with the weather, geographic location, and the effects of HVAC systems.

Hydrodynamics, or additional forces related to the momentum from moving water, affect the magnitude of a reverse flow and the transient nature of a flow demand. Pressure reversals at booster pump inlets and circulator pump inlets may cause other hydrodynamic issues. These pressure effects are superimposed on hydrostatic pressures. Nonetheless, impending reversals generally are affected by hydrostatics only.




**Figure 9-1 Hydrostatics Showing Reduced Absolute Pressure in a Siphon**


As an example, consider a 100-foot (30.5-m) tall water supply riser pipe with 20 pounds per square inch gauge (psig) (138 kPa) at its top. From Equation 9-1, the pressure at the base of the riser will be 63.3 psig (436 kPa). If an event causes a 30-psig (207-kPa) pressure loss, the pressure at the top fixture will be -10 psig (-69 kPa gauge), or 4.7 pounds per square inch absolute (psia) (32 kPa absolute). This vacuum will remain in the piping until any faucet, flush valve, or other valve is opened on the riser.

**CAUSES OF REVERSE FLOW**

Cross-connection control methods must be applied between varying water supplies to prevent pollution or a contaminant from inadvertently entering the potable water supply. A general water supply is represented in Figure 9-2. Although it shows only four endpoints, you can expand it to any number of endpoints with any arrangement of pipes of different elevations and lengths. Hence, the network of pipes may represent a small network, such as a residence,



**Figure 9-2 Pipe Network With Four Endpoints**



**Figure 9-3 Five Typical Plumbing Details Without Cross-Connection Control**

or it may represent a large network, such as a building complex or a major city.

At each endpoint in a plumbing water supply, any of five general details, such as shown in Figure 9-3, may be connected. Elevation is represented by the vertical lines. For illustration purposes, no CCC is included. An example of Figure 9-3(a) is a water storage tank with an open or vented top, such as a city water tower. Figure 9-3(b) could be a pressure vessel such as a boiler, Figure 9-3(c) a plumbing basin, Figure 9-3(d) a hose immersed in a plumbing basin or a supply to a water closet with a flushometer, and Figure 9-3(e) a fire suppression system, a hydronic system, or a connection point for process piping or for a building’s water distribution in contrast to the street distribution.

If you include a pump anywhere in a network, an elevated reservoir can illustrate the effect of the pump. The pump’s discharge head is equivalent to the surface elevation level of the reservoir relative to the piping system discharge level.



All discussions of CCC include identification of back-pressure and back-siphonage. Back-pressure is the pressure at a point in a water supply system that exists if the normal water supply is cut off or eliminated. Back-siphonage is an unintended siphon situation in a water supply with the source reservoir being a fixture or other source with an unknown level of contamination. A siphon can be defined as a bent tube full of water between two reservoirs under atmospheric pressure, causing flow in the reservoirs despite the barrier between them.

For example, the maximum back-pressure at the base of the riser in Figure 9-3(a), for a reservoir other than the normal water supply, occurs if the tank shown is filled to its rim or overflow outlet. In Figure 9-3(d), flow from the basin may occur if the water supply is cut off or eliminated and if the water elevation is near or above the pipe outlet. This reverse flow, or siphon action, is caused by atmospheric pressure against the free surface of the water in the basin.

In a network, when the law of hydrostatics is generally applied to the reservoir with the highest elevation, the network’s pressure distribution is

identifiable, and the direction of flow can be known through general fluid mechanics. In an ideal case, the presence of that reservoir generally keeps the direction of flow in a favorable direction. However, the connection of a supply reservoir is vulnerable to any cause for a pressure interruption, and the normal network pressure distribution may be disturbed. For example, when a valve anywhere in a general system isolates a part of the system away from the supply reservoir, another part of the isolated section may become the water source, such as any fixture, equipment, or connected system. Refer back to Figure 9-2. If endpoint 2 is the city water supply and endpoint 4 is a closed-loop ethylene glycol system on a roof, if the city supply is cut off, the glycol may freely feed into endpoints 1 and 3.

Other pressure interruptions include broken pipes, broken outlets, air lock, pressure caused by thermal energy sources, malfunctioning pumps, malfunctioning pressure-reducing valves, and uncommon water discharges such as a major firefighting event.

Because it cannot be predicted where a valve may close or where another type of pressure interruption may occur, each water connection point becomes a potential point for reverse flow. Thus, every fixture, every connected piece of equipment, and every connected non-plumbing system becomes a point of reverse flow. Containers of any liquid that receive water from a hose or even a spout of inadequate elevation potentially may flow in a reverse direction. Submerged irrigation systems or yard hydrants with a submerged drain point potentially may flow soil contaminants into the water supply system. Hence, the safety of a water supply distribution depends on effective control at each connection point. The safety is not ensured if the effectiveness of one point is unknown despite controls at all other points.

Further, control methods today do not detect or remove the presence of contaminants. A control device added to hot water piping supplying a laboratory will not be effective if the circulation return brings contaminated hot water out of the laboratory.

A manually closed water supply valve is not considered a cross-connection control, even if the valve is bubble-tight and well supervised. Ordinary check valves also are not considered a cross-connection control. The history of such good intentions for equipment connections or water fill into processing operations has not been sufficiently effective as compared to cross-connection control.

In addition, as a measure of containment, a control device in the water service is a primary candidate to isolate a hazard within a building.

**Table 9-1 Plumbing System Hazards**

Direct Connections	Potential Submerged Inlets
Air-conditioning, air washer	Baptismal font
Air-conditioning, chilled water	Bathtub
Air-conditioning, condenser water	Bedpan washer, flushing rim
Air line	Bidet
Aspirator, laboratory	Brine tank
Aspirator, medical	Cooling tower
Aspirator, herbicide and fertilizer sprayer	Cuspidor
Autoclave and sterilizer	Drinking fountain
Auxiliary system, industrial	Floor drain, flushing rim
Auxiliary system, surface water	Garbage can washer
Auxiliary system, unapproved well supply	Ice maker
Boiler system	Laboratory sink, serrated nozzle
Chemical feeder, pot type	Laundry machine
Chlorinator	Lavatory
Coffee urn	Lawn sprinkler system
Cooling system	Photo laboratory sink
Dishwasher	Sewer flushing manhole
Fire standpipe	Slop sink, flushing rim
Fire sprinkler system	Slop sink, threaded supply
Fountain, ornamental	Steam table
Hydraulic equipment	Urinal, siphon jet blowout
Laboratory equipment	Vegetable peeler
Lubrication, pump bearings	Water closet, flush tank, ball cock
Photostat equipment	Water closet, flush valve, siphon jet
Plumber’s friend, pneumatic	
Pump, pneumatic ejector	
Pump, prime line	
Pump, water-operated ejector	
Sewer, sanitary	
Sewer, storm	
Swimming pool or spa equipment	

However, its function is to preserve the safety of adjacent buildings and not the building itself. That is, reverse flows may occur within a building having only containment cross-connection control. Its occupants remain at risk even though the neighborhood is otherwise protected.

## HAZARDS IN WATER DISTRIBUTION

A hazard exists in a water supply system if a risk may occur and if the probability of occurrence is beyond the impossible. See Table 9-1 for a list of common hazards in plumbing systems. The various pressure interruptions previously described do not occur frequently, but they happen and often without warning. Hence, the probability cannot be discounted even if an occurrence is uncommon, especially in large networks.

Risks are more common since they are associated with every plumbing fixture, many types of equipment, and various connections with non-plumbing systems. The nature of the risk ranges from mere objections such as water color or odor to varying exposure levels of nuclear, chemical, or biological material. The varying level further ranges from imperceptible to mildly toxic to generally lethal in healthy adults. A risky material generally is referred to as a contaminant. The current list of drinking water contaminants and their maximum contaminant levels (MCLs) can be found on the U.S. Environmental Protection Agency's website at [water.epa.gov/drink](http://water.epa.gov/drink).

### Control Paradox

A paradox exists in a water supply. That is, reverse flows rarely happen, yet they are dangerous. Cross-connection control is poorly understood and often regarded as superfluous. Further, well-intentioned users often tamper with these controls. The hazard escapes notice because the pressure is rarely interrupted, and the potential source of a contaminant may not always be present at a perceptively dangerous level. For example, a disconnected vacuum breaker at a mop basin fitted with a detergent dispenser generally will not flow into the building water supply until a pressure interruption occurs, and then the effect of consuming contaminated water may be only mild for occupants on floors below the offending mop basin. However, another example may include hospital patients and more toxic chemicals.

### Classification of Hazards

Since risks can be ranked from those that are likely to be unsafe to those rarely unsafe, the CCC industry has developed two broad classifications: high and low. Examples of each are presented in Table 9-2. Less capital generally is invested in CCC where the hazard is low.

## CONTROL TECHNIQUES

Preventing reverse flow is achieved by techniques such as using certain piping designs and installing control devices. If no mechanical moving parts exist, the control can be regarded as passive. Effective operation is more inherent, but limitations warrant other controls. If moving parts are involved, the control can be regarded as active.

### Passive Techniques

Examples of passive controls include air gaps and barometric loops.

#### *Air Gap*

An air gap is regarded as effective if the outlet of the flow discharge is adequately above the rim of the receiving basin, generally twice the diameter of the outlet. However, air gap requirements vary with the plumbing codes. Some codes increase the distance to three times the diameter if the outlet is close to the basin wall. Others regard the valve seat as being the relevant diameter or the overflow pipework as establishing the flood level elevation. In modern plumbing, faucet spout outlets invariably discharge through an air gap positioned above the flood level rim of all plumbing fixtures. Fixed air gaps are a recognized method of backflow protection, but many authorities do not accept air gaps for water service protection when the air gap is located a considerable distance from the point of entry.

The theory behind the operation of an air gap is that with an excessively short vertical distance, a vacuum in the water supply draws room air, which also captures water from the surface of a full basin. The vacuum can be visualized as water in a riser pipe rapidly dropping. The void above this falling water produces a vacuum until the fall is complete. Another situation is when a valve in the water supply is opened after the vacuum has occurred because of lost pressure in the water supply moments earlier.

Other provisions of acceptable industry standards include recognition of overflow pipes in water closet tanks and diverter hoses such as in food sprayers on kitchen sinks. Following are several air gap standards for various applications.

- ASME A112.1.2: *Air Gaps In Plumbing Systems (For Plumbing Fixtures and Water-Connected Receptors)*
- ANSI/ASME A112.1.3: *Air Gap Fittings for Use with Plumbing Fixtures, Appliances, and Appurtenances*
- ANSI/ASSE 1002: *Performance Requirements for Anti-Siphon Fill Valves for Water Closet Tanks*
- ANSI/ASSE 1004: *Backflow Prevention Requirements for Commercial Dishwashing Machines*

**Table 9-2 Application of Cross-Connection Control Devices**

Standard	Device or Method	Type of Protection <sup>a</sup>	Hazard	Installation Dimensions and Position	Pressure Condition <sup>b</sup>	Comments	Use
ANSI A 112.2.1	Air Gap	BS and BP	High	Twice effective opening; not less than 1 inch above flood rim level	C		Lavatory, sink or bathtub spouts, Residential dishwasher (ASSE 1006) and clothes washers (ASSE 1007)
ASSE 1001	Pipe-applied vacuum breaker	BS	Low	6 inches above highest outlet; vertical position only	I		Goosenecks and appliances not subject to back pressure or continuous pressure
ASSE 1011	Hose bibb vacuum breaker	BS	Low	Locked on hose bibb threads; at least 6 inches above grade	I	Freeze-resistant type required	Hose bibbs, hydrants, and sillcocks
ASSE 1012 <sup>c</sup>	Dual-check valve with atmospheric vent	BS and BP	Low to moderate	Any position; drain piped to floor	C	Air gap required on vent outlet; vent piped to suitable drain	Residential boilers, spas, hot tubs, and swimming pool feedlines, sterilizers; food processing equipment; photo lab equipment; hospital equipment; commercial dishwashers; water-cooled HVAC; landscape hose bibb; washdown racks; makeup water to heat pumps
ASSE 1013	Reduced-pressure zone backflow preventer	BS and BP	High	Inside building: 18–48 inches (centerline to floor); outside building: 18–24 inches (centerline to floor); horizontal only	C	Testing annually (minimum); Overhaul five years (minimum); drain	Chemical tanks; submerged coils; treatment plants; solar systems; chilled water; heat exchangers; cooling towers; lawn irrigation (Type II); hospital equipment; commercial boilers, swimming pools, and spas; fire sprinkler (high hazard as determined by commission)
ASSE 1015	Dual-check valve assembly	BS and BP	Low	Inside and outside building: 18–24 inches (centerline to floor); horizontal only; 60 inches required above device for testing	C	Testing annually (minimum); overhaul five years (minimum)	Fire sprinkler systems (Type II low hazard); washdown racks; large pressure cookers and steamers
ASSE 1020	Pressure-type vacuum breaker	BS	High	12–60 inches above highest outlet; vertical only	C	Testing annually (minimum); overhaul five years (minimum)	Degreasers; laboratories; photo tanks; Type I lawn sprinkler systems and swimming pools (must be located outdoors)
ASSE 1024 <sup>c</sup>	Dual-check valve	BS and BP	Low	Any position	C		Fire sprinkler systems (Type I building); outside drinking fountains; automatic grease recovery device
ASSE 1035	Atmospheric	BS	Low	6 inches above flood level per manufacturer	I/C		Chemical faucets; ice makers; dental chairs; miscellaneous faucet applications; soft drink, coffee, and other beverage dispensers; hose sprays on faucets not meeting standards
ASSE 1056	Spill-resistant indoor vacuum breaker	BS	High	12–60 inches above highest outlet; vertical only	C	Testing annually (minimum); overhaul five years (minimum)	Degreasers; laboratories; photo tanks; Type I lawn sprinkler systems and swimming pools (must be located outdoors)

<sup>a</sup> BS = Back-siphonage; BP = Back-pressure


<sup>b</sup> I = Intermittent; C = Continuous

<sup>c</sup> A tab shall be affixed to all ASSE 1012 and 1024 devices indicating installation date and the following statement: "FOR OPTIMUM PERFORMANCE AND SAFETY, IT IS RECOMMENDED THAT THIS DEVICE BE REPLACED EVERY FIVE (5) YEARS."

**Table 9-3 Types of Back-Pressure Backflow Preventer**

Description	Alternate Description	Application	ASSE Reference
Dual-check valve with atmospheric vent	Intermediate atmospheric	Low hazard	1012
Reduced-pressure principle	Reduced-pressure zone	High hazard	1013
Dual-check valve with atmospheric vent	Intermediate atmospheric	Carbonated beverage	1022
Reduced-pressure principle detector assembly*	Reduced-pressure zone	Fire protection	1047

\* In most jurisdictions, the double check valve detector is approved.



**Figure 9-4 Siphon Sufficiently High to Create a Barometric Loop**

**Table 9-4 Types of Vacuum Breakers**

Description	Application	ASSE Reference
Pipe applied	Mop basin, indoor hose	1001
Hose connection	Indoor hose	1011
Hose connection	Handheld shower	1014
Frost resistant	Wall hydrant	1019
Pressure-type	Turf irrigation	1020
Pressure flush	Flushometer	1037
Spill resistant	High hazard	1056

- ASSE 1006: *Performance Requirements for Residential Use Dishwashers*
- ASSE 1007: *Performance Requirements for Home Laundry Equipment*


**Barometric Loop**

The design of a barometric loop requires part of the upstream supply pipe to be adequately above the receiving basin. The minimum height is derived from Equation 9-1. For an atmospheric pressure of 31 inches (788 mm) of mercury,  $h = 35.1$  feet (10.8 m). The technique, shown in Figure 9-4, is effective because the room’s atmospheric pressure is not sufficient to push a column of water up that much elevation.

**Active Techniques**

Mechanisms in an active control device prevent reverse flow either by allowing flow in one direction only or by opening the pipe to atmospheric pressure. The former generally is categorized as a back-pressure backflow preventer, which typically utilizes a disc that lifts from a seat to maintain normal flow. The latter is generally a vacuum breaker, which has greater application restrictions. A device of either broad category uses a specially designed, fabricated, tested, and certified assembly. For high hazard applications, the assembly often includes supply and discharge valves and testing ports. For various applications, Tables 9-3 and 9-4 list several back-pressure backflow preventer standards and vacuum breaker standards respectively.

Examples of locating back-pressure backflow preventers that are required for effective cross-connection control in Figure 9-3(a), (b), and (e) are shown with a small square in corresponding applications in Figure 9-5(a), (b), and (e). The hydrostatic pressure of the water downstream of the backflow preventer



**Figure 9-5 Five Typical Plumbing Details With Cross-Connection Control**

must be resisted by the active control in the event of water supply pressure failure. Figure 9-6 shows several backflow preventers as isolation at fixtures and equipment as well as hazard containment at the water service.




Figure 9-6 Example of Cross-Connection Controls in a Building




Figure 9-7 Double Check Valve

Types of back-pressure backflow preventers include double-check valve assemblies, reduced-pressure principle backflow preventers, and dual checks with atmospheric vents. Types of vacuum breakers include atmospheric, pressure, spill-resistant, hose connection, and flush valve.

**Double Check Valve Assembly**

This control, with its two check valves, supply valves, and testing ports, can effectively isolate a water supply from a low hazard system such as a fire standpipe and sprinkler system. The design includes springs and resilient seats (see Figure 9-7). Some large models, called detector assemblies, include small bypass systems of equivalent components and a meter, which monitors small water usages associated with quarterly testing of a fire sprinkler system.

A small version of a double check for containment CCC has been developed for residential water services.

**Reduced-Pressure Principle Backflow Preventer**

This control is similar to the double check valve but employs added features to isolate a water supply from a high hazard. An alternate name is reduced-pressure zone backflow preventer, or RPZ. A heavier spring is used on the upstream check valve, which causes a pronounced pressure drop for all portions of the piping system downstream. A relief port between the check valves opens to the atmosphere and is controlled by a diaphragm. Each side of the diaphragm is ported to each side of the upstream check valve (see Figure 9-8). A rated spring is placed on one side of the diaphragm. An artificial zone of reduced pressure across the check valve is created by torsion on the check valve spring. Pressure on the inlet side of the device is intended to remain a minimum of 2 psi (13.8 kPa) higher than the pressure in the reduced-pressure zone. If the pressure in the zone increases to within 2 psi (13.8 kPa) of the supply pressure, the relief valve will open to the atmosphere to ensure that the differential is maintained. This circumstance occurs if the downstream equipment or piping has excessive pressure. It also occurs if the upstream check valve fails or if the water supply is lost.

These devices are designed to be in-line, testable, and maintainable. They are equipped with test cocks and inlet and outlet shutoff valves to facilitate testing and maintenance and an air gap at the relief port. The device should be installed in an accessible

location and orientation to allow for testing and maintenance. Like the double check valve detector assembly, this backflow preventer is available as a detector assembly.

### ***Dual Check with Atmospheric Vent***

This control is similar to the reduced-pressure principle type, but the diaphragm design is replaced by a piston combined with the downstream check valve (see Figure 9-9). It effectively isolates a water supply from a low hazard such as beverage machines and equipment with nontoxic additives. The function of its design is not sufficiently precise for high hazards. The relief port is generally hard-piped with its air gap located remotely at a similar or lower elevation.

A vacuum breaker is of a similar design, but it is elevation-sensitive for effective isolation of a hazard. Permitted maximum back-pressure ranges from 4.3 psig (29.7 kPa) to zero depending on the type.

### ***Atmospheric Vacuum Breaker***

This control, with a single moving disc, can effectively isolate a water supply from a low hazard system. Without this control in Figure 9-3(d), a reverse flow will occur from the basin if the fluid level in the basin is near or above the pipe discharge, the water supply pressure is lost, and the highest elevation of the piping above the fluid level is less than that needed for a barometric loop. The reverse flow, referred to as back-siphonage, is caused by atmospheric pressure against the surface of the fluid, which pushes the fluid up the normal discharge pipe and down into the water supply. Static pressure for any point in the basin and in the pipe, after discounting pipe friction, is a function only of elevation. Above the fluid surface elevation,

this pressure is less than atmospheric; that is, it is a vacuum. The reverse flow therefore is stopped if the vacuum is relieved by opening the pipe to atmosphere. Figure 9-10 illustrates the vent port and the disc that closes under normal pressure.

### ***Pressure-Type Vacuum Breaker***

This control is similar to the atmospheric vacuum breaker but employs one or two independent spring-loaded check valves, supply valves, and testing ports. It is used to isolate a water supply from a high hazard system.

### ***Spill-Resistant Vacuum Breaker***

This control is similar to the pressure-type vacuum breaker, but it employs a diaphragm joined to the vacuum breaker disc. It is used to isolate a water supply from a high hazard system and to eliminate splashing from the vent port.

### ***Hose Connection Vacuum Breaker***

This control is similar to the atmospheric vacuum breaker in function but varies in design and application. The disc is more elastic, has a pair of sliced cuts in the center, and deforms with the presence of water supply pressure to allow the water to pass through the cuts (see Figure 9-11). The deformation also blocks the vent port. A more advanced form employs two discs, and the design allows performance testing.

### ***Flush Valve Vacuum Breaker***

This control is similar to the hose connection vacuum breaker in function but varies somewhat in the design of the elastic part.


### **Hybrid Technique**

A hybrid of passive and active controls is the break tank. Consisting of a vented tank, an inlet pipe with an air gap, and a pump at the discharge, a break tank provides effective control for any application ranging from an equipment connection to the water service of an entire building. Its initial and operating costs are obviously higher than those of other controls.

## **INSTALLATION**

All cross-connection controls require space, and the active controls require service access. In addition, an air gap cannot be confined to a sealed space or to a subgrade location, and it requires periodic access for inspection. A vacuum breaker may fail to open if it is placed in a ventilation hood or sealed space. A backflow preventer is limited to certain orientations.

If a water supply cannot be interrupted for the routine testing of a control device,



**Figure 9-8** Reduced-Pressure Principle Backflow Preventer

a pair of such devices is recommended. Some manufacturers have reduced the laying length of backflow preventers in their designs. Backflow preventers with relief ports cannot be placed in a subgrade structure that is subject to flooding because the air gap could potentially be submerged. Thus, backflow preventers for water services are located in buildings and abovegrade outdoors. Where required for climatic reasons, heated enclosures can be provided. Features




Figure 9-9 Dual-Check with Atmospheric Vent




Figure 9-10 Atmospheric Vacuum Breaker




Figure 9-11 Hose Connection Vacuum Breaker

include an adequate opening for the relief port flow and large access provisions.

Manufacturers of reduced-pressure principle backflow preventers recommend an inline strainer upstream of the backflow preventer and a drain valve permanently mounted at the strainer's upstream side. Periodic flushing of the screen and upstream piping should include brisk opening and closing to jar potential debris and flush it away before it can enter the backflow preventer. Manufacturers also have incorporated flow sensors and alarm devices that can provide warnings of malfunctions.

If special tools are required to service and maintain an active control device, the specification should require the tools to be furnished with and permanently secured to the device.

### Installation Shortfalls

Though relatively simple, air gaps have some shortfalls. Namely, the structure of the outlet must be sufficiently robust to withstand abuse while maintaining the gap. The general openings around the air gap must not be covered. The rim of the basin must be wide enough to capture attendant splashing that occurs from fast discharges. The nature of the rim must be adequately recognized so the gap is measured from a valid elevation. That is, if the top edge of the basin is not practical, the invert of a side outlet may be regarded as the valid elevation. Similarly, the rim of a standpipe inside the basin may be regarded as the valid elevation. In either design, the overflow and downstream piping must be evaluated to consider if it will handle the greatest inlet flow likely to occur. A common design of potable water filling a tank through an air gap that is below the tank rim, but where the tank has an overflow standpipe, is the design found in water closet tanks. The generous standpipe empties into the closet bowl so the air gap is never compromised.

Vacuum breakers also have several shortfalls. A valve downstream of the vacuum breaker will send shock waves through the vacuum breaker every time the valve closes. This causes the disc to drop during the percussion of the shock wave, which momentarily opens the vent port, allowing a minute amount of water to escape. The design of vacuum breakers is sensitive to the elevation of the breaker relative to the elevation of the water in the basin. A vacuum breaker mounted too low may allow back-siphonage because the vacuum is too low for the disc to respond.

With back-pressure backflow preventers, a floor drain or indirect waste receptor is required, which complicates its installation, especially in renovation work and for water services. An air gap is required for the relief port, which has its own set of shortfalls. Lastly, the public's perception of backflow preventers is muddled by confusing regulations, misunderstandings

when they fail, and modifications of the air gap when nuisance splashing occurs.

For the reduced-pressure principle backflow preventer, its testing disrupts the water service. In addition, it requires space for its large size and its accessibility requirement. Another hazard exists with this backflow preventer in fire protection supplies because of the additional pressure drop in the water supply in contrast with a single check valve. Reduced-pressure principle backflow preventers also represent a significant flood hazard during low-flow conditions if the upstream check has a slight leak because the pressure will equalize, which opens the relief to the supply pressure.

The vent openings of both active devices and air gaps are prone to splashing and causing wet floors. Each drain with its rim above the floor should be accompanied by a nearby floor drain or indirect waste drain.

In addition to noise, energy consumption, and maintenance, break tanks allow the opportunity for microbial growth. Chlorine eventually dissipates in the open air above the water level if consumption is modest. Lastly, an obstructed overflow pipe may render the air gap ineffective.

Existing water distribution systems and connection points commonly have installation faults. These range from submerged inlets in fixtures or tanks, direct connections to equipment or the sanitary drain system, tape wrapped around air gaps to limit splashing, and the discharge of relief pipes below floor drain rims. In retrofitting existing buildings with backflow prevention on the water services, complete knowledge of the building's water uses is essential. This must be confirmed by a field survey and reviewed by the building's operating personnel. Usually the existing building conditions present even greater challenge in providing backflow prevention. Existing buildings may require additional, more costly, equipment to accommodate the installation of the backflow prevention equipment.

With new construction, the installation of backflow prevention could result in increased drainage costs for RPZ reliefs and the associated water pumping. When providing RPZ-type devices for new construction inside the building, the ideal location is abovegrade on the main floor to minimize the possibility of submerging the relief port. However, on many buildings, this is a difficult location to obtain since the main floor is prime space reserved for building operational functions. If the RPZ must be installed in the space belowgrade, drainage provisions must be considered and designed to accommodate the maximum possible discharge flow. In small basements, the flooding potential is greater and, therefore, must be evaluated more carefully. In all basements, drainage provisions

must include emergency power for pumping as well as constantly monitored flood alarms.

## QUALITY CONTROL

### Product Standards and Listings

For quality assurance in cross-connection control, standard design and device testing have been part of the manufacturing and sale of active control devices. In addition, the product is furnished with an identifying label of the standard, and the model number is furnished in a list that is published by a recognized agency.

### Field Testing

Frequent testing, such as upon installation, upon repairs, and annually, provides additional quality assurance.

Tests for a pressure-type vacuum breaker and a spill-resistant vacuum breaker include observing the opening of the air-inlet disc and verifying the check valve(s). The air-inlet disc shall open at a gauge reading of not less than 1 psig (6.9 kPa) measured with a pressure gauge mounted on the vacuum breaker body. To test the check valve, open the downstream piping and mount a sight glass, open to atmosphere at its top, upstream of the check valve and purge it of air. Then open the supply valve and close it when 42 inches (1,070 mm) of water are in the sight glass. The water level in the sight glass of a properly functioning device will drop as water escapes past the check valve, but it will not drop below 28 inches (710 mm) above its connection point.

Tests for a reduced-pressure principle backflow preventer include verification of each check valve, the downstream shutoff valve, and operation of the relief valve. On a properly functioning device with all air purged, upstream pressure is deliberately applied downstream of the second check valve, and the pressure differential across it is held when the downstream shutoff is both open and closed. In the next test, a pressure differential is observed across the upstream check valve. A defect in the check valve seat will prevent a differential from being held. In the last test, a bypass on the test instrument is opened slowly to begin equalizing the pressure across this check valve, and the pressure differential, for a properly functioning device, is noted as not being less than 3 psi (20.7 kPa) when flow is first observed from the relief port.

### Regulatory Requirements

Authorities having jurisdiction create and enforce legally binding regulations regarding the applications of cross-connection control, the standards and listings for passive and active controls, and the types and frequencies of field testing. The authority may require evidence of field testing by keeping an instal-



lation record of each testable device and all tests of the device.

Authorities having jurisdiction typically are water purveyors, plumbing regulation officials, health department officials, or various qualified agents in contract with government regulators. Regulations of cross-connection control are generally part of a plumbing code, but they may be published by a local health department or as the requirements of a municipal water service connection.

## GLOSSARY

**Absolute pressure** The sum of the indicated gauge pressure and the atmospheric local pressure. Hence, gauge pressure plus atmospheric pressure equals absolute pressure.

**Air gap** A separation between the free-flowing discharge end of a water pipe or faucet and the flood level rim of a plumbing fixture, tank, or any other reservoir open to the atmosphere. Generally, to be acceptable, the vertical separation between the discharge end of the pipe and the upper rim of the receptacle should be at least twice the diameter of the pipe, and the separation must be a minimum of 1 inch (25.4 mm).

**Air gap, critical** The air gap for impending reverse flow under laboratory conditions with still water, with the water valve fully open and one-half atmospheric pressure within the supply pipe.

**Air gap, minimum required** The critical air gap with an additional amount. It is selected based on the effective opening and the distance of the outlet from a nearby wall.

**Approved** Accepted by the authority having jurisdiction as meeting an applicable specification stated or cited in the regulations or as suitable for the proposed use.

**Atmospheric pressure** Equal to 14.7 psig (101 kPa) at sea level.

**Atmospheric vacuum breaker** A device that contains a moving float check and an internal air passage. Air is allowed to enter the passage when gauge pressure is zero or less. The device should not be installed with shutoff valves downstream. The device typically is applied to protect against low hazard back-siphonage.

**Auxiliary water supply** Any water supply on or available to the premises other than the purveyor's approved public potable water supply.

**Backflow** An unwanted flow reversal.

**Backflow preventer** A device that prevents backflow. The device should comply with one or more

recognized national standards, such as those of ASSE, AWWA, or the University of Southern California Foundation for Cross-Connection Control and Hydraulic Research, and with the requirements of the local regulatory agency.

**Back-pressure** Backflow caused by pressure that exceeds the incoming water supply pressure.

**Back-siphonage** A type of backflow that occurs when the pressure in the water piping falls to less than the local atmospheric pressure.

**Barometric loop** A fabricated piping arrangement rising at least 35 feet at its topmost point above the highest fixture it supplies. It is utilized in water supply systems to protect against back-siphonage.

**Containment** A means of cross-connection control that requires the installation of a back-pressure backflow preventer in the water service.

**Contaminant** A substance that impairs the quality of the water to a degree that it creates a serious health hazard to the public, leading to poisoning or to the spread of disease.

**Cross-connection** A connection or potential connection that unintentionally joins two separate piping systems, one containing potable water and the other containing pollution or a contaminant.

**Cross-connection control** Active or passive controls that automatically prevent backflow. Such controls include active and passive devices, standardized designs, testing, labeling, and frequent site surveys and field testing of mechanical devices.

**Cross-connection control program** A program consisting of both containment and point-of-use fixture or equipment isolation. The containment program requires a control installed at the point where water leaves the water purveyor's system and enters the consumer side of the water meter. The isolation program requires an ongoing survey to ensure that there have been no alterations, changes, or additions to the system that may have created or recreated a hazardous condition. Isolation protects occupants as well as the public.

**Double check valve assembly** A device that consists of two independently acting spring-loaded check valves. They typically are supplied with test cocks and shutoff valves on the inlet and outlet to facilitate testing and maintenance. The device protects against both back-pressure and back-siphonage; however, it should be installed only for low hazard applications.

**Double check valve with intermediate atmospheric vent** A device having two spring-loaded

check valves separated by an atmospheric vent chamber.

**Dual check valve assembly** An assembly of two independently operating spring-loaded check valves with tightly closing shutoff valves on each side of the check valves, plus properly located test cocks for the testing of each check valve.

**Effective opening** The diameter or equivalent diameter of the least cross-sectional area of a faucet or similar point at a water discharge through an air gap. For faucets, it is usually the diameter of the faucet valve seat.

**Fixture isolation** A method of cross-connection control in which a backflow preventer is located to correct a cross-connection at a fixture location or equipment location. Such isolation may be in addition to containment.

**Flood level rim** The elevation at which water overflows from its receptacle or basin.

**Flushometer valve** A mechanism energized by water pressure that allows a measured volume of water for the purpose of flushing a fixture.

**Free water surface** A water surface in which the pressure against it is equal to the local atmospheric pressure.

**Hose bibb vacuum breaker** A device that is permanently attached to a hose bibb and acts as an atmospheric vacuum breaker.

**Indirect waste pipe** A drainpipe that flows into a drain system via an air gap above a receptacle, interceptor, vented trap, or vented and trapped fixture.

**Joint responsibility** The responsibility shared by the purveyor of water and the building owner for ensuring and maintaining the safety of the potable water. The purveyor is responsible for protecting their water supply from hazards that originate from a building. The owner is responsible for ensuring that the building's system complies with the plumbing code or, if no code exists, within reasonable industry standards. The owner is also responsible for the ongoing testing and maintenance of backflow devices that are required to protect the potable water supply.

**Negligent act** An act that results from a failure to exercise reasonable care to prevent foreseeable backflow incidents from occurring or when another problem is created when correcting a potential problem. For example, if a closed system is created by requiring a containment device without considering how such a device will alter the hydrodynamics within the system, and this causes the rupture

of a vessel such as a water heater, this could be considered negligent.

**Plumbing code** A legal minimum requirement for the safe installation, maintenance, and repair of a plumbing system, including the water supply system. Where no code exists, good plumbing practice should be applied by following reasonable industry standards.

**Pollutant** A foreign substance that, if permitted to get into the public water system, will degrade the water's quality so as to constitute a moderate hazard or to impair the usefulness or quality of the water to a degree that is not an actual hazard to public health but adversely and unreasonably affects the water for domestic use.

**Potable water** Water that is furnished by the water purveyor with an implied warranty that it is safe to drink. The public is allowed to make the assumption that it is safe to drink by the water purveyor or regulatory agency having jurisdiction.

**Pressure-type vacuum breaker** A device that contains two independently operating valves, a spring-loaded check valve, and a spring-loaded air inlet valve. The device has test cocks for inline testing and two tightly sealing shutoff valves to facilitate maintenance and testing. It is used only to protect against back-siphonage.

**Professional** An individual who, because of his or her training and experience, is held to a higher standard than an untrained person. The professional is exposed to liability for their actions or inaction.

**Reasonable care** Working to standards that are known and accepted by the industry and applying those standards in a practical way to prevent injury or harm via predictable and foreseeable circumstances.

**Reduced-pressure principle backflow preventer** A device consisting of two separate and independently acting spring-loaded check valves, with a differential pressure-relief valve situated between the check valves. Since water always flows from a zone of high pressure to a zone of low pressure, this device is designed to maintain a higher pressure on the supply side of the backflow preventer than is found downstream of the first check valve. This ensures the prevention of backflow. This device provides effective high hazard protection against both back-pressure and back-siphonage.

**Residential dual check** An assembly of two spring-loaded, independently operating check valves without tightly closing shutoff valves and test cocks. Generally, it is employed immediately

downstream of a residential water meter to act as a containment device.

**Special tool** A tool peculiar to a specific device and necessary for the service and maintenance of that device.

**Spill-resistant vacuum breaker** A device containing one or two independently operated spring-loaded check valves and an independently operated spring-loaded air inlet valve mounted on a diaphragm that is located on the discharge side of the check(s). The device includes tightly closing shutoff valves on each side of the check valves and properly located test cocks for testing.

**Survey** A field inspection within and around a building, by a qualified professional, to identify and report cross-connections. Qualification of a professional, whether an engineer or licensed plumber,

includes evidence of completion of an instructional course in cross-connection surveying.

**Vacuum** A pressure less than the local atmospheric pressure.

**Vacuum breaker** A device that prevents back-siphonage by allowing sufficient air to enter the water system.

**Water service entrance** That point in the owner's water system beyond the sanitary control of the water district, generally considered to be the outlet end of the water meter and always before any unprotected branch.

**Water supply system** A system of service and distribution piping, valves, and appurtenances to supply water in a building and its vicinity.



# 10

# Water Treatment

Many types of possible pathogenic organisms can be found in source water. These include dissolved gases, suspended matter, undesirable minerals, pollutants, and organic matter. These substances can be separated into two general categories: chemical and biological. They generally require different methods of remediation. No single filtration or treatment process satisfies all water-conditioning requirements.

Surface water may contain more of these contaminants than groundwater, but groundwater, while likely to contain less pathogens than surface water, may contain dissolved minerals and have undesirable tastes and odors. Water provided by public and private utilities is regarded to be potable, or adequately pure for human consumption so long as it meets the standards of the U.S. Environmental Protection Agency's Safe Drinking Water Act and the local health official. However, such water still might contain some levels of pathogens and other undesirable components. Even if the water quality would not cause a specific health threat to the general public, it may not be suitable for buildings such as hospitals and nursing homes that house populations that may be vulnerable. Moreover, it may not be pure enough for certain industrial, medical, or scientific purposes.

Impure water damages piping and equipment by scoring, scaling, and corroding. Under certain conditions, water containing particles in suspension erodes the piping and scores moving parts. Water containing dissolved acidic chemicals in sufficient quantities dissolves the metal surfaces with which it comes in contact. Pitted pipe and tank walls are common

**Table 10-1 Chemical Names, Common Names, and Formulas**

Chemical Name	Common Name	Formula
Bicarbonate (ion)	—	HCO <sub>3</sub> <sup>-</sup>
Calcium (metal)	—	Ca <sup>2+</sup>
Calcium bicarbonate	—	Ca(HCO <sub>3</sub> ) <sub>2</sub>
Calcium carbonate	Chalk, limestone, marble	CaCO <sub>3</sub>
Calcium hypochlorite	Bleaching powder, chloride of lime	Ca(ClO) <sub>2</sub>
Chlorine (gas)	—	Cl <sub>2</sub>
Calcium sulfate	—	CaSO <sub>4</sub>
Calcium sulfate	Plaster of paris	CaSO <sub>4</sub> ·½H <sub>2</sub> O
Calcium sulfate	Gypsum	CaSO <sub>4</sub> ·2H <sub>2</sub> O
Carbon	Graphite	C
Carbonate (ion)	—	CO <sub>3</sub> <sup>2-</sup>
Carbon dioxide	—	CO <sub>2</sub>
Ferric oxide	Buraf ochre	Fe <sub>2</sub> O <sub>3</sub>
Ferrous carbonate	—	FeCO <sub>3</sub>
Ferrous oxide	—	FeO
Hydrochloric acid	Muriatic acid	HCl
Hydrogen (ion)	—	H <sup>+</sup>
Hydrogen (gas)	—	H <sub>2</sub>
Hydrogen sulfide	—	H <sub>2</sub> S
Iron (ferric ion)	—	Fe <sup>3+</sup>
Iron (ferrous ion)	—	Fe <sup>2+</sup>
Magnesium bicarbonate	—	Mg(HCO <sub>3</sub> ) <sub>2</sub>
Magnesium carbonate	Magnesite	MgCO <sub>3</sub>
Magnesium oxide	Magnesia	MgO
Magnesium sulfate	—	MgSO <sub>4</sub>
Magnesium sulfate	Epsom salt	MgSO <sub>4</sub> ·7H <sub>2</sub> O
Manganese (metal)	—	Mn
Methane	Marsh gas	CH <sub>4</sub>
Nitrogen (gas)	—	N <sub>2</sub>
Oxygen (gas)	—	O <sub>2</sub>
Potassium (metal)	—	K
Potassium permanganate	Permanganate of potash	KMnO <sub>4</sub>
Sodium (metal)	—	Na
Sodium bicarbonate	Baking soda, bicarbonate of soda	NaHCO <sub>3</sub>
Sodium carbonate	Soda ash	Na <sub>2</sub> CO <sub>3</sub>
Sodium carbonate	Sal soda	Na <sub>2</sub> CO <sub>3</sub> ·10H <sub>2</sub> O
Sodium chloride	Salt	NaCl
Sodium hydroxide	Caustic soda, lye	NaOH
Sodium sulfate	Glauber's salt	Na <sub>2</sub> SO <sub>4</sub> ·10H <sub>2</sub> O
Sulfate (ion)	—	SO <sub>4</sub> <sup>2-</sup>
Sulfuric acid	Oil of vitrol	H <sub>2</sub> SO <sub>4</sub>
Water	—	H <sub>2</sub> O

manifestations of the phenomenon called corrosion. Scaling occurs when calcium or magnesium compounds in the water (in a condition commonly known as water hardness) become separated from the water and adhere to the piping and equipment surfaces. This separation is usually induced by a rise in temperature because these minerals become less soluble as the temperature increases. In addition to restricting flow, scaling damages heat-transfer surfaces by decreasing heat-exchange capabilities. The result of this condition is the overheating of tubes, followed by failures and equipment damage.

Changing the chemical composition of the water by means of mechanical devices (filters, softeners, demineralizers, deionizers, and reverse osmosis) is called external treatment because such treatment is outside the equipment into which the water flows. Neutralizing the objectionable constituents by adding chemicals to the water as it enters the equipment is referred to as internal treatment. Economic considerations usually govern the choice between the two methods. Sometimes it is necessary to apply more than one technology. For instance, a water softener may be required to treat domestic water, but a reverse osmosis system may be needed before the water is sent to HVAC or medical equipment. Another example is the need for an iron prefilter to remove large iron par-

ticles to protect a reverse osmosis membrane, which would be damaged by the iron particles.

For reference, the chemical compounds commonly found in water treatment technologies are tabulated in Table 10-1. Table 10-2 identifies solutions to listed impurities and constituents found in water.

### BASIC WATER TYPES

Following are the basic types of water. Keep in mind that these terms often have multiple meanings depending on the context or the discipline being used.

#### Raw Water

Raw water, or natural water, is found in the environment. Natural water is rainwater, groundwater, well water, surface water, or water in ponds, lakes, streams, etc. The composition of raw water varies. Often raw water contains significant contaminants in dissolved form such as particles, ions, and organisms.

#### Potable Water

Potable water as defined in the International Plumbing Code is water free from impurities present in amounts sufficient to cause disease or harmful physiological effects and conforming to the bacteriological and chemical quality requirements of the public health authority having jurisdiction. The U.S. EPA Safe Drinking Water Act defines the requirements for water to be classified as potable. Potable water is

**Table 10-2 Water Treatment—Impurities and Constituents, Possible Effects and Suggested Treatments**

	Possible Effects <sup>a</sup>						Treatment								
	Scale	Corrosion	Sludge	Foamin	Priming	Embrittlement	None (Inert)	Setting, coagulation, filtration, evaporation	Setting, coagulation, filtration, evaporation, ion exchange	Softening by chemicals, ion exchange materials, evaporators	Softening by heaters, chemicals, ion exchange materials, evaporators	Neutralizing, followed by softening or evaporation	Evaporation and demineralization by ion-exchange material	De-aeration	Coagulation, filtration, evaporation
<b>Constituents</b>															
Suspended solids	X		X	X	X			X							
Silica — SiO <sub>2</sub>	X							X							
Calcium carbonate — CaCO <sub>3</sub>	X								X						
Calcium bicarbonate — Ca(HCO <sub>3</sub> ) <sub>2</sub>	X									X					
Calcium Sulfate — CaSO <sub>4</sub>	X	X							X						
Calcium chloride — CaCl <sub>2</sub>	X								X						
Magnesium carbonate — MgCO <sub>3</sub>	X								X						
Magnesium bicarbonate — Mg(HCO <sub>3</sub> ) <sub>2</sub>	X								X						
Magnesium chloride — MgCl <sub>2</sub>	X	X							X						
Free acids — HCl, H <sub>2</sub> SO <sub>4</sub>		X									X				
Sodium chloride — NaCl							X						X		
Sodium carbonate — Na <sub>2</sub> CO <sub>3</sub>				X	X	X							X		
Sodium bicarbonate — NaHCO <sub>3</sub>				X	X	X							X		
Carbonic acid — H <sub>2</sub> CO <sub>3</sub>		X												X	
Oxygen — O <sub>2</sub>		X												X	
Grease and oil		X	X	X	X										X
Organic matter and sewage		X	X	X	X										X

<sup>a</sup> The possibility of the effects will increase proportionately to an increase in the water temperature.

often filtered, chlorinated, and/or otherwise treated to meet these standards for drinking water.

### **Process Wastewater**

Cooling tower water is classified as a process wastewater. Cooling tower water can scale and corrode. When left untreated, cooling tower water can encourage bacteria growth and the subsequent health risks. As with many process wastewaters, cooling tower water is monitored and controlled for pH, algae, and total dissolved solids.

### **Soft and Hard Water**

Soft water contains less than 60 parts per million (ppm) of dissolved calcium or magnesium.

Hard water contains dissolved minerals such as calcium or magnesium in varying levels. As defined by the U.S. Geological Survey, water containing 61–120 ppm of dissolved minerals is considered moderately hard, and water containing 121–180 ppm of dissolved minerals is considered hard. Water containing greater than 181 ppm of dissolved minerals is considered very hard. (Note: pH and temperature affect the behavior of dissolved minerals and should be considered in the design of systems containing hard water.)

### **Deionized Water**

Deionized water has been stripped of mineral ions such as cations from sodium, iron, calcium, and copper as well as anions of chloride and sulfate. However, the deionization process does not remove viruses, bacteria, or other organic molecules. Deionized water is specified in ranges of conductivity.

### **Distilled Water**

Distilled water also meets the requirements of the local health department as well as the Safe Drinking Water Act. Distilling water involves removing the impurities by boiling and collecting the condensing steam into a clean container. Distilled water has many applications, and distillation is commonly the process used to provide bottled water for consumption.

### **Purified Water**

Purified water meets the requirements of the local health department as well as the Safe Drinking Water Act. It is mechanically processed for laboratory or potable water use.

Pure water is a relative term used to describe water mostly free from particulate matter and dissolved gases that may exist in the potable water supply. Pure water is generally required in pharmacies, central supply rooms, laboratories, and laboratory glassware-washing facilities. The two basic types of pure water are high-purity water, which is free from minerals, dissolved gases, and most particulate matter, and biopure water, which is free from particulate matter, minerals, bacteria, pyrogens, organic matter, and most dissolved gases.

Water purity is most easily measured as specific resistance in ohm-centimeters ( $\Omega$ -cm) or expressed as parts per million of ionized salt (NaCl). The theoretical maximum specific resistance of pure water is 18.3 megaohm-centimeters ( $M\Omega$ -cm) at 25°C, a purity that is nearly impossible to produce, store, and distribute. It is important to note that the specific resistance of water is indicative only of the mineral content and in no way indicates the level of bacterial, pyrogenic, or organic contamination.

The four basic methods of producing pure water are distillation, demineralization, reverse osmosis, and filtration. Depending on the type of pure water required, one or more of the methods will be needed. Under certain conditions, a combination of methods may be required. These processes are explained in detail later in the chapter.

## **WATER CONDITIONS AND RECOMMENDED TREATMENTS**

### **Turbidity**

Turbidity is caused by suspended insoluble matter, including coarse particles that settle rapidly in standing water. Amounts range from almost zero in most groundwater and some surface supplies to 60,000 nephelometric turbidity units (NTU) in muddy, turbulent river water. Turbidity is objectionable for practically all water uses. The standard maximum for drinking water is 1 NTU (accepted by industry), which indicates quite good quality. Turbidity exceeding 1 NTU can cause health concerns.

Generally, if turbidity can be seen easily, it will clog pipes, damage valve seats, and cloud drinking water. For non-process water, if turbidity cannot be seen, it should present few or no problems.

Turbidity that is caused by suspended solids in the water may be removed from such water by coagulation, sedimentation, and/or filtration. In extreme cases, where a filter requires frequent cleaning due to excessive turbidity, it is recommended that engineers use coagulation and sedimentation upstream of the filter. Such a device can take the form of a basin through which the water can flow at low velocities to let the turbidity-causing particles settle naturally.

For applications where water demand is high and space is limited, a mechanical device such as a clarifier utilizing a chemical coagulant may be more practical. This device mixes the water with a coagulant (such as ferric sulfate) and slowly stirs the mixture in a large circular container. The coarse particles drop to the bottom of the container and are collected in a sludge pit, while the finer particles coagulate and also drop to the bottom of the container. The clarified water then leaves the device ready for use or further treatment, which may include various levels of filtration and disinfection.

The water provided by municipalities is usually low enough in turbidity and organic constituents to preclude the use of filters, clarifiers, or chlorinators. As always, however, there are exceptions to the rule. When dealing with health and safety or with the operating efficiency of machinery, engineers always must consider the occasional exception.

### Hardness

The hardness of water is due mainly to the presence of calcium and magnesium cations. These salts, in order of their relative average abundance in water, are bicarbonates, sulfates, chlorides, and nitrates. They all produce scale.

Calcium salts are about twice as soluble as magnesium salts in natural water supplies. The presence of bicarbonates of calcium and magnesium produces a condition in the water called temporary hardness because these salts can be easily transformed into a calcium or magnesium precipitate plus carbon dioxide gas. The noncarbonic salts (sulfates, chlorides, and nitrates) constitute permanent hardness conditions.

Hardness is most commonly treated by the sodium-cycle ion exchange process, which exchanges the calcium and magnesium salts for very soluble sodium salts. Only calcium and magnesium (hardness ions) in the water are affected by the softening process, which produces water that is non-scale forming. If the oxygen or carbon dioxide content of the water is relatively high, the water may be considered aggressive.

The carbonic acid may be removed by aeration or degasification, and the remaining acids may be removed by neutralization, such as by blending hydrogen and sodium cation exchanger water. Another method of neutralizing the acid in water is by adding alkali. The advantage of the alkali neutralization method is that the cost of the sodium cation exchange softener is eliminated. However, the engineer may want to weigh the cost of chemicals against the cost of the sodium ion exchange unit.

### Aeration and Deaeration

As hardness in water is objectionable because it forms scale, high oxygen and carbon dioxide contents are also objectionable because they corrode iron, zinc, brass, and several other metals.

Free carbon dioxide ( $\text{CO}_2$ ) can be found in most natural water supplies. Surface waters have the lowest concentration, although some rivers may contain as much as 50 ppm. In groundwater, the  $\text{CO}_2$  content varies from almost zero to concentrations so high that the carbon dioxide bubbles out when the pressure is released.

Carbon dioxide also forms when bicarbonates are destroyed by acids, coagulants, or high temperatures. The presence of  $\text{CO}_2$  accelerates oxygen corrosion.

Carbon dioxide can be removed from water by an aeration process. Aeration is simply a mechanical process that mixes the air and the water intimately. It can be done with spray nozzles, cascade aerators, pressure aerators, or forced draft units. When this aeration process is complete, the water is relatively free of  $\text{CO}_2$  gas.

Water with a high oxygen content can be extremely corrosive at elevated temperatures. Oxygen ( $\text{O}_2$ ) can be removed from the water by a deaeration process. Oxygen becomes less and less soluble as the water temperature increases; thus, it is removed easily from the water by bringing the water to its boiling point.

Pressure and vacuum deaerators are available. When it is necessary to heat the water, as in boilers, steam deaerators are used. Where the water is used for cooling or other purposes where heating is not desired, vacuum units may be employed.

With aerators and deaerators in tandem, water free of  $\text{CO}_2$  and  $\text{O}_2$  is produced.

### Minerals

Pure water is never found in nature. Natural water contains a series of dissolved inorganic solids, which are largely mineral salts. These mineral salts are introduced into the natural water by a solvent action as the water passes through (or across) the various layers of the Earth. The types of mineral salts absorbed by natural water depend on the chemical content of the soil through which the natural water passes before it reaches the consumer. This may vary from area to area. Well water differs from river water, and river water differs from lake water. Two consumers separated by a few miles may have water supplies of very dissimilar characteristics. The concentrations and types of minerals in the same water supply even may vary with the changing seasons.

Many industries can benefit greatly by being supplied with high-grade pure water. These industries are finding that they must treat their natural water supplies in various ways to achieve this condition. The recommended type of water treatment depends on the chemical content of the water supply and the requirements of the particular industry. High-grade pure water typically results in greater economy of production and better products.

Before the advent of the demineralization process, the only method used to remove mineral salts from natural water was distillation. Demineralization has a practical advantage over distillation. The distillation process involves removing the natural water from the mineral salts (or the larger mass from the smaller mass). Demineralization is the reverse of distillation: it removes the mineral salts from the natural water. This renders demineralization the more economical method of purifying natural water in most cases.



Many industries today are turning to demineralization as the answer to their water problems.

The stringent quality standards for makeup water for modern boilers are making demineralizers and reverse osmosis a must for these users. Modern plating practices also require the high-quality water that demineralization produces.

## CHLORINATION

Chlorination of water is most commonly used to destroy organic (living) impurities. Organic impurities fall into two categories: pathogenic, which cause disease such as typhoid and cholera, and nonpathogenic, which cause algae and slime that clog pipes and valves, discolor water, and produce undesirable odors. These pathogenic and nonpathogenic organisms can be controlled safely by chlorine with scientifically engineered equipment to ensure constant and reliable applications. An intelligent choice of the treatment necessary cannot be made until a laboratory analysis of the water has determined its quality and the quantities of water to be used are known. If microorganisms are present in objectionable amounts, a chlorination system is required.

Chlorination traditionally has been used for the disinfection of drinking water. However, the initial investment required to properly chlorinate a potable water supply has, in many cases, restricted its use to the large water consumer or to cities, which have the adequate financial support and sufficient manpower to properly maintain the chlorination system. Another drawback to the use of chlorine as a disinfectant is

that the transportation and handling of a gas chlorination system are potentially dangerous. When the safety procedures are followed, however, there are few problems than with either liquid or solid products.

Chemically, chlorine is the most reactive halogen and is known to combine with nitrogenous and organic compounds to form weak bactericidal compounds. Chlorine also combines with hydrocarbons to form potentially carcinogenic compounds (trihalomethanes).

When chlorine is added to the water, hypochlorous and hydrochloric acids are formed. Hydrochloric acid is neutralized by carbonates, which are naturally present in the water. The hypochlorous acid provides the disinfecting properties of chlorine solutions. Part of the hypochlorous acid is used quickly to kill (by the oxidation process) the bacteria in the water. The remaining acid keeps the water free of bacteria until it reaches the point of ultimate use.

This residual hypochlorous acid can take two forms. It may combine with the ammonia present in almost all waters to form a residual, or chloramine, that takes a relatively long time to kill the bacteria, but it is very stable. Thus, when a water system is large, it is sometimes desirable to keep a combined residual in the system to ensure safety from the treatment point to the farthest end use. If enough chlorine is added to the system, more hypochlorous acid than can combine with the ammonia in the water is present. The excess hypochlorous acid is called free residual. It is quite unstable, but it kills organic matter very quickly. Though the time it takes for this




Figure 10-1 Automatic Chlorinators

**Notes:** The system illustrated in (A) maintains a given residual where the flow is constant or where it changes only gradually. The direct residual control is most effective on recirculated systems, such as condenser cooling water circuits and swimming pools. The desired residual is manually set at the analyzer. The flow is chlorinated until the residual reaches a set upper limit. The analyzer starts the chlorinator and keeps it operating until the residual again reaches the established upper limit. In (B) the compound loop controls the chlorinator output in accordance with two variables, the flow and the chlorine requirements. Two signals (one from the residual analyzer and another from the flow meter), when simultaneously applied to the chlorinator, will maintain a desired residual regardless of the changes in the flow rates or the chlorine requirements.

water to pass from the treatment plant to the point of ultimate use is short, only free residual can ensure that all bacteria will be killed. Maintaining an adequate free residual in the water is the only way to ensure that the water is safe. Its presence proves that enough chlorine was originally added to disinfect the water. If no residual is present, it is possible that not all of the bacteria in the water were killed; therefore, more chlorine must be added.

Chlorine gas or hypochlorite solutions can be readily and accurately added to the water at a constant rate or by proportional feeding devices offered by a number of suppliers. Large municipal or industrial plants use chlorine gas because it is less expensive than hypochlorite solutions and convenient. Chlorinators, such as those shown in Figure 10-1, inject chlorine gas into the water system in quantities proportional to the water flow.

For the treatment of small water supplies, hypochlorite solutions sometimes are found to be more advantageous. In feeding hypochlorite solutions, small proportioning chemical pumps, such as the one illustrated in Figure 10-2, may be used to inject the hypochlorite solution directly into the pipelines or the reservoir tanks.

## CLARIFICATION

Turbid water has insoluble matter suspended in it. As turbidity in the water increases, the water looks more clouded, is less potable, and is more likely to clog pipes and valves.

Particles that are heavier than the fluid in which they are suspended tend to settle due to gravity according to Stokes' law:

### Equation 10-1

$$v = \frac{kd^2(S_1 - S_2)}{z}$$

where

- $v$  = Settling velocity of the particle
- $k$  = Constant, usually 18.5
- $d$  = Diameter of the particle
- $S_1$  = Density of the particle
- $S_2$  = Density of the fluid
- $z$  = Viscosity of the fluid

From Equation 10-1, it can be seen that the settling velocity of the particle decreases as the density ( $S_2$ ) and the viscosity ( $z$ ) of the fluid increase. Because the density and viscosity of the water are functions of its temperature, it is readily understood why, for example, the rate of the particle settling in the water at




Figure 10-2 Manual Control Chlorinator

a temperature of 32°F is only 43 percent of its settling rate at 86°F. Therefore, the removal of water turbidity by subsidence is most efficient in the summer.

Where the water turbidity is high, filtration alone may be impractical due to the excessive requirements for backwash and media replacement. Subsidence is an acceptable method for the clarification of water that permits the settling of suspended matter.

Although water flow in a horizontal plane does not seriously affect the particle's settling velocity, an upward flow in a vertical plane prevents particle settling. The design of settling basins should, therefore, keep such interferences to a minimum. For practical purposes, the limit for solids removal by subsidence is particles of 0.01 millimeter or larger in diameter. Smaller particles have such a low rate of settling that the time required is greater than can be allowed. Figure 10-3 shows a typical design of a settling basin. Obviously, when a large volume of water is being handled, the settling basin occupies a large amount of space. Also, it can present safety and vandalism problems if not properly protected.

Where space is limited, a more practical approach might be the use of a mechanical clarifier that employs chemical coagulants (see Figure 10-4). Such devices can be purchased as packaged units with simple in-and-out connections. Many chemical coagulants currently are available, including aluminum sulfate, sodium aluminate, ammonium alum, ferric sulfate, and ferric chloride. Each coagulant works better than the others in certain types of water. However, no simple rules guide the engineer in the choice of the proper coagulant, coagulant dosages, or coagulant aids. Water analysis, water temperature, type of clarification equipment, load conditions, and end use of the treated water are some of the factors that influence the selection of the proper coagulant. A few

tests conducted under actual operating conditions can assist the designer in achieving the best results.

Water leaves the settling basin on the mechanical clarifier at atmospheric pressure. Thus, the designer should bear in mind that the outputs must be pumped into the water distribution system.





Figure 10-3 Settling Basin



Notes: The turbid water enters the central uptake mixed with the coagulant and is forced toward the bottom of the unit. Some water and the suspended precipitates enter the lower end of the uptake for recirculation and contact with the incoming chemicals and the water. New coagulation is encouraged by contact with these previously formed precipitates. The water then enters the outer settling section. The clarified water rises to the outlet flume above. The heavier particles settle and are moved along the bottom to the sludge pit.

Figure 10-4 Mechanical Clarifier

## FILTRATION

Filtration is the process of passing a fluid through a porous medium to physically remove suspended solids. Various types of filters are available, ranging from a back-washable filter to filter cartridge housing. Depending on the type of filter, a drain may be required.

Where a clarifier of the type described above precedes the filters, the heavier, coagulated particles are removed from the water, and only the smaller, lighter particles reach the filter bed. As the suspended particles lodge between the grains of the filter medium, flow is restricted. The coagulated particles build up on the surface of the filter bed. Penetration of the filter medium by the coagulated particles is achieved at the surface in the first device or 2 inches of the bed. This coagulated mat then acts as a fine filter for smaller particles. The normal water flow rate for most filters is 3 gallons per minute (gpm) per square foot of filter area. Recent design improvements in coagulation have enabled flow rates as high as 5 gpm to 6 gpm for gravity filters.

The filter medium should be selected to provide a top layer coarse enough to allow some penetration of the top few inches of the bed by the coagulated material. Where a clarifier employing a chemical coagulant is placed ahead of the filters, a separate coagulant feed should be used to form a mat on the filter bed surface. Alum commonly is used for this purpose at a rate of about 1/10 pound for each square foot of filter bed surface. This coagulant mat should be replaced after each backwash.

Filters are either gravity or pressure type.

### Gravity Filters

As their name implies, the flow of water through gravity filters is achieved by gravity only.

The filter vessel may be rectangular or circular in configuration and made of steel or concrete. The filter most commonly used is the rectangular concrete unit illustrated in Figure




Figure 10-5 Rectangular Gravity Sand Filter

10-5. This unit has a very basic design. In its more sophisticated form, the gravity filter has storage wells for the clarified water, wash troughs for even collection of the backwash, and compressed air systems for agitation of the sand during backwash.

The advantages of the gravity filter over the pressure filter are that the filter sand can be easily inspected and the application of a coagulant is usually more easily controlled. The disadvantages are the initial pressure loss, requiring pumping of the water to pressurize the distribution system, the additional space required for installation, and the possibility of outside bacterial contamination.

### Pressure Filters

Pressure filters are more widely favored in industrial and commercial water-conditioning applications. These units have an advantage in that they may be placed in the line under pressure, eliminating the need to repump the water.

The design of the pressure filter is similar to that of a gravity filter with respect to the filter medium, gravel bed, underdrain system, and control devices. The filter vessel is usually a cylindrical steel tank.

Vertical pressure sand filters, such as the one shown in Figure 10-6, range in diameter from 1 foot to 10 feet with capacities from 210 gpm to 235 gpm at an average filter rate of 3 gpm per square foot.

Multimedia depth filters are replacing single-media pressure filters. The depth filter has four layers of filtration media, each of a different size and density. The media become finer and denser in the lower layers. Particles are trapped throughout the bed, not just in the top few inches, which allows a depth filter to run longer and use less backwash water.

Horizontal pressure sand filters, usually about 8 feet in diameter and 18 feet to 30 feet in length, have a water flow rate range of 218 gpm to 570 gpm. The industry trend in recent years has been back to the horizontal pressure sand filters, which provide the advantages of a vertical filter with a lower installed cost. When the filter tank is used in its horizontal position, a larger bed area can be obtained, thus increasing the flow rate available from a given tank size.

High-rate pressure filters, with filtration rates of 20 gpm per square foot, have proven to be very efficient in many industrial applications. The design overcomes the basic problem of most sand and other single-medium filters, which provide a maximum filtering efficiency only in the top few inches of the filter bed. The high-rate depth filters work at a maximum efficiency throughout the entire filter bed.

As with any mechanical device, proper operation and maintenance are key to continued high operating efficiency. Chemical pretreatment often is used to enhance filter performance, particularly when the turbidity includes fine colloidal particles.




Figure 10-6 Vertical Pressure Sand Filter




Figure 10-7 Backwashing




Figure 10-8 Filtration and Backwash Cycles

## Backwashing

As the suspended particles removed from the water accumulate on the filter material, it should be cleaned to avoid any excessive pressure drops at the outlet and the carryover of turbidity. The need for cleaning, particularly in pressure filters, is easily determined through the use of pressure gauges, which indicate the inlet and outlet pressures. Generally, when the pressure drop exceeds 5 pounds per square inch (psi), backwashing is in order.

In this process (see Figure 10-7), the filtered water is passed upward through the filter at a relatively high flow rate of 10–20 gpm per square foot. The bed should expand at least 50 percent, as illustrated in Figure 10-8. This process keeps the grains of the filter medium close enough to rub each other clean, but it does not lift them so high that they are lost down the drain. Backwashing can be automated by employing pressure differential switches (electronically, hydraulically, or pneumatically) to activate the diaphragm or control valves that initiate the backwash cycle at a given pressure drop.

Some problems connected with filter beds are illustrated in Figures 10-9 through 10-11. Extremely turbid water or insufficient backwashing causes accumulations called mudballs (see Figure 10-9). If not removed, mudballs result in uneven filtration and short filter runs and encourage fissures. When the filter bed surface becomes clogged with these deposits and simple backwashing does not remove them, the filter may need to be taken out of service and drained and the deposits removed by hand skimming, or the filter must be rebedded.

When fissures occur in the sand bed (see Figure 10-10), the cause usually can be traced to one or a combination of three items: the inlet water is not being distributed evenly or is entering at too high a velocity; backwash water is not being distributed evenly or is entering at too high a velocity; or mudballs have stopped the passage of water through certain areas and raised velocities in others. The filter must be drained and opened and the filter medium cleaned and reoriented.

Gravel upheaval (see Figure 10-11) usually is caused by violent backwash cycles during which water is distributed unevenly or velocities are too high. If not corrected, fissures are encouraged, or worse, filter media is allowed to pass into the distribution system where it may seriously damage valves and equipment as well as appear in potable water.

## Diatomaceous Earth Filters

The use of diatomaceous earth as a water-filtering medium achieved prominence during the 1940s as a result of the need for a compact, lightweight, and portable filtering apparatus.




Figure 10-9 Mudballs




Figure 10-10 Fissures




Figure 10-11 Gravel Upheaval

The water enters the filter vessel and is drawn through a porous supporting base that has been coated with diatomaceous earth. Filter cloths, porous stone tubes, wire screens, wire wound tubes, and porous paper filter pads are some of the support base materials most commonly used today. Figure 10-12 illustrates a typical leaf design filter.




Figure 10-12 Leaf Design, Diatomaceous Earth Filter

Diatomaceous earth, or silica ( $\text{SiO}_4$ ), is produced from mineral deposits formed by diatoms, or fossilized plants that are similar to algae. Deposits of diatoms have been found as much as 1,400 feet in thickness. Commercial filter aids are produced from the crude material by a milling process that separates the diatoms from one another. The finished product is in the form of a fine powder.

When diatomaceous earth forms a cake on the support base, a filter of approximately 10 percent solids and 90 percent voids is achieved. The openings in this filter are so small that even most bacteria are strained out of the water. However, the openings in the support base are not small enough initially to prevent the passage of individual diatomite particles. Some of these diatomite particles pass through the support base during the precoating operation. However, once the formation of the coating is complete, the interlocked mass of diatomite particles prevents any further passage of the particles.

Commercial diatomaceous earth is manufactured in a wide range of grades with differing filtration rates and differences in the clarity of the filtered water. The advantages of diatomaceous earth filters, as compared to pressure sand filters, are a considerable savings in the weight and required space, a higher degree of filtered water clarity and purity in the outgoing water, and no required coagulant use. One disadvantage is that only waters of relatively low turbidity can be used efficiently. It is not advisable to use these filters where incoming water turbidities exceed 100 ppm, since low-efficiency, short filter runs will result. Other disadvantages are that the initial and operating costs usually far exceed those of conventional sand filters and that the incidence of high pressure drop across the unit (as much as 25 to 50 psi) and intermittent flows cause the filter cake to detach from the support base.

## DEMINERALIZATION

Sometimes called deionization, demineralization produces high-purity water that is free from minerals, most particulate matter, and dissolved gases. Depending on the equipment, the treated water can have a specific resistance of 50,000  $\Omega$  to nearly 18 M $\Omega$ . However, it can be contaminated with bacteria, pyrogens, and organics, as these can be produced inside the demineralizer itself. Demineralized water can be used in most laboratories, in laboratory glassware-washing facilities as a final rinse, and as pretreatment for still feed water.

The typical demineralizer apparatus consists of either a two-bed unit with a resistivity range of 50,000  $\Omega$  to 1 M $\Omega$  or a mixed-bed unit with a resistivity range of 1 M $\Omega$  to nearly 18 M $\Omega$ . The columns are of an inert material filled with a synthetic resin that removes the minerals by an ionization process. Since the unit runs on pressure, a storage tank is not required or recommended, as bacteria may grow in it. A demineralizer must be chemically regenerated periodically, during which time no pure water is being produced. If a continuous supply of water is needed, a backup unit should be considered, as the regeneration process takes several hours. An atmospheric, chemical-resistant drain is needed, and higher-pressure water is required for backwash during regeneration.

If deionized water is required in a small amount and the facility does not want to handle the regenerant chemicals and/or the regenerant wastewater, it may contract with a deionized water service provider to supply the facility with the quality and quantity of deionized water required. The service deionized water (SDI) provider furnishes the facility with service deionized water exchange tanks to supply the quality, flow rate, and quantity of water required. When the tanks are exhausted, the SDI provider furnishes a new set of tanks. The SDI provider takes the exhausted tanks back to its facility for regeneration.

## Ion Exchange

According to chemical theory, compounds such as mineral salts, acids, and bases break up into ions when they are dissolved in water. Ions are simply atoms, singly or in groups, that carry an electric charge. They are of two types: cation, which is positively charged, and anion, which is negatively charged. For example, when dissolved in water, sodium chloride ( $\text{NaCl}$ ) splits into the cation  $\text{Na}^+$  and the anion  $\text{Cl}^-$ . Similarly, calcium sulfate ( $\text{CaSO}_4$ ) in solution is present as the cation  $\text{Ca}^{2+}$  and the anion  $\text{SO}_4^{2-}$ . All mineral salts in water are in their ionic form.

Synthetic thermosetting plastic materials, known as ion exchange resins, have been developed to remove these objectionable ions from the solution and to produce very high-purity water. These resins

are small beads (or granules) usually of phenolic, or polystyrene, plastics. They are insoluble in water, and their basic nature is not changed by the process of ion exchange. These beads (or granules) are very porous, and they have readily available ion exchange groups on all internal and external surfaces. The electrochemical action of these ion exchange groups draws one type of ion out of the solution and puts a different one in its place. These resins are of three types: cation exchanger, which exchanges one positive ion for another, anion exchanger, which exchanges one negative ion for another, and acid absorber, which absorbs complete acid groups on its surface.

A demineralizer consists of the required number of cation tanks and anion tanks (or, in the case of monobeds, combined tanks) with all of the necessary valves, pipes, and fittings required to perform the steps of the demineralization process for the cation resin, as well as an acid dilution tank material for the cation resin and an acid dilution tank, as sulfuric acid is too concentrated to be used directly. If hydrochloric acid is to be used as a cation regenerant, this mix tank is unnecessary since the acid is drawn in directly from the storage vessel. A mixing tank for soda ash or caustic soda, used in anion regeneration, is always provided.

Since calcium and magnesium in the raw regenerant water precipitate the hydroxide (or carbonate) salts in the anion bed, the anion resin must be regenerated with hardness-free water. This condition may be accomplished either with a water softener (which may be provided for this purpose) or by use of the effluent water from the cation unit to regenerate the anion resin. The use of a softener decreases the regeneration time considerably, as both units may be regenerated simultaneously rather than separately.

Provided with each unit is a straight reading volume meter, which indicates gallons per run as well as the total volume put through the unit. Also provided with each unit is a conductivity and resistivity indicator used to check the purity of the effluent water at all times. This instrument is essentially a meter for measuring the electrical resistance of the treated water leaving the unit. It consists of two principal parts: the conductivity cell, which is situated in the effluent line, and the instrument box to which the conductivity cell is connected.

The conductivity cell contains two electrodes across which an electric potential is applied. When these poles are immersed in the treated water, the resistance to the flow of the electricity between the two poles (which depends on the dissolved solids content of the water) is measured by a circuit in the instrument. The purity of the water may be checked by reading the meter. When the purity of the water is within the specific limits, the green light glows.

When the water becomes too impure to use, the red light glows. In addition, a bell may be added that rings when the red light glows to provide an audible as well as a visible report that the unit needs regeneration. This contact also can close an effluent valve, shift operation to another unit if desired, or put the unit into regeneration.

### Controls

Several types of controls are currently available to carry out the various steps of regeneration and return to service. The two most common arrangements follow:

- Type A: This consists of completely automatic, individual air- or hydraulic-operated diaphragm valves controlled by a sequence timer, and regeneration is initiated via a conductivity meter. This arrangement provides maximum flexibility in varying amounts and concentrations of regenerants, length of rinsing, and all other steps of the operating procedure. The diaphragm valves used are tight seating, offering maximum protection against leakage and thus contamination with minimal maintenance.
- Type B: This consists of manually operated individual valves. This system combines maximum flexibility and minimal maintenance with an economical first cost. It typically is used on larger installations.




Figure 10-13 Ion Exchange Vessel—Internal Arrangement




Figure 10-14 Hydrogen-Sodium Ion Exchange Plant




Figure 10-15 Sodium Cycle Softener Plus Acid Addition

### Internal Arrangements

The internal arrangements of the vessels are similar for all types of controls. The internal arrangement used on medium to large units is shown in Figure 10-13. Smaller units have simpler arrangements since the distribution problems are less complex. The positive and thorough distribution of regenerants, rinse, and wash waters to achieve maximum efficiency provides economy and reliability.

### Ion Exchange Water Softeners

A typical hydrogen-sodium ion exchange plant is shown in Figure 10-14. This process combines sodium-cycle ion exchange softening with hydrogen-cycle cation exchange.

The sodium ion exchange process is exactly the same as a standard ion exchange water softener. The hardness (calcium and magnesium) is replaced with sodium (non-scaling). The alkalinity (bicarbonates) and other anions remain as high as in the raw water.

The cation exchanger is exactly the same as the one used with demineralizers; therefore, its effluent contains carbonic acid, sulfuric acid, and hydrochloric acid. Sodium ion exchange units are operated in par-

allel, and their effluents are combined. Mineral acids in the hydrogen ion exchange effluent neutralize the bicarbonates in the sodium ion exchange effluent. The proportions of the two processes are varied to produce a blended effluent having the desired alkalinity. The carbon dioxide is removed by a degasifier. The effluent is soft, low in solids, and as alkaline as desired.

In the sodium ion exchange softener plus acid addition process (see Figure 10-15), the acid directly neutralizes the bicarbonate's alkalinity to produce a soft, low-alkaline water. The carbon dioxide produced is removed by a degasifier. The chief disadvantages of this process are that the total dissolved solids are not reduced and control of the process is difficult.

In a sodium ion exchange softener plus chloride dealkalizer process, water passes first through the sodium ion exchange softener, which removes the hardness, and then through a chloride dealkalizer, which is an ion exchanger that operates in the chloride cycle. The bicarbonates and sulfates are replaced by chlorides. The resin is regenerated with sodium chloride (common salt). The equipment is the same as that for sodium ion softeners. This process produces soft, low-alkaline water. Total dissolved solids are not reduced, but the chloride level is increased. The chief advantages of this process are the elimination of acid and the extreme simplicity of the operation. No blending or proportioning is required.

In some cases, the anion resin can be regenerated with salt and caustic soda to improve capacity and reduce the leakage of carbon dioxide.

## WATER SOFTENING

Water softening is required for practically all commercial and industrial building water usage. Generally speaking, almost any building supplied with water having a hardness of 3.5 grains per gallon (gpg) or



more should have a water softener. This is true even if the only usage of the water other than for domestic purposes is for heating because the principal threat to water heater life and performance is hard water. Approximately 85 percent of the water supplies in the United States have hardness values above the 3.5 gpg level.

However, it is not good practice to specify a water softener to supply the heating equipment only and disregard the softening needs for the balance of the cold water usage in the building. A typical example of this condition is a college dormitory. Many fixtures and appliances in a dormitory in addition to the hot water heater require soft water, including the piping itself, flush valve toilets, shower stalls, basins, and laundry rooms. Many fixtures and appliances that use a blend of hot and cold water experience scale buildup and staining, even when the hot water is softened.

One of the most common reasons for installing water softening equipment is to prevent hardness scale buildup in piping systems, valves, and other plumbing fixtures. Scale builds up continually and at a faster rate as the temperature increases. The graph in Figure 10-16 illustrates the degree of scale deposit and the rate increase as the temperature of the water is elevated on water having a hardness of 10 gpg. For water of 20-gpg hardness, scale deposit values can be multiplied by two. Although the rate of scale deposit is higher as the temperature increases, significant scale buildup occurs with cold water. Thus, the cold water scale, while taking a longer period to build up, is nevertheless significant.

### Water Softener Selection

The factors the designer should consider in sizing water softeners include the following: flow rate, softener capacity, frequency of regeneration, single versus multiple systems, space requirements, cost, and operating efficiency.

#### Flow Rate

After determining the total flow rate requirements for the building, including all equipment, the engineer can consider the size of the water

softener. The unit selected should not restrict the water flow rate beyond the pressure loss that the building can withstand, based on the pressures available at the source and the minimum pressure needed throughout the entire system. A water softener that meets both flow rate and pressure drop requirements should be selected.

The softener system also should be capable of providing the design flow rates within the desired pressure drop. This means not only that the pipe and valve sizes must be adequate, but also that the water softener tank and its mineral must be capable of handling the flows while providing the soft water. The water softener design should be based on hydraulic and chemical criteria.

Good design practices for general use dictate that service flow rates through the water softener be approximately 1–5 gpm per cubic foot with mineral bed depths of 30 inches or more. Based on these accepted practices, the water softener is generally able to handle peak flows for short periods.

Standard softener units are designed for a pressure differential of approximately 15 psi, the most common differential acceptable for building design. Thus,




Figure 10-16 Lime Deposited from Water of 10 Grains Hardness as a Function of Water Use and Temperature

for general usage, a water softener may be selected from a manufacturer's catalog. The engineer should give more detailed consideration to the selection of a water softener where especially low pressure losses are needed. Many equipment manufacturers offer complete pressure drop curves for their equipment, allowing the selection of components to fit any flow pressure drop conditions desired.

### ***Fixture Count Flow Rate Estimating Guide for Water Softeners***

This guide is for estimating average and maximum flow rate requirements (in gallons per minute) for both private and public buildings and is based on fixture flow rates and probability of use. It is to be used when actual continuous and peak flow rates are not known.

The average rates may be used when line pressure less the conditioner pressure drop is at least 30 psi at the highest point of use in the building. The maximum rates are equal to the fixture count figures commonly used to size water lines and are applicable especially in low water pressure areas where pressure drop is critical.

1. Count and list each type of fixture used intermittently. Multiply the total of each type by its private or public unit weight. Private or public unit weights must be determined by the use of the fixture. For example, lavatories in an apartment house are private. Lavatories in a restaurant are public. Add the products of each type of fixture to determine the total fixture count weight.
2. From the intermittent flow rate chart, select the total fixture count, or the next highest fixture count, determined in step 1.
3. Add to the flow rate determined in step 2 any continuously used flow rates in gallons per minute. These additional requirements may include commercial dishwashers, garbage disposals that run continually, boiler makeup water, or swimming pool makeup water. In some cases, these additional requirements are seasonal and used separately. For example, if boilers are shut down during the summer, use the additional requirement of the boiler or the air-conditioning system, whichever is greater.

#### ***Example 10-1***

For example, the flow rate for a 10-unit apartment building can be estimated as follows. In addition to the fixtures listed, the building has one air-conditioner with 5-gpm makeup. (Refer to the local code for the specific water supply load values used in the area.)

<b>Fixtures</b>	<b>Unit Weight</b>	<b>Total Weight</b>
10 kitchen sinks	× 2	= 20
10 bathtub/showers	× 2	= 20
10 lavatories	× 1	= 10
10 tank-type toilets	× 3	= 30
3 washing machines	× 2	= 6
<b>Total</b>		<b>= 86</b>

For a total of 86 fixture units, the corresponding flow rate is 31 gpm. Add 31 gpm to 5 gpm for the air-conditioner:  $31 + 5 = 36$  gpm. Select the smallest unit that has a continuous flow rate of 36 gpm.

4. Select the smallest water conditioner with a continuous flow rate that is equal to or greater than the total flow rate requirement in step 3.

The line pressure less the pressure drop of the selected unit must be at least 30 psi to handle the peak flow rate periods. If it is less than 30 psi, repeat step 2 using the maximum column on the intermittent flow rate chart and add the additional requirements of step 3. Select a water conditioner with a continuous flow rate that is equal to or greater than the new total flow rate requirement.

When the maximum figures are used, the line pressure less the conditioner pressure drop must be 20 psi minimum

Note: When water conditioners are installed in series, such as an iron filter in a water softener, the 30-psi and 20-psi minimum pressures must be maintained after both units. Select combinations of conditioners with a total pressure drop, when subtracted from the line pressure, of 30 psi minimum when using the average figures or 20 psi when using the maximum figures.

Where measurements of water consumption are not possible—for instance, where water meter records are not available—the information in Table 10-3 can be used to estimate the amount of water consumed in several establishments. (Note: For more accurate figures, take meter readings during average or peak periods—a week or a month. Water bills may be used to determine daily water consumption.) If manually operated equipment is desired, longer periods between regenerations may be desired to reduce the attention that an operator must give to the water softener. Thus, larger-capacity units must be selected.

#### ***Softener Capacity***

Once the size of the water softener is selected based on flow rate and pressure drop, the designer should consider the length of the service run. For each standard-size water softener, a nominal quantity of

softening mineral is used. This amount is based on the recommended depth of the mineral (normally 30–36 inches) and the proper free-board space above the mineral (the space required for the proper expansion of the mineral during backwashing). Thus, from the unit initially selected, a standard capacity is known.

The capacity of a water softener is its total hardness exchange ability, generally expressed in terms of grains exchange. The normal capacity of available softening mineral (resins) is 20,000–30,000 grains for each cubic foot of mineral. Thus, the total capacity

for the water softener is obtained by multiplying this value by the number of cubic feet of mineral in the water softener. The hardness of the raw water must be ascertained. By dividing the water hardness (grains per gallon), expressed as  $\text{CaCO}_3$  equivalent, into the total softener capacity (grains), the designer can determine the number of gallons of soft water that the unit will produce before requiring regeneration.

Knowing (or estimating) the total gallons of water used per day indicates the frequency of regeneration. Most often, it is best to have a slight reserve capacity to accommodate any small increases in water usage.

Softening is not really a form of water purification since the function of a softener is to remove only the hardness (calcium and magnesium) from the water and substitute, by ion exchange, the softer element of sodium. Softeners frequently are used in hard water areas as pretreatment to distillation to simplify maintenance. They are often necessary as a pretreatment to deionizers and reverse osmosis, depending on the analysis of the feed water and the type of deionizer.

The following steps should be taken prior to selecting a water softener.

1. Perform a water analysis by analyzing the water with a portable test kit, obtaining a water analysis from the local authorities, or sending a water sample to a qualified water testing lab.
2. Determine the water consumption using sizing charts or consumption figures from water bills or by taking water meter readings.
3. Determine continuous and peak flow rates using the fixture count flow rate estimating guide to determine the required flow rate, obtaining flow rate figures for the equipment to be serviced, or by taking water meter readings during peak periods of water consumption.
4. Determine the water pressure by installing a pressure gauge. If there is a well supply, check the pump's start and stop settings.
5. Determine the capacity: gallons per day  $\times$  grains per gallon = grains per day.
6. Select the smallest unit that can handle the maximum capacity required between regenerations with a low salt dosage. Avoid sizing equipment with the high dosage unless there is reason to do so, such as a high-pressure boiler.

#### **Example 10-2**

For example, the capacity required is 300,000 grains. What size unit should be selected?

A 300,000-grain unit will produce this capacity when regenerated with 150 pounds of salt.

A 450,000-grain unit will produce this capacity when regenerated with 60 pounds of salt.

**Table 10-3 Water Consumption Guide**

<b>Apartments</b>	
One-bedroom units	1.75 people/apartment
Two-bedroom units	Three people/apartment
Three-bedroom units	Five people/apartment
Full line	60 gpd/person
Hot only	25 gpd/person
One bath	1.5 gpm/apartment
Two baths	2.5 gpm/apartment
Barber shops	75 gpm/chair
Beauty shops	300 gpd/person
Bowling alleys	75 gpd/lane
<b>Factories (not including process waters)</b>	
With showers	35 gpd/person/shift
Without showers	25 gpd/person/shift
<b>Farm animals</b>	
Dairy cow	35 gpd
Beef cow	12 gpd
Hog	4 gpd
Horse	12 gpd
Sheep	2 gpd
Chickens	10 gpd/100 birds
Turkeys	18 gpd/100 birds
Hospitals	225 gpd/bed (Estimate air-conditioning and laundry separately.)
<b>Motels (Estimate the restaurant, bar, air-conditioning, swimming pool, and laundry facilities separately, and add these to the room gallonage for total consumption.)</b>	
Full line	100 gpd/room
Hot only	40 gpd/room
Mobile home courts	Estimate 3.75 people/home, and estimate 60 gpd/person. (Outside water for sprinkling, washing cars, etc., should be bypassed.)
<b>Restaurants</b>	
Total (full line)	8 gal/meal
Food preparation (hot and cold)	3 gal/meal
Food preparation (hot only)	1.5 gal/meal
Cocktail bar	2 gal/person
Rest homes	175 gpd/bed (Estimate laundry separately.)
<b>Schools</b>	
Full line	20 gpd/student
Hot only	8 gpd/student
Trailer parks	100 gpd/space

The 450,000-grain unit is the better selection to remove 300,000 grains. The salt consumption will be 75 pounds per regeneration as opposed to 150 pounds for the smaller unit, a 50 percent salt consumption savings. It should be noted that while a salt savings is realized in using the lower salting rate on the larger unit, hardness leakage will increase. If minimum hardness leakage is required, such as for boiler feed water, the maximum salting rate (15 pounds per cubic foot) should be used.

7. Determine if the unit selected will deliver the required flow rate.
  - a. When sizing to a continuous flow rate, subtract the pressure drop from the line pressure. At least 30 psi should be left for the working pressure.
  - b. When sizing to a peak flow rate, subtract the pressure drop from the line pressure. At least 20 psi should be left for the working pressure.

If one of those options results in less than the minimum allowable working pressure, select a larger model that has a higher flow rate. The water softener requires a dynamic pressure of 35 psi to draw brine.

8. Compare the dimensions of the unit selected with the space available for installation.
9. Make sure both the softener and the brine tank will fit through all doors and hallways to the installation area. If not, a twin unit or smaller brine tank may be used.
10. Make sure a drain is available that will handle the backwash flow rate of the unit selected. Refer to the specification sheet for backwash flow rates.

### ***Single or Multiple Systems***

A single-unit softener will bypass the hard water during periods of regeneration (normally 1.5 hours). This is the danger with a single-unit softener. If soft water requirements are critical and adequate soft water storage is not available, a twin or duplex water softener will be needed.

### ***Space Needs***

Many times a softener system is selected without much concern for space needs. Generally, sufficient floor space is available, although this factor should not be overlooked for storage. More commonly overlooked is the actual height of the softener tank and the additional height required (24 inches) for access through the top manhole opening for loading the unit. If height in the room is critical, the upper manhole can be located on the upper side shell of the softener tank (if so specified).

Severe room height restrictions normally require specifying a large-diameter, squat softener tank with

the same specified quantity of softening mineral. Further consideration must be given to the floor space around the equipment, particularly around the salt tanks, for loading purposes and accessibility for servicing the unit.

Where water softeners are installed in existing buildings, the door openings should be checked for passage of the softener equipment to the final loading.

### ***Cost***

Technical advances in the water-softening industry and increasing labor costs are, for the most part, responsible for the fact that almost all equipment produced is operated automatically. For budget-estimating purposes, automatic water-softening costs range from \$15 to \$40 per 1,000 grains of exchange capacity, depending on the degree of sophistication. This estimate is based on the total capacity of all units.

### ***Operating Efficiency***

Most water softeners are alike in terms of their operation. Their basic operating cost is the salt consumption. Practically all use a high-capacity, resinous mineral. The mineral can exchange 30,000 grains of hardness per cubic foot of mineral when regenerated with 15 pounds of salt, which is the nominal standard rating currently used in the industry.

As salt is the basic commodity that affects the operating cost, it is the only area where reduced costs may be considered. Fortunately, the softening mineral can be regenerated at different salt levels, yielding actual cost savings on the salt consumption. As indicated, with a 15-pound salt level, 30,000 gains per cubic foot can be obtained. With a salt dosage of 10 pounds or 6 pounds, a resulting capacity yield of 25,000 gains per cubic foot or 20,000 gains per cubic foot respectively is obtained.

Thus, approximately a 40 percent salt rating can be effected at the lower salt level. The lower salt levels can be used effectively on general applications, resulting in lower operating costs. However, where very high-quality soft water is required in an area where very hard water exists, this approach is not recommended.

### ***Sizing***

Figure 10-17 can be used to develop the data required to size the basic softening equipment. The final selection of a system for specification should be made using this information. In many cases, the importance of the water-softening equipment justifies calling on manufacturers' representatives for their recommendations. Their specialized knowledge can help in the design of a reliable, economical water softener system. Figure 10-18 provides a step-by-step procedure for selecting the water softener equipment.

### Salt Recycling Systems

To increase the efficiency of the water softener in terms of salt consumption and water usage during the regeneration cycle, one option to consider is the use of a salt recycling system. It is essentially a hardware modification available for both new and existing water softeners that immediately reduces the amount of salt needed to regenerate a softener by 25 percent, without any loss of resin capacity or treated water quality. It works best with water softener equipment that utilizes a nested diaphragm valve configuration as seen in Figure 10-19. It is not recommended for water softeners that utilize a top-mounted, multi-port motorized control valve.

The salt recycling process adds a brine reclaim step to the regeneration process after the brine draw has occurred. During brine reclaim, used dilute brine flow is diverted from the drain and routed back to the brinemaker tank where it is stored and resaturated for later use, thereby saving both salt and water. The salt savings occur because the make-up water to the brinemaker contains approximately 25 percent of the salt needed for the next regeneration. Therefore, only 75 percent of “new” salt is dissolved for the next regeneration. Water savings occur because the recycled brine is not discharged to drain but is used to make up the brine solution for the next regeneration. The effective salt dosage for the water softener is unchanged; therefore, the 25 percent salt savings can be realized in softener systems that use both maximum and minimum salt dosages.

The hardware package consists of a diverter valve (see Figure 10-19) in the drain line that routes the recycled brine to the brinemaker tank and a modi-

fied control system that incorporates the extra brine reclaim step.

### Salt Storage Options

A few options for salt storage are available. Salt blocks and bags of salt, or beads, may not be suitable for large systems in which dozens or even hundreds of pounds may be needed on a daily basis. These systems may require bulk salt storage and delivery systems, consisting of an aboveground storage tank that is loaded directly from salt trucks. The salt then is conveyed through piping to the brine tank. This system may be wet or dry.

Underground storage tanks almost always require the salt to be premixed with water in the storage tank. It then can be piped to the brine tank as a brine solution and mixed down to the desired concentration levels.

### DISTILLATION

Distillation produces biopure water that is free from particulate matter, minerals, organics, bacteria, pyrogens, and most dissolved gases and has a minimum specific resistance of 300,000  $\Omega$ -cm. Until recent advances in the industry, the use of distilled water was limited to hospitals and some pharmaceutical applications. Now, in hospitals, schools with science departments, laboratories, and industries other than pharmaceuticals, distilled water is vital to many operational functions. When used in healthcare facilities, biopure water is needed in the pharmacy, central supply room, and any other area where patient contact may occur. Biopure water also may be desired in specific laboratories at the owner’s request and as a final rinse in a laboratory glassware washer.

date \_\_\_\_\_

Project name \_\_\_\_\_

Location \_\_\_\_\_

Type of facility \_\_\_\_\_

What is water being used for? \_\_\_\_\_

---

Water analysis: (express in gr./ gal. or ppm as CaCO<sub>3</sub>)

Total hardness \_\_\_\_\_

Sodium \_\_\_\_\_

Total dissolved solids \_\_\_\_\_

Sodium to hardness ratio \_\_\_\_\_

Iron \_\_\_\_\_

Flow rate (gpm) peak \_\_\_\_\_ Normal \_\_\_\_\_ Average \_\_\_\_\_

Allowable pressure loss \_\_\_\_\_ System inlet pressure \_\_\_\_\_

Operating hours/day \_\_\_\_\_ Gallons/day \_\_\_\_\_

Influent header pipe size \_\_\_\_\_

Electrical characteristics \_\_\_\_\_

Type of operation \_\_\_\_\_

Special requirement or options (ASME, lining, accessories) \_\_\_\_\_

---

Space limitation L \_\_\_\_\_ W \_\_\_\_\_ H \_\_\_\_\_

Figure 10-17 Water Softener Survey Data

Date \_\_\_\_\_

Project name \_\_\_\_\_  
Location \_\_\_\_\_**Step 1. Operating conditions**

- A. Operating hours per day \_\_\_\_\_  
 B. Can regeneration take place once each day? Yes \_\_\_\_\_ No \_\_\_\_\_  
 C. If "B" is No, state days between regenerations \_\_\_\_\_  
 D. Is a twin unit required? Yes \_\_\_\_\_ No \_\_\_\_\_  
 E. Type of operation:  
 Time clock \_\_\_\_\_ Alarm meter \_\_\_\_\_ Auto reset meter \_\_\_\_\_  
 F. Allowable pressure loss \_\_\_\_\_ psi.

**Step 2.** Flow rate (gpm) \_\_\_\_\_ (peak, average, continuous)**Step 3.** Water usage per day:

$$\frac{\text{Operating hr/day}}{\text{Operating hr/day}} \times 60 \text{ min./hr.} \times \frac{\text{Average flow rate}}{\text{Average flow rate}} \text{ GPM} = \frac{\text{gal/day}}{\text{gal/day}}$$

**Step 4.** Required exchange capacity:

$$\frac{\text{Gal/day water usage}}{\text{Gal/day water usage}} \times \frac{\text{Water hardness (gr/gal)}}{\text{Water hardness (gr/gal)}} = \frac{\text{Required exchange capacity (gr/day)}}{\text{Required exchange capacity (gr/day)}}$$

**Step 5.** Select resin capacity & salt dosage per cu ft.:

$$(\text{_____}) 32,000 \text{ gr @ } 15\# (\text{_____}) 29,000 \text{ gr @ } 10\# (\text{_____}) 21,000 \text{ gr @ } 6\#$$

**Step 6.** One day of operation per regeneration (step no. 1-B)

$$\frac{\text{Required exch. cap (gr/day)}}{\text{Required exch. cap (gr/day)}} \div \frac{\text{Resin cap (gr/ft}^3\text{)}}{\text{Resin cap (gr/ft}^3\text{)}} = \frac{\text{Required resin (ft}^3\text{/day)}}{\text{Required resin (ft}^3\text{/day)}}$$

Note: If more than one day between regenerations is required, use step no. 7 instead of step no. 6.

**Step 7.** More than one day of operation per regeneration (step no. 1-B)

Cubic feet of resin required:

$$\frac{\text{Required exch. cap. (gr/day)}}{\text{Required exch. cap. (gr/day)}} \times \frac{\text{Number of days/regn.}}{\text{Number of days/regn.}} \div \frac{\text{Resin cap. (gr/ft}^3\text{)}}{\text{Resin cap. (gr/ft}^3\text{)}} = \frac{\text{Resin required (ft}^3\text{)}}{\text{Resin required (ft}^3\text{)}}$$

**Step 8.** Salt consumption per regeneration:

$$\frac{\text{Required resin (ft}^3\text{/regn.)}}{\text{Required resin (ft}^3\text{/regn.)}} \times \frac{\text{Salt dosage (lb/ft}^3\text{)}}{\text{Salt dosage (lb/ft}^3\text{)}} = \frac{\text{Salt regeneration (lb)}}{\text{Salt regeneration (lb)}}$$

**Step 9.** System selection:

(If auto-reset operation is desired, refer to step no. 10.)

- Select from the manufacturer's specification table, a single unit that meets the flow rate (step no. 2).
- Check that selected unit meets the allowable pressure loss at the flow rate (step no. 1-F).
- If a single unit will not meet both steps no. 9-A and 9-B, then a multiple unit is required (refer to step no. 10).
- Check that selected unit contains the required cubic feet of resin (step no. 6 or 7).
- If single unit will not meet step no. 9-D, then a multiple unit is required. (refer to step no. 10).
- Select a standard system that meets, or exceeds by no more than 10%, step nos. 9-A, 9-B, and 9-D. If a good balance is not available, refer to step no. 10.
- Check that brine-tank salt storage is sufficient to provide a minimum of two regenerations before requiring refill (step no. 8).

**Step 10.** Multiple systems:

The following procedure should be followed for a twin unit.

- Select either auto-reset meter initiation or time clock to start regeneration. Refer to the appropriate subtitle.
  - Auto-reset meter-initiated regeneration.
    - Select, from the specification table, a tank size that meets the *flow rate* (step no. 2) and the *allowable pressure loss* (step no. 1-F). Each tank in the system must meet these conditions.
    - Divide the required cu. ft. of resin (step no. 6 or 7) by two to determine the required cubic feet of resin contained in the tanks selected in step no. 10-B. Select a tank large enough to match the required cu. ft. resin/tank.
    - Check that the brine tank salt storage is sufficient to provide a minimum of four regenerations per tank.
  - Time clock regeneration
    - Divide the *flow rate* (step no. 2) by 2 to determine the *flow rate per tank*. Select a tank size that meets this flow rate. (Both tanks will be on line during the operating period.)
    - Check that the tank selected meets the *allowable pressure loss* (step no. 1-F) at the *flow rate per tank*.
    - Follow step no. 10-C to determine the required cubic feet of resin per tank.
    - Follow step no. 10-D to determine the brine tank to be used.

**Step 11.** Using this data, select a standard system from the softener specifications that most closely matches all the data. If none is available, a detailed specification should be developed which will allow the manufacturer to match the system requirements.**Step 12.** Select options such as ASME code tanks, lining, and materials of construction, as required.**Figure 10-18 Water Softener Sizing Procedure**




Figure 10-19 Water Softener with Salt Recycling System

### The Distillation Process

The typical water distillation system consists of an evaporator section, internal baffle system, water-cooled condenser, and storage tank. The heat sources, in order of preference based on economy and maintenance, are steam, electricity, and gas. (Gas is not a good choice.) The still may be operated manually or automatically. The distilled water may be distributed from the tank by gravity or by a pump. A drain is required. On stills larger than 50 gallons per hour (gph), a cooling tower should be considered for the condenser water.

The principles of distillation are quite simple. The water passes through two phase changes, from liquid to gas and back to liquid (see Figure 10-20). All the substances that are not volatile remain behind in the boiler and are removed either continuously or intermittently. Water droplets are prevented from coming up with the water vapor by proper design of the still, which takes into account the linear velocity, and by use of an appropriate system of baffles.

Although distillation removes nonvolatile substances sufficiently, the volatile substances in the feed water cause more problems. These, mainly carbon dioxide, which are already present in the feed water or are formed by the decomposition of bicarbonates, can be removed by keeping the distillate at a relatively high temperature because carbon dioxide is less soluble at high temperatures. Ammonia ( $\text{NH}_3$ ) is much more soluble in water than carbon dioxide, and its tendency to redissolve is much higher as well. Moreover, the ionization constant of ammonium hydroxide ( $\text{NH}_4\text{OH}$ ) is much greater than that of carbonic acid ( $\text{H}_2\text{CO}_3$ ), which means that equal amounts of ammonia and carbon dioxide show different conductivities

(that for ammonia is much higher than that for carbon dioxide).

The purity of the distillate is usually measured with a conductivity meter, and a resistivity of  $1 \text{ M}\Omega$ —or a conductivity of 1 microsiemen ( $\mu\text{S}$ )—is equivalent to approximately 0.5 ppm of sodium chloride. Most of the conductivity is accounted for by the presence of carbon dioxide (and ammonia) and not by dissolved solids. The question arises: Which is preferred,  $1 \text{ M}\Omega$  resistivity or a maximum concentration of dissolved solids? It is quite possible that a distillate with a resistivity of  $500,000 \Omega$  (a conductivity of  $2 \mu\text{S}$ ) contains fewer dissolved solids than a distillate with a resistivity of  $1,000,000 \Omega$  ( $1 \mu\text{S}$ ).

A problem in distillation can be scale formation. Scale forms either by the decomposition of soluble products of insoluble substances or because the solubility limit of a substance is reached during the concentration. Solutions to this problem include the following:

- A careful system of maintenance, with descaling at regular intervals
- Softening of the feed water, that is, removing all calcium and magnesium ions. However, this does




Figure 10-20 Distillation

not remove the silica, which then may form a hard, dense scale that is very difficult to remove.

- Removal of the alkalinity (bicarbonates). When originally present, sulfate and silica still form a harder scale than a carbonate scale.
- Removal of all or most of the dissolved substances. This can be done by demineralization with ion exchangers or by reverse osmosis.

It may sound foolish to remove the impurities from the water before distilling the water. However, keep in mind that distillation is the only process that produces water guaranteed to be free of bacteria, viruses, and pyrogens. It may pay to have pretreatment before a still to cut down on maintenance (descaling), downtime, and energy consumption and to have better efficiency, capacity, and quality. Pretreatment may require a higher initial investment, but the supplier who has the experience and technology in all water treatment systems can give unbiased advice—that is, to offer a systems approach instead of pushing only one method.

Distilled water is often called hungry water. This refers to the fact that distilled water absorbs in solution much of the matter, in any phase, with which it comes in contact. It becomes important, therefore, to select a practical material for the production, storage, and distribution of distilled water. Years of experience and research have shown that pure tin is the most practical material for the production, storage, and distribution of distilled water due to its inert characteristic. It is the least soluble. (Other materials, such as gold, silver, and platinum, have equal or superior qualities but are not considered for obvious reasons.) A secondary but almost equal advantage of tin is its relatively low porosity, which virtually eliminates the possibility of particle entrapment and growth in pores. In a good water still, therefore, all of the surfaces that come in contact with the pure vapors and distillate should be heavily coated with pure tin. Likewise, the storage tank should be heavily coated or lined with pure tin on all interior surfaces. Tinned stills and storage tanks are not significantly more expensive than glass ones in all but the smallest sizes.

Titanium is being strongly considered as a promising material for distillation equipment. Although some stills have been made of titanium, it is more expensive than tin and has not yet been proven superior.

### **Distillation Equipment Applications and Selection**

In the construction of buildings requiring distilled water, the selection of the appropriate equipment is usually the responsibility of the plumbing engineer. Before the proper equipment can be selected, the following factors should be considered:

- The quantity of distilled water that will be required per day (or per week) by each department
- The purity requirements of each department
- The space available for the equipment
- The availability of power

Regarding the first two items, the engineer should obtain the anticipated quantity and purity requirements from all department heads who require distilled water.

In this section, it is assumed that less than 1,000 gallons per day (gpd) of distilled water is required. The single-effect still operated at atmospheric pressure is generally the most practical and widely used. For the consumption of larger quantities of distilled water, consideration may be given to other types of stills (such as the multiple-effect and vapor-compression stills). These stills have advantages and disadvantages that should be studied when conditions warrant.

### ***Centralized vs. Decentralized Systems***

The choice between central distillation equipment and individual stills in each department is a matter of economics. In the case of central distillation, the factors to consider are the distances involved in piping the water to the various departments—hence, the cost of the appropriate piping and, possibly, the pumping requirements. The original and maintenance costs of multiple individual stills can be high. In the majority of installations, the use of one or two large, centrally located stills with piped distribution systems has proven more practical and economical than a number of small, individual stills.

### ***Stills***

While a well-designed still can produce pure distilled water for most purposes, the distilled water to be used by a hospital for intravenous injections or by a pharmaceutical company manufacturing a product for intravenous injections must be free of pyrogens (large organic molecules that cause individuals to go into shock). For such uses, a still with special baffles to produce pyrogen-free distilled water must be specified.

Other types of stills are designed to meet various purity requirements. The recommendations of the manufacturer should be obtained to specify the proper type of still for a specific application.

Due to the amount of heat required in the operation to change the water into steam, it is impractical to make large-capacity, electrically heated and gas-heated stills. All stills larger than 10 gph, therefore, should be heated by steam. For each gallon per hour of a still's rated capacity, steam-heated stills require approximately 1/3 boiler horsepower, electrically heated stills need 2,600 watts, and gas-fired stills need 14,000 British thermal units per hour.



The still must be well designed and baffled to effect an efficient vapor separation without the possibility of carryover of the contaminants and to ensure optimum removal of the volatile impurities. It is equally important that the materials used in construction of the still, storage reservoir, and all components coming in contact with the distilled water do not react with the distilled water.

### ***Distribution Systems***

Cost can be a significant factor in the distribution system, particularly if it is extensive. The distribution system can consist of 316 stainless steel, CPVC Schedule 80, and polyvinylidene fluoride (PVDF). The fittings should be of the same material.

The purity requirements should be considered and a careful investigation made of the properties and characteristics of the materials being considered. Many plastics have a relatively porous surface, which can harbor organic and inorganic contaminants. With some metals, at least trace quantities may be imparted to the distilled water.

### ***Storage Reservoir***

The storage reservoir used for distilled water should be made of a material that is suited for the application and sealed with a tight cover so that contaminants from the atmosphere cannot enter the system. As the distilled water is withdrawn from the storage tank, air must enter the system to replace it. To prevent airborne contamination, an efficient filter should be installed on the storage tank so that all air entering the tank may be filtered free of dust, mist, bacteria, and submicron particulate matter, as well as carbon dioxide.

Figure 10-21 illustrates a typical air filter. This air filter (both hydrophilic and hydrophobic) removes gases and airborne particles down to  $0.2 \mu$ . Purified air leaves at the bottom. The rectangular chamber is a replaceable filter cartridge. A and B are intake breather valves, and C is an exhaust valve.

As a further safeguard against any possible contamination of the distilled water by biological impurities, an ultraviolet light can be attached to the inside of the cover (not very effective) and/or immersed in the distilled water (also not very effective) or in the flow stream to effectively maintain its sterility. Ultraviolet lighting should be given strong consideration for hospital and pharmaceutical installations, as well as for any other applications where sterility is important.

### ***Example 10-3***


Assume that a total of 400 gpd of distilled water is required by all departments. A fully automatic still and storage tank combination should be used in this application. Fully automatic controls stop the still when the storage tank is full and start the still when the level in the storage tank reaches a predetermined

low level. In addition, the evaporator is flushed out each time it stops. A 30-gph still (with a 300-gallon storage tank) produces more than the desired 400 gpd. Because the still operates on a 24-hour basis, as the storage tank calls for distilled water (even if no distilled water is used during the night), 300 gallons are on hand to start each day. As water is withdrawn from the storage tank, the still starts and replenishes the storage tank at a rate of 30 gph.

In this example, the storage tank volume, in gallons, is 10 times the rated capacity of the still. This is a good rule of thumb for a fully automatic still and storage tank combination. A closer study of the pattern of the anticipated demands may reveal unusual patterns, which may justify a larger ratio.

### ***Purity Monitor***

One frequently used accessory is the automatic purity monitor. This device tests the purity of the distilled water coming from the still with a temperature-compensated conductivity cell. This cell is wired to a resistivity meter that is set at a predetermined standard of distilled water commensurate with the capability of the still. If for any reason the purity of the distilled water is below the set standard, the substandard water does not enter the storage tank and is automatically diverted to waste. At the same time, a signal alerts personnel that the still is producing substandard water so an investigation may be made as to the cause. Simple wiring may be used to make the



**Figure 10-21** Typical Air Filter

alarm signal visual or audible at any remote location, such as the plant engineer's office. The advantages of this automatic purity monitor are obvious, particularly ahead of large storage tanks (as one slug of bad water can ruin a whole tank).

## Feed Water

### *Pretreated Feed Water*

In the conventional or basic operation of a still, potable water is used to condense the pure vapors from the evaporator and is heated. Part of this preheated water enters the evaporator as feed water, while the greater part goes to the drain. A well-designed still has the intrinsic features to retard the formation of scale in the evaporator. These features include frequent, automatic flushing and a bleeder valve that continuously deconcentrates the buildup of impurities in the evaporator.

As a further aid in reducing the maintenance of a still in areas having exceptionally hard water, it is often desirable (but not essential) to demineralize (with a deionizer or reverse osmosis), soften, or otherwise pretreat the feed water. Demineralizing the feed water practically eliminates the need to clean the evaporator. For this purpose, the demineralizing process is relatively expensive; however, it does contribute to a higher purity of distilled water.

Because water softening is less expensive than the demineralizing process, it is used more often as a method of pretreatment. It does not have the advantages of demineralized water—eliminating cleaning and contributing to a higher purity—but it does eliminate hard scale formation in the evaporator.

When any kind of pretreated feed water is used, an adequate preheater (for pretreated water) and a float feeder valve should be specified by the designer. With these devices, the raw water is used only as cooling water for the condenser, and the pretreated feed water is piped separately to the still, eliminating the waste of the pretreated water. When the float feeder valve is used on any still equipped with an automatic drain, an automatic shutoff valve to the float feeder valve also should be specified so the supply of pretreated water stops at the same time the drain valve opens. Specifications prepared by the designer should describe the type of pretreated water to be used.

### *Condensate as Feed Water*

Another method of reducing maintenance on a steam-heated still is to use the condensed boiler steam as feed water. Here again, the raw water is used only as condenser cooling water. The condensate from the steam trap is cooled and then passed through an ion exchange cartridge and an organic removal filter. These cartridges remove any traces of scale-forming salts, ionized amines, odor, or taste impurities present

in the original condensate, as well as organics that may be given off by the ion exchange cartridge.

This type of system commonly is referred to as the feedback purifier. This design contributes to a higher purity of distillate and virtually eliminates the need to clean the still (since scale-forming hardness has been eliminated from the feed water).

It is important for the engineer to determine the characteristics of the steam condensate when considering the feedback purifier system. If amines are used as the treatment for the boiler feed water in an excessive amount, this method should not be used. However, most condensates are satisfactory for this purpose.

## Distribution Pressure

Whenever possible, it is best to locate the still and the storage tank where gravity can be employed to provide an adequate pressure to operate the distribution system. When this condition is not possible, centrifugal pumps of the appropriate size must be used. Along with the circulation pump, an orificed bypass back to the storage tank should be installed so the pump can be operated continuously, maintaining adequate pressure in the distribution system. Then the distilled water is available in any outlet all the time. The bypass relieves the pressure on the circulating pump when the water is not being drawn at its outlets.

A low water cutoff also should be installed on the storage tank to shut off the pump if the storage tank runs dry. This pump arrangement is simple in construction, efficient to operate, and less expensive than a pressurized tank.

## SPECIALIZED WATER TREATMENT

### Ozone Treatment

Ozone is a compound in which three atoms of oxygen are combined to form the ozone molecule  $O_3$ . It is a strong, naturally occurring, oxidizing, and disinfecting agent. The unstable ozone ( $O_3$ ) compound can be generated by the exposure of oxygen molecules to ultraviolet radiation or high-energy electrical discharge in manufactured ozone generators.

Ozone can react with any oxidizable substance, such as certain forms of inorganic materials like iron and manganese, many organic materials, and microorganisms. In an oxidation reaction, energy is transferred from the ozone molecule, leaving a stable oxygen ( $O_2$ ) and a highly reactive oxygen atom ( $O_1$ ). The molecule being oxidized then bonds with the loose oxygen atom, creating an oxidized product or a derivation of the substance. Bacterial cells and viruses are literally split apart (lysed) or inactivated through oxidation of their DNA and RNA chains by ozone in water and wastewater treatment applications. Ozone

is the most powerful oxidizer that can be safely used in water treatment.

Ozone frequently is used to treat wastewater and as a disinfectant and oxidant for bottled water, ultrapure waters, swimming pools, spas, breweries, aquariums, cooling towers, and many other applications. Ozone is not able to produce a stable residual in a distribution system. However, ozone can lower the chlorine demand and thus the amount of chlorine required and the chlorinated by-products.

Ozone systems can be big enough to serve central plants or municipalities. Figure 10-22 shows an example of a large-scale system. Figure 10-23 shows a simplified plan view of such a system.

### Ultraviolet Light Treatment

Ultraviolet light is electromagnetic radiation, or radiant energy, traveling in the form of waves. A short-range (UVC) wavelength is considered a germicidal UV. When ultraviolet light of a sufficient energy level is absorbed into matter, it causes a chemical or physical change. In the case of microorganisms, ultraviolet light is absorbed to a level that is just enough to physically break the bonds in DNA to prevent life reproduction. Therefore, ultraviolet light is a mechanism capable of disinfecting water. The most widely used source of this light is low-pressure mercury vapor lamps emitting a 254-nanometer (nm) wavelength. However, 185 nm can be used for both disinfection and total oxidizable carbon reduction. The dosage required to destroy microorganisms is the product of light intensity and exposure time. The exposure requirements for different microorganisms are well documented by the EPA. Ultraviolet bulbs are considered to provide 8,000 hours of continuous use and to not degrade to more than 55 percent of their initial output.

When ultraviolet equipment is sized, the flow rate and quality of the incoming water must be taken into consideration. It is generally necessary to filter the water before the ultraviolet equipment. Sometimes it may be necessary to filter downstream of the ultraviolet equipment with 0.2- $\mu$  absolute filter cartridges to remove dead bacteria and cell fragments.

Ultraviolet equipment often is used in drinking water, beverage water, pharmaceutical, ultra-pure rinse water, and other disinfection applications.

To validate effectiveness in drinking water systems, the methods described in the U.S. EPA's *Ultraviolet Disinfection Guidance Manual* is typically used. For wastewater systems, the National Water Research Institute's *Ultraviolet Disinfection Guidelines for Drinking Water and Water Reuse* is typically used, specifically in wastewater reclamation applications.

### Reverse Osmosis

Reverse osmosis produces a high-purity water that does not have the high resistivity of demineralized water and is not biopure. Under certain conditions, it can offer economic advantages over demineralized water. In areas that have high mineral content, it can be used as a pretreatment for a demineralizer or still when large quantities of water are needed. Reverse osmosis is used primarily in industrial applications and in some hospitals and laboratories for specific tasks. It also is used by some municipalities and end users for the removal of dissolved components or salts.





Figure 10-22 Schematic Diagram of a Large-Scale Ozone System



**Figure 10-23 Simplified Plan View of Ozone System**

Source: Ozone Technology, Inc. All rights reserved. Pressureless Ozone Water Purification Systems is a trademark of Ozone Technology, Inc. Copyright, 2006.

Several types of reverse osmosis units are available. Basically, they consist of a semipermeable membrane, and water is forced through the membrane under high pressure. A drain and storage tank are required with this system.

RO is a relatively simple concept. When equal volumes of water are separated by a semipermeable membrane, osmosis occurs as pure water permeates the membrane to dilute the more concentrated solution (see Figure 10-24). The amount of physical pressure required to equalize the two volumes after equilibrium has been reached is called the osmotic pressure. If physical pressure is applied in excess of the osmotic pressure, reverse osmosis (see Figure 10-25) occurs as water passes back through the membrane, leaving contaminants such as dissolved salts, organics, and colloidal solids concentrated upstream. In practice, the concentrate is diverted to drain, thus rejecting contaminants from the system altogether. The continuous flushing process of the membrane prevents a phenomenon known as concentration polarization, which is a buildup of the polarized molecules on the membrane surface that further restricts flow in a short period.

For dependable long-term performance, RO equipment for large-volume applications should be of all stainless steel fittings and bowls. Such a system should use solid-state controls (with simple indicator lights and gauges) plus a conductivity meter that reads the tap and permeates water quality. High-pressure

relief devices and low-pressure switches protect the membrane and the pump from any prefilter blockage and accidental feed water shutoff. A water-saver device that completely shuts off water flow when the storage tank is full but allows an hourly washing of the membrane is essential.

Three types of semipermeable membranes are manufactured from organic substances: tubular membrane, cellulose-acetate sheet membrane, and polyamide-hollow fiber membrane. They may be used for similar applications, assuming that the proper pre-treatment for each is furnished. In properly designed and maintained systems, RO membranes may last two or three years.

### **RO Membranes**

The current technology of RO developed rapidly as one specific application of the larger technology of synthetic membranes. Several code requirements had to be met before these membranes could be considered practical or economical for water purification processes.

First, the membrane had to be selective—that is, it had to be capable of rejecting contaminants and yet still be highly permeable to water. This condition meant that it had to have a consistent polymeric structure with a pore size in the range of the smallest contaminant molecules possible.

Second, the membrane had to be capable of sustained high flux rates to be economical and practical in water applications. This condition meant that the




Figure 10-24 Osmosis




Figure 10-25 Reverse Osmosis

membrane had to be thin and yet durable enough for long-term use.

Developments in membrane technology led to a membrane with a thin skin (approximately  $0.05 \mu$ ) cast on top of a porous support structure ( $100 \mu$  thick). This resulted in high flux rates, selectivity, and structural strength. The resulting RO membrane proved to be highly resistant to chemical and microbial degradation. It also could maintain the required water quality and flow rates under a sustained high pressure. Such a membrane could be incorporated into a system with relatively low capital, equipment, and operating costs. These attributes were combined successfully, and the resulting membrane achieved a flow rate of 20 gallons per square foot per day at 800 psi with 95 percent removal of salt.

### RO Water Quality

The term high purity often is applied to a type of water that may be exceptionally free of one class of contaminant and yet may contain large amounts of another. The key, of course, is the application involved. One useful distinction is between reagent-grade water and laboratory-grade water. Reagent-grade water means that all classes of contaminants have been removed from the water. Several nationally recognized standards for reagent-grade water are

published by ASTM and the College of American Pathologists (CAP). The minimum resistivity for reagent-grade water is  $10 \text{ M}\Omega\text{-cm}$  at  $25^\circ\text{C}$ . The production of reagent-grade water always requires more than one stage of treatment. It should be produced at the point of use to minimize (or eliminate) transportation and storage, which invariably degrade the reagent water purity. A system for producing reagent-grade water might, for example, use the RO process to produce laboratory-grade water, plus a combination of activated carbon, deionization, and  $0.20\text{-}\mu$  membrane filtration. Only the laboratory-grade water would be accumulated and stored. The reagent water would be

Table 10-4 Comparison of Laboratory-Grade Water Quality Produced by Centralized Systems

Contaminant	Tap, Typical	Reverse Osmosis		Distilled		Deionized	
		Actual	Percent Removal	Actual	Percent Removal	Actual	Percent Removal
Microorganism/ mL	100	1	>99	1	>99	1000 <sup>a</sup>	none
Particles $5 \mu\text{m}/\text{mL}$	10,000	1	>99	200	>97	10,000	none
Pyrogens	Variable	—	>99	—	>99	Variable	none
Dissolved							
organics ppm	12	1	>95	1	>95	12 <sup>b</sup>	none
Dissolved							
inorganics ppm $\text{CaCO}_3$	170	1–17	>90–98	1–8	>95–99	1–8	>95–99
Monovalent ions <sup>c</sup>	—	—	>90	—	>97	—	>97
Multivalent ions <sup>d</sup>	—	—	>97	—	>97	—	>97
Conductivity, $\mu\text{S}, 25^\circ\text{C}$	333	2–40	—	2–10	—	2–10	—
Specific resistance $\text{M}\Omega/\text{cm}, 25^\circ\text{C}$	0.003	0.025–0.5	—	0.1–0.5	—	0.1–0.5	—
Silicates ppm	1	0.1	>90	0.1	>90	0.1	>90
Heavy metals ppm	1	0.1	>97	0.1	>97	0.1	>90
pH	7.5	6.8	—	4–7.5	—	7.0	—

<sup>a</sup> Bacteria often multiply in large deionizing (D.I.) resin beds used directly on tap water.

<sup>b</sup> Large D.I. resin beds also contribute organics from the resin beds.

<sup>c</sup> Monovalent ions: Singly charged ions such as  $\text{Na}^+$ ,  $\text{K}^+$ ,  $\text{Cl}^-$

<sup>d</sup> Multivalent ions: Multiply charged ions such as  $\text{Ca}^{2+}$ ,  $\text{Mg}^{2+}$ ,  $\text{CO}_3^{2-}$ ,  $\text{SO}_4^{2-}$

produced at high flow rates as needed, thus eliminating the need to store it.

Laboratory-grade water is less rigorously defined, but it still refers to water from which one or more types of contaminants have been removed. This definition should be distinguished from other processes that exchange one contaminant for another, such as water softening (in which calcium and magnesium salts are removed by exchanging them with sodium salts). The reverse osmosis, deionization, and distillation processes are all capable of producing laboratory-grade water.

The quality of the laboratory-grade water produced by several methods of central-system water production is shown in Table 10-4. The RO and distillation processes remove more than 99 percent of all bacteria, pyrogens, colloidal matter, and organics above molecular weight 200. These methods remove the dissolved inorganic material, such as multivalent ions, calcium, magnesium, carbonates, and heavy metals to the level of 98 percent, while monovalent ions, such as sodium, potassium, and chloride, are removed to the level of 90 percent to 94 percent by RO and 97 percent by distillation.


Large-scale deionization processes achieve similar levels of inorganic ion removal, but they do not remove bacteria, pyrogens, particles, and organics. Bacteria, in fact, can multiply on the resins, resulting in an increase in biological contaminants over normal tap water.

It should be stressed that the degrees of water purity shown in Table 10-4 are obtainable only from well-cleaned equipment that is performing to its original specifications. Maintaining this condition for the deionization process means that the resins must be replaced (or regenerated) regularly and that the internal components of the still must be thoroughly cleaned. If a still is not properly and regularly cleaned, the residual contaminants can cause the pH value of the end product water to fall as low as 4. Reverse osmosis is the only one of the methods that uses a reject stream to continuously remove the residual contaminants. Regularly scheduled prefilter changes and system maintenance are, of course, necessary to maintain the desired water quality.

### Applications for RO

The quality and cost of RO water make RO a strong competitor for distillation and deionization in many applications. Table 10-5 compares the three methods of water purification for several research and industrial applications.

Frequently, the user needs both laboratory-grade and reagent-grade waters to meet a wide range of needs. Figure 10-26 shows two ways of approaching this situation. Alternative A consists of a central RO system from which the water is piped to a point-of-use polishing system to be upgraded to reagent-grade water. This approach utilizes the economics of a large central RO system while ensuring the highest reagent-grade purity at those use points that require it. Alternative B employs smaller point-of-use RO



**Figure 10-26 Approaches to Providing Laboratory-Grade and Reagent-Grade Water: (A) RO Water Purified Centrally and Transported by Pipe to Points of Use Then Polished, (B) RO System Coupled with Deionization System Totally at the Point of Use, Eliminating Piping**

**Table 10-5 Applications of Purified Water**

Water Use	Method of Purification		
	RO	Distilled	Deionized
General process use	Yes	Yes	Yes
General lab use (buffers, chemical mfg.)	Yes	Yes	Yes (except for pyrogens, bacteria, and organics)
Dishwasher final rinse	Yes	Yes	Yes
Critical lab use (reagents, tissue culture, etc.)	Post-treatment necessary		
USP XXIII water for injection	Yes (must meet purified water standard)	Yes	No
Hemodialysis	Yes	No	Yes (except for pyrogens, bacteria, and organics)

systems with point-of-use polishing, which eliminates lengthy distribution piping, a potential source of recontamination. Both alternatives include a final polishing by activated carbon, mixed-bed deionization, and 0.2- $\mu$  membrane filtration. In each case, laboratory-grade water is readily available directly from the RO system. Moreover, the transportation and storage of the reagent-grade water are avoided.

### Nanofiltration

Nanofiltration (NF) is a cross-flow membrane filtration system that removes particles in approximately the 300–1,000 molecular weight range, rejecting selected ionic salts and most organics. Nanofiltration rejects the dissociated inorganic salts that are polyvalent, such as calcium, magnesium, and sulfate, while passing monovalent salts, such as sodium and chloride. Therefore, nanofiltration often is called a softening membrane system. Nanofiltration operates at low feed pressures. The equipment is similar to that for reverse osmosis.

### Ultrafiltration

Ultrafiltration (UF) is a membrane filtration system that separates liquids and solids. This separation process is used in industry and research to purify and concentrate macromolecular solutions, especially protein solutions. It provides filtration in the range of 0.0015  $\mu$  to 0.1  $\mu$ , or approximately 1,000–100,000 molecular weight. Ultrafiltration in an industrial application often is used to separate oil and water as in cutting solutions, mop water, and coolants.

### Copper-Silver Ionization

Copper-silver ionization is not a filtration system, but a method of injecting positive ions into the water stream. The positive cations attach to the negative anions of organic pathogens, destroying their cell structures. It is used to eliminate *Legionella* and other waterborne organisms; thus, these systems are used extensively in hospitals and healthcare centers. Figure 10-27 shows the basic system components.

### GLOSSARY

**Absorption** The process of taking up a substance into the physical structure of a liquid or solid by a physical or chemical action but without a chemical reaction.

**Adsorption** The process by which molecules, colloids, and/or particles adhere to surfaces by physical action but without a chemical reaction.

**Algae** A microscopic plant growth that may be found in some well waters in certain areas of the country. This plant growth may collect on the resin in the water conditioner, resulting in poor operation because of restricted water flow. Chlorination and dechlorination control this problem and protect plumbing lines and fixtures.

**Figure 10-27 Silver Ionization Unit and Control Panel**

**Alkalinity** The capacity to neutralize acid, usually because of the presence of bicarbonate or carbonate ions.

**Anion** Negatively charged ion in a solution.

**Automatic softener** A fully automatic water softener that regenerates at regular intervals, without attention, to provide a continuous supply of soft, conditioned water.

**Backwashing** A process in which the flow of water through the resin bed of a water softener is reversed to carry out to the drain any dirt and oxidized iron collected on top of the resin bed. It is an important step after the ion exchange capacity of the water softener resin is exhausted to regenerate the resin so its original capacity may be restored. Backwashing also prevents the resin from becoming packed or channeled.

**Bacteria** Tiny organisms occurring naturally in waters. Pathogenic (disease-causing) bacteria cause illnesses, such as typhoid, dysentery, and cholera.

**Bacteriological examination** A test of new wells and private water supplies conducted by an official representative for the state board of health or drinking water regulatory agency in accordance with accepted practice and local standards that determines if the water is safe to drink.

**Bed depth** A measurement of the high-capacity resin or ion exchange mineral in inches of depth in the tank.

**Biochemical oxygen demand** A measurement of the amount of oxygen required for the biochemical degradation of organic material in water.

**Bleed through** The iron remaining in the effluent of treated water when all of the iron is not removed during the service cycle of a water softener (or iron remover).

**Brine** A solution of sodium chloride (common salt) used for regenerating water softeners.

**Brine tank** A separate tank in the system employed to store the water and salt (sodium chloride) to form a brine solution.

**Bypass** A connection or a valve system that allows hard water to supply the system while the water softener is being regenerated or serviced.

**Calcium** One of the principal elements that constitutes the Earth's crust. When dissolved in water, calcium compounds make the water hard, contributing to the formation of scale and insoluble soap curds. Often expressed as calcium carbonate ( $\text{CaCO}_3$ ).

**CAP** College of American Pathologists, which has set water purification standards for laboratory use.

**Capacity** The ability of certain size water conditioners to remove a specific quantity of hardness minerals, iron, or manganese from the water going through the water conditioner.

**Carbon dioxide** A gas that is produced from the air when water falls as rain or by the decaying action of organic matter.

**Cartridge filter** A filter device, usually disposable, with a wide range of micron sizes.

**Cation** A positively charged ion.

**Chemical oxygen demand** A measurement of the amount of oxygen required to oxidize chemicals in water.

**Chloride** An element commonly found in most natural groundwater and generally combined with other minerals, such as sodium chloride ( $\text{NaCl}$ ).

**Clarifier** A device that removes turbidity, which is defined as sand, clay, silt, or other undissolved foreign matter.

**Coagulant** A chemical added to water and wastewater applications to form flocs that adsorb, entrap, and bring together suspended matter so it can be removed.

**Coalescing** The separation of immiscible fluids (such as oil and water) with different specific gravities.

**Concurrent regeneration** During regeneration of a water conditioner, when the flow is in the same direction of the service flow in all steps except the backwash.

**Concentrate** In cross-flow filtration, reverse osmosis, nanofiltration, and ultrafiltration, the amount of feed stream that does not permeate the membrane and thus concentrates the ions, suspended solids, and organics in the waste stream.

**Conductivity** The ability of water to conduct electricity. Conductivity is the inverse of resistivity. It is measured with a conductivity meter and described as microsiemens per centimeter, which is the same as micromhos per centimeter.

**Control valve** A device on a water conditioner that may be manually or automatically operated and used to direct (or control) the flow of the water in a certain direction.

**Corrosion** The attack by water on any part of a water system causing the wasting away of metal parts.



**Countercurrent regeneration** During the regeneration of a water conditioner, in all steps of the regeneration cycle, when the flow is in the opposite direction of the service flow.

**Cross-flow membrane filtration** The separation of the components of a fluid by a semipermeable membrane such as reverse osmosis, nanofiltration, ultrafiltration, and microfiltration.

**Cubic foot of mineral** A measurement of the high-capacity resin or ion exchange mineral used in a water softener.

**Cycle** The length of time a water softener will operate without backwashing and/or regeneration.

**Cycle operation** Usually the sequence of valve operations on automatic water softeners. A two-cycle valve is a device in which upflow brining is combined with the backwash cycle, sacrificing the performance on both the backwashing and the brining. The five-cycle valve performs each essential regeneration step separately, providing a longer life, more efficient service, and better performance.

**Diatom** An organism commonly found in waters and considered by health officials to be non-harmful. Diatoms occasionally may impart objectionable odors, and their calcified skeletons make chalk and provide a diatomite powder used for swimming pool features.

**Dissolved iron** Iron that is dissolved in water. The dissolved, or ferrous, iron is highly soluble in most waters, and the undissolved, or ferric, iron is almost always insoluble in water.

**Dissolved solids** The residual material remaining after a filtered solution evaporates.

**Distributor** A device used within a softener tank to distribute the flow of the water throughout the tank and to prevent the resin from escaping into the lines. Sometimes called a strainer.

**Down flow** Usually designates the down direction in which the water flows during the brine cycle of manual and semiautomatic water softeners.

**Drain valve (drain line)** A valve or line employed to direct or carry the backwash water, used regenerant, and rinse water to the nearest drain of the waste system.

**Effluent** The water moving away from, or out of, a water conditioner.

**Endotoxin** A heat-resistant pyrogen found in the cell walls of viable and nonviable bacteria. Expressed as EDU units.

**Exhaustion** In water softening or ion exchange, the point where the resin no longer can exchange additional ions of the type for which the process was designed.

**Ferric iron** The insoluble form of iron. Ferrous iron in water is readily converted to ferric iron by exposure to oxygen in the air.

**Ferrous iron** The soluble form of iron.

**Filter-ag** A ceramic-like, insoluble, granular material used in a clarifier to physically separate the suspended matter in some water supplies. It backwashes freely with less water than sand and other similar filter materials.

**Filtration** The process of passing a fluid through a filter material for the purpose of removing turbidity, taste, color, or odor.

**Floc** The suspended particles in water that have coagulated into larger pieces and may form a mat on the top of the mineral or resin bed in a water conditioner and reduce or impair the efficient operation of the equipment.

**Flow rate** In water treatment, the quantity of water flowing, in a unit of time, often given in gallons per minute or gallons per hour.

**Flow regulator** A mechanical or automatic device used in water treatment equipment to regulate the flow of the water to a specified maximum flow rate.

**Flux** In cross-flow filtration, the unit membrane throughput, expressed as volume per unit of time per area, such as gallons per day per square foot.

**Free board** The space above a bed of ion exchange resin or mineral in a water softener tank that allows for the unobstructed expansion of the bed during the backwash cycle.

**Grains capacity** The amount of hardness mineral (calcium or magnesium) that is removed by a water softener mineral or resin within a specified length of time or by a specific quantity of resin.

**Grains per gallon** A common basis of reporting water analysis. One grain per gallon equals 17.1 parts per million. One grain is 1/7,000 of a pound.

**Hardness** The compounds of calcium and magnesium that are usually present in hard water.

**Hardness leakage** The presence of hardness minerals (calcium and magnesium) after the water has passed through the softener due to hardness retained in the resin bed from the previous service run. The amount of leakage expected in a properly operating system is directly proportional

to the salt rate and the total dissolved solids in the incoming water. While some leakage is normal, excessive leakage usually indicates faulty regeneration.

**High-capacity resin** A manufactured material, in the form of beads or granules, that has the power to take hardness-forming ions and give up softness-forming ions and the reverse cycle thereof. Sometimes called ion exchange resin.

**High purity** A term describing highly treated water with attention to microbiological reduction or elimination, commonly used in the electronic and pharmaceutical industries.

**Hydrogen sulfide** A highly corrosive gas that often is found in water supplies. Water containing hydrogen sulfide gas has a characteristic rotten egg odor.

**Influent** The water moving toward, or into, a water softener.

**Inlet or outlet valve** A gate valve on the inlet or outlet piping of a water conditioner.

**Installation sequence** In water treatment applications, the proper procedure for installing equipment when more than one piece of water treatment equipment is needed to properly condition the untreated water.

**Ion** An electrically charged atom or molecule.

**Ion exchange** The replacement of one ion by another. In the softening process, the sodium in the softener resin is exchanged for calcium, magnesium, iron, and manganese (if present).

**Iron** An element common to most underground water supplies, though not present in the large quantities that calcium and magnesium can be. Even small amounts of iron are objectionable in the water system.

**Limestone** A common rock composed primarily of calcium. It combines with carbon dioxide present in groundwater to form calcium carbonate and causes hardness of water.

**Magnesium** An element that, along with calcium, is responsible for the hardness of water.

**Natural water** Water containing dissolved inorganic solids, mostly mineral salts, which are introduced into the water by a solvent action as the water passes through, or across, various layers of the Earth.

**Nitrate** A naturally occurring form of nitrogen found in soil and groundwater. High nitrate levels, generally 10 parts per million or more, can cause

a condition known as blue baby that inhibits the transfer of oxygen through the lung tissue to the bloodstream, resulting in oxygen starvation.

**Ohm** A unit of measurement. One ohm ( $1\Omega$ ) equals  $0.5 \times 10^{-6}$  parts per million or  $10^{-6}$  microsiemens.

**Parts per million** A common method of reporting water analyses. 17.1 ppm equals 1 grain per gallon. Parts per million is commonly considered equivalent to milligrams per liter.

**pH value** A number denoting the alkaline or acidic nature of water (or a solution). The pH scale ranges from 0 to 14, with 7 being the accepted neutral point. A pH value below 7 indicates acidity, and values above 7 indicate alkalinity.

**Precipitate** A solid residue formed in the process of removing certain dissolved chemicals out of a solution.

**Pressure drop** A decrease in water pressure, typically measured in pounds per square inch.

**Regeneration** A process that refreshes the resin bed in a water softener to remove any hardness ions collected in the resin.

**Resin** A synthetic polystyrene ion exchange material (often called high-capacity resin).

**Rinse** Part of the regeneration cycle of a water softener where freshwater is passed through a water softener to remove the excess salt (sodium chloride) prior to placing the water softener into service.

**Salt** A high-grade sodium chloride of a pellet or briquette type used for regenerating a water softener.

**Service run** The operating cycle of a water softener, during which the hard water passes through the ion exchange resin and enters the service lines as soft water.

**Sodium** An element usually found in water supplies (depending on local soil conditions) that is a basic part of common salt (sodium chloride).

**Soft water** Water without hardness material, which has been removed either naturally or through ion exchange.

**Sulfate** A compound commonly found in waters in the form of calcium sulfate ( $\text{CaSO}_4$ ) or magnesium sulfate ( $\text{MgSO}_4$ ).

**Suspension** The foreign particles carried (but not dissolved) in a liquid, like rusty iron in water.

**Tannin** An organic color or dye, not a growth, sometimes found in waters. (The latter is the result of decomposition of wood buried underground.)

**Titration** A laboratory method of determining the presence and amount of chemical in a solution, such as the grains hardness (calcium and magnesium) of water.

**Total dissolved solids** All dissolved materials in the water that cannot be removed by mechanical filtration, generally expressed in terms of parts per million.

**Turbidity** A term used to define the degree of cloudiness of water due to undissolved materials such as clay, silt, or sand. It is measured in nephelometric turbidity units.

**Upflow** The upward direction in which water flows through the water conditioner during any phase of the operating cycle.

**Virus** A tiny organism that is smaller than bacteria and resistant to normal chlorination. Viruses cause diseases, such as poliomyelitis and hepatitis (both of which are transmitted primarily through water supplies).



# 11

# Thermal Expansion

All piping materials undergo dimensional changes due to temperature variations in a given system. The amount of change depends on the material characteristics (the linear coefficient of thermal expansion or contraction) and the amount of temperature change. The coefficient of expansion or contraction is defined as the unit increase or decrease in length of a material per 1°F increase or decrease in temperature. Coefficients of thermal expansion or contraction for a number of commonly used pipe materials are shown in Table 11-1. These coefficients are in accordance with ASTM D696 and are based on completely unrestrained specimens.

If the coefficient of thermal expansion or contraction is known, the total change in length may be calculated as follows:

### Equation 11-1

$$L_2 - L_1 = \alpha L_1 (T_2 - T_1)$$

where

- $L_1$  = Original pipe length, feet
- $L_2$  = Final pipe length, feet
- $T_1$  = Original temperature, °F
- $T_2$  = Final temperature, °F
- $\alpha$  = Coefficient of expansion or contraction, foot/foot/°F

A typical range of temperature change in a hot water piping system is from 40°F entering water to 120°F distribution water, for an 80°F temperature differential. Total linear expansion or contraction for a 100-foot length of run when subject to an 80°F change in temperature can be calculated for the usual piping materials in a hot water system. A typical range of temperature in a drain, waste, and vent (DWV) system is from 100°F (the highest temperature expected) to 50°F (the lowest temperature expected), for a 50°F temperature differential.

## THERMAL STRESS

To not exceed the maximum allowable strain in the piping, the developed length can also be calculated from the following equation.

### Equation 11-2

$$\Delta = \frac{PL^3}{3EI}$$

where

- $\Delta$  = Maximum deflection at the end of a cantilever beam, inches
- $P$  = Force at end, pounds
- $L$  = Length of pipe subjected to flexible stress, inches
- $E$  = Flexural modulus of elasticity, pounds per square inch (psi)
- $I$  = Moment of inertia, inches<sup>4</sup>

For pipes in which the wall thickness is not large with respect to the outside diameter, the moment of inertia and the sectional modulus can be calculated as follows:

$$I = \pi R^3 t$$

and

$$Z = \pi R^2 t$$

where

- $R$  = Outside radius, inches
- $t$  = Wall thickness, inches
- $Z$  = Section modulus, cubic inches

For thin-walled pipes, the maximum allowable stress and the maximum allowable strain can be calculated as follows:

$$S = \frac{4PL}{\pi D^2 t}$$

$$\epsilon = \frac{\pi D^2 S t}{4L}$$

where

- $S$  = Maximum fiber stress in bending =  $M/Z$ , psi
- $M$  = Bending moment =  $PL$ , inch-pounds
- $D$  = Outside diameter, inches
- $\epsilon$  = Strain

Substituting the maximum allowable stress and the maximum allowable strain into Equation 11-2,

the development length of piping can be estimated by Equations 11-3 and 11-4 respectively.

**Equation 11-3**

$$L = \left( \frac{3ED\Delta}{2S} \right)^{1/2}$$

**Equation 11-4**

$$L = \left( \frac{3D\Delta}{2\varepsilon} \right)^{1/2}$$

Equation 11-3 is used when the maximum allowable stress is fixed, and Equation 11-4 is used when the maximum allowable strain is fixed. When Equation 11-4 is used, the flexural modulus of elasticity must be known. In cases where the modulus of the specific compound is not available, the following approximately average values are usually adequate:

Material	E at 73°F (psi)	S at 73°F (psi)*
Steel	30,000,000	16,450
Copper (type L)	17,000,000	6,000
Brass (red)	17,000,000	6,000
ABS 1210	250,000	1,000
ABS 1316	340,000	1,600
PVC 1120	420,000	2,000
PVC 1220	410,000	2,000
PVC 2110	340,000	1,000
PB 2110	38,000	1,000
PE 2306	90,000	630
PE 3306	130,000	630
PE 3406	150,000	630
CPVC 4120	423,000	2,000

\*ASME B31 values

Equation 11-3 can be factored to yield the following equation:

**Equation 11-5**

$$L = \left( \frac{3E}{2S} \right) \left( D\Delta \right)^{1/2}$$

where

E and S = Constants for any given material

L is measured in feet.

Using the values for E and S in the above table, Equation 11-3 or Equation 11-5 reduces to the following:

- Steel pipe:  $L = 6.16 (D\Delta)^{1/2}$
- Brass pipe:  $L = 7.68 (D\Delta)^{1/2}$
- Copper pipe:  $L = 7.68 (D\Delta)^{1/2}$
- ABS 1210:  $L = 1.61 (D\Delta)^{1/2}$
- ABS 1316:  $L = 1.49 (D\Delta)^{1/2}$

- PVC 1120:  $L = 1.48 (D\Delta)^{1/2}$
- PVC 1220:  $L = 1.46 (D\Delta)^{1/2}$
- PVC 2110:  $L = 1.88 (D\Delta)^{1/2}$
- PB 2110:  $L = 0.63 (D\Delta)^{1/2}$
- PE 2306:  $L = 1.22 (D\Delta)^{1/2}$
- PE 3306:  $L = 1.47 (D\Delta)^{1/2}$
- PE 3406:  $L = 1.57 (D\Delta)^{1/2}$
- CPVC 4120:  $L = 1.48 (D\Delta)^{1/2}$

Many computer programs are available that readily solve these equations as well as address the various installation configurations. Also, refer to the manufacturer of the material that is being used for specific information regarding expansion and contraction.

Provisions must be made for the expansion and contraction of all hot water and circulation mains, risers, and branches. If the piping is restrained from moving, it will be subjected to compressive stress on a temperature rise and to tensile stress on a temperature drop. The pipe itself usually can withstand these stresses, but failure frequently occurs at pipe joints and fittings when the piping cannot move freely. The two methods commonly used to absorb pipe expansion and contraction without damage to the piping are expansion loops and offsets and expansion joints.

### Expansion Loops and Offsets

The total movement to be absorbed by any expansion loop or offset often is limited to a maximum of 1½ inches for metallic pipes. Thus, by anchoring at the points on the length of run that produce 1½-inch movement and placing the expansion loops or joints midway between the anchors, the maximum movement that must be accommodated is limited to ¾ inch. The piping configuration used to absorb the movement can be in the form of a U bend, a single-elbow offset, a two-elbow offset, or a three-, five-, or six-elbow swing loop. In the great majority of piping systems, the loop or joint can be eliminated by taking advantage of the changes in direction typically required in the layout.

Table 11-2 provides the total developed length required to accommodate a 1½-inch expansion. (The developed length is measured from the first elbow to the last elbow, as shown in Figure 11-1.)

### Expansion Joints

Expansion loops and offsets should be used wherever possible; however, when movements are too large and not enough space is available to provide an expansion loop (especially for risers in high-rise buildings), expansion joints can be used.

It should be noted that expansion joints are mechanical devices that present a failure risk. If not installed properly with guides and anchors, they can

Material	Coefficient, in/in/°F	Expansion or Contraction, in/100 ft/10°F
Steel	0.0000065	0.078
Cast Iron	0.0000056	0.0672
Copper	0.0000098	0.1176
Brass	0.0000104	0.1248
ABS 1210	0.000055	0.66
ABS 1316	0.00004	0.48
PVC Type 1 (PVC 1120 and 1220)	0.00003	0.36
PVC Type 2 (PVC 2110, 2112, 2116, 2120)	0.000045	0.54
Polybutylene (PB) 2110	0.000075	0.90
Polyethylene (PE) 2306	0.00008	0.96
Polyethylene (PE) 3306	0.00007	0.84
Polyethylene (PE) 3406	0.00006	0.72
CPVC 4120	0.0000035	0.042

Nominal Pipe Size, in.	Steel Pipe, ft	Copper Pipe, ft	Sch. 40 ABS Pipe, ft	Sch. 40 PVC Pipe, ft
0.5	6.92	7.44	1.81	1.62
0.75	7.70	8.80	2.01	1.81
1	8.68	9.98	2.26	2.02
1.25	9.75	11.0	2.54	2.27
1.50	10.4	12.0	2.72	2.43
2	11.5	13.7	3.00	2.72
2.5	12.8	15.2	3.35	2.99
3	14.2	16.6	3.70	3.30
4	16.0	19.1	4.18	3.74

Note: mm = in. x 25.4; m = ft x 0.3048




Figure 11-1 Expansion Loop Detail

leak, which can be catastrophic if they are located inside an inaccessible chase space. It is recommended that expansion joints be located in an accessible space to allow maintenance or replacement. The guides allow axial movement, but prevent lateral and angular movement. Without guides and anchors, the pipe may buckle, causing the expansion joint to fail. Most manufacturers of expansion joints require guides and anchors to be installed properly to ensure the manufacturer’s warranty. The quantity and location of the guides depend on the pipe size, proximity of the expansion joint to the anchor, and length of pipe run.

An expansion joint should be installed every 30 feet according to the manufacturer’s recommendations. Typically, the expansion joint is installed in the thermal neutral position so it can move in either direction to absorb expansion or contraction. On vertical piping, the pipe should be anchored by side inlets or clamps at or near the joint.

Two types of expansion joints accommodate axial movement. The packed slip type depends on slipping or sliding to accommodate movement and requires an elastomeric seal with packing and lubrication. The packless bellows has a thin-wall convoluted section that allows movement by bending or flexing.

### ABOVEGROUND PIPING

Two examples of aboveground piping are hot water pipe that carries hot water intermittently with a gradual cooling in between and DWV pipe into which water ranging from 50°F to 100°F is intermittently discharged. These greater temperature changes are offset by the fact that most aboveground piping involves short runs with several changes in direction. Thus, for many installations, such as one- or two-family dwellings, no special precautions need to be taken. Of particular concern are hot water and DWV systems in high-rise buildings.

#### Pressure Piping

Aboveground pressure piping incorporating short runs and several changes in direction normally accommodate expansion or contraction. Precaution should be taken to ensure that pipe hangers or clamps allow longitudinal movement of the pipe and that the 90-degree bends are not butted against a wall or similar structure that restricts movement. If runs in excess of 20 feet are required, flexural offsets or loops should be provided.

#### Drain, Waste, and Vent Piping

Expansion or contraction usually does not present a problem in DWV installations in one- and two-family dwellings due to the short lengths of piping involved. It does create problems in high-rise buildings where

long stacks are installed. Three methods of accommodating expansion or contraction are described below.

1. Offsets may be provided. The developed length of the offset that should be provided can be calculated in accordance with the appropriate formula. For example, for a 50°F temperature differential in the straight run, the amount to be accommodated at the branch connection is approximately 3/8 inch. To accommodate this amount of expansion, the branch pipe must have sufficient developed length to overcome a bending twist without being subjected to excessive strain.
2. Where allowed by applicable codes, expansion joints may be used.
3. Engineering studies have shown that by restraining the pipe every 30 feet to prevent movement, satisfactory installations can be made. Tensile or compressive stresses developed by contraction or expansion are readily absorbed by the piping without any damage. Special stack anchors are available and should be installed according to the manufacturer's recommendations.

**THERMOPLASTIC PIPING**

Thermoplastic piping (ABS, PVC, PE, and CPVC) expands and contracts in reaction to temperature changes at a much faster rate, up to 10 times faster, than metallic pipe. Because of this, some manufactur-

ers of plastic piping use a maximum allowable strain of 0.005 inch per inch. When this is the case, Equation 11-4 reduces to:

$$L = 1.44 (D\Delta)^{1/2}$$


Use of plastic piping in high-rise buildings in particular requires careful calculations to minimize expansion and contraction.

**UNDERGROUND PIPING**

Underground piping temperature changes are less drastic than aboveground piping changes because the piping is not exposed to direct heating from solar radiation, the insulating nature of the soil prevents rapid temperature changes, and the temperature of the transported medium can have a stabilizing effect on the pipe's temperature.

Contraction or expansion of flexible pipe can be accommodated by snaking the pipe in the trench. An approximate sine wave configuration with a displacement from the centerline and a maximum offset as shown in Table 11-3 accommodate most situations. The installation should be brought to the service temperature prior to backfilling. After increased length is taken up by snaking, the trench can be backfilled in the normal manner.

Up to 3-inch nominal size, rigid pipe can be handled by snaking in the same manner used for flexible pipe.



**Flexible Pipe**  
Maximum Temperature Variation (Between Installation and Service), °F

	10	20	30	40	50	60	70	80	90	100
<b>Loop Length, ft</b>	<b>Offset for Contraction, in.</b>									
20	3	4	5	6	7	8	9	10	11	12
50	7½	10	12½	15	17½	20	22½	25	27½	30
100	15	20	25	30	35	40	45	50	55	60

**Rigid Pipe**  
Maximum Temperature Variation (Between Installation and Service), °F

	10	20	30	40	50	60	70	80	90	100
<b>Loop Length, ft</b>	<b>Offset for Contraction, in.</b>									
20	1½	2	2½	3	3½	4	4½	5	5½	6
50	3¾	5	6¼	7½	8¾	10	11¼	12½	13¾	15
100	7½	10	12½	15	17½	20	22½	25	27½	30

Note: °C = (F - 32) / 1.8  
mm = in. × 25.4  
m = ft × 0.3048

**Table 11-3 Approximate Sine Wave Configuration With Displacement**



Offsets and loop lengths under specific temperature variations are shown in Table 11-3. For distances of less than 300 feet, 90-degree changes in direction take up any expansion or contraction that occurs.

For larger sizes of pipe, snaking is not practical or possible in most installations. In such cases, the pipe is brought to within 15°F of the service temperature, and the final connection is made. This can be accomplished by shade backfilling, allowing the pipe to cool at night and then connecting early in the morning, or cooling the pipe with water. The thermal stresses produced by the final 15°F service temperature are absorbed by the piping.

### EXPANSION TANKS

When water is heated, it expands. If this expansion occurs in a closed system, dangerous water pressures can be created. A domestic hot water system can be a closed system when the hot water fixtures are closed and the cold water supply piping has backflow preventers or any other device that can isolate the domestic hot water system from the rest of the domestic water supply, as shown in Figure 11-2(A).

These pressures can quickly rise to a point at which the relief valve on the water heater unseats, thus relieving the pressure, but at the same time compromising the integrity of the relief valve, as shown in Figure 11-2(B). A relief valve installed on a water heater is not a control valve, but a safety valve. It is not designed or intended for continuous usage. Repeated excessive pressures can lead to equipment and pipe failure and personal injury.

When properly sized, an expansion tank connected to the closed system provides additional system volume for water expansion while ensuring a maximum desired pressure in a domestic hot water system. It does this by utilizing a pressurized cushion of air (see Figure 11-3). The following discussion explains how to size an expansion tank for a domestic hot

water system and the theory behind the design and calculations. It is based on the use of a diaphragm or bladder-type expansion tank, which is the type most commonly used in the plumbing industry. This type of expansion tank does not allow the water and air to be in contact with each other.

### Expansion of Water

A pound of water at 140°F has a larger volume than the same pound of water at 40°F. To put it another way, the specific volume of water increases with an increase in temperature. If the volume of water at a specific temperature condition is known, the expansion of water can be calculated as follows:

$$V_{ew} = V_{s2} - V_{s1}$$

where

$V_{ew}$  = Expansion of water, gallons

$V_{s1}$  = System volume of water at temperature 1, gallons

$V_{s2}$  = System volume of water at temperature 2, gallons

$V_{s1}$  is the initial system volume and can be determined by calculating the volume of the domestic hot water system. This entails adding the volume of the water-heating equipment to the volume of the piping and any other part of the hot water system.

$V_{s2}$  is the expanded system volume of water at the design hot water temperature.  $V_{s2}$  can be expressed in terms of  $V_{s1}$ . To do that, look at the weight of the water at both conditions.

The weight ( $W$ ) of water at temperature 1 ( $T_1$ ) equals the weight of water at  $T_2$ , or  $W_1 = W_2$ . At  $T_1$ ,  $W_1 = V_{s1}/v_{sp1}$ , and similarly at  $T_2$ ,  $W_2 = V_{s2}/v_{sp2}$ , where  $v_{sp}$  equals the specific volume of water at the two temperature conditions. (See Table 11-4 for specific volume data.) Since  $W_1 = W_2$ , then:

$$\frac{V_{s1}}{v_{sp1}} = \frac{V_{s2}}{v_{sp2}}$$

Solving for  $V_{s2}$ :

$$V_{s2} = V_{s1} \left( \frac{v_{sp2}}{v_{sp1}} \right)$$

Earlier it was stated that  $V_{ew} = V_{s2} - V_{s1}$ . Substituting  $V_{s2}$  from above, it can be calculated that since

$$V_{s2} = V_{s1} \left( \frac{v_{sp2}}{v_{sp1}} \right), \text{ then}$$

$$V_{ew} = V_{s1} \left( \frac{v_{sp2}}{v_{sp1}} \right) - V_{s1}, \text{ or}$$

### Equation 11-6

$$V_{ew} = V_{s1} \left( \frac{v_{sp2}}{v_{sp1} - 1} \right)$$

**Table 11-4 Thermodynamic Properties of Water at a Saturated Liquid**

Temp., °F	Specific Volume, ft <sup>3</sup> /lb
40	0.01602
50	0.01602
60	0.01604
70	0.01605
80	0.01607
90	0.01610
100	0.01613
110	0.01617
120	0.01620
130	0.01625
140	0.01629
150	0.01634
160	0.01639




Figure 11-2 Closed Hot Water System Showing the Effects as Water and Pressure Increase from (A)  $P_1$  and  $T_1$  to (B)  $P_2$  and  $T_2$




Figure 11-3 Effects of an Expansion Tank in a Closed System as Pressure and Temperature Increase from (A)  $P_1$  and  $T_1$  to (B)  $P_2$  and  $T_2$

**Example 11-1**

A domestic hot water system has 1,000 gallons of water. How much will the 1,000 gallons expand from a temperature of 40°F to a temperature of 140°F?

From Table 11-4,  $v_{sp1} = 0.01602$  (at 40°F) and  $v_{sp2} = 0.01629$  (at 140°F). Utilizing Equation 11-6,

$$V_{ew} = 1,000 \left( \frac{0.01629}{0.01602 - 1} \right) = 16.9 \text{ gallons}$$

Note that this is the amount of water expansion and should not be confused with the size of the expansion tank needed.

**Expansion of Material**

Will the expansion tank receive all of the water expansion? The answer is no, because not just the water is expanding. The piping and water-heating equipment expand with an increase in temperature as well. Any expansion of these materials results in less of the water expansion being received by the expansion tank. Another way of looking at it is as follows:

$$V_{enet} = V_{ew} - V_{emat}$$

where

$V_{enet}$  = Net expansion of water received by the expansion tank, gallons

$V_{ew}$  = Expansion of water, gallons

$V_{emat}$  = Expansion of material, gallons

To determine the amount of expansion each material experiences per a certain change in temperature, look at the coefficient of linear expansion for that material. For copper, the coefficient of linear expansion is  $9.5 \times 10^{-6}$  inch/inch/°F, and for steel it is  $6.5 \times 10^{-6}$  inch/inch/°F. From the coefficient of linear expansion, a material's coefficient of volumetric expansion can be determined. The coefficient of volumetric expansion is three times the coefficient of linear expansion:

$$\beta = 3\alpha$$

where

$\beta$  = Volumetric coefficient of expansion

$\alpha$  = Linear coefficient of expansion

Thus, the volumetric coefficient for copper is  $28.5 \times 10^{-6}$  gallon/gallon/°F, and for steel it is  $19.5 \times 10^{-6}$  gallon/gallon/°F. The material will expand proportionally with an increase in temperature.

**Equation 11-7**

$$V_{emat} = V_{mat} \times \beta (T_2 - T_1)$$

Making the above substitution and solving for  $V_{enet}$ ,

**Equation 11-8**

$$V_{enet} = V_{ew} - [V_{mat1} \times \beta_1 (T_2 - T_1) + V_{mat2} \times \beta_2 (T_2 - T_1)]$$

**Table 11-5 Nominal Volume of Piping**

Pipe Size, in.	Volume of Pipe, gal/linear ft of pipe
½	0.02
¾	0.03
1	0.04
1¼	0.07
1½	0.10
2	0.17
2½	0.25
3	0.38
4	0.67
6	1.50
8	2.70

**Example 11-2**

A domestic hot water system has a water heater made of steel with a volume of 900 gallons. It has 100 feet of 4-inch piping, 100 feet of 2-inch piping, 100 feet of 1½-inch piping, and 300 feet of ½-inch piping. All of the piping is copper. Assuming that the initial temperature of the water is 40°F and the final temperature of the water is 140°F, (1) how much will each material expand, and (2) what is the net expansion of water that an expansion tank will see?

- Utilizing Equation 11-7 for the steel (material no. 1),  $V_{mat1} = 900$  gallons and  $V_{emat1} = 900 (19.5 \times 10^{-6})(140 - 40) = 1.8$  gallons.

For the copper (material no. 2), first look at Table 11-5 to determine the volume of each size of pipe:

$$4 \text{ inches} = 100 \times 0.67 = 67 \text{ gallons}$$

$$2 \text{ inches} = 100 \times 0.17 = 17 \text{ gallons}$$

$$1\frac{1}{2} \text{ inches} = 100 \times 0.10 = 10 \text{ gallons}$$

$$\frac{1}{2} \text{ inch} = 300 \times 0.02 = 6 \text{ gallons}$$


$$\text{Total volume of copper piping} = 100 \text{ gallons}$$

Utilizing Equation 11-7 for copper,  $V_{mat2} = 100$  gallons and  $V_{emat2} = 100 (28.5 \times 10^{-6})(140 - 40) = 0.3$  gallon.

- The initial system volume of water ( $V_{S1}$ ) equals  $V_{mat1} + V_{mat2}$ , or 900 gallons + 100 gallons. From Example 11-1, 1,000 gallons of water going from 40°F to 140°F expands 16.9 gallons. Thus, utilizing Equation 11-8,  $V_{enet} = 16.9 - (1.8 + 0.03) = 15$  gallons. This is the net amount of water expansion that the expansion tank will see. Once again, note that this is not the size of the expansion tank needed.

**Boyle's Law**

After determining how much water expansion the expansion tank will see, it is time to look at how the cushion of air in an expansion tank allows the designer to limit the system pressure.



NOTE: PRESSURE OF WATER = PRESSURE OF AIR  
**Figure 11-4 Sizing the Expansion Tank**

Boyle's law states that at a constant temperature, the volume occupied by a given weight of perfect gas (including for practical purposes atmospheric air) varies inversely as the absolute pressure (gauge pressure + atmospheric pressure). It is expressed by the following:

**Equation 11-9**

$$P_1 V_1 = P_2 V_2$$

where

- $P_1$  = Initial air pressure, pounds per square inch absolute (psia)
- $V_1$  = Initial volume of air, gallons
- $P_2$  = Final air pressure, psia
- $V_2$  = Final volume of air, gallons

How does this law relate to sizing expansion tanks in domestic hot water systems? The air cushion in the expansion tank provides a space into which the expanded water can go. The volume of air in the tank decreases as the water expands and enters the tank. As the air volume decreases, the air pressure increases.

Utilizing Boyle's law, the initial volume of air (i.e., the size of the expansion tank) must be based on (1) initial water pressure, (2) desired maximum water pressure, and (3) change in the initial volume of the air. To utilize the above equation, realize that the pressure of the air equals the pressure of the water at each condition, and make the assumption that the temperature of the air remains constant at condition 1 and condition 2 in Figure 11-4. This assumption is reasonably accurate if the expansion tank is installed on the cold water side of the water heater. Remember, in sizing an expansion tank, the designer is sizing a tank of air, not a tank of water.

Referring to Figure 11-4, at condition 1 the tank's initial air pressure charge,  $P_1$ , equals the incoming

water pressure on the other side of the diaphragm. The initial volume of air in the tank,  $V_1$ , is also the size of the expansion tank. The final volume of air in the tank,  $V_2$ , also can be expressed as  $V_1$  less the net expansion of water ( $V_{enet}$ ). The pressure of the air at condition 2,  $P_2$ , is the same pressure as the maximum desired pressure of the domestic hot water system at the final temperature,  $T_2$ .  $P_2$  should always be less than the relief valve setting on the water heater.

Utilizing Boyle's law,  $P_1 V_1 = P_2 V_2$ . Since  $V_2 = V_1 - V_{enet}$ , then:

$$P_1 V_1 = P_2 (V_1 - V_{enet})$$

$$P_1 V_1 = P_2 V_1 - P_2 V_{enet}$$

$$(P_2 - P_1) V_1 = P_2 V_{enet}$$

$$V_1 = \frac{P_2 V_{enet}}{P_2 - P_1}$$

Multiplying both sides of the equation by  $(1/P_2)$  ( $1/P_2$ ), or by 1, the equation becomes:

**Equation 11-10**

$$V_1 = \frac{V_{enet}}{1 - (P_1/P_2)}$$

where

$V_1$  = Size of expansion tank required to maintain the desired system pressure,  $P_2$ , gallons

$V_{enet}$  = Net expansion of water, gallons

$P_1$  = Incoming water pressure, psia (Note: Absolute pressure is gauge pressure plus atmospheric pressure, or 50 psig = 64.7 psia.)

$P_2$  = Maximum desired pressure of water, psia

**Example 11-3**

Looking again at the domestic hot water system described in Example 11-2, if the cold water supply

pressure is 50 psig and the maximum desired water pressure is 110 psig, what size expansion tank is required?

Example 11-2 determined that Venet equals 15 gallons. Converting the given pressures to absolute and utilizing Equation 11-10, the size of the expansion tank needed can be determined as:

$$V_1 = \frac{15}{1 - (64.7/124.7)} = 31 \text{ gallons}$$

Note: When selecting the expansion tank, make sure the tank's diaphragm or bladder can accept 15 gallons of water (Venet).

## SUMMARY

Earlier in this section, the following were established:

### Equation 11-6

$$V_{ew} = V_{s1} \left( \frac{vsp_2}{vsp_1 - 1} \right)$$

### Equation 11-8

$$Venet = V_{ew} - [V_{mat1} \times \beta_1 (T_2 - T_1) + V_{mat2} \times \beta_2 (T_2 - T_1)]$$

In Equation 11-6,  $V_{s1}$  was defined as the system volume at condition 1.  $V_{s1}$  also can be expressed in terms of  $V_{mat}$ :

$$V_{s1} = V_{mat1} + V_{mat2}$$

Making this substitution and combining the equations provides the following two equations, which are required to properly size an expansion tank for a domestic hot water system.

### Equation 11-11

$$Venet = (V_{mat1} + V_{mat2}) \left( \frac{vsp_2}{vsp_1 - 1} \right) -$$

$$[V_{mat1} \times \beta_1 (T_2 - T_1) + V_{mat2} \times \beta_2 (T_2 - T_1)]$$

### Equation 11-10

$$V_1 = \frac{Venet}{1 - (P_1/P_2)}$$

where

Venet = Net expansion of water seen by the expansion tank, gallons

Vmat = Volume of each material, gallons

vsp = Specific volume of water at each condition, cubic feet per pound

$\beta$  = Volumetric coefficient of expansion of each material, gallon/gallon/°F

T = Temperature of water at each condition, °F

P = Pressure of water at each condition, psia

$V_1$  = Size of expansion tank required, gallons



# 12

## Potable Water Coolers and Central Water Systems

In the early 1900s, Halsey Willard Taylor and Luther Haws both invented their own version of the drinking fountain. Haws later patented the first drinking faucet (see Figure 12-1) in 1911. While the original fixtures supplied room-temperature water, demand for chilled water led to the development of a unit that used large blocks of ice to chill the water. A later evolution was a cumbersome floor-standing unit with a belt-driven ammonia compressor used to chill the water.

Today, a plethora of types and aesthetically pleasing models of water coolers satisfies even the most demanding applications. The industry is focused on providing the highest quality of water while using the least amount of floor space, allowing water coolers to be installed in heavy-traffic areas while satisfying code and end-user requirements.



**Figure 12-1 Early Drinking Faucet**  
Source: Haws Corp.

### WATER AND THE HUMAN BODY

The importance of nutrients is judged by how long the human body can function without them. Water is essential because humans can subsist for only about

a week without it. It constitutes approximately 75 percent of the human body and on average it takes eight cups of water to replenish the water a body loses each day.

Water has two primary tasks in the metabolic process: It carries nutrients and oxygen to different parts of the body through the bloodstream and lymphatic system, and it allows the body to remove toxins and waste through urine and sweat. Furthermore, it regulates body temperature, cushions joints and soft tissues, and lubricates articulations, hence balancing the functions of the body.

Considering the importance of water to the human body, the plumbing designer should keep in mind that the plumbing codes are nothing more than minimum requirements; therefore, the designer should evaluate if the code requirements will be sufficient to satisfy the building occupants' water needs.

### UNITARY COOLERS

A mechanically refrigerated drinking-water cooler consists of a factory-made assembly in one structure. This cooler uses a complete mechanical refrigeration system to cool potable water and provide such water for dispensing by integral and/or remote means.

Water coolers differ from water chillers. Water coolers are used to dispense potable water, whereas water chillers are used in air-conditioning systems for residential, commercial, and industrial applications and in cooling water for industrial processes.

The capacity of a water cooler is the quantity of water cooled in one hour from a specified inlet temperature to a specified dispensing temperature, expressed in gallons per hour (gph) (L/h). Standard capacities of water coolers range from 1 gph to 30 gph (3.8 L/h to 114 L/h).

### Ratings

Water coolers are rated on the basis of their continuous flow capacity under specified water temperature and ambient conditions (see Table 12-1). ARI 1010: *Self-Contained, Mechanically Refrigerated Drinking*

*Water Coolers* provides the generally accepted rating conditions and references test methods as prescribed in ANSI/ASHRAE 18: *Methods of Testing for Rating Drinking-Water Coolers with Self-Contained Mechanical Refrigeration*.

**Water Cooler Types**

The three basic types of water coolers are:

- Bottled water cooler (see Figure 12-2), which uses a bottle, or reservoir, to store the supply of water to be cooled and a faucet or similar means to fill glasses, cups, or other containers. It also includes a wastewater receptacle. The designer should always check with the authority having jurisdiction to ensure that a bottled water cooler satisfies the local minimum plumbing fixture requirements.
- Pressure-type water cooler (see Figures 12-3 and 12-4), which is supplied with potable water under pressure and includes a wastewater receptacle or means of disposing water to

a plumbing drainage system. Such coolers can use a faucet or similar means to fill glasses or cups, as well as a valve to control the flow of water as a projected stream from a bubbler so water may be consumed without the use of a glass or cup.

- Remote-type cooler, which is a factory-assembled single structure that uses a complete mechanical refrigeration system. Its primary function is to cool potable water for delivery to a separately installed dispenser.

**Table 12-1 Standard Rating Conditions**

Type of Cooler	Temperature, °F (°C)				
	Ambient	Inlet Water	Cooled Water	Heated Potable Water <sup>a</sup>	Spill(%)
Bottle type	90 (32.2)	90 (32.2)	50 (10)	165 (73.9)	None
Pressure type					
Utilizing precooler (bubbler service)	90 (32.2)	80 (26.7)	50 (10)	165 (73.9)	60
Not utilizing precooler	90 (32.2)	80 (26.7)	50 (10)	165 (73.9)	None
Compartment type cooler	During the standard capacity test, there shall be no melting of ice in the refrigerated compartment, nor shall the average temperature exceed 46°F (7.8°C).				

Source: ARI Standard 1010, reprinted by permission.

Note: For water-cooled condenser water coolers the established flow of water through the condenser shall not exceed 2.5 times the base rate capacity, and the outlet condenser water temperature shall not exceed 130°F (54.4°C). The base rate capacity of a pressure water cooler having a precooler is the quantity of water cooled in 1 h, expressed in gallons per hour, at the standard rating conditions, with 100% diversion of spill from the precooler.

<sup>a</sup> This temperature shall be referred to as the "standard rating temperature" (heating).



**Figure 12-2 Bottled Water Cooler**



**Figure 12-3 Wheelchair-Accessible Pressure-Type Water Cooler**

Source: Halsey Taylor



**Figure 12-4 Pressure-Type Pedestal Water Cooler**

Source: Halsey Taylor



In addition to these three basic types, water coolers are categorized by specialized conditions of use, additional functions they perform, or the type of installation, as described below.

### ***Special-Purpose Water Coolers***

Explosion-proof water coolers are constructed for safe operation in hazardous locations (volatile atmospheres), as classified in Article 500 of the National Electrical Code.

Vandal-resistant water coolers are made for heavy-use applications such as in schools or prisons.

Extreme climate water coolers include frost resistance for occasional cold temperatures and freeze protection for those used during sustained cold temperatures.

A cafeteria-type cooler is supplied with water under pressure from a piped system and is intended

primarily for use in cafeterias and restaurants to dispense water rapidly and conveniently into glasses or pitchers. It includes a means for disposing wastewater to a plumbing drainage system.

A drainless water cooler is a pressure-type cooler supplied by ¼-inch tubing from an available water supply and does not have a waste connection. As with the bottled water cooler, a drip cup sits on a pressure switch to activate a solenoid valve on the inlet supply to shut off the supply by the weight of the water in the cup.

Water coolers that accommodate wheelchairs are available in several styles. In the original design, the chilling unit was mounted behind the backsplash, with a surface-mounted bubbler projecting 14 inches from the wall, enabling a person in a wheelchair to roll under the fixture. In today's wheelchair-accessible units, the chilling unit is located below the level of the basin (see Figures 12-3 and 12-5), with the bubbler projecting from the wall at such a height that a person in a wheelchair can roll under it. Dual-height designs (see Figures 12-6 and 12-7), also known as barrier-free, are the most popular designs today. These units recognize the needs of able-bodied individuals, those with bending difficulties, and those in wheelchairs at a consolidated location. In fully recessed accessible designs, or barrier-free inverted, the chilling unit is mounted above the dispenser to allow a recess under the fountain for wheelchair access. When using this



**Figure 12-5 Wheelchair-Accessible Unit**

Source: Halsey Taylor



**Figure 12-6 Dual-Height Design**

Source: Halsey Taylor



**Figure 12-7 Dual-Height Design with Chilling Unit Mounted Above Dispenser**

Source: Haws Corp.



**Figure 12-8 Fully Recessed Water Cooler**

Source: Halsey Taylor



**Figure 12-9 Fully Recessed Water Cooler with Accessories**

Source: Halsey Taylor



**Figure 12-10 Fully Recessed, Barrier-Free Water Cooler**

Source: Oasis



**Figure 12-11 Semi-Recessed or Simulated Recessed Water Cooler**

Source: Halsey Taylor

style, the designer should ensure that the grill vanes go upward and that the recess is of sufficient depth and width for a person in a wheelchair. (For additional information on ADA-compliant fixtures, refer to *Plumbing Engineering Design Handbook, Volume 1*, Chapter 6, “Plumbing for People with Disabilities” and ICC/ANSI A117.1: *Accessible and Useable Buildings and Facilities*. Child requirements are based on the final ruling of the U.S. Access Board.)

The different types of water cooler installations include the following:

- Freestanding (see Figure 12-4)
- Wall hung (see Figures 12-3, 12-5, and 12-6)
- Fully recessed (see Figure 12-8), allowing an unobstructed path
- Fully recessed with accessories (see Figure 12-9)
- Fully recessed barrier-free (see Figure 12-10), for wheelchair access
- Semi-recessed or simulated recessed (see Figure 12-11)

### Options and Accessories

The designer should consider all accessories and options to satisfy project requirements. Water coolers are available with several different options:

- Activation devices, such as hands-free, sensor-operated, foot pedals, or push bottoms and push bars
- Glass or pitcher fillers, such as push lever or push down
- Bottle fillers, an industry response to new trends that aim to eliminate plastic water bottles (see Figure 12-12)
- Ice and/or cup dispensers, hot water dispensers, water filters, and refrigerated compartments
- Cane apron, an accessory designed to bring wall-hung, dual-mount water coolers into ADA compliance
- Bubblers, including standard, vandal resistant, and flexible, which is constructed of pliable polyester elastomer that flexes on impact before returning to its original position to help protect against accidental injuries. Flexible bubblers usually contain an antimicrobial agent blended into the plastic to

prevent bacteria from multiplying on the surface of the bubbler.

### Water Cooler Components

Water coolers may contain any of the following components (see Figure 12-13):

1. Antimicrobial safety
2. Stainless steel basin
3. Activation, such as push button, push bar, or infrared
4. Stream height regulator, which automatically maintains a constant stream height
5. Water system, manufactured of copper components or other lead-free materials
6. Compressor and motor
7. Non-pressurized cooling tank
8. Fan motor and blade
9. Condenser coil, fin or tube type
10. Drier, which prevents internal moisture from contaminating the refrigeration system
11. Drain outlet with 1¼-inch slip-joint fitting
12. Preset cooler control
13. Water inlet connection (not shown), which ac-

cepts ¾-inch outside diameter tubing for hookup to incoming water line

14. Inline strainer (not shown)

15. Water filtration

### Stream Regulators

Since the principal function of a pressure-type water cooler is to provide a drinkable stream of cold water from a bubbler, it usually is provided with a valve to maintain a constant stream height, independent of supply pressure. A flow rate of 0.5 gallon per minute (gpm) (0.03 L/s) from the bubbler generally is accepted as providing an optimum stream for drinking.

### REFRIGERATION SYSTEMS


As stipulated in the Montreal Protocol of 1987 and substantially amended in 1990 and 1992, HFC-134a refrigerant replaced the use of chlorofluorocarbons (CFCs), which have been implicated in the accelerated depletion of the ozone layer. HFC-134a is a commercially available, environmentally acceptable hydrofluorocarbon (HFC) commonly used as a refrigerant in HVAC systems.

Hermetically sealed motor compressors commonly are used for alternating-current (AC) applications, both 50 hertz (Hz) and 60 Hz. Belt-driven compressors generally are used only for direct-current (DC) and 25-Hz supply. The compressors are similar to those



**Figure 12-12** Bottle Filler

Source: Elkay



**Figure 12-13** Water Cooler Accessories

used in household refrigerators and range from 0.08 horsepower (hp) to 0.5 hp (0.06 kW to 0.37 kW).

Forced air-cooled condensers are most commonly used. In coolers rated less than 10 gallons per hour (gph) (38 L/h), natural convection, air-cooled (static) condensers sometimes are included. Water-cooled condensers of tube-on-tube construction are used on models intended for high ambient temperatures or where lint and dust in the air make air-cooled types impractical.

Capillary tubes are used almost exclusively for refrigerant flow control in hermetically sealed systems.

Pressure-type coolers often are equipped with precoolers to transfer heat from the supply water to the wastewater. When drinking from a bubbler stream, the user wastes about 60 percent of the cold water down the drain. In a precooler, the incoming water is put in a heat exchange relationship with the wastewater. Sometimes the cold wastewater also is used to subcool the liquid refrigerant. A precooler with this arrangement is called an economizer. Coolers intended only to dispense water into cups are not equipped with precoolers since no appreciable quantity of water is wasted.

Most water coolers manufactured today consist of an evaporator formed by refrigerant tubing bonded to the outside of a water circuit. The water circuit is usually a tank or a coil of large tubing. Materials used in the water circuit are usually nonferrous or stainless steel. Since the coolers dispense water for human consumption, sanitary requirements are essential (see UL 399: *Drinking Water Coolers*).

Water coolers that also provide a refrigerated storage space, commonly referred to as compartment coolers, have the same control compromises common to all refrigeration devices that attempt two-temperature refrigeration using a single compressor. Most bottle-type compartment coolers are provided with the simplest series system, one in which the refrigerant feeds first to a water-cooling coil and then through a restrictor device to the compartment. When the compressor operates, both water cooling and compartment cooling take place. The thermostat usually is located to be more affected by the compartment temperature, so the amount of compressor operation and water cooling available depends considerably on the usage of the compartment.

Some compartment coolers, generally pressure types, are equipped with more elaborate systems, ones in which separate thermostats and solenoid valves are used to switch the refrigerant flow from a common high side to either the water-cooling evaporator or the compartment evaporator. A more recently developed method of obtaining the two-temperature function uses two separate and distinct systems, each

having its own compressor, high side, refrigerant flow-metering device, and controls.

## WATER CONDITIONING

Most water coolers are classified by UL in accordance with NSF/ANSI 61: *Drinking Water System Components—Health Effects* and the Safe Drinking Water Act, which protects public health by regulating the nation’s public drinking water and its sources. Also, this legislation makes professional engineers, contractors, architects, building owners, and maintenance staff responsible for the quality of water dispensed from the equipment and fixtures they provide.

The effects of lead are devastating to the human body, as it accumulates on vital organs and alters the neurological system. Children are particular sensitive to lead because their bodies and vital organs are still developing. Even in low concentrations, lead can hinder growth and cause learning disabilities. High lead levels also can cause seizures, unconsciousness, and, in extreme cases, death from encephalopathy.




Figure 12-14 Upfeed Central System

In cases where the quality of a building's water supply is a concern, manufacturer units can be equipped with lead-reduction systems designed to remove cysts, lead particles, and chlorine. Methods to avoid and remove lead before it enters the water for the cooler include the following:

- Lead-absorbent filters, for installation on the incoming water to the cooler
- Reverse osmosis (RO) systems, which can be built into the water cooler
- Lead-free plumbing products complying with NSF/ANSI 61 Annex G and NSF/ANSI 372: *Drinking Water System Components—Lead Content*

## CENTRAL SYSTEMS

A central chilled drinking water system typically is designed to provide water at 50°F (10°C) to the drinking fountains. Water is cooled to 45°F (7.2°C) at the central plant, thus allowing for a 5°F (2.8°C) increase in the distribution system. System working pressures




Figure 12-15 Downfeed Central System

generally are limited to 125 pounds per square inch gauge (psig) (861 kPa). (The designer should check the local code for the maximum pressure allowed.) A central chilled drinking water system should be considered in any building, such as a multistory office building, where eight or more drinking fountains are stacked one above the other.

## Components

A central chilled drinking water system consists of the chilling unit, distribution piping, drinking fountains, and controls.

### Chilling Unit

The chiller may be a built-up or factory-assembled unit, but most installations use factory-assembled units. In either case, the chiller consists of the following:

- A semi-hermetic, direct-driven compressor using HFC-134a
- A condenser of the shell-and-tube or shell-and-coil type (water- or air-cooled)
- A direct-expansion water cooler of the shell-and-tube type, with a separate field-connected storage tank or an immersion-type coil installed in the storage tank. If a separate tank is used, a circulating pump normally is needed to circulate the water between the evaporator and the tank. Evaporator temperatures of 30°F to 34°F (-1.1°C to 1.1°C) are used.
- An adequately sized storage tank to accommodate the fluctuating demands of a multiple-outlet system. Without a tank or with a tank that is too small, the fluctuations will cause overloading or short-cycling, causing excessive wear on the equipment. The tank must be of nonferrous construction. The evaporator mounted in the tank should be of the same construction as the tank to reduce galvanic action.
- Circulating pumps, normally of the bronze-fitted, close-coupled, single-stage type with mechanical seals. For systems designed for 24-hour operation, duplex pumps are installed, with alternating controls allowing each pump to be used 12 hours per day.
- Controls consisting of high- and low-pressure cutouts, freeze protection, and thermostatic control to limit the temperature of the water leaving the chiller. A flow switch or differential pressure control also should be provided to stop the compressor when there is no flow through the cooler. Another desirable item is a time switch that can be used to operate the plant during periods of building occupancy.



Source: Haws Corp.



Source: Halsey Taylor

**Figure 12-16 Drinking Fountains**

### ***Distribution Piping System***

The distribution piping delivers chilled water to the drinking fountains. Systems can be upfeed as shown in Figure 12-14 or downfeed as shown in Figure 12-15. The piping can be copper, brass, or plastic (CPVC, PP, or PEX) designed for a working pressure of 125 psig (861 kPa).

The makeup cold water lines are the same material as the distribution piping. When the water supply has objectionable characteristics, such as high iron or calcium content, or contains odoriferous gases in solution, a filter should be installed in the makeup water line.

Insulation is necessary on all distribution piping and the storage tanks. The insulation should be glass fiber or closed cell foam insulation—such as that normally used on chilled-water piping—with a conductivity ( $k$ ) of 0.22 (32) at a 50°F (10°C) mean temperature and a vapor barrier jacket, or equal. All valves and piping, including the branch to the fixture, should be insulated. The waste piping from the drinking fountain, including the trap, should be insulated. This insulation is the same as is recommended for use on cold water lines.

### ***Drinking Fountains***

Any standard drinking fountain (see Figure 12-16) can be used in a central drinking water system. However, the automatic volume or stream regulator provided with the fountain must be capable of providing a constant stream height from the bubbler with inlet pressures up to 125 psig (861 kPa).

### **System Design**

#### ***Refrigeration***

For an office building, a usage load of 5 gph (19 L/h) per fountain for an average corridor and office is normal. The water consumption for other occupancies is given in Table 12-2. Table 12-3 is used to convert the usage load in gph (L/h) to the refrigeration load in British thermal units per hour (Btuh) (W). The heat gain from the distribution piping system is based on a circulating water temperature of 45°F (7.2°C). Table 12-4 lists the heat gains for various ambient temperatures. The length of all lines must be included when calculating the heat gain in the distribution piping. Table 12-5 tabulates the heat input from variously sized circulating pump motors.

The total cooling load consists of the heat removed from the makeup water, heat gains from the piping, heat gains from the storage tank, and heat input from the pumps. A safety factor of 10 to 20 percent is added before selecting a condensing unit. The size of the safety factor is governed by usage. For example, in a building with weekend shutdowns, the higher safety factor allows pickup when reopening the building on Monday morning when the total volume of water in the system would need to be cooled to the operating temperature. Since the water to the chiller is a mixture of makeup and return water, the chiller selection should be based on the resultant mixed water temperature.

#### ***Circulating Pump***

The circulating pump is sized to circulate a minimum of 3 gpm (0.2 L/s) per branch or the gpm (L/s) necessary to limit the temperature rise of the circulatory water to 5°F (2.8°C), whichever is greater. Table 12-6 lists the circulating pump capacity needed to limit the temperature rise of the circulated water to 5°F (2.8°C). If a separate pump is used to circulate water between the evaporator and the storage tank, the energy input to this pump must be included in the heat gain.

#### ***Storage Tank***

The storage tank's capacity should be at least 50 percent of the hourly usage. The hourly usage may be selected from Table 12-2.

#### ***Distribution Piping***

General criteria for sizing the distribution piping for a central chilled drinking water system are as follows:

- Limit the maximum velocity of the water in the circulating piping to 3 feet per second (fps) (0.9 m/s) to prevent the water from having a milky appearance.
- Avoid excessive friction head losses. The energy necessary to circulate the water enters the water as heat and requires additional capacity in the water chiller. Accepted practice limits the maximum friction loss to 10 feet (3 m) of head per 100 feet (30 m) of pipe.
- Dead-end piping, such as that from the main riser to the fountain, should be kept as short as possible, and in no event should it exceed 25 feet (7.6 m) in length. The maximum diameter of such dead-end piping should not exceed 3/8-inch (9.5-mm) iron pipe size (IPS), except on very short runs.
- Size piping on the total number of gallons circulated. This includes gallons consumed plus gallons necessary for heat leakage.

General criteria for the design layout of piping for a central chilled drinking water system are as follows:

- Keep pipe runs as straight as possible with a minimum number of offsets.
- Use long sweep fittings wherever possible to reduce friction loss.

- In general, limit the maximum pressure developed in any portion of the system to 80 psi (552 kPa). If the height of a building should cause pressures in excess of 80 psi (552 kPa), divide the building into two or more systems.
- If more than one branch line is used, install balancing cocks on each branch.
- Provide a pressure relief valve and air vents at high points in the chilled water loop.

The following example illustrates the calculations required to design a central chilled drinking water system.

**Example 12-1**

Design a central drinking water system for the building in Figure 12-15. The net floor area is 14,600 square feet (1,356 square meters) per floor, and occupancy is assumed to be 100 square feet (9.3 m<sup>2</sup>) per person. Domestic water is available at the top of the building, with 15-psig (103-kPa) pressure. Applicable codes are the Uniform Plumbing Code and the Uniform Building Code.

First calculate the number of drinking fountains required. The occupancy is 146 people per floor (14,600/100). The Uniform Building Code requires one fountain on each floor for every 75 people, so

**Table 12-2 Drinking Water Requirements**

Location	Bubbler Service: Persons Served Per Gallon (Liter) of Standard Rating Capacity	Cup Service: Persons Served Per Gallon (Liter) of Base Rate Capacity
Offices	12 (3)	30 (8)
Hospitals	12 (3)	—
Schools	12 (3)	—
Light manufacturing	7 (2)	—
Heavy manufacturing	5 (2)	—
Hot heavy manufacturing	4 (1)	—
Restaurants		10 (3)
Cafeterias		12 (3)
Hotels (corridors)		—

		Required Rated Capacity per Bubbler, gph (L/h)	
		One Bubbler	Two or More Bubblers
Retail stores, hotel lobbies, office building lobbies	12 (3)	5 (20)	5 (20)
Public assembly halls, amusement parks, fairs, etc.	100 (26)	20–25 (80–100)	15 (60)
Theaters	19 (5)	10 (40)	7.5 (30)

Source: Reprinted from ARI Standard 1010, by permission.  
 Note: Based on standard rating conditions, with delivered water at 50°F (10°C).

**Table 12-3 Refrigeration Load**

Water inlet temp., °F (°C)	Btu/Gal (W/L) Cooled to 45°F (7.2°C)					
	65 (18.3)	70 (21.1)	75 (23.9)	80 (26.7)	85 (29.4)	90 (32.2)
Btu/gal	167 (13)	208 (17)	250 (20)	291 (23)	333 (27)	374 (30)

Multiply load for 1 gal (L) by total gph (L/h).

146/74 = 1.94 fountains per floor. Therefore, use two fountains per floor, or a total of 20 fountains.

Calculate the estimated fountain usage. From Table 12-2, (146 × 0.083)/2 = 6 gph (22.7 L/h) per fountain.

Then determine the total anticipated makeup water. 6 gph × 10 fountains = 60 gph per riser, or 120 gph for two risers (22.7 L/h × 10 fountains = 227 L/h per riser, or 454 L/h for two risers).

The refrigeration load to cool the makeup water is determined from Table 12-3. Assuming 70°F (21.1°C) water inlet temperature, 120 gph × 208 Btuh per gallon = 25,000 Btuh (454 L/h × 16 W/L = 7,300 W).

Determination of heat gain in piping requires pipe sizes, but these sizes cannot be accurately known until the heat gains from the makeup water, piping, storage tank, and pumps are known. Therefore, assume 1-inch (25-mm) diameter chilled water risers, circulation line, and distribution piping to the risers. Then, the heat gains in the piping system are as follows (from Table 12-4):

Risers: (120 feet) (490 Btu/100 feet) (2 risers) = 1,189 Btuh (349 W)

Distribution mains: (90 feet) (490 Btu/100 feet) = 440 Btuh (129 W)

Return riser: (330 feet) (490 Btu/100 feet) = 1,620 Btuh (475 W)

Total piping heat gain = 3,249 Btuh (953 W)

The water that must be cooled and circulated is at a minimum of 3 gpm (11.4 L/h) per riser, or a total of 6 gpm (22.7 L/h).

Next, calculate the refrigeration load due to the circulating pump input. The pump head can be determined from data given in Table 12-7 and Figure 12-15. The results of the calculations are given in Table 12-8, with the indicated pumping requirements being 6 gpm (22.7 L/h) at a 25.77-foot (7.85-m) head. Data from one manufacturer indicates that a 3/4-hp

(0.56-kW) motor is needed. From Table 12-5, the heat input of the pump motor is 1,908 Btuh (559 W).

Finally, calculate the refrigeration load due to the storage tank heat gain. The tank is normally sized for 50 percent of the total hourly demand. Thus, for 100 gph (379 L/h), a 50-gallon (190-L) tank would be used. This is approximately the capacity of a standard 16-inch (406-mm) diameter, 60-inch (1,524-mm) long tank. Assume 1½-inch (38-mm) insulation, 45°F (7.2°C) water, with the tank in a 90°F (32.2°C) room. Assume an insulation conductivity of 0.13 Btuh per square foot (0.4 W/m²). The surface area of the tank is about 24 square feet (2.2 m²). Thus, the heat gain is 24 × 0.13 × (90 – 45) = 140 Btuh (41 W).

Thus, the load summary is as follows:

Item	Heat Gain, Btuh (W)
Makeup water	25,000 (7,325)
Piping	3,240 (949)
Pump heat input	1,908 (559)
Storage tank	140 (41)
Subtotal	30,288 (8,874)
20 percent safety factor	6,050 (1,773)
Required chiller capacity	36,338 (10,647)

**Installation**

A supply stop should be used so the unit may be serviced or replaced without shutting down the water system. Also, the designer should consult local, state, and federal codes for proper mounting height.

**STANDARDS, CODES, AND REGULATIONS**

Whether a self-contained (unitary) cooler or a central chilled water system, most mechanical installations are subject to regulation by local codes. They must comply with one or more plumbing, refrigeration, electrical, and accessibility codes. The majority of such local codes are based on model codes prepared by associations of nationally recognized experts.

**Table 12-4 Circulating System Line Loss**

Pipe Size, in. (mm)	Btu/h per Ft Per °F (W/°C/m)	Btu/h per 100 Ft (W per 100 m) [45°F (7.2°C) Circulating Water]		
		Room Temperature, °F (°C)		
		70 (21.1)	80 (26.7)	90 (32.2)
½ (13)	0.110(0.190)	280(269)	390(374)	500(480)
¾ (19)	0.119(0.206)	300(288)	420(403)	540(518)
1 (25)	0.139(0.240)	350(336)	490(470)	630(605)
1¼ (32)	0.155(0.268)	390(374)	550(528)	700(672)
1½ (38)	0.174(0.301)	440(422)	610(586)	790(758)
2 (51)	0.200(0.346)	500(480)	700(672)	900(864)
2½ (64)	0.228(0.394)	570(547)	800(768)	1030(989)
3 (76)	0.269(0.465)	680(653)	940(902)	1210(1162)

**Table 12-6 Circulating Pump Capacity**

Pipe Size, in. (mm)	Room Temperature, °F (°C)		
	70 (21.1)	80 (26.7)	90 (32.2)
½ (13)	8.0(99)	11.1(138)	14.3(177)
¾ (19)	8.4(104)	11.8(146)	15.2(188)
1 (25)	9.1(113)	12.8(159)	16.5(205)
1¼ (32)	10.4(129)	14.6(181)	18.7(232)
1½ (38)	11.2(139)	15.7(195)	20.2(250)

Notes

- Capacities are in gph per 100 ft (L/h per 100 m) of pipe including all branch lines necessary to circulate to limit temperature rise to 5°F (2.8°C) [water at 45°F (7.2°C)].
- Add 20% for a safety factor. For pump head, figure longest branch only. Install pump on the return line to discharge into the cooling unit. Makeup connection should be between the pump and the cooling unit.

**Table 12-5 Circulating Pump Heat Input**

Motor, Hp (kW)	¼(0.19)	½(0.25)	¾(0.37)	1(0.56)	1(0.75)
Btu/h (W)	636(186)	850(249)	1272(373)	1908(559)	2545(746)



**Table 12-7 Friction of Water in Pipes**

gpm (L/h)	½-in. (13-mm) Pipe		¾-in. (19-mm) Pipe		1-in. (25-mm) Pipe		1¼-in. (32-mm) Pipe		1½-in. (38-mm) Pipe	
	Velocity, ft/s (m/s)	Head, ft (m)	Velocity, ft/s (m/s)	Head, ft (m)	Velocity, ft/s (m/s)	Head, ft (m)	Velocity, ft/s (m/s)	Head, ft (m)	Velocity, ft/s (m/s)	Head, ft (m)
1 (227)	1.05 (0.32)	2.1 (0.64)	—	—	—	—	—	—	—	—
2 (454)	2.10 (0.64)	7.4 (2.26)	1.20 (0.37)	1.90 (0.58)	—	—	—	—	—	—
3 (681)	3.16 (0.96)	15.8 (4.82)	1.80 (0.55)	4.1 (1.25)	1.12 (0.34)	1.26 (0.38)	—	—	—	—
4 (912)	—	—	2.41 (0.73)	7.0 (2.13)	1.49 (0.65)	2.14 (0.65)	0.86 (0.26)	0.57 (0.17)	—	—
5 (1,135)	—	—	3.01 (0.92)	10.5 (3.20)	1.86 (0.57)	3.25 (0.99)	1.07 (0.33)	0.84 (0.26)	0.79 (0.24)	0.40 (0.12)
10 (2,270)	—	—	—	—	3.72 (1.13)	11.7 (3.57)	2.14 (0.65)	3.05 (0.93)	1.57 (0.48)	1.43 (0.44)
15 (3,405)	—	—	—	—	—	—	3.20 (0.98)	6.50 (1.98)	2.36 (0.72)	3.0 (0.91)
20 (4,540)	—	—	—	—	—	—	—	—	3.15 (0.96)	5.2 (1.58)

Note: Table gives loss of head in feet (meters) due to friction per 100 ft (30 m) of smooth straight pipe.

**Table 12-8 Pressure Drop Calculations for Example 12-1**

From <sup>a</sup>	Pipe Length, ft (m)		Water Flow, gpm (L/h)	Selected gpm Size, in.	Pressure Drop, ft (m)		Cumulative Pressure Drop, ft (m)
	Actual	Equivalent <sup>b</sup>			100 ft	Actual ft	
A to B	30(9)	45(14)	6(23)	1	5.0(1.5)	2.25(0.7)	2.25(0.7)
B to D	180(55)	270(82)	3(11.5)	1	1.3(0.4)	3.5(1.1)	5.75(1.8)
D to A	270(82)	406(124)	6(23)	1	5.0(1.5)	20.02(6.1)	25.77(7.9)

<sup>a</sup> Refer to Figure 12-15.

<sup>b</sup> Increase 50% to allow for fittings. If an unusually large number of fittings is used, each should be considered for its actual contribution to pressure drop.

Municipalities choose one of these model codes and modify it to suit local conditions. For this reason, it is important to refer to the code used in the locality and to consult the authority having jurisdiction.

Local refrigeration codes vary considerably. The Uniform Building Code sets up guide regulations pertaining to the installation of refrigeration equipment. It is similar in most requirements to ANSI/ASHRAE 15: *Safety Standard for Refrigeration Systems*, with some notable exceptions. Therefore, it is important to carefully apply the local code in the design of the refrigeration portion of a chilled drinking water system. Other local codes that merit careful review are the electrical regulations as they apply to controls, disconnection switches, power wiring, and ASME requirements for tanks and piping.

In addition to ARI 1010 and ANSI/ASHRAE 18, UL 399 covers safety and sanitation requirements. Federal Specification WW-P-541: *Plumbing Fixtures*, among others, usually is prescribed by government purchasers.

NSF/ANSI 61 is intended to cover specific materials or products that come into contact with drinking water, drinking water treatment chemicals, or both. The focus of the standard is the evaluation of contaminants or impurities imparted indirectly to drinking water.

A few states, including California, Vermont, Maryland, and Louisiana, have enacted “lead-free” legislation applicable to any product that dispenses or conveys water for human consumption. (Note that this does not replace NSF/ANSI 61 requirements.) Federal legislation revising the definition for “lead free” within the Safe Drinking Water Act as it pertains to pipe, pipe fittings, and fixtures will go into effect on January 4, 2014.

Many local plumbing codes apply directly to water coolers. Primarily, these codes are directed toward eliminating any possibility of cross-connection between the potable water system and the wastewater (or refrigerant) system. Therefore, most coolers are made with double-wall construction to eliminate the possibility of conflict with any code.



# 13 Bioremediation Pretreatment Systems

Pretreatment of effluent prior to discharge is a requirement established by federal legislation and implemented by federal regulations and state and local legislation. Pretreatment requirements apply to both direct discharges (i.e., to drain fields, streams, lakes, and oceans) and indirect discharges as in collection systems leading to treatment works. Pretreatment is required of all industrial discharges, which includes all discharges other than those from a domestic residence.

Pretreatment can involve the removal of metals, adjustment of pH, and removal of organic compounds. CFR Title 40: Protection of Environment, published by the U.S. Environmental Protection Agency (EPA), defines pretreatment as “the reduction of the amount of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a POTW [publicly owned treatment works]. The reduction or alteration may be obtained by physical, chemical, or biological processes, process changes, or by other means, except as prohibited.”

Bioremediation is a pretreatment method that simultaneously removes a pollutant from the waste stream and disposes of it by altering its chemical or physical structure such that it no longer depreciates water quality (in the case of direct discharges) or causes interference or pass-through (in the case of indirect discharges). Generally speaking, bioremediation can be described as the action of living organisms on organic or inorganic compounds to reduce in complexity or destroy the compound. Typically, bioremediation processes are conducted at the source of the pollutant to avoid transporting large quantities of polluted wastewater or concentrations of pollutants. The most common application of bioremediation to plumbing systems is for the disposal of fats, oils, and grease (FOG).

## PRINCIPLE OF OPERATION

Bioremediation systems, as described here, do not include the practice of adding enzymes, bacteria, nu-

trients, or combinations thereof (additives) to grease waste drainage, grease traps, or grease interceptors. The use of additives in conventional apparatus is a cleaning method resulting in the removal of FOG from the apparatus and its deposition downstream. Recombined FOG is usually a dense form, which is more difficult to remove from sewer mains and lift stations than the substance not altered by the application of additives.


Bioremediation systems are engineered systems containing the essential elements of a bioreactor that can be operated by the kinetic energy imparted from flowing water or mechanically agitated by various pumping and aeration methods. Bioremediation systems can be aerobic (requiring oxygen for the metabolic activity of the organisms), anaerobic (not requiring oxygen), or a combination of both. The type of bioremediation system employed is determined mainly by the target compound and the organisms necessary to metabolize that compound. In the case of FOG, typically the application of bioremediation is aerobic. Figure 13-1 shows a kinetically operated aerobic bioremediation system.

Central to the operation of all on-site bioremediation systems applied to FOG are:

- Separation, or the removal of FOG from the dynamic waste flow
- Retention, allowing the cleaned wastewater to escape, except for the static water content of the device
- Disposal, or the metabolic disassembly of FOG to its elements of hydrogen, oxygen, and carbon, usually in the form of water and carbon dioxide

Incidental to the application of a bioremediation system to FOG are:

- Sizing, or the calculation of the potential maximum flow over a designated interval
- Food solids removal from the liquid waste stream



**Figure 13-1 Kinetically Operated Aerobic Bioremediation System**

- Placement, to minimize the length of untreated grease waste piping

### Separation

Separation of FOG with the greatest efficiency, measured as the percentage of FOG present in the waste stream and the time necessary to effect separation, is essential to the accomplishment of retention and disposal. The standards for this measurement are PDI G101, PDI G102, and ASME A112.14.6. Separation can be effected by simple gravity flotation, in which case the device must be of sufficient volume to provide the proper retention time and quiescence to allow ascension of suspended FOG (see Chapter 8). Separation also can be effected by coalescence, coagulation, centrifugation, dissolved air flotation, and skimming. In these instances, for a given flow, the device is typically smaller in dimension than in the gravity flotation design.

Because food particles generally have a specific gravity greater than 1 and are oleophilic, the presence of food particles materially interferes with the efficient separation of FOG from the waste stream. Food grinders typically are not used upstream of bioremediation systems for this reason and because of the increased biological oxygen demand (BOD) that the additional waste places on the system.

### Retention

The retention of FOG in a bioremediation system is essential to its disposal by a reduction in its constituent elements. Retention is facilitated by baffles,

compartmentalization, or sedimentation, depending on the system design. Because only 15 percent of suspended FOG (at a specific gravity of 0.85) is above the water's surface, bioremediation systems that retain FOG a greater distance from dynamic flows generally have greater retention efficiencies and capacities than those that rely on suspension alone.

### Disposal

The disposal of FOG by biochemical processes within an on-site system is the most distinguishing feature of bioremediation systems. The organisms responsible for metabolizing the FOG may be endemic to the waste stream or, more likely, seeded by means of a timed or flow-sensitive metering device. Crucial to a disposal function equal to ongoing separation and retention rates is a sufficient population of organisms in contact with the FOG. While this is a function of sizing (see the section on sizing guidelines later in this chapter), it is also a function of system design.

The mechanism typically utilized to provide a stable, structured population of organisms in a bioremediation system is a biofilm, which is a controlled biological ecosystem that protects multiple species of organisms from washouts, biocides, and changing environmental conditions in the bioremediation system. Biofilm forms when bacteria adhere to surfaces in aqueous environments and begin to excrete a slimy, glue-like substance that can anchor them to many materials, such as metals, plastics, soil particles, medical implants, and tissue.

Biofilms are cultivated on structures of various configurations of the greatest possible surface area per given volume. The structure or structures generally are referred to as media. The media may be fixed (i.e., stationary relative to the device and the waste flow), moved by a mechanism such as a series of rotating discs or small, ball-shaped elements, or moved randomly by the energy of the waste stream flow and/or pump or aerator agitation.

The organisms inhabiting a biofilm reduce the FOG to carbon dioxide and water through a process called beta oxidation, in which fatty acid chains are shortened by the successive removal of two carbon fragments from the carboxyl end of the chain. Bioremediation systems utilizing structured biofilms are much more resistant to the effects of biocides, detergents, and other chemicals frequently found in kitchen effluent than systems using planktonic application of organisms. The efficiency of bioremediation systems in terms of disposal depends on the total surface area of the media relative to the quantity of FOG separated and retained, the viability and species diversity of the biofilm, system sizing, and installation.

## FLOW CONTROL

Flow control is sometimes used with bioremediation systems depending on system design. When flow control devices are prescribed by the manufacturer, generally they are best located near the discharge of the fixtures they serve. However, because bioremediation systems are engineered systems, the use and placement of system elements are prescribed by the manufacturer. In instances in which elements of a bioremediation system may be common to the plumbing industry, the manufacturer's prescription for the application of those elements to the system shall prevail over common practice or code requirements.

## SIZING GUIDELINES

These guidelines are intended as a tool for the engineer to quantify the maximum hydraulic potential from a given facility. Typically, fixture unit equivalency prediction sizing methods and other estimation tools based on utilization rate weighted factors are not acceptable sizing tools for bioremediation systems. Bioremediation systems must be capable of accommodating maximum hydraulic events without experiencing upset, blockage, or pass-through.

The sizing procedure is as follows:

1. Fixture inventory: Itemize every fixture capable of liquid discharge to the grease waste piping system including but not limited to sinks, hoods, ware washers, floor sinks and drains, and kettles. Grinder pulpers are generally not discharged to bioremediation systems. Review the manufacturer's requirements for each particular system.
2. Capacity calculation: Calculate the capacity of liquid-retaining devices such as sinks as follows:
 
$$\text{Length} \times \text{Width} \times \text{Depth} = \text{Capacity, in cubic inches}$$

$$\text{Capacity} \times \text{Number of compartments} = \text{Total capacity, in cubic inches}$$

$$\text{Total cubic capacity} \div 231 = \text{Gallons capacity}$$

$$\text{Gallons capacity} \times 0.75 \text{ (fill factor)} = \text{Rated discharge, in gallons per minute (gpm)}$$
 (Note: If a two-minute drain duration is used, divide the rated discharge by two.)
3. Rated discharges: Fixtures such as ware washers with a manufacturer's rated water consumption or single discharge rate are calculated at the greater rate.
4. Floor sinks and drains: Floor sinks and drains generally are rated at 4 gpm. Count the number of floor drains and sinks not receiving indirect discharges from the fixtures calculated above and multiply by four to determine the gpm potential. If this number exceeds the total supply to the facility, select the smaller of the two numbers.
5. Loading influences: Some manufacturers may prescribe multipliers for various facility characteristics such as cuisine to accommodate anticipated increased organic content per gallon of calculated discharge. Refer to the manufacturer's requirements for specific systems.

## DESIGN STANDARDS

Each manufacturer of a bioremediation system has specific design elements to establish fitness for the purpose of its particular design. Certain fundamental materials and methods utilized in the design and manufacture of bioremediation systems are indicated by the following standards:

- ASME A112.14.6: *FOG (Fats, Oils, and Greases) Disposal Systems*
- ASTM C33: *Standard Specification for Concrete Aggregates*
- ASTM C94: *Standard Specification for Ready Mixed Concrete*
- ASTM C150: *Standard Specification for Portland Cement*
- ASTM C260: *Standard Specification for Air-Entraining Admixtures for Concrete*
- ASTM C618: *Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete*
- PDI G101: *Testing and Rating Procedure for Hydro Mechanical Grease Interceptors*

- PDI G102: *Testing and Certification for Grease Interceptors with FOG Sensing and Alarm Devices*
- ACI 318: *Building Code Requirements for Structural Concrete*
- IAPMO PS 1: *Tank Risers*
- UL 5085-3: *Low Voltage Transformers—Part 3: Class 2 and Class 3 Transformers*
- AASHTO H20-44
- U.S. EPA Test Method 1664

## MATERIALS

### Concrete

If concrete is used as the container material for a bioremediation system, the concrete and reinforcement should be of sufficient strength to resist stresses caused during handling and installation without structural cracking and be of such corrosion-resistant quality to resist interior and exterior acids that may be present. Concrete should have a minimum compressive strength of 3,500 pounds per square inch (psi) (24,132 kPa) and a maximum water-cementing materials ratio of 6 gallons per sack of cement. Concrete should be made with Type II or V, low-alkali Portland cement conforming to ASTM C150 and also should include the sulfate expansion option as specified in Table 4 of ASTM C150 for Type II or V. Concrete should contain 4 to 7 percent entrained air utilizing admixtures conforming to ASTM C260. Concrete aggregates should conform to ASTM C33. If ready-mix concrete is used, it should conform to ASTM C94. Fly ash and raw or calcined natural pozzolan, if used as mineral admixture in Portland cement concrete, should conform to ASTM C618.

### Stainless Steel

Stainless steel used in bioremediation systems should be of type 316 or of some other type with equal or greater corrosion resistance.

### Fiberglass-Reinforced Polyester

Bioremediation systems constructed principally of fiberglass-reinforced polyester should comply with the minimum requirements expressed for septic tanks in Section 5 of IAPMO PS 1.

### Polyethylene

Bioremediation systems constructed principally of polyethylene should comply with the minimum standards expressed for septic tanks in Section 5 of IAPMO PS 1.

## STRUCTURAL CONSIDERATIONS

Bioremediation systems should be designed to handle all anticipated internal, external, and vertical loads.

Bioremediation system containers, covers, and structural elements that are intended for burial and/or traffic loads should be designed for an earth load of not less than 500 pounds per square foot (24 kPa) when the maximum coverage does not exceed 3 feet (0.9 meter). Each system and cover should be structurally designed to withstand all anticipated earth or other loads and should be installed level and on a solid surface.

Bioremediation systems, containers, covers, and structural elements for installation in traffic areas should be designed to withstand an AASHTO H20-44 wheel load and an additional 3-foot (0.9-m) earth load with an assumed soil weight of 100 pounds per square foot (4.8 kPa) and a fluid equivalent sidewall pressure of 30 pounds per square foot (1.4 kPa).

Internal construction of separations, coalescing surfaces, baffles, and structures that may compartmentalize fluids should be designed to withstand the maximum expected hydrostatic pressure, which includes the pressure exerted by one compartment at maximum capacity with adjacent compartments empty. The internal structures should be of suitable, sound, and durable materials consistent with industry standards.

In buried applications, bioremediation systems should have safe, reasonable access for prescribed maintenance and monitoring. Access could consist of horizontal manways or manholes. Each access opening should have a leak-resistant closure that cannot slide, rotate, or flip. Manholes should extend to grade, have a minimum diameter of 20 inches (0.5 m) or be 20 × 20 inches (0.5 × 0.5 m) square, and should comply with IAPMO PS 1 Section 4.7.1.

Bioremediation systems should be provided with drawings as well as application and disposal function details. Descriptive materials should be complete, showing dimensions, capacities, flow rates, structural and process ratings, and all application and operation facts.

## DIMENSION AND PERFORMANCE CONSIDERATIONS

Bioremediation systems differ regarding type and operating method, but all should have a minimum volume-to-liquid ratio of 0.4 gallon per 1-gpm flow rating and a minimum retention ratio of 3.75 pounds of FOG per 1-gpm flow. The inside dimension between the cover and the dynamic water level at full-rated flow should be a minimum of 2 inches (51 mm). While the air space should have a minimum volume equal to 10.5 percent of the liquid volume, air management and venting shall be prescribed by the manufacturer.

The bioremediation system's separation and retention efficiency rating should be in accordance

with PDI G101. Bioremediation systems should show no leakage from seams, pinholes, or other imperfections.

Performance testing of bioremediation systems should demonstrate performance equal to or exceeding manufacturer claims and should have a minimum discharge FOG content not to exceed 100 milligrams per liter. Performance testing should be conducted only by accredited, third-party, independent laboratories in accordance with current scientific methods and EPA analysis procedures.

## **INSTALLATION AND WORKMANSHIP**

Installation should be in accordance with the manufacturer's requirements. Bioremediation systems should be free of cracks, porosity, flashing, burrs, chips, and filings or any defects that may affect performance, appearance, or serviceability.





# 14 Green Plumbing

Plumbing engineers are not the green police. Their primary responsibility is serving the client who hires them to design a specific set of plumbing systems. However, plumbing engineers can try to educate clients and help them appreciate the immediate and long-term benefits of sustainable design, and as a result of these efforts, more projects are going green. In fact, many authorities having jurisdiction require some of the practices discussed in this chapter.

By incorporating sustainable design practices into their projects, plumbing engineers can help clients save water, energy, and money, as well as potentially obtain Leadership in Energy and Environmental Design (LEED) certification. All parties benefit by increasing the efficiency of buildings. Also, it is essential to make efforts to preserve some of the natural resources that are being flushed away every day. Some of these design considerations are mandated by federal law. Some may be legislated in the future. Others provide immediate financial benefits, and many provide health benefits. Sustainable design practices are constantly evolving, and it is up to each individual to investigate emerging technologies and choose the best systems for their clients.

## WHAT IS SUSTAINABLE DESIGN?

Sustainable design is not a new concept. It has been done for decades. In some cases, current sustainable design practices actually return to old technologies that were abandoned when petroleum products became so available and cheap. However, sustainable design has taken on new meaning with the popularity of green building. Plumbing engineers should always consider the efficiency of the systems they design for any project and utilize the sustainable technologies that are appropriate for each project's needs. While some sustainable practices help achieve LEED certification, many do not, but certification should not be the only objective.

In a 1987 report, the Brundtland Commission, formerly known as the U.N. World Commission on

the Environment and Development, defined sustainable development as “development that meets the needs of the present without compromising the ability of future generations to meet their needs.” Sustainable development also might be described as design and construction practices that significantly reduce or eliminate the negative impact of buildings on the environment and occupants in five broad areas: sustainable site planning, safeguarding water and water efficiency, energy efficiency and renewable energy, conservation of materials and resources, and indoor environmental quality.

## ASSESSMENT AND VALIDATION

Numerous organizations worldwide provide rating and accreditation processes for various types of construction. The Building Research Establishment Environmental Assessment Method (BREEAM) is the European equivalent to the U.S. Green Building Council's LEED program.

### The USGBC and LEED

The U.S. Green Building Council is a nonprofit coalition of leaders from across the building industry who promote buildings that are environmentally responsible, profitable, and healthy places to live and work. The purpose of this organization is to integrate building industry sectors and lead a market transformation—including the education of owners and practitioners.

LEED stands for Leadership in Energy and Environmental Design. The LEED certification program encourages a whole-building approach. It promotes and guides a collaborative process of integrated design and construction. Rating systems are available for new construction, existing building operations and maintenance, core and shell, commercial interiors, schools, retail, homes, healthcare, and neighborhood development.

LEED helps plumbing engineers design systems that optimize environmental and economic factors, increasing efficiency in these areas. LEED also

**Table 14-1 Treatment Stages for Water Reuse**

Level 1	Components
Nonpotable systems needing limited treatment <ul style="list-style-type: none"> <li>• Catchment flushing</li> <li>• Large contaminate removal</li> <li>• Sediment filtration</li> </ul>	<ul style="list-style-type: none"> <li>• Screen</li> <li>• First Flush</li> <li>• Vortex/Centrifugal</li> </ul>
Level 2	Components
Low-level potable systems <ul style="list-style-type: none"> <li>• All of the previous steps</li> <li>• Treatment for odor control</li> <li>• Increased level of filtration</li> <li>• Limited treatment for disease-causing pathogens</li> </ul>	<ul style="list-style-type: none"> <li>• Everything above</li> <li>• Cartridge filters</li> <li>• Automated sand filters</li> <li>• Ultraviolet (UV) light</li> <li>• Ozone</li> </ul>
Level 3	Components
Potable water for human consumption <ul style="list-style-type: none"> <li>• All of the previous steps</li> <li>• Automated system testing of pre-potable incoming water</li> <li>• Increased level of filtration</li> <li>• Increased level of disinfection processes</li> <li>• Automated system of testing the water after treatment to confirm water quality meets the standards for human consumption</li> </ul>	<ul style="list-style-type: none"> <li>• Everything above</li> <li>• Membrane filtration</li> <li>• Reverse osmosis (RO)</li> <li>• Nanofiltration</li> <li>• Chlorination as required</li> </ul>
Level 4	Components
Black water for nonpotable systems <ul style="list-style-type: none"> <li>• All of the previous steps</li> <li>• Bio-remediation with membrane system and air injectors</li> <li>• Post-recovery filtration similar to Level 3: RO, O3, UL, etc.</li> <li>• Additional testing with strict manual and electronic monitoring</li> <li>• Biosludge disposal</li> <li>• On-site technician, 24/7</li> </ul>	<ul style="list-style-type: none"> <li>• Everything above.</li> <li>• Manmade wetlands</li> <li>• Additional filtration</li> <li>• Additional testing and monitoring.</li> <li>• 24-hour technician on site</li> <li>• 24-hour technician on site</li> <li>• Proper disposal plan and systems</li> </ul>
Level 5	Components
Black water for potable systems <ul style="list-style-type: none"> <li>• All of the previous steps</li> <li>• Additional filtration similar to Level 3: RO, O3, UL, etc.</li> <li>• Additional testing with strict manual and electronic monitoring</li> <li>• On-site technician, 24/7</li> </ul>	<ul style="list-style-type: none"> <li>• Everything above</li> <li>• Additional filtration</li> <li>• Additional testing and monitoring</li> <li>• Proper disposal plan and systems</li> </ul>

provides recognition of quality buildings and environmental stewardship through third-party validation of achievement and federal, state, and local government incentives.

The four levels of LEED certification are Certified, Silver, Gold, and Platinum. Note that the certification levels are subject to change and reflect the current system. Always double-check which system and version applies to each particular project. For the latest information on LEED systems and certification, visit [usgbc.org](http://usgbc.org).

The LEED program is broken into categories in which numerous credits can be obtained. The program focuses on sustainable sites, water efficiency, energy and the atmosphere, materials and resources, indoor environmental quality, and innovation in design. The plumbing systems that plumbing engineers design can help obtain credits in many of the categories.

### REAL-LIFE FINANCIAL BENEFITS

The most common objections to building green are the perceived high cost of LEED documentation and higher design and construction costs. While it is estimated that construction costs may increase 3 percent for a

LEED-certified building, the construction cost of a typical office building has been shown to be about 2 percent of the total lifetime cost, assuming a 20-year lifespan, and about 5 percent for operation and maintenance, whereas the people inhabiting the building may account for as much as 92 percent of the total cost through salaries and benefits.

Increased sustainability in plumbing system designs can have direct financial rewards. Some of the ways that sustainable design practices can provide tangible financial benefits are through reduced operating and maintenance costs, as well as reduced insurance and liability through the improved health of occupants, greater occupant satisfaction, improved performance of occupants, reduced absentee-

ism, lower environmental impacts, and streamlined regulatory approvals. Sustainable design also leads to higher building valuations. The rule of thumb is to divide the reduction in annual operating costs by 10 percent to get the increased value of the building, which may be up to \$4 in increased valuation for every \$1 spent. Green buildings also typically enjoy higher visibility and marketability.

## HOW PLUMBING SYSTEMS CONTRIBUTE TO SUSTAINABILITY

### Domestic Water Use Reduction for Irrigation

Some LEED credits are related to irrigation. A building can earn points by reducing or eliminating the amount of domestic water required for irrigation and landscaping. How can this be accomplished? Methods for earning these credits include many design choices, such as utilizing plantings that do not require watering other than the rain that they receive naturally, using rainwater to sustain the landscaping, and capturing and reusing wastewater from the building, such as condensate waste, for landscaping needs.

1.28 gpf / 4.8 Lpf  
HIGH EFFICIENCY TOILET  
SLOAN

SLOAN  
HIGH EFFICIENCY TOILET  
1.28 gpf / 4.8 Lpf

# sloan performance

also comes in  
white



A full line of vitreous fixtures engineered and built exclusively for commercial use

Maximum performance at any flush volume

The perfect partner to our industry leading flushometers and faucets

From the leader of energy- and water- efficient commercial restroom solutions



Scan with  
Smart Phone  
for more  
information

[www.sloanvalve.com](http://www.sloanvalve.com)



SLOAN®

## Domestic Water Use Reduction for Fixtures

To earn LEED points for plumbing fixtures, the project team must demonstrate that the domestic water required for the plumbing fixtures was reduced. Specifying low-flow fixtures in lieu of conventional fixtures can easily accomplish this objective for most projects. The standards used as the reference, or baseline, are per the requirements of the Energy Policy Act of 1992. This includes 1.6-gallon-per-flush (gpf) toilets, 1-gpf urinals, 2.5-gallon-per-minute (gpm) faucets, and 2.5-gpm showerheads. Note that flush fixtures are rated in gpf, and flow fixtures are rated in gpm. These fixture types have different characteristics and need to be addressed relative to their functionality.

Some of the reduced-consumption fixtures include 1.28-gpf toilets; 0.5-gpf, 0.125-gpf, and waterless urinals; 0.5-gpm faucets; 1.6-gpm kitchen faucets; and 2-gpm, 1.8-gpm, 1.5-gpm, and even 1-gpm showerheads. Which fixtures are best? It depends on the project. This is a decision that must be made by the plumbing designer in conjunction with the architect, taking into consideration the needs of the owner. Some of the considerations may be site-specific. For instance, waterless urinals may be a good choice in areas that have little or no water supply. 0.125-gpf urinals may be more appropriate for other projects.

Another water-saving technique is vacuum-operated waste transport systems. They are used on cruise ships and in some prisons. The water closets require only 0.5 gpf, but additional energy is required to operate the vacuum pumping system. This drainage system relies on a mechanical device requiring power to operate, which adds another potential weak point to the system.

## Wastewater Management

Wastewater management must be part of a total sustainable building strategy. This includes consideration of the environmental impacts of wastewater: the quality, quantity, and classification of wasted matter must be taken into account. The wastewater expelled from buildings is a combination of biodegradable waste, reusable waste, storm water runoff, and non-degradable waste. The biodegradable waste can be considered a source of nutrients that can go back into nature by bioremediation methods. Many non-degradable wastes can be recycled. Some by-products may require handling as hazardous materials.

Storm water runoff can be recycled and used to reduce domestic water consumption.

Wastewater reclamation and reuse systems can be categorized into the following levels (see Table 14-1).

- **Level 1—Nonpotable systems needing limited treatment:** Rainwater and condensate waste collection systems shall be provided for irrigation and cooling use. Provide a collection tank, circulating pump, and point of connection for landscaping, coordinating with the landscape and heating, ventilating, and air-conditioning (HVAC) contractors. Recovery and delivery systems should include redundant tanks and other equipment to facilitate cleaning and maintenance. Domestic water makeup also should be included for emergency use and when supplementary water is required. Excess water production from Level 1 shall be conveyed to Level 2.
- **Level 2—Low-level potable systems:** Level 2 systems shall collect water from graywater processing, as well as from Level 1 production surpluses. Each system should include redundant tanks and other equipment to facilitate cleaning and maintenance. Domestic water makeup also should be included for emergency use and when supplementary water is required. Each graywater system shall include filters, an ultraviolet (UV) system, tanks, pumps, etc., all of which must be indicated on the plumbing drawings. The graywater reuse fixtures may return their waste to a black water treatment system. This type of system typically treats suspended




Figure 14-1 Typical Small Rainwater Cistern System Diagram

solids, odors, and bacteria in water to be reused for toilet flushing.

- Level 3—Potable water for human consumption: Level 3 consists of both public domestic water and water from Level 1 and Level 2 systems, with additional treatment. Water shall be collected from the public water utility, as well as from Level 1 and Level 2 production surpluses. The Level 1 and 2 water must be processed with UV, reverse osmosis (RO), ozone, and filtering systems similar to Level 2, but monitored to EPA or NSF International standards or the local equivalents. Each system shall include filters, a UV or similar system, tanks, pumps, etc., all of which must be indicated on the plumbing drawings.
- Level 4—Black water for nonpotable systems: Level 4 includes water not meant for human consumption without further processing. It can be used for toilet flushing and laundry facilities. This system must include redundancy. Water shall be collected from the graywater system, as well as from Level 1 and Level 2 production surpluses. Each system shall be provided with emergency domestic water makeup. Each system shall include filters, a UV system, tanks, pumps, etc., all of which must be indicated on the plumbing drawings.

**Table 14-2 Rainwater Treatment Options**

Treatment Method	Location	Result
<b>Screening</b>		
Leaf screens and strainers	Gutters and downspouts	Prevents leaves and debris from entering tank
<b>Settling</b>		
Sedimentation	Within tank	Settles out particulates
Activated charcoal	Before tap	Removes chlorine*
<b>Filtering</b>		
Roof washers	Before tank	Removes suspended material
Inline multistage cartridge	After pump	Sieves sediment
Activated charcoal	After sediment filter	Removes chlorine* and improves taste
Slow sand filters	After tank	Traps particulates
<b>Microbial Treatment/Disinfection</b>		
Boiling/distilling	Before use	Kills microorganisms
Chemical treatment (chlorine or iodine)	Within tank or at pump (liquid, tablet, or granular) before activated charcoal	Kills microorganisms
Ultraviolet light	After activated charcoal filter and before tap	Kills microorganisms
Silver ionization	After activated charcoal filter and before tap	Kills microorganisms
Ozonation	After activated charcoal filter and before tap	Kills microorganisms
Nanofiltration	Before use, polymer membrane (10 <sup>-3</sup> –10 <sup>-4</sup> pores)	Removes molecules
Reverse osmosis	Before use, polymer membrane (10 <sup>-3</sup> –10 <sup>-4</sup> pores)	Removes ions (contaminants) and microorganisms

\*Should be used if chlorine has been used as a disinfectant.

Source: *Texas Guide to Rainwater Harvesting*, 2<sup>nd</sup> edition, Texas Water Development Board

**Table 14-3 Filtration/Disinfection Method Comparison**

Treatment Method	Cost	Maintenance	Effectiveness	Comments
Cartridge filters	\$20–60	Change filters regularly	Removes particulates > 3 microns	Disinfection treatment also is recommended
Reverse osmosis	\$400–1,500	Change filter when clogged (depends on turbidity)	Removes particulates > 0.001 microns	Disinfection treatment also is recommended
Ultraviolet light	\$350–1,000 (\$80 bulb replacement)	Replace bulb every 10,000 hours or 14 months; clean protective cover regularly	Disinfects filtered water provided (< 1,000 coliforms per 100 millimeters)	Water must be filtered prior to exposure for maximum effectiveness
Ozonation	\$700–2,600	Monitor effectiveness with frequent testing or monitoring equipment (about \$1,200)	Less effective in high turbidity; should be prefiltered	Requires pump to circulate ozone molecules
Chlorination	\$1/month manual dose or \$600–3,000 for automatic dosing system	Include monitoring with automatic dosing	Less effective in high turbidity; should be prefiltered	Excessive chlorine levels have been linked to health issues and damage to copper piping systems

Source: *Texas Guide to Rainwater Harvesting*, 2<sup>nd</sup> edition, Texas Water Development Board

- **Level 5—Black water for potable systems:** Level 5 includes water not meant for human consumption or contact without additional treatment. It consists of black water that has been collected and treated. Each system shall include membrane filters, bio-chambers, a UV system, tanks, pumps, etc., as indicated on the plumbing drawings. Sludge accumulation shall be conveyed to a suitable site for further processing and disposal, based on an analysis of the sludge components.

**Rainwater Capture and Reuse**

Rainwater reuse can help earn more than one credit: water use reduction, wastewater management, storm water management, and innovation in design. The captured water may be used for irrigation, flushing toilets, or cooling tower makeup, among other uses. Various filtration methods may be necessary, depending on the final use of the water. Ideally, the storage tanks should be elevated, such as on the top floor of the building, to reduce or eliminate pumping requirements. Remember that tanks store water, but also can store pressure by permitting the stored water to flow by gravity. Static head increases with height. If the building is high enough to require multiple water pressure zones, multiple tanks can be located at varying levels, possibly with one tank cascading down to another. As with all aspects of design, the approach must be customized relative to each individual project. Figure 14-1 shows a typical small cistern system diagram.

Many jurisdictions require rainwater detention to control the release rate into the sewer systems. Many municipal systems are overloaded and cannot process the storm water entering the system during significant rain events. Some cities have combined storm and sanitary sewer systems, which can make the problem even worse. One of the causes of this

problem is increased impermeable surface features due to increased density, a result of urban sprawl. This effect can be reduced through the use of green roofs, permeable paving materials, storm water detention, and other innovative approaches.

Table 14-2 outlines some types of treatment for rainwater systems. Many options are available, for different purposes. Most systems require some combination of these treatment options. Table 14-3 compares the cost, maintenance, and effectiveness of these filtration and disinfection methods.

Storage tanks come in many shapes, sizes, and materials. They can be located below grade, above grade, near the roof, or in many other locations. Table 14-4 compares the different storage tank options for rainwater collection.

**Graywater and Black Water**

About 68 percent of household wastewater is graywater. The other approximately 32 percent is black water. Figure 14-2 and Table 14-5 compare the two types. Wastes from dishwashers and kitchen sinks can be piped to automatic grease separators. These separators automatically siphon off the fats, oils, and greases, which can be used for bio-diesel fuel. The remaining wastewater then is processed as black water. It’s a good idea to locate these facilities on the truck dock or another location that provides plenty of external venting to reduce odors indoors.

**Biosolids Technology**

Biosolids can be a by-product of graywater, but they primarily come from black water processing. A biosolid is the remaining sludge and also what is skimmed from the surface. It consists of different components requiring a variety of handling methods and technologies.

**Table 14-4 Storage Tank Options**

Material	Features	Cautions	Cost	Weight
<b>Plastics</b>				
Polyethylene/polypropylene	Commercially available, alterable, and moveable	UV-degradable; must be painted	\$.035–1.00/gallon	8 lbs/gallon
Fiberglass	Commercially available, alterable, and moveable	Must be sited on smooth, solid, level footing	\$0.50–2.00/gallon	8 lbs/gallon
<b>Metals</b>				
Steel	Commercially available, alterable, and moveable	Prone to rust and corrosion	\$0.50–2.00/gallon	8 lbs/gallon
Welded steel	Commercially available, alterable, and moveable	Possibly prone to rust and corrosion; must be lined for potable use	\$0.80–4.00/gallon	8 lbs/gallon
<b>Concrete and Masonry</b>				
Ferrocement	Durable and immovable	Potential to crack and fail	\$0.50–2.00/gallon	8 lbs/gallon
Stone, concrete block	Durable and immovable	Difficult to maintain	\$0.50–2.00/gallon	8 lbs/gallon
Monolithic/poured in place	Durable and immovable	Potential to crack and fail	\$0.30–1.25/gallon	8 lbs/gallon
<b>Wood</b>				
Redwood, fir, cypress	Attractive, durable, can be disassembled and moved	Expensive	\$2.00/gallon	8 lbs/gallon

A compostable material is one that undergoes physical, chemical, thermal, and/or biological degradation in a mixed municipal solid waste (MSW) composting facility such that it is physically indistinguishable from the finished compost. The final product ultimately mineralizes (biodegrades to carbon dioxide, water, and biomass as new microorganisms) at a rate like that of known compostable materials in solid waste such as paper and yard waste. A compost-compatible material is one that disintegrates and becomes indistinguishable from the final compost and is either biodegradable or inert in the environment. A removable material is one that can be removed (not to be composted) by existing technologies in MSW composting (such as plastics, stones, or glass).

To ensure that biosolids applied to the land do not threaten public health, the EPA created 40 CFR Part 503. This rule categorizes biosolids as Class A or B depending on the level of pathogenic organisms in the material and describes specific processes to reduce pathogens to these levels. The rule also requires vector attraction reduction (VAR)—reducing the potential of the spreading of infectious disease agents by vectors (i.e., flies, rodents, and birds)—and spells out specific management practices, monitoring frequencies, record keeping, and reporting requirements. Incineration of biosolids also is covered in the regulation.

Class A biosolids contain minute levels of pathogens. To achieve Class A certification, biosolids must undergo heating, composting, digestion, or increased pH to reduce pathogens to less than detectable levels. Some treatment processes change the composition of the biosolids to a pellet or granular substance, which can be used as a commercial fertilizer. Once these goals are achieved, Class A biosolids can be applied to land without any pathogen-related restrictions at the site. Class A biosolids can be bagged and marketed to the public for application on lawns and gardens.


Class B biosolids have less stringent standards for treat-

ment and contain small but compliant amounts of bacteria. Class B requirements ensure that pathogens in biosolids have been reduced to levels that protect public health and the environment and include certain restrictions for crop harvesting, grazing animals, and public contact for all forms of Class B biosolids. As is true of their Class A counterpart, Class B biosolids are treated in a wastewater treatment facility and undergo heating, composting, digestion, or increased pH processes before leaving the plant. This semi-solid material can receive further treatment when exposed to the natural environment as a fertilizer, where heat, wind, and soil microbes naturally stabilize the biosolids.

**Class A Technologies**

Technologies that can meet Class A standards include thermal treatment methods such as composting, heat drying, heat treatment, thermophilic (heat generating) aerobic digestion, and pasteurization. Class A

**Figure 14-2 Graywater vs. Black Water**



**Table 14-5 Comparison of Graywater and Black Water**

Parameter	Graywater	Black Water	Grey + Black
BOD <sub>5</sub> <sup>1</sup> (g/p/d <sup>2</sup> and mg/l)	25 and 150-300	20 and 2,000–3,000	71
BOD <sub>5</sub> (% of UOD <sup>3</sup> )	90	40	–
COD <sup>4</sup> (g/p/d and mg/l)	48 and 300	72 and 2,000–6,000	–
Total P (g/p/d and mg/l)	2 and 4–35	1.6	4.6
Total N (g/p/d)	1 (0.6–5 mg/l)	11 (main source urine)	13.2
TSS (g/p/d)	18	> 50	70
Pathogens	Low	Very high	Very high
Main Characteristic	Inorganic chemicals	Organics, pathogens	Inorganics, organics, and pathogens

<sup>1</sup> BOD<sub>5</sub> = Oxygen required for the decomposition of the organic content in graywater during the first five days, determined as BOD after a five-day period of incubation under standard conditions

<sup>2</sup> g/p/d = grams/person/day

<sup>3</sup> UOD = Ultimate (total) oxygen demand in a sample taken

<sup>4</sup> COD = Oxygen demand for all chemical (organic and inorganic) activities; a measure of organics

Sources: Haug 1993; Droste 1997; Dixon et al. 1999b; Hammes et al. 2000; Lindstrom 2000a, 2000b

technologies are known as PFRP, or processes that can further reduce pathogens. The technologies must process the biosolids for a specific length of time at a specific temperature.

- **Composting:** This is an environmentally friendly way to recycle the nutrients and organic matter found in wastewater solids. Composting systems turn wastewater biosolids, sawdust, yard waste, and wood chips into high-quality compost. As the material decomposes, oxygen filters through the compost site, releasing water, heat, and carbon dioxide. This process helps dry the organic material, while the generated heat increases the rate of decomposition and kills pathogens.
- **Heat drying:** This process applies direct or indirect heat to reduce the moisture in biosolids. It eliminates pathogens, reduces volume, and results in a product that can be used as a fertilizer or soil amendment. Because dryers produce a 90 percent dry material, additional VAR is not required.
- **Digestion:** In autothermal thermophilic aerobic digestion (ATAD) systems, biosolids are heated from 131°F to 140°F (55°C to 60°C) and aerated for about 10 days. This autothermal process generates its own heat and reduces volume. The result is a high-quality Class A product acceptable for reuse as a liquid fertilizer.
- **Pasteurization:** Pasteurization produces a Class A material when the biosolids are heated to at least 158°F (70°C) for 30 minutes. This extreme heat kills pathogens in the organic matter. When followed by anaerobic digestion, the VAR is attained, and the biosolids can be applied to land with minimal restrictions. The majority of the energy used in the pasteurization process is recovered with an innovative heat exchanger system and used to maintain the proper temperature in downstream anaerobic digesters.


### Class B Technologies

EPA regulations list technologies, which, under certain operating conditions, can treat and reduce pathogens so the material qualifies as a Class B biosolid. These processes are known as processes that can significantly reduce pathogens, or PSRP. Class B technologies include anaerobic digestion, aerobic digestion, composting, air-drying, and lime stabilization.

Several EPA-approved stabilization technologies are available for anaerobic and aerobic digestion, including:

- Heaters, heat exchangers, digester covers, gas, and hydraulic mixing systems, all important components in conventional anaerobic digestion systems
- Temperature-phased anaerobic digestion (TPAD) systems, which optimize anaerobic digestion through a heat-recovery system that pre-heats raw material and simultaneously cools the digested biosolids
- Membrane gas storage systems, which include an expandable membrane cover that provides variable digester gas storage, optimizes digester gas utilization for heating and electrical generation, and increases storage capacity
- Hydraulic mixers, which use a multi-port discharge valve to greatly improve biosolids mixing in the digestion process
- Air diffusers and aerators, which can be incorporated in any aerobic digester configuration

Adding lime can stabilize biosolids by raising the pH and temperature. While adding sufficient amounts of lime to wastewater solids produces Class B biosolids, adding higher amounts yields Class A biosolids. Combining low amounts of lime with anoxic storage also can yield Class A biosolids.



#### LEGEND

- |    |                                   |    |                       |
|----|-----------------------------------|----|-----------------------|
| 1. | SOLAR COLLECTORS                  | 5. | WATER SUPPLY          |
| 2. | TEMPERATURE/PRESSURE RELIEF VALVE | 6. | AUXILLARY HEAT SOURCE |
| 3. | STORAGE TANK                      | 7. | TO BUILDING           |
| 4. | HEAT EXCHANGER                    |    |                       |

Figure 14-3 Simple Solar Domestic Water Heater Diagram



## Energy Requirements

Rainwater and condensate collection systems use minimal electrical power. Graywater systems for a large project may require up to 10,000 kilowatt-hours per year. Black water systems for the same project may be estimated to require as much as 20,000 kilowatt-hours per year. These numbers are subject to the building systems for the particular project and vary greatly from project to project.

As an example, the power consumption ratios of a typical bioremediation system may consist of 38 percent for membrane aeration blowers, 35 percent for other blowers, 16 percent for recirculation pumps, 5 percent for process pumps, 4 percent for mixers, and 2 percent for controls, monitors, and other equipment. This does not include pumping the water throughout the building, which may require additional power.

## ENERGY EFFICIENCY AND ENERGY-SAVING STRATEGIES

Energy consumption within plumbing systems can be reduced using several methods, such as variable-frequency drive domestic booster pump systems. However, energy savings are difficult to define precisely and vary for every project.

Water heaters offer a potential area for energy savings, as plumbing engineers are specifying more high-efficiency equipment these days. If required to specify a minimum efficiency of 84 percent for gas-fired boilers, specifying 98 percent efficient units can save 14 percent of energy costs, theoretically. One problem in quantifying these savings lies in the fact that efficiencies vary with several factors, including incoming water temperature and return temperature. These factors apply to all types of heaters, but the numbers typically are jaded. Thus, it might be reasonable to assume that the system is still 14 percent more efficient. Using low-flow fixtures, with their related reduced hot water consumption, saves as much as 40 percent of the energy required to heat the domestic hot water.

The expected energy savings can be calculated using gallon-per-day (gpd) figures and extrapolating an

estimated savings. These numbers, combined with energy consumption and reduction figures for other aspects of the building, can indicate the percentage of total energy saved. These savings may be applied to LEED energy credits.

High efficiency does not always come from high-efficiency equipment alone. The efficacy must be considered relative to the application. 98 percent efficient water heaters do not necessarily save energy on every system. All designs require an integrated approach and a balance of the correct elements relative to the needs of the project and the goals of the client.

## Solar Water Heating

Solar water heating is an excellent way to reduce energy consumption. The average solar system for a typical home (see Figure 14-3) can save about two-thirds of the home's yearly cost for providing domestic hot water. The energy savings for a commercial application are more difficult to precisely quantify, but they may be in the same range, depending on a variety of factors.

One important factor in any system involving heat transfer is the loading of the system. Other than when they are shut down and using no energy, heat exchangers, like pumps, are most efficient when they are running at 100 percent capacity. Oversizing equipment leads to reduced efficiencies and maybe even premature failure of the equipment.

Refer to other *Plumbing Engineering Design Handbook* chapters for additional information, including Volume 3, Chapter 10: "Solar Energy" and Volume 2, Chapter 6: "Domestic Water Heating Systems," as well as the resources listed at the end of this chapter.

## Geothermal Systems

Geothermal energy can be used for homes, as well as industrial and commercial buildings. They even are used by some utility companies to generate steam to spin turbines, creating electrical power for municipalities. They can be used for radiant heat, as well as radiant cooling. Refer to other *Plumbing Engineering Design Handbook* chapters for additional information, including Volume 4, Chapter 10.



# Index

$\mu$  (micro) prefix, 2009 V1: 34  
S (ohms), 2009 V1: 34  
S cm (ohm-centimeter units), 2011 V3: 47, 2012 V4: 175  
S m (ohm-meters), 2009 V1: 34  
1-compartment sinks, 2012 V4: 11  
1-occupant toilet rooms, 2012 V4: 21  
1-piece water closets, 2012 V4: 3  
1-stage distillation, 2010 V2: 200  
1-time costs, defined, 2009 V1: 217  
1-wall tanks, 2011 V3: 139  
2-bed deionizing units, 2011 V3: 48  
2-compartment sinks, 2012 V4: 11  
2-pipe venturi suction pumps, 2010 V2: 157  
2-point vapor recovery, 2011 V3: 145  
2-step deionization (dual-bed), 2010 V2: 206, 207  
2-valve parallel pressure-regulated valves, 2010 V2: 69–70  
2-way braces, 2012 V4: 136  
2-word expressions of functions, 2009 V1: 218, 225  
3-bolt pipe clamps, 2012 V4: 135  
3-compartment sinks, 2012 V4: 11  
3E Plus, 2009 V1: 118  
4-way braces, 2012 V4: 130  
10-year storms, 2010 V2: 42  
18-8 SS, 2009 V1: 132  
18-8-3 SS, 2009 V1: 132  
28 CFR Part 36, 2009 V1: 98  
70:30 Cu Ni, 2009 V1: 132  
80/20 rule, 2009 V1: 218, 249  
90:10 Cu Ni, 2009 V1: 132  
100% area (full port), 2012 V4: 89  
100-year storms, 2010 V2: 42  
1964 Alaska Earthquake, 2009 V1: 152  
1971 San Francisco Earthquake, 2009 V1: 152  
3408 HDPE. *See* HDPE (high density polyethylene)  
6061 aluminum alloy, 2011 V3: 277

## A

A, X#, X#A (compressed air). *See* compressed air  
A/m (amperes per meter), 2009 V1: 33  
A (amperes). *See* amperes  
A (area). *See* area (A)  
a (atto) prefix, 2009 V1: 34  
AAMI (Association for the Advancement of Medical Instrumentation), 2010 V2: 187, 219, 220  
AAV (automatic air vents), 2009 V1: 10

abandoned fuel tanks, 2011 V3: 154  
abandoned septic tanks, 2010 V2: 148  
abandoned wells, 2010 V2: 159  
abbreviations  
    existing building survey reports, 2009 V1: 269–270  
    International System of Units, 2009 V1: 33  
    plumbing and piping symbols, 2009 V1: 7–15  
    text, drawings, and computer programs, 2009 V1: 14–15  
The ABC's of Lawn Sprinkler Systems, 2011 V3: 96  
above-finished floor (AFF), 2009 V1: 14  
above-slab grease interceptors, 2012 V4: 154  
aboveground piping  
    inspection checklist, 2009 V1: 95  
    materials for, 2010 V2: 12–13  
    thermal expansion and contraction, 2012 V4: 207–208  
aboveground sanitary piping codes, 2009 V1: 42  
aboveground tank systems  
    abandonment and removal, 2011 V3: 154  
    codes and standards, 2011 V3: 137  
    connections and access, 2011 V3: 148  
    construction, 2011 V3: 147–148  
    corrosion protection, 2011 V3: 148  
    electronic tank gauging, 2011 V3: 142  
    filling and spills, 2011 V3: 148  
    industrial wastes, 2011 V3: 84  
    installation, 2011 V3: 152  
    leak prevention and monitoring, 2011 V3: 148–149  
    leakage detection, 2011 V3: 141–145  
    liquid fuel systems, 2011 V3: 147–149  
    materials for, 2011 V3: 147–148  
    overfill prevention, 2011 V3: 148  
    product-dispensing systems, 2011 V3: 149  
    tank protection, 2011 V3: 149  
    testing, 2011 V3: 152–154  
    vapor recovery, 2011 V3: 149  
    venting, 2011 V3: 148  
abrasion, 2010 V2: 16, 186  
    corrosion and, 2009 V1: 136  
    defined, 2009 V1: 16  
    insulation and, 2012 V4: 103  
    specifications to prevent, 2009 V1: 256–258  
ABS. *See* acrylonitrile-butadiene-styrene (ABS)  
abs, ABS (absolute), 2009 V1: 14  
absolute (abs, ABS), 2009 V1: 14  
absolute pressure

- Boyle's law, 2012 V4: 211–213  
 defined, 2009 V1: 16, 2011 V3: 183, 186, 2012 V4: 169  
 formulas, 2012 V4: 159  
 in vacuums, 2010 V2: 166
- absolute temperature, 2009 V1: 16, 2011 V3: 183
- absolute zero, 2009 V1: 16
- absorber (plate), defined, 2011 V3: 190
- absorber area, defined, 2011 V3: 190
- absorphan (carbon filtration). *See* activated carbon filtration (absorphan)
- absorptance, defined, 2011 V3: 190
- absorption  
 air drying, 2011 V3: 178–179  
 defined, 2009 V1: 16, 2012 V4: 199  
 rates for soils, 2011 V3: 91  
 trenches. *See* soil-absorption sewage systems
- AC (air chambers). *See* air chambers (AC)
- ac, AC (alternating current), 2009 V1: 14
- AC-DC rectifiers, 2009 V1: 139, 140
- acc (accumulate or accumulators), 2009 V1: 16
- acceleration  
 earthquakes, 2009 V1: 149, 150  
 linear, 2009 V1: 34, 35  
 measurements, 2009 V1: 34
- acceleration limiters, 2012 V4: 125
- accelerators (dry-pipe systems), 2011 V3: 8–9
- accelerograms, 2009 V1: 150
- access. *See also* people with disabilities  
 aboveground tank systems, 2011 V3: 148  
 bioremediation pretreatment systems, 2012 V4: 230  
 clean agent gas fire containers, 2011 V3: 27  
 to equipment, piping and, 2012 V4: 25  
 underground liquid fuel tanks, 2011 V3: 139–140
- access channels for pipes, 2012 V4: 125
- access doors, 2009 V1: 16
- access openings for pipes, 2012 V4: 125
- access to (defined), 2009 V1: 16
- accessibility, 2009 V1: 16. *See also* people with disabilities  
 storm drainage, 2010 V2: 48–49
- Accessibility Guidelines for Buildings and Facilities*, 2009 V1: 97
- Accessible and Usable Buildings and Facilities*, 2009 V1: 97, 115, 2012 V4: 2
- accessories  
 as source of plumbing noise, 2009 V1: 189  
 in plumbing cost estimation, 2009 V1: 85, 88  
 section in specifications, 2009 V1: 71
- accreditation of health care facilities, 2011 V3: 51
- accumulation, defined, 2009 V1: 16
- accumulators (acc, ACCUM), 2009 V1: 16, 2012 V4: 125
- accuracy  
 defined, 2009 V1: 16  
 in measurements, 2009 V1: 33  
 of pressure-regulating valves, 2010 V2: 94
- ACEC (American Consulting Engineers Council), 2009 V1: 56
- acetone, 2009 V1: 141
- acetylene, 2010 V2: 114
- ACF (altitude correction factor), 121, 2010 V2: 117
- acfh (actual cfh), 2010 V2: 126
- acfm (actual cubic feet per minute)  
 defined, 2011 V3: 76, 187  
 gas systems, 2011 V3: 269  
 medical air compressors, 2011 V3: 62  
 medical vacuum systems, 2011 V3: 64  
 vacuum systems, 2010 V2: 166
- acid absorbers in ion exchange, 2012 V4: 183
- acid-containing inhibitors, 2010 V2: 207
- acid dilution tanks, 2012 V4: 183
- acid feed pumps, 2011 V3: 129–130
- acid fumes, 2011 V3: 46
- acid manholes, 2011 V3: 231
- acid neutralization, 2011 V3: 43–44, 85
- acid-neutralization tanks, 2011 V3: 43–44
- acid pickling, 2012 V4: 56
- acid radicals, 2010 V2: 189
- acid regenerants, 2010 V2: 199, 206, 207
- acid resins, 2010 V2: 199
- acid-resistant floor drains, 2010 V2: 15
- acid-resistant glass foam insulation, 2012 V4: 106
- acid-resistant piping, 2010 V2: 13, 239
- acid-resistant sinks, 2011 V3: 41
- acid vents (AV), 2009 V1: 8, 16
- acid-waste systems  
 acid-waste treatment, 2010 V2: 235  
 continuous systems, 2010 V2: 236  
 health and safety concerns, 2010 V2: 229–230  
 health care facilities, 2011 V3: 42–46  
 introduction, 2010 V2: 229  
 large facilities, 2010 V2: 235  
 metering, 2011 V3: 45  
 piping and joint material, 2010 V2: 232–234, 2012 V4: 51  
 solids interceptors, 2011 V3: 45  
 system design considerations, 2010 V2: 234–235  
 types of acid, 2010 V2: 230–232
- acid wastes (AW), 2009 V1: 8, 16, 2011 V3: 42–46
- acidity  
 in corrosion rates, 2009 V1: 134  
 pH control, 2011 V3: 85–87  
 in water, 2010 V2: 160, 189, 192
- acids  
 defined, 2009 V1: 16, 2010 V2: 188  
 feed water treatment, 2010 V2: 220
- acoustics in plumbing systems  
 cork insulation, 2012 V4: 139  
 costs of mitigation, 2009 V1: 188  
 critical problems with noise, 2012 V4: 137  
 design and construction issues, 2009 V1: 201–202  
 drainage system mitigation, 2009 V1: 189–190  
 hangers and supports, 2012 V4: 118  
 insulation and, 2012 V4: 103, 113  
 introduction, 2009 V1: 187–188  
 mitigating fixture noise, 2009 V1: 193–194  
 neoprene vibration control, 2012 V4: 139  
 noise-related lawsuits, 2009 V1: 263  
 pumps, 2009 V1: 194–201  
 silencers on vacuum systems, 2010 V2: 179  
 sources of noise, 2009 V1: 188–189  
 STC (Sound Transmission Class), 2009 V1: 187  
 transmission in pipes, 2010 V2: 13–14  
 vacuum systems, 2010 V2: 174  
 valves, pumps and equipment, 2009 V1: 194–201  
 water distribution system noise mitigation, 2009 V1: 190–193

- water hammer, 2010 V2: 70–73
- acoustics in swimming pools, 2011 V3: 108
- acquisition costs
  - acquisition prices defined, 2009 V1: 210
  - base acquisition costs, 2009 V1: 217
- ACR/MED pipes, 2012 V4: 32
- ACR piping, 2012 V4: 32
- acres, converting to SI units, 2009 V1: 38
- acrylic fixtures, 2012 V4: 1
- acrylic insulation jackets, 2012 V4: 108
- acrylonitrile-butadiene rubber (ABR), 2011 V3: 150
- acrylonitrile-butadiene-styrene (ABS)
  - corrosion, 2009 V1: 141
  - defined, 2009 V1: 32
  - expansion and contraction, 2012 V4: 208
  - fixtures, 2012 V4: 1
  - insulation jackets, 2012 V4: 108
  - piping, 2010 V2: 13, 14, 2011 V3: 49, 2012 V4: 39, 51
  - standards, 2012 V4: 70
  - stress and strain figures, 2012 V4: 206
  - thermal expansion or contraction, 2012 V4: 207
- activated alumina air dryers, 2011 V3: 179
- activated alumina water treatment, 2010 V2: 218
- activated carbon filtration (absorphan)
  - in gray-water systems, 2010 V2: 25
  - illustrated, 2010 V2: 205
  - overview, 2010 V2: 201–204
  - pure-water systems, 2010 V2: 221
  - RO treatments, 2012 V4: 197, 199
  - small water systems, 2010 V2: 218
  - well water, 2010 V2: 160
- Activated Carbon Process for Treatment of Wastewater Containing Hexavalent Chromium (EPA 600/2-79-130)*, 2011 V3: 89
- activated sludge, 2009 V1: 16
- activated sludge systems, 2011 V3: 88
- active, defined, 2009 V1: 141
- active controls, cross-connections, 2012 V4: 164–166
- active potential, defined, 2009 V1: 141
- Active Solar Energy System Design Practice Manual*, 2011 V3: 204
- active solar systems, 2011 V3: 192
- active solar water heaters, 2009 V1: 122
- active verbs in function analysis, 2009 V1: 218
- activities in FAST approach, 2009 V1: 223
- actual capacity, 2009 V1: 16
- actual cfm (acfh), 2010 V2: 126
- actual cubic feet per minute. *See* acfm (actual cubic feet per minute)
- actual flow rates, 2011 V3: 4, 210
- actual liters per minute (aL/min), 2011 V3: 187
- actual pressure. *See* static pressure (SP)
- actuators, 2009 V1: 16
- ad (area drains), 2009 V1: 14
- ADA. *See* Americans with Disabilities Act
- ADAAG (Americans with Disabilities Act Accessibility Guidelines), 2009 V1: 97, 98
- ADAAG Review Federal Advisory Committee, 2009 V1: 115
- adapter fittings, 2009 V1: 16
- addenda in contract documents, 2009 V1: 56–57
- additions to buildings, 2009 V1: 265–266
- adhesives, 2009 V1: 16
- adiabatic compression, 2009 V1: 16
- adjustable, defined, 2012 V4: 127
- adjustable diverter plate, fountains, 2011 V3: 103
- adjustable high-pressure propane regulators, 2010 V2: 133
- adjustment devices, 2012 V4: 127
- adjustment section in specifications, 2009 V1: 64, 72
- administrative and operation costs in value engineering. *See* overhead
- administrative authorities, 2009 V1: 16
- admiralty brass, 2009 V1: 132
- adsorption, 2009 V1: 16, 2011 V3: 178–179, 2012 V4: 199
- adult-sized wheelchairs, dimensions, 2009 V1: 100. *See also* wheelchairs
- advanced oxidation water treatment, 2010 V2: 218
- Advanced Plumbing Technology*, 2010 V2: 46, 47, 55
- aerated lagoons, 2011 V3: 88
- aeration, 2009 V1: 16, 2012 V4: 176
- aeration cells, 2009 V1: 141
- aerators
  - aeration treatment, 2010 V2: 197–198, 218
  - lavatories and sinks, 2011 V3: 35
  - Provent aerators, 2010 V2: 17–18
  - Solvent aerators, 2010 V2: 17–18
- aerobic, defined, 2009 V1: 16
- aerobic bioremediation, 2012 V4: 227
- aerobic digestion, biosolids, 2012 V4: 239
- aerobic wastewater treatment plants, 2010 V2: 150
- aerosols, 2009 V1: 16
- AFF (above-finished floor), 2009 V1: 14
- AFFF foam concentrates, 2011 V3: 25
- affinity laws (pumps), 2012 V4: 94, 95
- after cold pull elevation, 2012 V4: 127
- after-coolers, 2009 V1: 16
  - air compressors, 2011 V3: 174, 178
  - medical air compressors, 2011 V3: 62
- after-cooling, defined, 2011 V3: 183
- AGA (American Gas Association)
  - defined, 2009 V1: 32
  - relief valve standards, 2010 V2: 106
  - water heating standards, 2010 V2: 112
- age of water mains, 2011 V3: 6
- age-related disabilities, 2009 V1: 99
- agglomeration, 2012 V4: 149
- aggressiveness index, 2010 V2: 196
- aging, 2009 V1: 16
- aging disabilities, 2009 V1: 99
- aging water mains, 2011 V3: 6
- agitators in kill tanks, 2010 V2: 242
- agreement documents, 2009 V1: 56
- agreement states, 2010 V2: 238
- AHJ. *See* authorities having jurisdiction
- AHRI (Air Conditioning, Heating, and Refrigeration Institute), 2009 V1: 46
- AI (aggressiveness index), 2010 V2: 196
- AIA (American Institute of Architects). *See* American Institute of Architects
- air
  - compressed, 2009 V1: 16
  - depleted in air chambers, 2010 V2: 72
  - expansion and contraction, 2012 V4: 211–213
  - free, 2009 V1: 16, 2011 V3: 171–172, 186
  - oil-free, 2011 V3: 76

- in pipes, 2010 V2: 2
- pollutants, 2011 V3: 264–265
- properties, 2011 V3: 171–172, 263–266
- standard, 2009 V1: 16, 2011 V3: 187
- water vapor in, 2011 V3: 172–173
- air, compressed. *See* compressed air
- air, free, 2009 V1: 16, 2011 V3: 171–172, 186
- air, oil-free, 2011 V3: 76
- air, standard, 2009 V1: 16, 2011 V3: 187
- air-admittance valves, 2009 V1: 16, 43, 2010 V2: 39
- air-bleed vacuum controls, 2010 V2: 179
- air-bleed valves, 2010 V2: 171
- air breaks. *See* air gaps
- air chambers (AC)
  - defined, 2009 V1: 16
  - symbols for, 2009 V1: 11
  - water hammer arresters, 2010 V2: 72
- air circuits in instrumentation, 2011 V3: 171
- air compressors
  - accessories, 2011 V3: 177–182
  - compressed air systems, 2011 V3: 174–176
  - dry-pipe systems, 2011 V3: 8
  - laboratory inlet piping, 2011 V3: 280
  - medical systems, 2011 V3: 61–62
  - pulsation, 2011 V3: 177
  - sizing, 2011 V3: 183
  - types of, 2011 V3: 174–176
  - vacuum pumps, 2010 V2: 169–170
- AIR COND (air conditioning). *See* air-conditioning systems
- Air-Conditioning and Refrigeration Institute (ARI), 2012 V4: 215–216
- air-conditioning cooling towers. *See* cooling-tower water air-conditioning engineers, 2011 V3: 29
- Air-Conditioning, Heating, and Refrigeration Institute (AHRI), 2009 V1: 46
- air-conditioning systems (AIR COND)
  - direct water connections, 2012 V4: 161
  - fixture-unit values, 2010 V2: 8
  - pipes, 2012 V4: 32
  - waste heat usage, 2009 V1: 123
  - water chillers, 2012 V4: 215
- air-consuming devices, 2011 V3: 180
- air-cooled after-coolers, 2011 V3: 178
- air densities, calculating, 2009 V1: 5
- air dryers
  - compressed air systems, 2011 V3: 178–179
  - deliquescent dryers, 2011 V3: 178
  - desiccant dryers, 2011 V3: 179
  - medical air compressors, 2011 V3: 63
  - refrigerated air dryers, 2011 V3: 178
  - selection, 2011 V3: 179
- air filters
  - hydrophilic and hydrophobic, 2012 V4: 193
  - still, 2012 V4: 193
- air gaps. *See also* effective openings
  - booster pumps and, 2010 V2: 64
  - defined, 2009 V1: 16, 2012 V4: 169
  - shortfalls, 2012 V4: 167
  - standards, 2012 V4: 162–164
- air-gate valves, 2010 V2: 179
- air-handling units, condensate traps, 2011 V3: 167
- air intakes, 2011 V3: 182, 2012 V4: 155
- air lines
  - ABS pipe, 2012 V4: 51
  - direct connection hazards, 2012 V4: 161
- air locks, 2009 V1: 16
- air pressure, 2010 V2: 166, 2011 V3: 8
- air purges in vacuum pumps, 2010 V2: 171
- air receivers, 2011 V3: 177–178
- air solar systems, 2011 V3: 192
- air springs in noise mitigation, 2009 V1: 197
- air temperature
  - condensate estimates, 2011 V3: 167
  - swimming pools and, 2011 V3: 108
- air tests
  - in cold-water systems, 2010 V2: 90
  - defined, 2009 V1: 16
- air velocity in vacuum cleaning systems, 183, 2010 V2: 181
- air vents in centralized drinking-water systems, 2012 V4: 223
- airborne contamination, 2012 V4: 193
- airborne noise, 2009 V1: 187, 190
- aircraft cable bracing method, 2009 V1: 160
- aircraft fuel, 2010 V2: 12
- airgaps. *See* air gaps
- airport runways, piping underneath, 2012 V4: 118
- airport security checkpoints, numbers of fixtures before, 2012 V4: 19
- AISC. *See* American Institute of Steel Construction (AISC)
- aL/min (actual liters per minute), 2011 V3: 187
- ALARA (as low as reasonably achievable), 2010 V2: 238
- alarm check valves, 2009 V1: 13, 16, 2011 V3: 6
- alarm lines on sprinklers, 2011 V3: 6
- alarm relays, 2011 V3: 28
- alarms
  - defined, 2009 V1: 16, 2011 V3: 76
  - on aboveground tanks, 2011 V3: 149
  - on bulk oxygen supply, 2011 V3: 59
  - on compressed air systems, 2011 V3: 182
  - on corrosive-waste systems, 2011 V3: 43
  - on hazardous waste systems, 2011 V3: 84
  - on kill tanks, 2010 V2: 242
  - on laboratory gas systems, 2011 V3: 275
  - on medical gas systems
    - area alarms, 2011 V3: 67
    - master alarms, 2011 V3: 67
    - testing, 2011 V3: 74–75
  - on pressurized fuel delivery systems, 2011 V3: 145
  - on vacuum systems, 2010 V2: 169, 173
  - overflow prevention, 2011 V3: 141, 148
- Alaska Earthquake, 2009 V1: 152
- Albern, W.F., 2010 V2: 186
- alcohol-resistant AFFF foam concentrates, 2011 V3: 25
- algae, 2010 V2: 188, 195, 2012 V4: 177, 199
- alignment, storm drainage piping, 2010 V2: 47
- alkali, 2009 V1: 16
- alkali neutralization, 2012 V4: 176
- alkalinity
  - after ion exchange, 2012 V4: 184
  - alkaline solutions in corrosion rates, 2009 V1: 134
  - boiler feed water, 2010 V2: 216
  - cork and, 2012 V4: 139
  - dealkalizing treatment, 2010 V2: 199
  - defined, 2012 V4: 200

- distillation feed water, 2012 V4: 192
- low-alkalinity water, 2012 V4: 184
- measuring, 2010 V2: 189
- neutralization of water, 2012 V4: 176
- pH and, 2010 V2: 192, 228–229, 2011 V3: 85
- predicting scale and corrosion, 2010 V2: 196
- swimming pools, 2011 V3: 127–131
- water saturation, 2010 V2: 196
- all-service jackets (ASJ), 2012 V4: 106, 108
- allowable gas pressure, 2010 V2: 119–121
- allowable leakage in compressed air systems, 2011 V3: 183
- allowable radiation levels, 2010 V2: 237
- allowable vacuum system pressure loss, 2010 V2: 174
- alloy pipes, 2009 V1: 17
- alloys, 2009 V1: 16, 2012 V4: 127
- alpha ray radiation, 2010 V2: 236–237
- alterations (altrn, ALTRN), 2009 V1: 265–266
- alternate bracing attachments for pipes, 2009 V1: 167
- alternating current (ac, AC), 2009 V1: 14
- alternative collection and treatment of waste water, 2010 V2: 144–145, 149
- alternative energy sources, 2009 V1: 121–126
- alternative sanitary drainage systems, 2010 V2: 16–19
- Alternatives for Small Wastewater Treatment Systems: Cost-Effectiveness Analysis*, 2010 V2: 154
- Alternatives for Small Wastewater Treatment Systems: On-site Disposal/Seepage Treatment and Disposal*, 2010 V2: 154
- Alternatives for Small Wastewater Treatment Systems: Pressure Sewers/Vacuum Sewers*, 2010 V2: 154
- alternators
  - medical air compressors, 2011 V3: 62
  - vacuum systems, 2011 V3: 65
- altitude (alt, ALT), 2011 V3: 183. *See also* elevation
  - air pressure corrections, 2011 V3: 264
  - natural gas and, 2010 V2: 121
- altitude correction factor (ACF), 121, 2010 V2: 117
- altitude valves, 2010 V2: 163–164
- alum, 2010 V2: 199, 2012 V4: 178
- aluminosilicates, 2011 V3: 179
- aluminum, 2009 V1: 129, 132, 2010 V2: 189
- aluminum 1100, 2009 V1: 132
- aluminum 2017 and 2024, 2009 V1: 132
- aluminum gas cylinders, 2011 V3: 268
- aluminum hydroxide, 2010 V2: 189
- aluminum jackets, 2012 V4: 108
- aluminum mills, 2011 V3: 26
- aluminum piping, 2010 V2: 122, 2011 V3: 49, 277, 2012 V4: 54
- aluminum silicates, 2010 V2: 205
- aluminum sulfate, 2010 V2: 199, 2012 V4: 178
- aluminum tubing, 2010 V2: 122
- ambient temperature
  - defined, 2009 V1: 17
  - drinking-water coolers and, 2012 V4: 216
  - hangers and supports for systems, 2012 V4: 119
  - piping for ambient temperatures, 2012 V4: 118
- ambulatory accessible stalls, 2009 V1: 106
- American Chemical Society, 2009 V1: 142
- American Concrete Institute (ACI), 2010 V2: 54
- American Consulting Engineers Council (ACEC), 2009 V1: 56
- American Gas Association (AGA), 2010 V2: 117
  - abbreviation for, 2009 V1: 14, 32
  - codes and standards, 115, 2010 V2: 114, 115
  - relief valve standards, 2010 V2: 106
  - water heating standards, 2010 V2: 112
- American Institute of Architects (AIA)
  - General Conditions of the Contract for Construction*, 2009 V1: 56
  - Masterspec, 2009 V1: 65
  - medical gas guidelines, 2011 V3: 51
  - specifications format, 2009 V1: 57
- American Institute of Steel Construction (AISC), 2009 V1: 14
- American National Standards Institute (ANSI)
  - abbreviation for, 2009 V1: 14, 32
  - consensus process, 2009 V1: 41
  - gas approvals, 2010 V2: 114
  - list of standards, 2009 V1: 45–46
  - publications (discussed)
    - accessibility standards, 2012 V4: 2, 13
    - air gap standards, 2012 V4: 162
    - backflow prevention standards, 2012 V4: 162
    - backflow protection standards, 2012 V4: 13
    - copper drainage fittings standards, 2012 V4: 33
    - drinking water system standards, 2012 V4: 220
    - emergency eyewash and showers, 2012 V4: 18
    - gasket standards, 2012 V4: 63
    - medical gas tube standards, 2012 V4: 34
    - pipe and fittings standards, 2012 V4: 68–71
    - plug valve standards, 2012 V4: 87
    - plumbing fixture standards, 2012 V4: 2
    - plumbing fixture support standards, 2012 V4: 5
    - prefabricated grease interceptors standards, 2012 V4: 145
    - tee fittings standards, 2012 V4: 58
    - water closet standards, 2012 V4: 4, 8
    - water quality standards, 2010 V2: 220
  - publications (listed), 2009 V1: 41
    - ANSI A117.1-1980*, 2009 V1: 97
    - ANSI A117.1-1986*, 2009 V1: 97
    - ANSI A117.1-1998*, 2009 V1: 97, 98, 99–115
    - ANSI/ASME B36.10: Welded and Seamless Wrought-Steel Pipe*, 2010 V2: 122
    - ANSI LC/CSA 6.26: Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing*, 2010 V2: 122
    - ANSI/NFPA 30: Flammable and Combustible Liquids Code*, 2010 V2: 115
    - ANSI/NFPA 54: National Fuel Gas Code*, 2011 V3: 251, 256
    - ANSI/UL 144: Pressure Regulating Values for Liquefied Petroleum Gas*, 2010 V2: 115
    - ANSI Z21.75/CSA 6.27: Connectors for Outdoor Gas Appliances and Manufactured Homes*, 2010 V2: 124
    - ANSI Z83.3: Gas Utilization Equipment for Large Boilers*, 2010 V2: 115
    - ANSI ZE 86.1: Commodity Specification for Air*, 2011 V3: 61, 76
    - ASA A117.1-1961*, 2009 V1: 97
    - Connectors for Gas Appliances*, 2010 V2: 124
    - Connectors for Movable Gas Appliances*, 2010 V2: 124

- NSF/ANSI 50: Equipment for Swimming Pools, Spas, Hot Tubs, and Other Recreational Water Facilities*, 2011 V3: 111, 122
- web site, 2011 V3: 89
- American Petroleum Institute (API)
- API abbreviation, 2009 V1: 14
- publications (discussed)
- emergency vent standards, 2011 V3: 148
  - fiberglass pipe standards, 2012 V4: 53
  - removal of globules standards, 2010 V2: 245
  - separators, 2011 V3: 88
  - valve standards, 2012 V4: 73
- publications (listed)
- AOIRP 1004: Bottom Loading and Vapor Recovery for MC-306 Tank Motor Vehicles*, 2011 V3: 156
  - API Bulletin no. 1611: Service Station Tankage Guide*, 2011 V3: 156
  - API Bulletin no. 1615: Installation of Underground Gasoline Tanks and Piping at Service Stations*, 2011 V3: 156
  - API Specification 12D: Field Welded Tanks for Storage of Production Liquids*, 2011 V3: 88
  - API Specification 12F: Shot Welded Tanks for Storage of Production Liquids*, 2011 V3: 88
  - API Standard 650: Welded Tanks for Oil Storage*, 2011 V3: 88
- web site, 2011 V3: 89, 156
- American Public Health Service, 2010 V2: 193
- American Society for Healthcare Engineering (ASHE), 2010 V2: 108–109
- American Society for Testing and Materials (ASTM)
- abbreviation for, 2009 V1: 14, 32
- ASTM A53 piping, 2011 V3: 257
- ASTM A106 piping, 2011 V3: 257
- ASTM B819 tubing, 2011 V3: 69
- consensus process, 2009 V1: 41
- list of standards, 2009 V1: 41, 49–51
- publications (discussed)
- aluminum insulation jacket standards, 2012 V4: 108
  - bronze valve standards, 2012 V4: 83
  - calcium silicate insulation standards, 2012 V4: 106
  - cast iron valve standards, 2012 V4: 83
  - cellular glass insulation standards, 2012 V4: 106
  - concrete aggregate standards, 2012 V4: 230
  - copper drainage tube standards, 2012 V4: 33
  - copper water tube standards, 2012 V4: 29
  - elastomeric insulation standards, 2012 V4: 105
  - electric-resistance-welded steel pipe standard, 2012 V4: 37
  - electrofusion joining standards, 2012 V4: 61
  - electronics-grade water standards, 2010 V2: 219
  - fiberglass insulation standards, 2012 V4: 105
  - flame testing standards, 2012 V4: 105
  - flux standards, 2012 V4: 30, 59
  - foamed plastic insulation standards, 2012 V4: 106
  - gray iron standards, 2012 V4: 77
  - high-purity water standards, 2010 V2: 218–219
  - hub and spigot cast iron soil pipe, 2012 V4: 25
  - hubless coupling standards, 2012 V4: 57
  - low-zinc alloy valve stems, 2012 V4: 83
  - membrane filters, 2010 V2: 194
  - pipe and fittings standards, 2012 V4: 68–71
  - plastic pipe and tubing standards, 2010 V2: 123–124
  - polyurethane insulation standards, 2012 V4: 106
  - Portland cement standards, 2012 V4: 230
  - ready-mix concrete standards, 2012 V4: 230
  - reagent-grade water standards, 2010 V2: 187, 218–219, 2012 V4: 197
  - silicon bronze valve stems, 2012 V4: 83
  - soldering standards, 2012 V4: 30, 59
  - stainless steel insulation jacket standards, 2012 V4: 108
  - steel gas pipe specifications, 2010 V2: 122
  - steel pipe standards, 2012 V4: 36
  - surface burning pipe characteristics, 2010 V2: 224
  - tee fittings standards, 2012 V4: 58
  - thermal expansion and contraction standards, 2012 V4: 205
- publications (listed)
- A-270: Standard Specification for Seamless and Welded Austenitic Stainless Steel Sanitary Tubing*, 2011 V3: 276
  - B-75: Standard Specification for Seamless Copper Tube*, 2011 V3: 276
  - B-88: Standard Specification for Seamless Copper Water Tube*, 2011 V3: 276
  - B-210: Standard Specification for Aluminum and Aluminum-Alloy Drawn Seamless Tubes*, 2011 V3: 277
  - B-280: Standard Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service*, 2011 V3: 276
  - B-819: Standard Specification for Seamless Copper Tube for Medical Gas Systems*, 2011 V3: 276
  - D-2863: Method for Measuring the Minimum Oxygen Concentration to Support Candle-like Combustion of Plastics*, 2011 V3: 77
- American Society of Civil Engineers (ASCE)
- contract publications, 2009 V1: 56
- Minimum Design Loads for Buildings and Other Structures*, 2009 V1: 147, 174, 185
- sewer publications, 2010 V2: 55
- American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE)
- abbreviation for, 2009 V1: 14, 32
- list of standards, 2009 V1: 46
- publications (discussed)
- cold water systems, 2010 V2: 96
  - drinking water cooler standards, 2012 V4: 225
  - drinking water coolers standards, 2012 V4: 216
  - Legionella standards, 2010 V2: 108–109
  - refrigeration system standards, 2012 V4: 225
  - water heating codes and standards, 2010 V2: 112
- publications (listed)
- Equipment Handbook*, 2011 V3: 204
  - Handbook of Fundamentals*, 2009 V1: 2, 5, 6, 39, 2010 V2: 136, 2011 V3: 169, 203
  - Systems and Applications Handbook*, 2011 V3: 204
- American Society of Mechanical Engineers (ASME)
- abbreviation for, 2009 V1: 14, 32
- list of standards, 2009 V1: 46–48
- publications (discussed)
- air gap standards, 2012 V4: 162



- air receivers, 2011 V3: 177
- backflow protection standards, 2012 V4: 13
- boiler and pressure vessel codes, 2010 V2: 112
- drinking water cooler standards, 2012 V4: 225
- grease interceptor standards, 2012 V4: 228
- hydraulic requirements for water closets and urinals, 2012 V4: 4
- medical gas tube standards, 2012 V4: 34
- pipe and fittings standards, 2012 V4: 68–71
- plumbing fixture standards, 2012 V4: 2
- plumbing fixture support standards, 2012 V4: 5
- propane tank specifications, 2010 V2: 132
- relief valve standards, 2010 V2: 106
- urinal standards, 2012 V4: 8
- publications (listed)
  - ASME A17.1: Safety Code for Elevators and Escalators*, 2011 V3: 29
  - ASME A112.18.8: Suction Fittings for Use in Swimming Pools, Wading Pools, and Hot Tubs*, 2011 V3: 101, 104, 112, 135
  - ASME B31.3: Process Piping Design*, 2011 V3: 176, 277
  - ASME International Boiler and Pressure Vessel Code*, 2011 V3: 88
  - Fuel-Gas Piping*, 2010 V2: 136
  - Welded and Seamless Wrought-Steel Pipe*, 2010 V2: 122
- web site, 2011 V3: 89
- American Society of Plumbing Engineers (ASPE)
  - abbreviation for, 2009 V1: 14, 32
  - list of standards, 2009 V1: 48
  - publications (discussed)
    - medical gas station guidelines, 2011 V3: 51, 52
  - publications (listed)
    - Domestic Water Heating Design Manual*, 2010 V2: 96, 2011 V3: 47
    - Plumbing Engineering and Design Handbook of Tables*, 2010 V2: 130
    - Siphonic Roof Drainage*, 2010 V2: 55
- American Society of Plumbing Engineers Research Foundation (ASPERF), 2009 V1: 32
- American Society of Sanitary Engineering (ASSE)
  - abbreviation for, 2009 V1: 14, 32
  - list of standards, 2009 V1: 48–49
  - publications
    - anti-siphon fill valve standards, 2012 V4: 162
    - backflow prevention standards, 2012 V4: 162
    - dishwasher standards, 2012 V4: 162–164
    - laundry equipment standards, 2012 V4: 164
    - siphon fill valves standard, 2012 V4: 6
    - water hammer arrester certification, 2010 V2: 72
- American standard pipe threads, 2009 V1: 17
- American Standard Specifications for Making Buildings and Facilities Usable by the Physically Handicapped*, 2009 V1: 97
- American Standards Association. *See* American National Standards Institute (ANSI)
- American Water Works Association (AWWA)
  - abbreviation for, 2009 V1: 14, 32
  - list of standards, 2009 V1: 51
  - publications (discussed)
    - cold water systems, 2010 V2: 94
    - gate valve standards, 2012 V4: 83, 88
    - pipe and fittings standards, 2012 V4: 68–71
    - valve epoxy coating standards, 2012 V4: 83, 88
- publications (listed)
  - AWWA Standard for Disinfecting Water Mains*, 2010 V2: 95
  - AWWA Standard for Disinfection of Water Storage Facilities*, 2010 V2: 95
  - AWWA Standard for Hypochlorites*, 2010 V2: 95
  - AWWA Standard for Liquid Chlorine*, 2010 V2: 95
  - Recommended Practice for Backflow Prevention and Cross-connection Control*, 2010 V2: 95
- American Welding Society (AWS), 2009 V1: 51, 159, 2012 V4: 58
- Americans with Disabilities Act (ADA)
  - ADAAG Review Federal Advisory Committee, 2009 V1: 115
  - faucet flow rates, 2009 V1: 128
  - fixture standards, 2012 V4: 2
  - history, 2009 V1: 98–99
  - overview, 2009 V1: 97, 98–99
  - swimming pool guidelines, 2011 V3: 135
- Americans with Disabilities Act Accessibility Guidelines (ADAAG)*, 2009 V1: 98–99
- Amin, P, 2010 V2: 224
- amines in boiler feed water, 2012 V4: 194
- ammonia (NH<sub>3</sub>), 2010 V2: 189, 199, 2012 V4: 191
- ammonium alum, 2012 V4: 178
- ammonium hydroxide (NH<sub>4</sub>OH), 2012 V4: 191
- amoebic dysentery, 2012 V4: 200
- amp, AMP, AMPS (ampere). *See* amperes
- ampacity, 2011 V3: 76
- amperes (A, amp, AMP, AMPS)
  - amperes per meter, 2009 V1: 33
  - corrosion, 2009 V1: 129
  - measurement conversions, 2009 V1: 33
  - symbols for, 2009 V1: 14
- amphoteric corrosion, defined, 2009 V1: 141
- amphoteric materials, 2009 V1: 134
- amplification factor in seismic protection, 2009 V1: 177
- amplifiers, 2009 V1: 17
- amplitude, 2009 V1: 17
- anaerobic, defined, 2009 V1: 17, 141
- anaerobic bacteria in septic tanks, 2010 V2: 145
- anaerobic bioremediation, 2012 V4: 227
- anaerobic digestion, biosolids, 2012 V4: 240
- anaerobic wastewater treatment, 2011 V3: 88
- analysis, 2009 V1: 17
- Analysis phase of value engineering, 2009 V1: 209, 218–223. *See also* Function Analysis phase in value engineering
- analytical grade water, 2010 V2: 219
- anchor bolts, 2012 V4: 128
- anchoring equipment
  - anchorage forces in earthquakes, 2009 V1: 180
  - anchors, defined, 2009 V1: 185
  - fire-protection equipment, 2011 V3: 28
  - seismic protection, 2009 V1: 153
- anchoring pipes, 2010 V2: 16, 54
- anchors, defined, 2012 V4: 127
- anchors for hangers and supports, 2012 V4: 123
- DWV stacks, 2012 V4: 208

- hangers and supports, 2012 V4: 123–125
- types of anchors, 2012 V4: 59–60, 62, 124
- water hammer and, 2012 V4: 117
- anchors, defined, 2009 V1: 17, 2012 V4: 127
- anesthesia workrooms
  - fixtures, 2011 V3: 39
  - health care facilities, 2011 V3: 36
  - medical air, 2011 V3: 53
  - medical gas stations, 2011 V3: 52
- anesthetic gas management, 2011 V3: 65–66
- anesthetics, 2011 V3: 76
- anesthetizing locations, 2011 V3: 76
- angle of incidence, defined, 2011 V3: 190
- angle of reflection, defined, 2011 V3: 190
- angle of refraction, defined, 2011 V3: 190
- angle snubbers, 2009 V1: 156
- angle stops, 2009 V1: 17
- angle valves (AV), 2009 V1: 9, 17
  - abbreviation for, 2009 V1: 14
  - defined, 2012 V4: 75
  - resistance coefficients, 2010 V2: 92
  - stems, 2012 V4: 79
- angled grates in school shower rooms, 2010 V2: 11
- angles (ANG), measurements, 2009 V1: 34
- angles of bend, 2009 V1: 17
- angular acceleration measurements, 2009 V1: 34
- angular velocity measurements, 2009 V1: 34
- animal research centers, 2010 V2: 241, 2011 V3: 52
- animal shelters, 2010 V2: 15
- animal treatment rooms, 2011 V3: 47
- anion exchangers, defined, 2012 V4: 183
- anions
  - anion resins, 2010 V2: 191, 207
  - defined, 2009 V1: 17, 141, 2010 V2: 187, 2012 V4: 182, 200
  - in electromotive force series, 2009 V1: 134
  - in ion exchange, 2010 V2: 205
  - in pH values, 2010 V2: 229
- annealed temper (soft), 2012 V4: 29
- annealing, 2009 V1: 17
- annual costs. *See* costs and economic concerns
- annular chambers in dry-pipe systems, 2011 V3: 8
- annular spaces in wells, 2010 V2: 156, 158
- annunciators, 2011 V3: 28
- anodes
  - anode expected life, 2009 V1: 138
  - anodic protection, 2009 V1: 141
  - defined, 2009 V1: 129, 141
  - galvanic series of metals, 2009 V1: 132
  - sacrificial anodes, 2009 V1: 137
- anodic inhibitors, 2009 V1: 141
- anodic potential (electronegative potential), 2009 V1: 14
- anodic protection, defined, 2009 V1: 141
- ANSI. *See* American National Standards Institute (ANSI)
- anthracite coal filters, 2010 V2: 160, 201
- anthropometrics for wheelchairs, 2009 V1: 99–101
- anti-cross-connection precautions, 2010 V2: 27
- anti-siphon ballcocks, 2012 V4: 6
- antifreeze, 2009 V1: 122
- antifreeze systems, fire sprinklers, 2011 V3: 11
- antisiphons, 2009 V1: 17
- apartment buildings
  - firefighting demand flow rates, 2011 V3: 224
  - gas demand, 2010 V2: 123, 124, 130
  - hot water demand, 2010 V2: 99, 100
  - natural gas demand, 2010 V2: 123
  - numbers of fixtures for, 2012 V4: 21
  - plumbing noise, 2009 V1: 187
  - water consumption, 2012 V4: 187
- API. *See* American Petroleum Institute
- appearance functions
  - defined, 2009 V1: 218
  - in value engineering, 2009 V1: 223
- appearance of pipes, 2009 V1: 262–263, 2012 V4: 103, 107
- appliance gas regulators, 2010 V2: 117
- appliances. *See also* fixtures
  - appliance regulators, 2010 V2: 117
  - as source of plumbing noise, 2009 V1: 189
  - codes and standards, 2009 V1: 43–44
  - flexible gas connections, 2010 V2: 124
  - gas control valves, 118, 2010 V2: 115
  - gas demand, 2010 V2: 115, 116
  - gas regulators, 2011 V3: 254–255
  - propane vaporizers, 2010 V2: 134
  - venting systems, 2010 V2: 118
- Applied Technology Council (ATC), 2009 V1: 174, 185
- approaches (heat), 2009 V1: 17
- approaches to toilet compartments, 2009 V1: 106
- approvals
  - for radioactive materials systems, 2010 V2: 238
  - for special-waste drainage systems, 2010 V2: 227–228
- approved, defined, 2009 V1: 17, 2012 V4: 169
- approved testing agencies, 2009 V1: 17
- approximate values, 2009 V1: 33
- aquastats, 2009 V1: 10
- Aqueous Film-Forming Foam (AFFF), 2011 V3: 25
- aquifers
  - defined, 2009 V1: 17, 2010 V2: 155
  - formation of, 2010 V2: 155
  - potentiometric surfaces, 2010 V2: 157
  - unconsolidated aquifers, 2010 V2: 157
- Arabic numerals, 2009 V1: 33
- Architect-engineers Turf Sprinkler Manual*, 2011 V3: 96
- architect's supplemental instructions (ASI), 2009 V1: 57
- Architectural Barriers Act (90-480), 2009 V1: 98
- area (A)
  - calculating, 2009 V1: 3–5
  - conversion factors, 2009 V1: 35
  - measurements, 2009 V1: 34
  - non-SI units, 2009 V1: 34
- area, aperture, defined, 2011 V3: 190
- area, gross collector, defined, 2011 V3: 190
- area alarms, 2011 V3: 50, 67, 75
- area drains (ad), 2009 V1: 14, 17
- areas of sprinkler operation, 2011 V3: 12
- areaways, 2009 V1: 17
- ARI (Air Conditioning and Refrigeration Institute), 2012 V4: 215–216
- arm baths, 2010 V2: 99, 2011 V3: 36, 38, 40
- Army Corps of Engineers, 2009 V1: 57
- arresters for water hammer. *See* water hammer arresters
- articulated-ceiling medical gas systems, 2011 V3: 56
- as built, defined, 2012 V4: 128
- as low as reasonably achievable (ALARA), 2010 V2: 238

- ASA. *See* American National Standards Institute (ANSI)
- ASA A117.1-1961, 2009 V1: 97
- asbestos cement piping, 2010 V2: 75, 2011 V3: 242
- ASCE. *See* American Society of Civil Engineers (ASCE)
- ASHE (American Society for Healthcare Engineering), 2010 V2: 108–109
- ASHRAE. *See* American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE)
- ASHRAE Handbook - Fundamentals, 2010 V2: 136
- ASI (architect's supplemental instructions), 2009 V1: 57
- ASJ (all-service jackets), 2012 V4: 106, 108
- ASME. *See* American Society of Mechanical Engineers (ASME)
- ASPE. *See* American Society of Plumbing Engineers (ASPE)
- ASPERF (American Society of Plumbing Engineers Research Foundation), 2009 V1: 32
- asphalt-dipped piping, 2010 V2: 78
- asphalt mixers, 2010 V2: 133
- asphalt pavement, runoff, 2010 V2: 42
- asphyxiant gases, 2009 V1: 17
- aspirators, 2009 V1: 17, 2011 V3: 40, 2012 V4: 161
- ASSE. *See* American Society of Sanitary Engineering (ASSE)
- assemblies, defined, 2012 V4: 128
- assembly costs, 2009 V1: 210
- assisted creativity, 2009 V1: 227
- Association for the Advancement of Medical Instrumentation (AAMI), 2010 V2: 187, 219, 220
- Association of Pool and Spa Professionals (APSP), 2011 V3: 104
- Association of State Drinking Water Administrators, 2010 V2: 155
- ASTM. *See* American Society for Testing and Materials (ASTM)
- ASTs (aboveground storage tanks). *See* aboveground tank systems
- asynchronous, defined, 2009 V1: 17
- ATBCB (U.S. Architectural and Transportation Barriers Compliance Board), 2009 V1: 98, 99
- ATC-3 (Tentative Provisions for the Development of Seismic Regulations for Buildings), 2009 V1: 174, 185
- Atienze, J., 2010 V2: 29
- atmospheres (atm, ATM)
- converting to SI units, 2009 V1: 38
- vacuum units, 2010 V2: 166
- atmospheric backflow preventers, 2012 V4: 163
- atmospheric pressure
- Boyle's law, 2012 V4: 211–213
- defined, 2012 V4: 169
- in vacuum, 2010 V2: 165
- atmospheric regulators, 2011 V3: 255
- atmospheric tanks
- defined, 2011 V3: 136
- foam, 2011 V3: 25
- venting, 2011 V3: 141
- atmospheric vacuum breakers (AVB)
- backflow prevention, 2012 V4: 166
- defined, 2009 V1: 17, 2012 V4: 169
- faucets, 2012 V4: 13
- illustrated, 2012 V4: 167
- irrigation sprinklers, 2011 V3: 95
- atmospheric vaporizers, 2011 V3: 57
- atmospheric vents (steam or hot vapor) (ATV), 2009 V1: 9
- atomic weight, 2009 V1: 17
- attachments, 2009 V1: 185
- atto prefix, 2009 V1: 34
- ATV (atmospheric vents), 2009 V1: 9
- Auciello, Eugene P., 2010 V2: 55
- auditoriums, numbers of fixtures for, 2012 V4: 20, 22
- augered wells, 2010 V2: 156
- austenitic stainless steel, 2012 V4: 56
- authorities having jurisdiction
- alterations to existing buildings, 2009 V1: 266
- alternative sanitary systems, 2010 V2: 16
- clean agent fire-suppression systems, 2011 V3: 27
- cross-connection programs, 2012 V4: 168–169
- defined, 2009 V1: 17, 2011 V3: 76
- fire-protection system design, 2011 V3: 1
- fixture vents, 2010 V2: 32
- gas approvals, 2010 V2: 114
- laboratory gas systems, 2010 V2: 121, 2011 V3: 263
- manholes, 2011 V3: 225
- medical gas stations, 2011 V3: 51
- public sewer availability, 2011 V3: 225
- swimming pools, 2011 V3: 104, 107
- vent stacks, 2010 V2: 39–40
- autoclaves, 2012 V4: 161
- autoignition, 2009 V1: 17
- automatic air vents (AAV), 2009 V1: 10
- automatic alternators, 2011 V3: 65
- automatic controls on ion exchangers, 2012 V4: 183
- automatic drain valves, 2011 V3: 95
- automatic drains in vacuum systems, 2011 V3: 65
- automatic dry standpipe systems, 2011 V3: 20
- automatic fire-detection devices, 2011 V3: 9
- automatic fire-protection systems
- history and objectives, 2011 V3: 1
- pipes and hangers, 2011 V3: 18, 19
- automatic flushometer valves, 2012 V4: 7
- automatic grease interceptors, 2012 V4: 151–152
- automatic heat-up method, condensate drainage, 2011 V3: 164
- automatic overflow prevention, 2011 V3: 148
- automatic overrides for irrigation controllers, 2011 V3: 95
- automatic purity monitors, 2012 V4: 193
- automatic softeners, 2012 V4: 200
- automatic sprinkler systems
- combined dry-pipe and pre-action, 2011 V3: 10–11
- design density, 2011 V3: 11–12
- elevator shafts, 2011 V3: 29
- fire hazard evaluation, 2011 V3: 2
- fire pumps for, 2011 V3: 21–22
- foam fire-suppression systems and, 2011 V3: 25
- history, 2011 V3: 1
- hydraulic design, 2011 V3: 11–13
- numbers of sprinklers in operation, 2011 V3: 12
- pipes, 2011 V3: 9
- pipes and hangers, 2011 V3: 18, 19
- pre-action systems, 2011 V3: 9
- system design, 2011 V3: 2–18
- types, 2009 V1: 28–29, 2011 V3: 6–11
- water supplies, 2011 V3: 2–6

*Automatic Sprinkler Systems Handbook*, 2009 V1: 185  
 automatic storage water heaters, 2010 V2: 101  
 automatic tank gauging, 2011 V3: 142  
 automatic trap primers, 2010 V2: 11  
 automatic wet standpipe systems, 2011 V3: 20  
 automotive traffic, 2010 V2: 11  
 autopsy rooms  
   fixtures, 2011 V3: 38, 40  
   health care facilities, 2011 V3: 36  
   medical gas stations, 2011 V3: 52, 56  
   medical vacuum, 2011 V3: 54  
   non-potable water, 2011 V3: 47  
 auxiliary energy subsystems, 2011 V3: 190  
 auxiliary stops, 2012 V4: 128  
 auxiliary water supplies  
   defined, 2012 V4: 169  
   direct connection hazards, 2012 V4: 161  
 AV (acid vents), 2009 V1: 8, 16  
 AV (angle valves). *See* angle valves (AV)  
 availability. *See* demand  
 availability of water, 2009 V1: 17  
 available net positive suction head, 2012 V4: 100  
 available vacuum, safety factors and, 2010 V2: 186  
 AVB. *See* atmospheric vacuum breakers (AVB)  
 average flow rates for fixtures, 2012 V4: 186  
 average water use, 2009 V1: 117  
 AW (acid wastes), 2009 V1: 8, 16, 2011 V3: 42–46, 2012 V4: 51  
 AWS. *See* American Welding Society (AWS)  
 AWWA. *See* American Water Works Association (AWWA)  
 axial braces, 2012 V4: 128  
 axial flow, 2012 V4: 100  
 axial motions, hangers and supports and, 2012 V4: 116, 118  
 axial pumps, 2012 V4: 91  
 Ayres, J.M., 2009 V1: 185

## B

back pressure, 2012 V4: 169  
 back pressure tests, 2012 V4: 5  
 back pressures in pipes, 2010 V2: 2, 4, 2011 V3: 255, 2012 V4: 161  
 back-siphonage, 2010 V2: 94, 2011 V3: 95. *See also* backflow  
   defined, 2009 V1: 17, 2012 V4: 169  
   reverse flow, cause of, 2012 V4: 161  
 back-spud water closets, 2012 V4: 3  
 back-to-back water closets, 2012 V4: 5  
 backfilling  
   around septic tanks, 2010 V2: 146  
   backfill defined, 2009 V1: 17  
   building sewers and, 2010 V2: 14–15  
   labor productivity rates, 2009 V1: 87, 88  
   in plumbing cost estimation, 2009 V1: 85  
   storage tanks, 2011 V3: 137, 155  
 backflow. *See also* back-siphonage  
   backflow connections, defined, 2009 V1: 17  
   defined, 2009 V1: 17, 2010 V2: 94, 2012 V4: 169  
   prevention, 2012 V4: 164–166, 169  
   swing check valves, 2012 V4: 76  
 backflow preventers (BFP)  
   codes, 2009 V1: 42  
   cold-water systems, 2010 V2: 60  
   cross-connection control devices, 2010 V2: 60–61

  defined, 2009 V1: 14, 17, 2012 V4: 169, 170  
   domestic cold water systems, 2010 V2: 60  
   domestic water supply, 2011 V3: 214–216  
   faucets, 2012 V4: 12–13  
   fire-protection connections, 2011 V3: 217, 220  
   fixtures in health care facilities, 2011 V3: 35  
   pressure loss, 2011 V3: 215  
   reduced pressure zones, 2011 V3: 215  
   thermal expansion compensation and, 2010 V2: 106  
   vacuum breakers, 2011 V3: 35, 46  
 background levels of radiation, 2010 V2: 237  
 backing rings, 2009 V1: 17  
 backpressure, 2009 V1: 17  
 backpressure appliance regulators, 2010 V2: 117  
 backup, defined, 2009 V1: 17  
 backup demineralizers, 2011 V3: 48  
 backup storm-drainage systems, 2010 V2: 52  
 backwash from water softeners, 2010 V2: 160, 210  
 backwashing  
   defined, 2012 V4: 200  
   filters, 2010 V2: 201, 2012 V4: 180, 181  
   pressure differential switches, 2012 V4: 181  
   in regeneration cycle, 2010 V2: 206  
 backwater valves, 2009 V1: 17, 43, 2010 V2: 12  
 bacteria  
   biological fouling, 2010 V2: 195, 217  
   chemical control, 2010 V2: 213  
   copper-silver ionization, 2012 V4: 199  
   defined, 2012 V4: 200  
   demineralizer systems, 2011 V3: 48  
   distilled water and, 2011 V3: 47–48, 2012 V4: 189, 192  
   drinking water and, 2010 V2: 160, 2012 V4: 174–175  
   in feed water, 2010 V2: 188  
   in filters, 2010 V2: 201  
   in hot water, 2011 V3: 47  
   killing in water systems, 2010 V2: 109–111  
   laboratory grade water and, 2012 V4: 197  
   ozone treatments and, 2012 V4: 194  
   in septic tanks, 2010 V2: 145  
   solar water heating and, 2011 V3: 196  
   in storm water, 2010 V2: 27, 43  
   in water-heating systems, 2010 V2: 108–111  
   in wells, 2010 V2: 158  
 bacteriological examination, 2012 V4: 200  
 baffle systems  
   bioremediation pretreatment systems, 2012 V4: 230  
   bioremediation systems, 2012 V4: 228  
   grease interceptors, 2012 V4: 150  
   stills, 2012 V4: 192  
   water distillation, 2011 V3: 48  
 baffleplates, 2009 V1: 17  
 bag-filter gross filtration, 2010 V2: 201  
 Bahamas, gray-water systems in, 2010 V2: 27  
 bailers, 2011 V3: 144  
 baking soda, 2012 V4: 173  
 balanced-piston valves, 2012 V4: 82  
 balancing cocks, 2012 V4: 223  
 balancing valves (BLV), 2009 V1: 9  
 ball check valves, 2009 V1: 18  
 ball joints, 2009 V1: 18, 161, 2012 V4: 63  
 ball removal tests, 2012 V4: 5  
 ball valves (BV), 2009 V1: 9, 14, 18, 2010 V2: 92, 230

- compressed-air systems, 2012 V4: 84
- defined, 2012 V4: 75, 88
- handle extensions, 2012 V4: 75
- high-rise service, 2012 V4: 88
- hot and cold water supply service, 2012 V4: 83
- low-pressure steam systems, 2012 V4: 85
- medical gas service, 2011 V3: 67, 2012 V4: 85
- noise mitigation, 2009 V1: 194
- vacuum system service, 2012 V4: 84–85
- Ballanco, Julius, 2010 V2: 55
- ballast pads, 2011 V3: 155
- ballcocks, 2012 V4: 6
- Baltimore Dept. of Public Works, 2010 V2: 29
- band hangers, 2012 V4: 119, 128
- baptismal fonts, 2012 V4: 161
- bar joist hangers, 2012 V4: 126
- bar joists, 2012 V4: 126
- bare earth, runoff, 2010 V2: 42
- bare pipe, 2009 V1: 139
- bariatric water closets (WC), 2012 V4: 4, 6
- barium, 2010 V2: 189
- baro pr, BARO PR (barometric pressure). *See* barometric pressure
- barometers (baro, BARO), 2010 V2: 166
- barometric loops, 2012 V4: 169
- barometric pressure (baro pr, BARO PR, BP)
  - altitude adjustments, 2010 V2: 166–167
  - defined, 2011 V3: 172, 183, 186
  - in vacuums, 2010 V2: 166, 185
- barrels
  - converting to SI units, 2009 V1: 38
  - dimensions, 2012 V4: 27–29
- barrier free, 2009 V1: 18. *See also* people with disabilities
- barrier-free water coolers, 2012 V4: 217
- barriers around tanks, 2011 V3: 149
- bars, converting to SI units, 2009 V1: 38
- base acquisition costs, 2009 V1: 217
- base materials
  - base defined, 2009 V1: 18
  - compounds in water, 2010 V2: 188
  - pH control, 2011 V3: 85–87
- base supports, 2012 V4: 128
- base units, 2009 V1: 33
- basic functions in value engineering, 2009 V1: 219, 221
- basic material standards, 2009 V1: 61
- basket strainers, 2010 V2: 92
- bathhouses, 2010 V2: 151, 2011 V3: 108–110
- bathing rooms, 2009 V1: 104–105
- bathroom groups, 2009 V1: 18, 2011 V3: 206
- bathtub fill valves, 2012 V4: 17
- bathtub spout noise mitigation, 2009 V1: 200
- bathtubs (BT)
  - abbreviations for, 2009 V1: 14
  - accessibility design, 2009 V1: 109–110
  - acoustic ratings of, 2009 V1: 194
  - bathtub enclosures, 2009 V1: 110
  - fixture pipe sizes and demand, 2010 V2: 86
  - fixture-unit loads, 2010 V2: 3
  - grab bars, 2009 V1: 109
  - gray-water systems and, 2009 V1: 126
  - health care facilities, 2011 V3: 36
  - hot water demand, 2010 V2: 99
  - infant bathtubs, 2011 V3: 38
  - minimum numbers of, 2012 V4: 20–23
  - noise mitigation, 2009 V1: 194, 198, 201
  - overflows, 2012 V4: 16
  - patient rooms, 2011 V3: 37
  - seats, 2009 V1: 114–115
  - standards, 2012 V4: 2
  - submerged inlet hazards, 2012 V4: 161
  - temperatures, 2011 V3: 47
  - types and requirements, 2012 V4: 16–17
  - water fixture unit values, 2011 V3: 206
- batteries, corrosion cells in sacrificial anodes, 2009 V1: 137
- batteries of fixtures, 2009 V1: 18
- battery installations of water-pressure regulators, 2012 V4: 82
- Baumeister, Theodore, 2009 V1: 1, 2, 3, 5, 39
- BCMC (Board for Coordination of Model Codes), 2009 V1: 98
- BCuP brazing, 2012 V4: 34
- beach components in pools, 2011 V3: 108
- bead-to-bead joints, 2012 V4: 36, 61
- bead-to-cut-glass end joints, 2012 V4: 36
- bead-to-plain-end joints, 2012 V4: 61
- beadless butt fusion, 2012 V4: 62
- beads, ion exchange, 2012 V4: 183
- beam attachments, 2012 V4: 126
- beam clamps, 2009 V1: 182, 2012 V4: 119, 120, 126, 128
- bearing plates. *See* roll plates; slide plates
- Beckman, W.A., 2011 V3: 204
- bed depths, 2012 V4: 200
- bed locator units, 2011 V3: 55
- bedding and settlement
  - building sewers and, 2010 V2: 14–15
  - defined, 2009 V1: 18, 2011 V3: 225–226
  - illustrated, 2011 V3: 227
  - pipe supports and, 2010 V2: 12
  - protecting against settlement, 2010 V2: 16
  - settlement loads, 2009 V1: 180
- bedpan washers, 2011 V3: 36, 37, 39, 40, 2012 V4: 161
- beer, 2009 V1: 141
- bell-and-spigot joints and piping. *See also* hub-and-spigot piping and joints
  - defined, 2009 V1: 18
  - earthquake protection and, 2009 V1: 160
- bell-hub depressions, 2010 V2: 14
- bell-mouth inlets or reducers, 2010 V2: 93
- bellows expansion joints, 2012 V4: 207
- bellows-style water hammer arresters, 2010 V2: 72–74
- bellows traps, 2011 V3: 162
- bells, defined, 2009 V1: 18
- belt-driven compressors, 2012 V4: 219
- bending moments, 2012 V4: 205
- bending movements, 2009 V1: 35
- bending pipes, 2012 V4: 61
- bending presses, 2012 V4: 61
- benefits in value engineering presentations, 2009 V1: 249
- Bennett, E.R., 2010 V2: 154
- bentonite clay, 2010 V2: 205
- bentonite grout, 2010 V2: 157
- bents, 2012 V4: 128
- Bergstrom, Ken, 2011 V3: 135
- Bernoulli's equation, 2009 V1: 5–6

- defined, 2012 V4: 100
- pump applications, 2012 V4: 94
- beta oxidation, 2012 V4: 229
- beta ray radiation, 2010 V2: 236–237
- beveling edges for welding, 2012 V4: 61
- BFP (backflow preventers). *See* backflow preventers
- BFV (butterfly valves). *See* butterfly valves
- bhp, BHP (brake horsepower), 2009 V1: 6, 14, 2011 V3: 21, 2012 V4: 100
- bicarbonate ions (HCO<sub>3</sub>), 2012 V4: 173, 184
- bicarbonate of soda, 2012 V4: 173
- bicarbonates, 2010 V2: 189, 196, 199, 2012 V4: 176, 184
- bid bonds, 2009 V1: 56
- bid by invitation, 2009 V1: 56
- bid shopping, 2009 V1: 62
- bidders
  - defined, 2009 V1: 55
  - information in project manuals, 2009 V1: 55
  - well construction, 2010 V2: 164
- bidding documents, 2009 V1: 55
- bidding requirements, 2009 V1: 55
- Biddison, 2009 V1: 185
- bidets, 2010 V2: 86, 2011 V3: 206, 2012 V4: 2, 17, 161
- bilge pumps, 2012 V4: 98
- bimetallic traps, 2011 V3: 162
- binding, preventing in cleanouts, 2010 V2: 9
- biochemical measurements of microorganisms, 2010 V2: 188
- biocides, 2010 V2: 213, 217, 222–223
- biodegradable foam extinguishers, 2011 V3: 26
- biofilm, 2010 V2: 109, 2012 V4: 228
- biofouling, 2010 V2: 195, 217
- biohazardous materials. *See* infectious and biological waste systems
- biological and biomedical laboratories. *See* laboratories
- biological characteristics of drinking water, 2010 V2: 217
- biological control in pure water systems. *See* microbial growth and control
- biological fouling, 2010 V2: 195, 217
- biological oxygen demand (BOD), 2011 V3: 26, 88, 2012 V4: 200, 228
- biological treatment
  - in gray-water treatment, 2010 V2: 27
  - of oil spills, 2010 V2: 245
  - in pure water systems, 2010 V2: 222–223
  - of sewage in septic tanks, 2010 V2: 145
  - wastewater treatment plants, 2011 V3: 88
- biological waste systems. *See* infectious and biological waste systems
- biopure water
  - defined, 2012 V4: 175
  - distillation, 2012 V4: 175
  - health care facilities, 2011 V3: 47
- bioreactors, 2012 V4: 227
- bioremediation grease interceptors, 2012 V4: 152
- bioremediation pretreatment systems
  - codes and standards, 2012 V4: 229–230
  - defined, 2012 V4: 227
  - dimensions and performance, 2012 V4: 230–231
  - flow control, 2012 V4: 229
  - materials and structure, 2012 V4: 230
  - principles, 2012 V4: 227–229
  - retention system, 2012 V4: 228
  - separation, 2012 V4: 228
  - sizing, 2012 V4: 229
  - types of, 2012 V4: 227
- biosafety cabinets, 2010 V2: 240
- Biosafety in Microbiological and Biomedical Laboratories, 2010 V2: 172
- biosafety levels (BL1–BL4), 2010 V2: 172, 241
- biosolids, 2012 V4: 238–240
- biostats, 2010 V2: 213, 217
- birthing rooms, 2011 V3: 39, 52, 56
- bitumastic-enamel-lined piping, 2010 V2: 75
- BL1–4 levels, 2010 V2: 241
- black iron coated pipe, 2012 V4: 37
- black pipes, 2009 V1: 18
- black steel piping, 2010 V2: 122, 2011 V3: 148, 257
- black-water systems
  - amount of generated black water, 2012 V4: 238
  - compared to gray water, 2010 V2: 21
  - defined, 2010 V2: 21
  - estimating sewage quantities, 2010 V2: 150–152
  - sources, 2012 V4: 239
  - types of, 2012 V4: 237
- bladder bags, 2009 V1: 108
- bladder tanks, 2011 V3: 26, 2012 V4: 209
- Blake, Richard T., 2010 V2: 224
- blank flanges, 2009 V1: 18
- blast furnace gas, 2010 V2: 114
- blast gates, 2010 V2: 179
- bleach, 2009 V1: 141
- bleaches, 2010 V2: 147
- bleaching powder, 2012 V4: 173
- bleed air, 2010 V2: 171
- bleed cocks, 2011 V3: 3
- bleed throughs, 2012 V4: 200
- block-like soils, 2010 V2: 141
- block-method irrigation, 2011 V3: 92
- blocking creativity, 2009 V1: 225
- blood analyzers, 2010 V2: 13
- blood or other objectionable materials, 2010 V2: 15. *See also* infectious and biological waste systems
- blood-type floor drains, 2011 V3: 38
- blow-off in air compressors, 2011 V3: 177
- blowdown
  - boiler blowdown, 2010 V2: 216
  - cooling towers, 2010 V2: 216
  - removing sludge, 2010 V2: 195
- blowout urinals, 2012 V4: 8
- blowout water closets, 2012 V4: 2–3
- blue dyes in gray water, 2010 V2: 27
- BLV (balancing valves), 2009 V1: 9
- Board for Coordination of Model Codes (BCMC), 2009 V1: 98
- BOCA. *See* Building Officials and Code Administrators International, Inc. (BOCA)
- BOD (biological oxygen demand), 2011 V3: 26, 88, 2012 V4: 200, 228
- bodies of valves, 2012 V4: 73, 88
- body sprays, 2012 V4: 16
- Boegly, W.J., 2010 V2: 154
- boiler blow-offs, 2009 V1: 18
- boiler room earthquake protection, 2009 V1: 158
- Boiler Water Treatment*, 2010 V2: 224

- boilers
  - allowable pressure, 2010 V2: 119
  - boiler steam as distillation feed water, 2012 V4: 194
  - cast-iron supports for, 2009 V1: 152
  - central heating, 2011 V3: 127
  - codes and standards, 2009 V1: 42
  - direct connection hazards, 2012 V4: 161
  - earthquake protection, 2009 V1: 153
  - feed lines, 2012 V4: 29
  - feed water corrosion inhibitors, 2009 V1: 140
  - feed water treatments, 2010 V2: 215–216
  - gas demand, 2010 V2: 116
  - gas train arrangements, 2011 V3: 255
  - scaling, 2010 V2: 195
  - sediment buckets in drains, 2010 V2: 11
- boiling points (bp, BP)
  - defined, 2009 V1: 18, 2010 V2: 135
  - liquid fuels, 2011 V3: 136
  - liquid oxygen, 2011 V3: 57
- bollards, 2011 V3: 149, 155
- bolted bonnet joints, 2012 V4: 79
- bolted bonnets, 2012 V4: 88
- bolts and bolting
  - defined, 2012 V4: 128
  - lubricating, 2012 V4: 60
  - problems in seismic protection, 2009 V1: 184
  - types of bolts, 2012 V4: 120
  - water closets, 2012 V4: 5
- bonded joints, 2009 V1: 140
- bonding, electrical, 2010 V2: 125
- bonds and certificates, 2009 V1: 56
- bonnets, 2009 V1: 18, 2012 V4: 73, 79, 88
- booster pump control valves, 2012 V4: 82
- booster pump controls, 2012 V4: 99
- booster-pump systems
  - cold-water supplies, 2010 V2: 61–68
  - connections, 2011 V3: 217
  - domestic water service, 2011 V3: 206
  - fire-protection systems, 2011 V3: 6
  - in health care facilities, 2011 V3: 46
  - swimming pool heaters, 2011 V3: 126
  - vacuum systems, 2010 V2: 172
- booster systems, gas, 2010 V2: 119
- booster water heaters, 2009 V1: 18, 121, 2010 V2: 104
- borate, 2010 V2: 189
- bored wells, 2010 V2: 156–157
- borosilicate glass piping, 2010 V2: 13, 14, 75, 2011 V3: 42, 2012 V4: 35
- Bosich, Joseph F., 2009 V1: 144
- bottle fillers, 2012 V4: 219
- bottle water coolers, 2012 V4: 216
- bottled gas regulators, 2010 V2: 117
- bottled water, 2012 V4: 13, 216
- Bottom Loading and Vapor Recovery for MC-306 Tank Motor Vehicles (AOIRP 1004)*, 2011 V3: 156
- Bourdon gauges, 2010 V2: 171
- bowl depth of sinks, 2009 V1: 109
- Boyle's law, 2010 V2: 65, 2012 V4: 211–213
- BP (barometric pressure). *See* barometric pressure
- bp, BP (boiling points). *See* boiling points (bp, BP)
- BR (butadiene), 2009 V1: 32
- braces (walking aids), 2009 V1: 99
- bracing
  - aircraft cable method, 2009 V1: 160
  - alternate attachments for pipes, 2009 V1: 167
  - brace assemblies, 2012 V4: 128
  - brace, hanger, or support drawings, 2012 V4: 128
  - defined, 2009 V1: 185, 2012 V4: 128
  - hanger rod connections, 2009 V1: 170
  - hanger rods, 2009 V1: 158
  - hubless cast-iron pipe, 2009 V1: 170
  - lateral sway bracing, 2009 V1: 175–176
  - longitudinal and transverse bracing, 2009 V1: 173
  - longitudinal-only bracing, 2009 V1: 165, 173
  - open-web steel joists, 2009 V1: 169
  - pipes on trapeze and, 2009 V1: 168, 171
  - piping systems for seismic protection, 2009 V1: 158–179
  - riser bracing for hubless pipes, 2009 V1: 171
  - self bracing, 2009 V1: 184
  - spacing of, 2009 V1: 177
  - steel beam connections, 2009 V1: 168
  - structural angle bracing, 2009 V1: 160
  - structural channel bracing, 2009 V1: 160
  - strut bracing, 2009 V1: 166, 168
  - superstrut, 2009 V1: 163
  - sway bracing, 2009 V1: 172, 173, 175–176, 178–179, 181
  - Tension 360 bracing, 2009 V1: 162
  - transverse bracing, 2009 V1: 160, 172
  - truss-type actions, 2009 V1: 182
  - typical earthquake bracing, 2009 V1: 161
- brackets
  - defined, 2012 V4: 128
  - hangers and supports, 2012 V4: 119
  - illustrated, 2012 V4: 64, 121
  - securing pipes, 2012 V4: 65
- brainstorming in creativity, 2009 V1: 227
- brake horsepower (bhp, BHP)
  - defined, 2011 V3: 186, 2012 V4: 100
  - fire pumps, 2011 V3: 21
  - pumps, 2009 V1: 6
  - symbols for, 2009 V1: 14
- branch-bottom connections, 2009 V1: 11
- branch intervals, 2009 V1: 18, 2010 V2: 35
- branch length gas pipe sizing method, 2010 V2: 130
- branch length method, 2010 V2: 87, 89, 94
- branch-side connections, 2009 V1: 11
- branch tees, 2009 V1: 18
- branch-top connections, 2009 V1: 11
- branch vents
  - air admittance valves, 2010 V2: 39
  - defined, 2009 V1: 18
- branches
  - branch lines, defined, 2011 V3: 78
  - clear water waste, 2010 V2: 50
  - defined, 2009 V1: 18
  - laboratory gases, 2011 V3: 280
  - thermal expansion and contraction in, 2012 V4: 206
- brand names in specifications, 2009 V1: 60, 62
- brass
  - corrosion, 2012 V4: 176
  - dezincification, 2009 V1: 132
  - in electromotive force series, 2009 V1: 132
  - in galvanic series, 2009 V1: 132
  - stress and strain figures, 2012 V4: 206

- thermal expansion or contraction, 2012 V4: 207
- valves, 2012 V4: 77
- brass floor drains, 2010 V2: 15
- brass (copper alloy) pipe, 2010 V2: 12–13
- brass pipes, 2010 V2: 75, 78, 122, 2011 V3: 102
- brass tubing, 2010 V2: 122
- brazed ends on valves, 2012 V4: 79
- brazed joints
  - earthquake protection and, 2009 V1: 160
  - inspection, 74, 2011 V3: 69
  - laboratory gas systems, 2011 V3: 277
  - medical gas tubing, 2011 V3: 69, 2012 V4: 34
- brazing, defined, 2009 V1: 18, 2012 V4: 58
- brazing ends, 2009 V1: 18
- break tanks, 2010 V2: 64, 2012 V4: 166, 168
- breathing apparatus for emergencies, 2010 V2: 229, 231
- BREEAM (Building Research Establishment Environmental Assessment Method), 2012 V4: 233
- brine tanks
  - defined, 2012 V4: 200
  - submerged inlet hazards, 2012 V4: 161
- brines
  - defined, 2012 V4: 200
  - hydrostatic monitoring systems, 2011 V3: 143
  - refrigerants, 2009 V1: 140
  - in water softening, 2010 V2: 210, 2012 V4: 189
- British thermal units (Btu, BTU)
  - British thermal units per hour (Btu/h), 2009 V1: 18
  - Btu (J) (fire loads), 2011 V3: 2
  - calculating hot water savings, 2009 V1: 118
  - condensate estimates, 2011 V3: 167
  - converting to SI units, 2009 V1: 38
  - defined, 2009 V1: 18, 128, 2012 V4: 103
  - natural gas services, 2011 V3: 252
  - solar energy, 2011 V3: 193
  - symbols for, 2009 V1: 14
- bromine, 2010 V2: 110, 2011 V3: 131
- bromotrifluoro-methane CBrF<sub>3</sub> (halon 1301), 2009 V1: 24
- bronze-mounted, defined, 2009 V1: 18
- bronze sediment buckets, 2010 V2: 13
- bronze valves, 2012 V4: 77
- bronze, in electromotive force series, 2009 V1: 132
- Brown, F.R., 2009 V1: 185
- Brown, J., 2010 V2: 224
- Brundtland Commission, 2012 V4: 233
- BT (bathtubs), 2009 V1: 14
- Btu, BTU (British Thermal units). *See* British Thermal units
- Btu (J) (fire loads), 2011 V3: 2
- Btu/h (British thermal units per hour), 2009 V1: 18
- bubble aerators, 2010 V2: 198
- bubble tight, defined, 2009 V1: 18
- bubble-tight shutoff plug valves, 2012 V4: 77
- bubble-tight valve seating, 2012 V4: 74
- bubbler irrigation heads, 2011 V3: 94
- bubbler system (surge tanks), 2011 V3: 132
- bubblers on water coolers
  - illustrated, 2012 V4: 222
  - pressure-type water coolers, 2012 V4: 217
  - rating conditions, 2012 V4: 216
  - stream regulators, 2012 V4: 219
  - types of, 2012 V4: 218–219
  - wastage, 2012 V4: 220
- water consumption, 2012 V4: 223
- bubbles. *See* detergents; soaps; suds
- bucket traps, 2011 V3: 162–163, 166
- Budnick, J., 2011 V3: 203
- building code list of agencies, 2009 V1: 42
- building drains
  - combined, 2009 V1: 18
  - cross-sections of, 2010 V2: 2
  - defined, 2009 V1: 18
  - flow in, 2010 V2: 2
  - house drains, 2009 V1: 25
  - inspection checklist, 2009 V1: 95
  - installation, 2010 V2: 14–15
  - pneumatic pressure in, 2010 V2: 2–3
  - sanitary. *See* sanitary drainage systems
  - storm. *See* storm-drainage systems
- Building Officials and Code Administrators International, Inc. (BOCA), 2010 V2: 55
  - BOCA Basic Plumbing Code*, 2010 V2: 55
- Building Research Establishment Environmental Assessment Method, 2012 V4: 233
- building sewers (house drains), 2009 V1: 18, 2010 V2: 14–15
- building sites. *See* site utilities; sites
- building storm-sewer pipe codes, 2009 V1: 42
- building structure attachments, 2012 V4: 119
- building subdrains, 2009 V1: 18
- building traps
  - defined, 2009 V1: 18
  - design, 2010 V2: 31–32
  - house traps, 2009 V1: 25
- buildings
  - construction and fire hazards, 2011 V3: 2
  - defined, 2009 V1: 18
  - dwellings, defined, 2009 V1: 22
  - essential facilities, 2009 V1: 185
  - expansion, 2011 V3: 50
  - minimum numbers of fixtures, 2012 V4: 20–23
  - plumbing noise issues, 2009 V1: 187–188
  - standard fire tests, 2011 V3: 2
  - storm-drainage systems. *See* storm-drainage systems
  - subdrains, 2009 V1: 18
  - surveying existing conditions, 2009 V1: 265–270, 267–270
  - traps, 2009 V1: 18
  - type of structure and earthquake protection, 2009 V1: 159
  - utilities. *See* site utilities
  - vibration and, 2012 V4: 137
- built-in showers, 2012 V4: 13
- bulk oxygen systems, 2011 V3: 57–59
- bulkhead fittings, 2011 V3: 145
- bull head tees, 2009 V1: 18
- Buna-N (nitrile butadiene), 2011 V3: 150, 2012 V4: 75, 84
- Bunsen burners, 2010 V2: 116, 121
- buoyancy, tanks, 2011 V3: 241
- burat ochre, 2012 V4: 173
- buried piping. *See* underground piping
- burners, defined, 2010 V2: 135
- burning methane, 2009 V1: 122
- burning rates of plastic pipe, 2012 V4: 50
- burrs, 2009 V1: 18
- burst pressure, 2009 V1: 18
- bushels, converting to SI units, 2009 V1: 38



- bushings, 2009 V1: 18, 2010 V2: 92
- businesses, numbers of fixtures for, 2012 V4: 20
- butadiene (BR), 2009 V1: 32
- butadiene and acrylonitrile (Buna-N). *See* Buna-N
- butane, 2010 V2: 114, 135. *See also* fuel-gas piping systems
- butt caps on fire hydrants, 2011 V3: 3
- butt-end welding, 2012 V4: 79
- butt-welded standard weight pipe, 2012 V4: 37
- butt welding
- butt-weld end connections, 2009 V1: 22
  - butt weld joints, 2009 V1: 19
  - butt weld pipes, 2009 V1: 19
  - defined, 2012 V4: 61
  - radioactive drainage systems, 2010 V2: 239
- butterfly valves (BFV), 2009 V1: 9, 14, 18, 2010 V2: 92
- compressed-air service, 2012 V4: 84
- defined, 2012 V4: 76, 89
  - high-rise service, 2012 V4: 88
  - hot and cold water supply service, 2012 V4: 83–84
  - low-pressure steam systems, 2012 V4: 85
  - medium-pressure steam service, 2008V4: 88
  - swimming pool use, 2011 V3: 125, 131
  - vacuum service, 2012 V4: 84–85
- butylene, 2010 V2: 114
- BV (ball valves), 2009 V1: 9, 14, 18, 2010 V2: 230
- bypass systems for water-pressure regulators, 2012 V4: 80
- bypass valves, 2009 V1: 19, 2012 V4: 18, 74
- bypasses, 2009 V1: 19, 2012 V4: 200
- ## C
- C, °C (Celsius), 2009 V1: 14, 30, 34
- c (centi) prefix, 2009 V1: 34
- C (coulombs), 2009 V1: 34, 129
- c (curies), 2010 V2: 237
- C (specific heat). *See* specific heat
- C clamps, 2012 V4: 119, 120, 126, 128
- C/m<sup>3</sup> (coulombs per cubic meter), 2009 V1: 34
- CA. *See* compressed air (A, CA, X#, X#A)
- CA (cellulose acetate), 2009 V1: 32
- CAAA (Clean Air Act Amendments), 2011 V3: 137
- CAB (cellulose acetate butyrate), 2009 V1: 32
- cable sway braces, 2012 V4: 126, 128
- cables
- defined, 2012 V4: 128
  - earthquake protection and, 2009 V1: 158
- cadmium, 2009 V1: 132, 2010 V2: 27
- cafeteria-type water coolers, 2012 V4: 217
- calcined natural pozzolan, 2012 V4: 230
- calcium
- defined, 2010 V2: 190, 2012 V4: 200
  - in hardness, 2012 V4: 183
  - laboratory grade water, 2012 V4: 198
  - metal (Ca<sup>2+</sup>), 2012 V4: 173
  - nanofiltration, 2012 V4: 199
  - scale formation and corrosion, 2010 V2: 196
  - in water, 2010 V2: 160, 189
  - water hardness and, 2012 V4: 176
- calcium 45, 2010 V2: 238
- calcium bicarbonate, 2010 V2: 189, 2012 V4: 173
- calcium carbonate (lime), 2010 V2: 189, 190, 191, 196, 2012 V4: 173
- calcium chloride, 2010 V2: 190
- calcium hardness, swimming pools, 2011 V3: 127–131
- calcium hydroxide, 2010 V2: 190
- calcium hypochlorite, 2010 V2: 160, 2012 V4: 173
- calcium phosphate, 2010 V2: 190
- calcium salts, 2012 V4: 176
- calcium silicates, 2010 V2: 190, 2012 V4: 107
- calcium sulfate, 2010 V2: 189, 2012 V4: 173
- calculations. *See* equations
- calendars for irrigation controllers, 2011 V3: 95
- calibration gases, 2011 V3: 266
- calibrations, 2009 V1: 19
- California Code of Regulations*, 2009 V1: 174, 185
- California Office of Statewide Health Planning and Development (OSHPD), 2012 V4: 132
- calories, converting to SI units, 2009 V1: 38
- calorific values in fire loads, 2011 V3: 2
- calsil, 2012 V4: 107
- Cameron Hydraulic Data*, 2010 V2: 96, 2011 V3: 214
- camps, septic tank systems for, 2010 V2: 151–152
- can pumps, 2009 V1: 23
- Canadian Mortgage and Housing Corporation
- Research Report: Water Reuse Standards and Verification Protocol*, 2010 V2: 29
  - wastewater issues of concern, 2010 V2: 22, 24
- The Canadian Renewable Energy Guide*, 2011 V3: 204
- Canadian Solar Industries Association web site, 2011 V3: 203
- Canadian Standards Association (CSA), 2009 V1: 14
- consensus process, 2009 V1: 41
  - list of standards, 2009 V1: 52
  - publications (discussed)
  - medical compressed air standards, 2011 V3: 61
  - pipe and fittings standards, 2012 V4: 68–71
  - water closet standards, 2012 V4: 4
  - publications (listed)
    - CSA Z-305.1: Non-flammable Medical Gas Piping Systems*, 2011 V3: 78
  - web site, 2011 V3: 78
- candelas (cd), 2009 V1: 33
- candelas per meter squared (cd/m<sup>2</sup>), 2009 V1: 33
- canisters (pumps), 2012 V4: 93
- canopies, 2009 V1: 19
- cantilevered drinking fountains, 2009 V1: 104
- cantilevers, 2012 V4: 128
- CAP (cellulose acetate propionate), 2009 V1: 32
- CAP (College of American Pathologists), 2010 V2: 187, 219, 2012 V4: 197, 200
- capacitance
- measurements, 2009 V1: 34
  - tank gauging, 2011 V3: 142
- capacity
- air, defined, 2011 V3: 183
  - defined, 2009 V1: 19
  - gas cylinders, 2011 V3: 268
  - swimming pools, 2011 V3: 106–107, 111–112
  - water conditioners, 2012 V4: 200
  - water coolers, 2012 V4: 215
  - water softeners, 2012 V4: 186–188
- capacity (flow). *See* flow rates
- capacity coefficient, defined, 2012 V4: 95, 101
- capillaries, 2009 V1: 19
- capillary tubes (water coolers), 2012 V4: 220

- Capitol Dome, Washington, D.C., 2012 V4: 117
- caps on ends of pipes, 2009 V1: 11
- caps on valves, 2012 V4: 89
- capture-type vacuum pumps, 2010 V2: 169
- capturing rainwater, 2012 V4: 237–238
- car traffic, 2010 V2: 11
- carbohydrazide, 2010 V2: 216
- carbon
- adsorption of oil spills, 2010 V2: 245
  - as contaminant in air, 2011 V3: 265
  - corrosion, 2009 V1: 129, 134
  - storm water, 2010 V2: 27
  - total organic carbon, 2010 V2: 194
  - in water, 2010 V2: 189, 2012 V4: 173
- carbon 14, 2010 V2: 238
- carbon dioxide (CO<sub>2</sub>)
- as contaminant in air, 2011 V3: 265
  - biofilms and, 2012 V4: 229
  - color coding, 2011 V3: 55
  - decarbonation, 2010 V2: 199
  - defined, 2012 V4: 200
  - distillation and, 2012 V4: 191
  - extinguishing systems, 2011 V3: 36
  - feed system, 2011 V3: 130
  - formula, 2012 V4: 173
  - from cation exchange, 2012 V4: 184
  - medical gas supply systems, 2011 V3: 60
  - medical gas system tests, 2011 V3: 76
  - portable fire extinguishers, 2011 V3: 28–29
  - reductions from solar energy use, 2011 V3: 189
  - symbols for, 2009 V1: 9
  - in water, 2010 V2: 189, 190, 199, 2012 V4: 176
- Carbon Dioxide Extinguishing Systems (NFPA 12)*, 2011 V3: 26
- carbon filtration (absorphan). *See* activated carbon filtration (absorphan)
- carbon footprints, 2011 V3: 189
- carbon monoxide, 2010 V2: 114, 2011 V3: 76, 189
- carbon steel, 2009 V1: 132, 2011 V3: 84, 85, 2012 V4: 123
- carbon steel gas cylinders, 2011 V3: 268
- carbon steel piping, 2010 V2: 122
- carbonate films, 2009 V1: 140
- carbonate ions, 2012 V4: 173
- carbonate salts, 2012 V4: 183
- carbonates, 2010 V2: 189, 196, 2012 V4: 177, 198
- carbonic acid (H<sub>2</sub>CO<sub>3</sub>), 2010 V2: 189, 2012 V4: 176, 191
- carboxymethyl cellulose, 2009 V1: 32
- carburetted water gas, 2010 V2: 114
- carcinogens, diatomaceous earth as, 2011 V3: 119
- carpets, vacuum calculations for, 2010 V2: 180
- carrier-grade gases, 2011 V3: 266, 267
- carrier support system noise mitigation, 2009 V1: 197
- cartridge filtration, 2010 V2: 201, 208, 214, 221, 2012 V4: 200
- Cartwright, Peter, 2010 V2: 224
- cascade waterfall aerators, 2010 V2: 198
- casein, 2009 V1: 32
- casings
- driven wells, 2010 V2: 157
  - jetted wells, 2010 V2: 157
  - pumps, 2012 V4: 91
  - well casings, 2010 V2: 156
- Cassidy, Victor M., 2009 V1: 128
- cast-filled acrylic fixtures, 2012 V4: 1
- cast-filled fiberglass fixtures, 2012 V4: 1
- cast glands, 2011 V3: 221
- cast-in-place anchor bolts, 2009 V1: 154
- cast iron (CI)
- in electromotive series, 2009 V1: 132
  - fixtures. *See* cast-iron fixtures
  - in galvanic series, 2009 V1: 132
  - graphitization, 2009 V1: 132
  - hanging rolls, 2012 V4: 119
  - noise mitigation and, 2009 V1: 189–190, 192
  - pipe sleeves, 2012 V4: 67
  - piping. *See* cast-iron soil pipe
  - pumps, 2011 V3: 122–123
  - stanchions, 2012 V4: 119
  - stress and strain figures, 2012 V4: 206
  - supporting rolls, 2012 V4: 119
  - thermal expansion or contraction, 2012 V4: 207
- cast-iron boiler supports, 2009 V1: 152
- cast-iron fixtures
- enameled, 2012 V4: 1
  - in health care facilities, 2011 V3: 35
  - standards, 2012 V4: 2
- cast-iron floor drains, 2010 V2: 15
- cast-iron piping
- bracing, 2009 V1: 170
  - corrosion and, 2009 V1: 140
  - gas systems and, 2010 V2: 122
  - laboratories, 2011 V3: 42
  - Manning formula and, 2011 V3: 242
  - natural gas, 2011 V3: 257
  - radioactive materials systems and, 2010 V2: 239
  - roughness, 2010 V2: 75, 78
  - sanitary drainage systems, 2010 V2: 12–13
- cast-iron soil pipe
- dimensions of hubs, spigots and barrels, 2012 V4: 27–29
  - gaskets, 2012 V4: 57
  - hangers, 2012 V4: 122
  - lead and oakum joints, 2012 V4: 57
  - shielded hubless coupling, 2012 V4: 57
  - standards, 2012 V4: 68
  - telescoping and laying lengths, 2012 V4: 27–28
  - types, 2012 V4: 25–26
- Cast-iron Soil Pipe and Fittings Engineering Manual*, 2010 V2: 55
- Cast Iron Soil Pipe Institute (CISPI), 2009 V1: 32, 51, 2010 V2: 55
- hub and spigot cast iron soil pipe standards, 2012 V4: 25
  - hubless coupling standards, 2012 V4: 57
- cast-iron tank legs, 2009 V1: 154
- catch basins, 2009 V1: 19, 2010 V2: 48
- Category I-IV gas venting, 2010 V2: 119
- Category II, III, or IV vent systems, 2009 V1: 43
- cathodes
- defined, 2009 V1: 129, 141
  - galvanic series of metals, 2009 V1: 132
- cathodic, defined, 2009 V1: 141
- cathodic corrosion, 2009 V1: 141
- cathodic inhibitors, 2009 V1: 141
- cathodic potential (electropositive potential), 2009 V1: 14
- cathodic protection

- criteria, 2009 V1: 140
- defined, 2009 V1: 19, 141
- introduction, 2009 V1: 129
- liquid fuel tanks, 2011 V3: 136
- methods, 2009 V1: 137–140
- wells, 2010 V2: 164
- cation exchangers
  - defined, 2012 V4: 183
  - hydrogen-sodium ion exchange plants, 2012 V4: 184
- cations
  - cation resins, 2010 V2: 191, 206
  - defined, 2009 V1: 141, 2010 V2: 187, 2012 V4: 200
  - in ion exchange, 2010 V2: 205, 2012 V4: 182
  - in pH values, 2010 V2: 229
- caulked joints, defined, 2012 V4: 57
- caulking
  - caulked joints on floor drains, 2010 V2: 15
  - defined, 2009 V1: 19
  - drains, 2010 V2: 13
  - pipe sleeves, 2012 V4: 67
- causes and effects
  - in creativity checklist, 2009 V1: 227
  - of earthquakes, 2009 V1: 148–149
- caustic embrittlement, 2009 V1: 141
- caustic soda, 2010 V2: 235, 2011 V3: 85. *See also* sodium hydroxide (lye or caustic soda)
- caustic waste from regeneration cycle, 2010 V2: 206
- cavitation
  - cavitation corrosion, 2009 V1: 142
  - defined, 2009 V1: 19, 142
  - preventing, 2012 V4: 93
  - pump pressure and, 2012 V4: 100
- CCS (Certified Construction Specifier), 2009 V1: 65
- CD. *See* construction contract documents (CD)
- cd (candelas), 2009 V1: 33
- CD (condensate drains), 2009 V1: 8
- CDA (Copper Development Association), 2009 V1: 32
- CDC (Centers for Disease Control and Prevention), 2009 V1: 14, 2010 V2: 108–109
- CDI (continuous deionization), 2010 V2: 209–210
- CE (coefficient of expansion), 2012 V4: 67
- ceiling-mounted medical gas systems, 2011 V3: 55–56
- ceiling plates, 2012 V4: 126
- ceiling-with-gas-stacks systems, 2011 V3: 55–56
- ceilings, piping in, 2009 V1: 202
- cell pairs, 2010 V2: 209
- cells, defined, 2009 V1: 142
- cellular glass insulation, 2012 V4: 106, 107
- cellular urethane, 2012 V4: 107
- cellulose acetate, 2009 V1: 32
- cellulose acetate butyrate (Celcon), 2009 V1: 32
- cellulose acetate membranes, 2010 V2: 213, 2012 V4: 196
- cellulose acetate propionate, 2009 V1: 32
- cellulose gas filters, 2011 V3: 252
- cellulose nitrate, 2009 V1: 32
- cellulose propionate, 2009 V1: 32
- cellulose tricetate membranes, 2010 V2: 213
- cellulose water filters, 2011 V3: 122
- Celsius (°C), 2009 V1: 14, 30
- cement grout, 2010 V2: 157
- cement joints, 2009 V1: 19
- cement-lined piping
  - Manning formula and, 2011 V3: 242
  - pressure classes, 2012 V4: 30
  - roughness, 2010 V2: 75
  - in sprinkler hydraulic calculations, 2011 V3: 13
  - water pipes, 2012 V4: 29
- cement plaster joints, 2012 V4: 29
- center beam clamps, 2012 V4: 128
- Center, J.C., 2010 V2: 29
- centerline spacing of gas outlets, 2011 V3: 51
- Centers for Disease Control and Prevention, 2009 V1: 14, 2010 V2: 108–109
- centersets for faucets, 2012 V4: 10
- centi prefix, 2009 V1: 34
- Centigrade conversion factors, 2009 V1: 37. *See also* Celsius
- centipoise, 2009 V1: 38, 2011 V3: 137
- central heating boilers, 2011 V3: 127
- central manifold gas system configurations, 2010 V2: 122
- central-supply rooms, 2011 V3: 47
- central-water purification equipment, 2010 V2: 223–234
- centralized distillation, 2012 V4: 192
- centralized drinking-water cooler systems
  - chillers, 2012 V4: 221
  - circulating pumps, 2012 V4: 222
  - codes and standard, 2012 V4: 224–225
  - design layout and example, 2012 V4: 223–224
  - fountains, 2012 V4: 222
  - overview, 2012 V4: 222
  - pipes and piping, 2012 V4: 222, 222–223
  - refrigeration, 2012 V4: 222
  - storage tanks, 2012 V4: 222
- centrally-located vacuum cleaning systems. *See* vacuum cleaning systems
- centrifugal air compressors, 2011 V3: 62, 175–176, 176, 177
- centrifugal drum traps, 2011 V3: 46
- centrifugal pumps
  - acid wastes and, 2010 V2: 231
  - defined, 2009 V1: 23
  - end-suction, 2011 V3: 122–123
  - flow, 2012 V4: 94
  - pump pressure and, 2010 V2: 62
  - shallow well discharge, 2010 V2: 162
  - types, 2012 V4: 91
  - vacuum pumps, 2010 V2: 169
- centrifugal separators
  - centrifugal-type vacuum separators, 2010 V2: 178
  - for oil spills, 2010 V2: 246
- centrifugal vacuum cleaning systems, 186, 2010 V2: 184
- centrifugation in FOG separation, 2012 V4: 228
- centrifugation of oil, 2010 V2: 245
- ceramic filters, 2011 V3: 273
- ceramic fixtures
  - standards, 2012 V4: 2
  - types of, 2012 V4: 1
- CERCLA (Comprehensive Environmental Response Compensation and Liability Act), 2011 V3: 82, 83
- certificates of insurance, 2009 V1: 56
- certification
  - certification of performance, 2010 V2: 91
  - LEED program, 2012 V4: 233–234
  - medical gas systems, 74–76, 2011 V3: 69
  - medical gas zones, 2011 V3: 67

- storage tanks, 2011 V3: 152
- Certified Construction Specifier (CCS), 2009 V1: 65
- Certified Plumbing Designer (CPD), 2009 V1: 65
- cesspools
  - defined, 2009 V1: 19
  - irrigation systems and, 2010 V2: 25
- CFCs (chlorofluorocarbons), 2011 V3: 26
- cfh (cubic feet per hour), 2011 V3: 172, 251
- cfm (cubic feet per minute). *See* cubic feet per minute
- CFR (*Code of Federal Regulations*), 2011 V3: 82
- cfus (colony forming units), 2010 V2: 188
- CGA. *See* Compressed Gas Association, Inc.
- cGMP (current good manufacturing practices), 2009 V1: 14, 2010 V2: 224, 227
- CGPM (General Conference of Weights and Measures), 2009 V1: 32, 33
- chain hangers, 2012 V4: 65
- chainwheel-operated valves, 2009 V1: 19
- chalk, 2012 V4: 173
- chambers (air chambers). *See* air chambers (AC)
- Chan, Wen-Yung W., 2009 V1: 39
- change orders, 2009 V1: 57, 254
- changed standpipes, 2009 V1: 13
- changeover gas manifolds, 2011 V3: 270–271
- Changes in LEED 2009 for Plumbing Fixtures and Process Water, 2010 V2: 29
- channel clamps, 2012 V4: 128
- channels, 2009 V1: 19
- character in creativity checklist, 2009 V1: 227
- characteristic curves for pumps, 2012 V4: 95–97
- Characteristics and Safe Handling of Medical Gases (CGA P-2), 2011 V3: 78
- Characteristics of Rural Household Waste Water, 2010 V2: 29
- chases, 2009 V1: 19, 2012 V4: 6, 7, 9, 10
- check valves (CV)
  - compressed-air service, 2012 V4: 84
  - defined, 2009 V1: 19, 2012 V4: 89
  - dry-pipe systems, 2011 V3: 7
  - flow data, 2010 V2: 95
  - high-pressure steam service, 2012 V4: 87
  - high-rise service, 2012 V4: 88
  - hot and cold water supply service, 2012 V4: 84
  - irrigation systems, 2011 V3: 94
  - laboratory gas systems, 2011 V3: 274
  - low-pressure steam systems, 2012 V4: 86
  - medium-pressure steam service, 2012 V4: 86
  - swing check and lift check valves, 2012 V4: 76
  - symbols for, 2009 V1: 9, 14
  - thermal expansion compensation and, 2010 V2: 106
  - types of, 2012 V4: 73
  - vacuum systems, 2010 V2: 179
- checklists and forms
  - creativity worksheets, 2009 V1: 226, 228
  - designs and drawings, 2009 V1: 92–94
  - detail/product/material specification checklist, 2009 V1: 215
  - evaluation checklists, 2009 V1: 230–231
  - field checklists, 2000 V1: 95–96
  - final checklist, 2009 V1: 96
  - forms of agreement, 2009 V1: 56
  - fuel systems, 2011 V3: 154
  - function definitions, 2009 V1: 219–224
  - functional evaluation worksheets, 2009 V1: 236–247
  - general checklists for jobs, 2009 V1: 91–92
  - health care facility medical gas and vacuum systems, 2011 V3: 50
  - idea development and estimated cost forms, 2009 V1: 234
  - idea evaluation worksheet, 2009 V1: 245
  - project information checklists, 2009 V1: 211–216
  - project information sources checklists, 2009 V1: 216
  - recommendations worksheets, 2009 V1: 249, 250
  - storage tanks, 2011 V3: 155–156
  - surveying existing buildings, 2009 V1: 265–266
  - value engineering checklists, 2009 V1: 209
- Chemical and Petroleum Industry, 2009 V1: 14
- chemical cleaning connections, 2011 V3: 48
- chemical coagulants
  - in filtration, 2012 V4: 179
  - functions of, 2012 V4: 175
  - mechanical clarifiers, 2012 V4: 178
- chemical descaling, 2012 V4: 56
- chemical feed pumps, 2011 V3: 129
- chemical feeders, 2012 V4: 161
- chemical fumes, 2012 V4: 117
- chemical oxygen demand (COD), 2012 V4: 200
- chemical plants, 2011 V3: 81
- chemical pre-treatment
  - oils, 2011 V3: 88
  - sand filters, 2012 V4: 180
- chemical reactions, hangers and supports and, 2012 V4: 117
- chemical regeneration in demineralizers, 2011 V3: 48
- chemical-resistance testing, 2012 V4: 1
- chemical spill emergency fixtures, 2012 V4: 17–18
- chemical-waste drains
  - glass pipe, 2012 V4: 35
  - plastic pipes, 2012 V4: 39
- chemical-waste systems
  - air admittance valves, 2010 V2: 39
  - codes and standards, 2010 V2: 242
  - defined, 2009 V1: 19
  - design considerations, 2010 V2: 243
  - pipe and joint selection, 2010 V2: 242–243
- chemically-stabilized emulsions, 2010 V2: 244
- chemicals. *See also* names of specific chemicals
  - air contamination, 2011 V3: 265
  - chemical characteristics of drinking water, 2010 V2: 217
  - chemical control of microbes in water, 2010 V2: 213
  - chemical treatment of oil spills, 2010 V2: 245
  - emulsions, 2011 V3: 88
  - laboratory vacuum systems, 2010 V2: 171
  - material safety data sheets, 2011 V3: 83
  - names and formulas, 2012 V4: 173
  - in septic tanks, 2010 V2: 147
  - in special-waste effluent, 2010 V2: 228
  - swimming pools, 2011 V3: 115, 127–131
  - water softeners, 2012 V4: 173, 174
- chemistry of water, 2010 V2: 187–189
- Chicago
  - city building code, 2010 V2: 108–109
- children, fixtures and
  - fixture heights, 2009 V1: 99
  - in hot water demand classifications, 2010 V2: 99
  - water closets, 2012 V4: 4

- water coolers, 2012 V4: 13
- chilled centralized drinking-water systems, 2012 V4: 221–224
- chilled drinking water recirculating (DWR), 2009 V1: 8
- chilled drinking water supply (DWS), 2009 V1: 8, 2011 V3: 37
- chilled water returns (CWR), 2009 V1: 8
- chilled water supply (CWS), 2009 V1: 8, 191, 2012 V4: 52
- chimney liners, 2009 V1: 43
- chimneys
  - codes, 2009 V1: 43
  - defined, 2010 V2: 135
- china fixtures, 2012 V4: 1. *See also* ceramic fixtures
- chips in acid-neutralization tanks, 2011 V3: 44, 45
- chloramine, 2010 V2: 201, 2012 V4: 177
- chloride (Cl)
  - defined, 2012 V4: 200
  - laboratory grade water, 2012 V4: 198
  - nanofiltration, 2012 V4: 199
  - water hardness and, 2012 V4: 176
- chloride of lime, 2012 V4: 173
- chlorides, 2009 V1: 136, 2010 V2: 189, 190, 206
  - acid-proof steel and, 2012 V4: 56
  - storm water, 2010 V2: 27
- chlorinated isobutene isoprene, 2009 V1: 32
- chlorinated polyethylene, 2009 V1: 32
- chlorinated polyethylene sheet shower pans, 2012 V4: 16
- chlorinated polyvinyl-chloride (CPVC), 2009 V1: 32
  - corrosion, 2009 V1: 141
  - defined, 2010 V2: 94
  - distilled water piping, 2012 V4: 193
  - expansion and contraction, 2012 V4: 208
  - industrial waste usage, 2011 V3: 85
  - pipe characteristics, 2011 V3: 49, 2012 V4: 39, 50
  - pipes, 2010 V2: 190, 2012 V4: 51
  - standards, 2012 V4: 70
  - thermal expansion or contraction, 2012 V4: 207
  - velocity and, 2010 V2: 78
  - VOCs and, 2010 V2: 190
- chlorination
  - automatic chlorinators, 2012 V4: 177
  - defined, 2012 V4: 177, 177–178
  - direct connection hazards, 2012 V4: 161
  - domestic water systems, 2010 V2: 91
  - drinking water, 2010 V2: 160
  - economic concerns, 2012 V4: 178
  - feed water, 2010 V2: 220
  - gray water, 2010 V2: 22
  - manual control chlorinators, 2012 V4: 178
  - wells, 2010 V2: 158
- chlorine
  - as biocides, 2010 V2: 109
  - bleaches, 2010 V2: 147
  - chlorine-resistant grates, 2010 V2: 13
  - cyanide and, 2011 V3: 87
  - formula, 2012 V4: 173
  - hyperchlorination, 2010 V2: 110
  - hypochlorous and hydrochlorous acids, 2012 V4: 177
  - microbial control, 2010 V2: 213
  - pure water systems, 2010 V2: 221
  - reflecting pools and fountains, 2011 V3: 98
  - removing, 2010 V2: 201
  - reverse osmosis and, 2011 V3: 48
  - small drinking water systems, 2010 V2: 218
  - swimming pools, 2011 V3: 127–131
    - in water chemistry, 2010 V2: 189, 190
  - chlorine dioxide gas injection, 2010 V2: 109
  - chlorine dioxide treatment, 2010 V2: 110
  - chlorine sulphonyl polyethylene, 2009 V1: 32
  - chlorofluorocarbons (CFCs), 2011 V3: 26
  - chloroform, 2011 V3: 66
  - chloroprene rubber (Neoprene), 2009 V1: 32
  - Chlorox bleach, 2009 V1: 141
  - cholera, 2012 V4: 177
  - chromium III, 2011 V3: 87
  - chromium-iron, 2009 V1: 132
  - chromium VI, 2011 V3: 87
  - Church, James, 2010 V2: 55
  - churn, defined, 2012 V4: 101
  - CI. *See* cast iron (CI)
  - cigarette burn testing, 2012 V4: 1
  - CIIR (chlorinated isobutene isoprene), 2009 V1: 32
  - CIP (cleaned in place), 2011 V3: 277
  - circles, calculating area, 2009 V1: 5
  - circuit venting, 2009 V1: 19, 2010 V2: 32–33
  - circuits (ckt, CKT), 2009 V1: 19
  - circular concrete piping, 2012 V4: 30
  - circular lavatories, 2012 V4: 9
  - circulating pumps
    - centralized drinking-water coolers, 2012 V4: 222, 224
    - chilled drinking-water systems, 2012 V4: 221
    - controls, 2012 V4: 99–100
    - swimming pools, 2011 V3: 113–116, 122–123
  - circulating water systems
    - in geothermal energy systems, 2009 V1: 123
    - hot water systems, 2010 V2: 105
    - standby losses in, 2009 V1: 119
  - circulation loops (water systems), 2011 V3: 48
  - CISPI (Cast Iron Soil Pipe Institute)
    - abbreviation, 2009 V1: 32
    - Cast Iron Soil Pipe and Fittings Engineering Manual*, 2010 V2: 55
    - hub and spigot soil pipe standards, 2012 V4: 25
    - publications, 2009 V1: 51
  - cisterns, 2009 V1: 19, 2010 V2: 162, 2012 V4: 238
  - citing codes and standards, 2009 V1: 61
  - citric acid, 2009 V1: 136, 141
  - City of Chicago Building Code, 2010 V2: 108–109
  - city rainfall rate table, 2010 V2: 57
  - city water. *See* municipal water supply
  - ckt, CKT (circuits), 2009 V1: 19
  - CL, C/L (critical level), 2009 V1: 20
  - clad steel tanks, 2011 V3: 136, 147, 155
  - Claes, 2009 V1: 144
  - clamp joints, 2012 V4: 26
  - clamping tools, 2012 V4: 57
  - clamps
    - beam clamps, 2012 V4: 120
    - defined, 2012 V4: 128
    - hangers and supports, 2012 V4: 119
    - noise mitigation, 2009 V1: 193
    - pipe clamps, 2012 V4: 120
    - types of, 2012 V4: 64
  - clams, 2010 V2: 188

- clappers, 2011 V3: 8, 2012 V4: 89
- clarification treatments for water, 2010 V2: 198–199, 215, 2012 V4: 178–179
- clarifiers
  - defined, 2012 V4: 200
  - turbidity and, 2012 V4: 175
- clarifying tanks, 2011 V3: 43
- classes, biosolids, 2012 V4: 239
- classes of service, standpipe systems, 2009 V1: 30, 2011 V3: 20
- classifications
  - bedding, 2011 V3: 225–226, 227
  - disabilities, 2009 V1: 99
  - fires, 2011 V3: 2
  - liquid fuel, 2011 V3: 136–137
- claw-type pumps, 2010 V2: 169
- clay loams, 2011 V3: 91, 239
- clay piping
  - industrial discharge piping, 2010 V2: 243
  - noise insulation, 2010 V2: 13–14
  - surface roughness, 2010 V2: 75
  - vitrified clay pipe, 2012 V4: 53, 54
- clay soils, 2010 V2: 25
- clays
  - in feed water, 2010 V2: 195
  - in soil texture, 141, 2010 V2: 140
- Claytor, Richard A., 2010 V2: 55
- Clean Agent Extinguishing Systems (NFPA 2001)*, 2011 V3: 27, 28
- clean agent fire suppression systems, 2011 V3: 26–28
- Clean Air Act Amendments (CAAA), 2011 V3: 137
- clean extinguishing agents, 2011 V3: 26–28
- clean rooms, 2009 V1: 19
- Clean Water Act, 2010 V2: 41, 242, 2011 V3: 82
- cleaned in place (CIP), 2011 V3: 277
- cleaning
  - cold-water systems, 2010 V2: 90–94
  - fixtures, 2012 V4: 1
  - insulation, 2012 V4: 104, 107
  - laboratory gas systems, 2011 V3: 277
  - medical gas pipes, 2011 V3: 69
  - pipes and piping, 2012 V4: 25
  - pure-water systems, 2011 V3: 48
  - radioactive waste piping, 2010 V2: 239
  - section in specifications, 2009 V1: 64, 72
  - septic tanks, 2010 V2: 148
- cleaning liquids, 2012 V4: 117
- cleanout deck plates (codp), 2009 V1: 14
- cleanout plugs (CO), 2009 V1: 11
- cleanouts (CO)
  - chemical-waste systems, 2010 V2: 243
  - cleaning drains, 2010 V2: 15
  - defined, 2009 V1: 14, 19
  - manholes, 2011 V3: 234
  - radioactive waste systems, 2010 V2: 240
  - sanitary drainage systems, 2010 V2: 9–10
  - storm drainage, 2010 V2: 48–49
  - vacuum cleaning systems, 2010 V2: 186
- cleanouts to grade (CO), 2009 V1: 11
- cleanup/utility rooms, 2011 V3: 36
- clear floor space
  - bathtub accessibility, 2009 V1: 109
  - drinking fountains and water coolers, 2009 V1: 104, 2012 V4: 217–218
  - insulation in confined spaces, 2012 V4: 113
  - laundry equipment, 2009 V1: 115
  - lavatories and sinks, 2009 V1: 108
  - urinal design, 2009 V1: 108
  - water closet and toilet accessibility, 2009 V1: 105–108
  - water softeners and, 2012 V4: 188
  - for wheelchairs, 2009 V1: 99–101, 102, 2012 V4: 217–218
- clear space in septic tanks, 2010 V2: 146
- clear-water waste, 2009 V1: 19
- clear water waste branches, 2010 V2: 50
- clearance
  - clean agent gas fire containers, 2011 V3: 27
  - fixtures in health care facilities, 2011 V3: 35
  - piping and, 2012 V4: 25
- clevis devices and clevis hangers
  - defined, 2012 V4: 128
  - functions, 2012 V4: 65
  - illustrated, 2012 V4: 120
  - insulating, 2012 V4: 110
  - insulation for, 2012 V4: 105
  - selecting, 2012 V4: 119
- clevis plates, 2012 V4: 125
- climate. *See* weather conditions
- clinic sinks, 2011 V3: 36
- clinics, 2011 V3: 76
- clips, 2012 V4: 119, 120
- clo, converting to SI units, 2009 V1: 38
- clogging in grease interceptors, 2012 V4: 154, 155, 158
- close-coupled water closets, 2012 V4: 3
- close nipples, 2009 V1: 19
- closed-circuit cooling systems, 2009 V1: 140
- closed proprietary specifications, 2009 V1: 62
- closed solar systems, 2011 V3: 192
- closed systems, dangerous pressures in, 2012 V4: 209
- closed-type sprinklers, 2011 V3: 6
- cloth lagging, 2012 V4: 109
- clothes washers. *See* laundry systems and washers
- clubs, hot water demand, 2010 V2: 99
- CMC (carboxymethyl cellulose), 2009 V1: 32
- CMPR (compressors). *See* compressors
- CN (cellulose nitrate), 2009 V1: 32
- condct, CNDCT (conductivity), 2009 V1: 34
- CO (cleanout plugs), 2009 V1: 11
- CO (yard cleanouts or cleanouts to grade). *See* cleanouts; cleanouts to grade
- CO<sub>2</sub> (carbon dioxide). *See* carbon dioxide
- coagulation
  - coagulants in clarification, 2010 V2: 198–199, 2012 V4: 178, 200
  - in filtration, 2012 V4: 179
  - flow rates and, 2012 V4: 179
  - FOG separation, 2012 V4: 228
  - in gray-water treatment, 2010 V2: 25–26
  - turbidity and, 2012 V4: 175
- coal tar epoxy, 2011 V3: 139
- coalescence
  - bioremediation pretreatment systems, 2012 V4: 230
  - coalescing, defined, 2009 V1: 19, 2012 V4: 200
  - filtration of oil spills, 2010 V2: 245
  - FOG separation, 2012 V4: 228

- coalescing filters in vacuum systems, 2010 V2: 171
- coalescing media, 2011 V3: 88
- coarse sands, 2010 V2: 25, 2011 V3: 91
- coarse vacuum, 2010 V2: 165
- coat hooks
  - accessibility in toilet and bathing rooms, 2009 V1: 105
  - ambulatory accessible toilet compartments, 2009 V1: 107
- coated metal
  - cathodic protection, 2009 V1: 140
  - corrosion protection, 2009 V1: 136–137
  - passivation, 2009 V1: 136
  - sprinkler head ratings, 2011 V3: 13
  - storage tanks, 2011 V3: 155
- coaxial fill hoses (tanks), 2011 V3: 140
- coaxial vapor recovery, 2011 V3: 145, 148
- cocks, 2009 V1: 19
- COD (chemical oxygen demand), 2012 V4: 200
- Code for Motor Fuel Dispensing Facilities and Repair Garages (NFPA 30A)*, 2011 V3: 137, 156
- Code of Federal Regulations (CFR)*, 2010 V2: 218, 2011 V3: 82, 89, 137
  - PVDF standard, 2012 V4: 70
- codes and standards
  - alterations to existing buildings, 2009 V1: 266
  - bioremediation pretreatment systems, 2012 V4: 229–230
  - building sound isolation, 2009 V1: 188
  - centralized drinking-water cooler systems, 2012 V4: 224–225
  - chemical-waste systems, 2010 V2: 242
  - citing, 2009 V1: 61
  - codes, defined, 2009 V1: 19
  - cold water systems, 2010 V2: 59
  - compressed air systems, 2011 V3: 171
  - cross-connections, 2012 V4: 169
  - domestic water supply, 2011 V3: 206
  - fire protection, 2011 V3: 1, 218
  - fixtures, 2012 V4: 2
  - fountains, 2011 V3: 100–101
  - gasoline and diesel-oil systems, 2011 V3: 137
  - gray-water systems, 2010 V2: 22
  - grease interceptors, 2012 V4: 154, 156–157
  - health care facilities, 2011 V3: 33, 35
  - hot-water systems, 2010 V2: 112
  - industrial wastewater treatment, 2011 V3: 82–83
  - infectious and biological waste systems, 2010 V2: 241
  - laboratory gas systems, 2011 V3: 263
  - medical gas systems, 2011 V3: 76
  - natural gas services, 2011 V3: 251
  - natural gas systems, 2010 V2: 115
  - NFPA standards, 2011 V3: 1
  - plumbing codes, defined, 2012 V4: 170
  - plumbing materials and equipment, 2009 V1: 41–54
  - plumbing standards for people with disabilities, 2009 V1: 97–98
  - pools, 2011 V3: 100–101
  - preventing Legionella growth, 2010 V2: 108–109
  - private water systems, 2010 V2: 155
  - reference-based standards, 2009 V1: 61
  - reflecting pools, 2011 V3: 100–101
  - sanitary drainage systems, 2010 V2: 1
  - seismic protection, 2009 V1: 147, 155, 161, 174
  - site utilities, 2011 V3: 205
  - special-waste drainage systems, 2010 V2: 227
  - standards, defined, 2009 V1: 29
  - storm-drainage systems, 2010 V2: 41–42
  - storm sewers, 2011 V3: 238
  - sustainable design, 2012 V4: 233–234
  - swimming pools, 2011 V3: 104–106
  - vacuum-cleaning systems, 2010 V2: 178
  - vacuum systems, 2010 V2: 172
  - valves, 2012 V4: 73
  - water analysis, treatment and purification, 219, 2010 V2: 187, 218
    - water heaters, 2009 V1: 121, 155
- codp (cleanout deck plates), 2009 V1: 14
- coefficient, runoff, 2010 V2: 43
- coefficients of expansion (CE), 2009 V1: 19, 2012 V4: 67, 207, 211
- coefficients of hydrant discharge, 2011 V3: 3–4
- coefficients of permeability (K factor), 2010 V2: 158
- coefficients of volumetric expansion, 2012 V4: 211
- coffee sinks. *See* sinks and wash basins
- coffee urns, 2012 V4: 161
- cogeneration systems, waste heat usage, 2009 V1: 123
- coherent unit systems, 2009 V1: 33
- coke oven gas, 2010 V2: 114
- cold elevation, 2012 V4: 128. *See also* after cold pull elevation; design elevations
- cold flow, 2009 V1: 19
- cold fluids
  - hangers and supports for systems, 2012 V4: 119
  - pipng for, 2012 V4: 118
- cold hanger location, 2012 V4: 128
- cold loads, 2012 V4: 129
- cold settings, 2012 V4: 129
- cold shoes, 2012 V4: 129
- cold spring, 2012 V4: 129
- cold water (CW), 2009 V1: 8, 14
- cold-water systems
  - backflow prevention, 2010 V2: 60
  - booster pump systems, 2010 V2: 61–68
  - chilled drinking-water systems, 2012 V4: 222
  - codes and standards, 2010 V2: 59
  - constant pressure in, 2010 V2: 63
  - cross connection controls, 2010 V2: 60–61
  - domestic water meters, 2010 V2: 59–60
  - examples for pipe sizing, 2010 V2: 87–89
  - excess water pressure, 2010 V2: 68–70
  - glossaries, 2010 V2: 94–95
  - heat loss, 2012 V4: 110
  - introduction, 2010 V2: 59
  - noise mitigation, 2009 V1: 191
  - pipe codes, 2009 V1: 45
  - pipe sizing, 2010 V2: 75–84
  - potable water systems, 2011 V3: 47
  - references, 2010 V2: 95–96
  - sizing, 2010 V2: 84–89
  - testing, cleaning, and disinfection, 2010 V2: 90–94
  - valves for, 2012 V4: 83–84
  - water flow tests, 2010 V2: 84–87
  - water hammer, 2010 V2: 70–73
  - water line sizing, 2010 V2: 73–90
  - water pressure, 2012 V4: 83
  - water supply graph, 2011 V3: 212

- cold working pressure (CWP), 2012 V4: 83
- Colebrook formula, 2010 V2: 74–75
- coliform, 2009 V1: 19
- coliform group of bacteria, 2009 V1: 19
- coliform organism tests, 2010 V2: 91
- collective bargaining agreements, cost estimates and, 2009 V1: 90
- collectors (dug wells), 2010 V2: 156
- collectors (solar)
- concentrating, 2011 V3: 190, 193
  - cover, defined, 2011 V3: 191
  - defined, 2011 V3: 190
  - efficiency, defined, 2011 V3: 191
  - evacuated tube (vacuum tube), 2011 V3: 190
  - flat-plate, 2011 V3: 190, 193–195
  - subsystem, defined, 2011 V3: 191
  - tilt, defined, 2011 V3: 191
  - transpired, defined, 2011 V3: 190
  - trickle, defined, 2011 V3: 191
  - vacuum tube, 2011 V3: 190, 193
- College of American Pathologists (CAP), 2010 V2: 187, 219, 2012 V4: 197, 200
- Collentro, W.V., 2010 V2: 224
- colloidal particles
- laboratory grade water, 2012 V4: 198
  - removing, 2010 V2: 198–199, 2011 V3: 88
- colloidal silica, 2010 V2: 190
- colony forming units (cfus), 2010 V2: 188
- color
- of drinking water, 2010 V2: 217
  - of feed water, 2010 V2: 188, 193
  - of gray water, 2010 V2: 27
  - of soils, 141, 2010 V2: 140
- color codes
- copper drainage tube, 2012 V4: 30
  - copper pipes, 2012 V4: 32
  - medical gas codes, 2011 V3: 51, 55
  - medical gas tube, 2012 V4: 34
  - seamless copper water tube, 2012 V4: 29
- colored finishes, 2012 V4: 129
- columns in ion exchange systems, 2010 V2: 205
- combination building water supplies, 2011 V3: 218–220
- combination drain and vent, 2010 V2: 33
- combination dry-pipe and pre-action systems, 2009 V1: 28, 2011 V3: 10–11
- combination fixtures, 2009 V1: 19
- combination storm-drainage and sanitary sewers, 2010 V2: 12, 2011 V3: 249
- combination temperature and pressure relief valves, 2010 V2: 106
- combination thermostatic and pressure balancing valves, 2012 V4: 16
- combination vacuum-cleaning systems, 2010 V2: 178
- combination waste and vent systems, 2009 V1: 19
- combined residuals, 2012 V4: 177
- combustibles
- defined, 2011 V3: 76, 136
  - fire loads, 2011 V3: 2
  - metal fires, 2011 V3: 24
- combustion efficiency, 2009 V1: 19
- combustion products, 2011 V3: 76
- combustion properties of gases, 2010 V2: 114
- The Coming Plague*, 2010 V2: 49, 55
- Commercial Energy Conservation Manual*, 2009 V1: 128
- commercial facilities
- commercial/industrial gas service, 2011 V3: 252
  - estimating sewage quantities, 2010 V2: 150–152
  - firefighting demand flow rates, 2011 V3: 224
  - gray-water systems, 2010 V2: 23–24
  - grease interceptors, 2010 V2: 12
  - oil interceptors in drains, 2010 V2: 12
  - radioactive waste drainage and vents, 2010 V2: 235
- commercial kitchen sinks, 2012 V4: 11–12
- commercial land use, runoff, 2010 V2: 42
- commercial laundries. *See* laundry systems and washers
- commercial piping systems, 2012 V4: 129
- commercial service gas, 2010 V2: 114
- commercial sites, runoff volume calculation, 2010 V2: 56
- Commercial Standards (CS), 2009 V1: 32
- Commercial Water Use Research Project*, 2010 V2: 29
- commissioning section in specifications, 2009 V1: 64–65, 72
- Commodity Specification for Air (CGA G-7.1/ANSI ZE 86.1)*, 2011 V3: 61, 76, 78
- Commodity Specification for Nitrogen (CGA G-10.1)*, 2011 V3: 78
- commodity standards, gases, 2011 V3: 263
- common vents (dual vents), 2010 V2: 32–33
- defined, 2009 V1: 19
- community bathhouses, 2010 V2: 151
- compacted fill, building sewers and, 2010 V2: 14
- comparing functions in value engineering, 2009 V1: 235
- compartment coolers, 2012 V4: 216, 220
- compartmentalization in bioremediation systems, 2012 V4: 228, 230
- compartments in septic tanks, 2010 V2: 147
- competition swimming pools, 2011 V3: 107
- components
- defined, 2012 V4: 129
  - section in specifications, 2009 V1: 71
- composite land use, runoff, 2010 V2: 42
- composite tanks, 2011 V3: 138–139
- composition disc valves
- angle valves, 2012 V4: 75
  - globe valves, 2012 V4: 74
- composting biosolids, 2012 V4: 239, 240
- composting toilets, 2009 V1: 127
- compound magnetic drive meters, 2010 V2: 88
- Compound Parabolic Concentrator (CPC) system, 2011 V3: 196
- compound water meters, 2010 V2: 59–60, 59–61
- compounds in water, 2010 V2: 189
- Comprehensive Environmental Response Compensation and Liability Act (CERCLA), 2011 V3: 82, 83
- compressed air (A, CA, X#, X#A). *See also* compressed air systems
- compared to free air, 2011 V3: 171
  - defined, 2011 V3: 183
  - flow rates, 2011 V3: 172
  - generating, 2011 V3: 270
  - joints, 2011 V3: 176
  - laboratory or medical compressed air, 2009 V1: 8, 2011 V3: 41, 61–64, 70, 75–76
  - overview, 2011 V3: 171–172
  - supplies to water tanks, 2010 V2: 162



- symbols for, 2009 V1: 8, 16
- tools and equipment, 2011 V3: 180
- use factors, 2011 V3: 174
- uses, 2011 V3: 171
- water vapor in, 2011 V3: 172–173, 265–266
- Compressed Air and Gas Data*, 2010 V2: 136
- Compressed Air for Human Respiration (CGA G-7.0)*, 2011 V3: 78
- compressed air systems
  - accessories, 2011 V3: 177–182
  - air dryers, 2011 V3: 178–179
  - air receivers, 2011 V3: 177–178
  - alarms, 2011 V3: 182
  - codes and standards, 2011 V3: 171
  - compressors, 2011 V3: 174–176
  - contaminants, 2011 V3: 173–174
  - definitions, 2011 V3: 183–187
  - flow meters, 2011 V3: 177
  - flushing and testing, 2011 V3: 183
  - friction loss table, 2011 V3: 181
  - glossary, 2011 V3: 183–187
  - gravity filters, 2012 V4: 180
  - hoses and fittings, 2011 V3: 181–182
  - inlet piping, 2011 V3: 182
  - measurement units, 2011 V3: 172
  - overview, 2011 V3: 171
  - piping system design
    - air-consuming devices, 2011 V3: 182–183
    - air dryers, 2011 V3: 178–179
    - design sequence, 2011 V3: 182–183
    - duty cycles, 2011 V3: 182
    - earthquake bracing, 2009 V1: 158
    - future expansion, 2011 V3: 182
    - leakage, 2011 V3: 183
    - materials, 2011 V3: 176
    - sizing piping, 2011 V3: 69, 72–73, 183
    - use factors, 2011 V3: 183
  - pressure drops, 2011 V3: 177, 181
  - regulation methods, 2011 V3: 179–180
  - relief valves, 2011 V3: 180–181
  - tool requirements, 2011 V3: 180
  - tools and equipment, 2011 V3: 180
  - valves, 2011 V3: 176, 2012 V4: 84
  - vibration isolation, 2011 V3: 182
  - water vapor in air, 2011 V3: 172–173
- compressed cork, 2012 V4: 139
- compressed gas. *See* natural gas systems
- Compressed Gas Association, Inc. (CGA), 2009 V1: 14
  - color coding system, 2011 V3: 55
  - list of standards, 2009 V1: 52
  - publications (discussed)
    - purity standards, 2011 V3: 263
  - publications (listed)
    - CGA C-9: Standard for Color-marking of Compressed Gas Cylinders Intended for Medical Use*, 2011 V3: 78
    - CGA G-7.0: Compressed Air for Human Respiration*, 2011 V3: 78
    - CGA G-7.1/ANSI ZE 86.1: Commodity Specification for Air*, 2011 V3: 76, 78
    - CGA G-8.1: Standard for the Installation of Nitrous Oxide Systems at Consumer Sites*, 2011 V3: 78
  - CGA G-10.1: Commodity Specification for Nitrogen*, 2011 V3: 78
  - CGA P-2: Characteristics and Safe Handling of Medical Gases*, 2011 V3: 78
  - CGA P-9: Inert Gases: Argon, Nitrogen and Helium*, 2011 V3: 74, 78
  - CGA V-5: Diameter-Index Safety System*, 2011 V3: 76, 78
  - web site, 2011 V3: 78
- Compressed Gases and Cryogenic Fluids Code (NFPA 55)*, 2011 V3: 263
- compressibility, 2011 V3: 183
- compressibility factor (Z), 2011 V3: 183
- compression couplings
  - clay pipe, 2012 V4: 53
  - flexible couplings, 2012 V4: 63
  - glass pipe, 2012 V4: 36
  - mechanical joints, 2012 V4: 57
- compression efficiency, 2011 V3: 183
- compression fittings
  - cast iron, 2012 V4: 26
  - defined, 2009 V1: 23
- compression ratio, 2011 V3: 183–184
- compressive strength of plastic pipe, 2012 V4: 50
- compressive stresses
  - piping, 2012 V4: 67
  - stacks, 2012 V4: 207–208
  - with temperature change, 2012 V4: 206
- compressors (cprsr, CMPR)
  - centralized drinking-water systems, 2012 V4: 221
  - defined, 2009 V1: 19
  - earthquake protection, 2009 V1: 157
  - vibration and noise problems, 2012 V4: 138
  - water coolers, 2012 V4: 219
- computer-controlled grease interceptors, 2012 V4: 151–152
- computer processing of specifications, 2009 V1: 65
- computer programs
  - 3E Plus, 2009 V1: 118
  - abbreviations in, 2009 V1: 14–15
  - computer analysis of piping systems, 2009 V1: 180
  - plumbing cost estimation, 2009 V1: 85, 89
  - specifications programs, 2009 V1: 65
- computer room waste heat usage, 2009 V1: 123
- computerization of specifications programs, 2009 V1: 65
- concealed piping, 2011 V3: 68
- concealed sprinklers, 2009 V1: 29
- concentrates, cross flow filtration and, 2012 V4: 200
- concentrating collectors, 2011 V3: 190, 193, 195–196
- concentrating ratio, defined, 2011 V3: 191
- concentration cells
  - attack corrosion, 2009 V1: 129, 131–132
  - defined, 2009 V1: 142
- concentration gradients, 2010 V2: 211
- concentration polarization, 2009 V1: 142, 2012 V4: 196
- concentration, rainfall, 2010 V2: 44–46
- concentration tests, 2011 V3: 75
- concentrators, defined, 2011 V3: 191
- concentric reducers, 2009 V1: 10
- concrete
  - anchoring to, 2012 V4: 123
  - bioremediation pretreatment systems, 2012 V4: 230

- noise mitigation and, 2009 V1: 201
- concrete aggregates, 2012 V4: 230
- concrete anchors
  - anchoring pipes to, 2012 V4: 123
  - concrete block anchors, 2012 V4: 59–60
  - floor-mounted equipment, 2009 V1: 154
  - problems in seismic protection, 2009 V1: 182
- concrete ballast pads, 2011 V3: 155
- concrete barriers around tanks, 2011 V3: 149
- concrete block anchors, 2012 V4: 59–60
- concrete embedments, 2009 V1: 184
- concrete fasteners, 2012 V4: 129
- concrete floors, leveling around, 2010 V2: 16
- concrete grease interceptors, field-formed, 2012 V4: 153
- concrete gutters, 2011 V3: 114
- concrete insert boxes, 2012 V4: 129
- concrete inserts, 2012 V4: 120, 124, 125, 129
- concrete pavement, runoff, 2010 V2: 42
- Concrete Pipe Handbook*, 2010 V2: 54
- concrete piping
  - circular, 2012 V4: 30
  - flow rate, 2011 V3: 242
  - noise insulation, 2010 V2: 13–14
  - roughness, 2010 V2: 78
  - standards, 2012 V4: 68
  - surface roughness, 2010 V2: 75
  - underground piping, 2012 V4: 29
- concrete restraints, 2011 V3: 221
- concrete shielding from radiation, 2010 V2: 238
- concrete slab hangers, 2012 V4: 65
- concrete-tank saddles, 2009 V1: 154
- concrete tanks, 2011 V3: 84, 147–148
- concurrent regeneration, 2012 V4: 200
- cond, COND (condensers, condensation). *See*
  - condensation; condensers
- condensate drains (CD), 2009 V1: 8
  - as source of plumbing noise, 2009 V1: 188
  - poor examples of, 2009 V1: 255, 257
- condensate traps
  - air-handling units, 2011 V3: 167
  - shell and tube heat exchangers, 2011 V3: 167
  - space-heating equipment, 2011 V3: 166–167
  - unit heaters, 2011 V3: 167
- condensates. *See also* steam and condensate systems
  - as feed water for distillation, 2012 V4: 194
  - corrosion inhibitors, 2009 V1: 141
  - defined, 2009 V1: 19, 2010 V2: 135, 2011 V3: 157–159
  - drainage, 2011 V3: 163–166
  - high-pressure piping, 2011 V3: 166
  - removal, 2011 V3: 161–162
- condensation (cond, COND)
  - air drying, 2011 V3: 178
  - corrosion and, 2009 V1: 136
  - dew points, 2011 V3: 173
  - earthquakes and, 2009 V1: 160
  - formation of, 2012 V4: 109, 110–112
  - insulation and, 2009 V1: 118, 2012 V4: 103
  - protecting against, 2010 V2: 16
  - regional requirements for plumbing installations, 2009 V1: 262
  - swimming pools, 2011 V3: 108
  - vacuum piping, 2010 V2: 174
- condensed steam
  - condensate removal, 2011 V3: 161–162
  - defined, 2011 V3: 157–159
- condensers
  - centralized drinking-water systems, 2012 V4: 221
  - condenser system water treatments, 2010 V2: 216
  - distilled water systems, 2011 V3: 48
  - noise mitigation, 2009 V1: 191
  - scale deposits, 2010 V2: 195
  - waste heat reclamation, 2009 V1: 124, 125
- condensing gas water heaters, 2009 V1: 121
- conditioning compressed air, 2011 V3: 178
- conditioning water. *See* water treatment
- conditions in creativity checklist, 2009 V1: 227
- conditions of existing buildings, 2009 V1: 267–270
- conductance (C), 2012 V4: 103
- conductance (S), 2009 V1: 34
- conduction, defined, 2011 V3: 191
- conductivity (cndct, CNDCT, K). *See also* thermal
  - conductivity (k, K)
  - defined, 2009 V1: 20, 2012 V4: 103, 200
  - hangers and supports and, 2012 V4: 117–118
  - insulation, 2012 V4: 103
  - laboratory grade water, 2012 V4: 197
  - measurements, 2009 V1: 34
  - mho (specific conductivity), 2010 V2: 193
- conductivity cells, 2012 V4: 183, 193
- conductivity/resistivity meters, 2012 V4: 183, 191, 196
- conductors, 2009 V1: 20
- conduits
  - defined, 2009 V1: 20
  - seismic protection, 2009 V1: 145
- cones
  - calculating volume, 2009 V1: 4
  - of depression, 2010 V2: 157
- Conference Generale de Poids et Mesures, 2009 V1: 33
- confluent vents, 2009 V1: 20
- connected loads, 2009 V1: 20, 2010 V2: 136
- connected standbys, 2011 V3: 27
- connection strainers, 2011 V3: 124
- connections section in specifications, 2009 V1: 72
- connectors, flexible gas hose, 2010 V2: 124–125
- Connectors for Gas Appliances*, 2010 V2: 124
- Connectors for Movable Gas Appliances*, 2010 V2: 124
- conserving energy. *See also* green building and plumbing
  - alternate energy sources, 2009 V1: 121–126
  - Bernoulli's equation, 2009 V1: 5–6
  - domestic water temperatures, 2009 V1: 117–120
  - glossary, 2009 V1: 128
  - hot water system improvements, 2009 V1: 118
  - insulation thickness and, 2012 V4: 106, 107, 110
  - introduction, 2009 V1: 117
  - off-peak power, 2009 V1: 119
  - reduced water flow rates, 2009 V1: 118
  - references, 2009 V1: 128
  - saving utility costs, 2009 V1: 119
  - standby losses in circulating systems, 2009 V1: 119
  - thermal insulation thickness, 2009 V1: 118
  - waste heat usage, 2009 V1: 123–126
- conserving water. *See also* green building and plumbing
  - design techniques, 2009 V1: 126
  - domestic water supply, 2011 V3: 46

- institutional wastewater systems, 2010 V2: 149
- introduction, 2009 V1: 117
- rain shutoff devices, 2011 V3: 96
- urinals, 2012 V4: 8
  - water closet fixtures, 2012 V4: 2
- constant-pressure pumps, 2010 V2: 63
- constant support hangers and indicators, 2012 V4: 129
- constant velocity method, 2010 V2: 87, 94
- Constructed Science Research Foundation Spectext, 2009 V1: 65
- construction change directives, 2009 V1: 57
- construction contract documents (CD)
  - checklists for existing buildings, 2009 V1: 270
  - contract documents defined, 2009 V1: 55
  - defined, 2009 V1: 20, 55
  - overview, 2009 V1: 55
  - project manuals, 2009 V1: 56–57
  - value engineering clauses in, 2009 V1: 251
- construction costs in value engineering, 2009 V1: 207–208
- Construction Specifications Canada (CSC) Unifomat, 2009 V1: 57–58
- Construction Specifications Institute (CSI)
  - classes, 2009 V1: 65
  - Constructed Science Research Foundation, 2009 V1: 65
  - general conditions documents, 2009 V1: 56
  - Manual of Practice*, 2009 V1: 55
  - MasterFormat, 2009 V1: 57
  - MasterFormat 2004, 2009 V1: 58–59, 72–83
  - MasterFormat Level Four (1995), 2009 V1: 68–69
  - MasterFormat Level One (1995), 2009 V1: 66
  - MasterFormat Level Three (1995), 2009 V1: 68
  - MasterFormat Level Two (1995), 2009 V1: 66–68
  - section shell outline, 2009 V1: 68–72
  - Sectionformat, 2009 V1: 59
  - solar energy specifications, 2011 V3: 199
  - Unifomat, 2009 V1: 57–58, 64–65
  - web site, 2009 V1: 58
- Consumer Product Safety Commission (CPSC), 2011 V3: 106, 112
- consumption. *See* demand
- contact corrosion, defined, 2009 V1: 142
- contact sheets, 2011 V3: 205
- contact time for microbial control, 2010 V2: 213
- containment
  - biological wastes, 2010 V2: 240
  - defined, 2012 V4: 169
  - gas piping, 2010 V2: 135
- Containment Control in Biotechnology Environments*, 2010 V2: 246
- containment floors or dikes, 2011 V3: 84
- containment sumps, 2011 V3: 139, 145, 148
- contaminants
  - concentration, storm water, 2010 V2: 27
  - defined, 2012 V4: 169
  - removing from gas, 2011 V3: 273
  - urban storm water, 2010 V2: 43–44
- contamination issues
  - backflow prevention, 2010 V2: 60
  - bored wells, 2010 V2: 157
  - compressed air, 2011 V3: 173–174
  - contaminant classification, 2011 V3: 215
  - contaminators, defined, 2009 V1: 20
    - dug wells, 2010 V2: 156
    - gray-water irrigation systems and, 2010 V2: 27–28
    - well protection, 2010 V2: 158–159
- contingency
  - plans for industrial wastes, 2011 V3: 83
  - in plumbing cost estimation, 2009 V1: 86
- continuing education, 2009 V1: 65
- continuous acid-waste treatment systems, 2010 V2: 236
- continuous deionization (CDI), 2010 V2: 209–210
- continuous duty pumps, 2011 V3: 22
- continuous flow. *See* steady flow
- continuous inserts, 2012 V4: 129
- continuous vents, defined, 2009 V1: 20
- continuous waste, 2009 V1: 20
- continuous wastewater treatment, 2011 V3: 87
- continuous welding technique, 2012 V4: 37
- contract documents. *See* construction contract documents
- contraction of materials, 2009 V1: 189, 2012 V4: 208
- contraction of pipes
  - aboveground piping, 2012 V4: 207–208
  - anchors, 2012 V4: 62
  - calculating, 2009 V1: 3
  - hangers and supports, 2012 V4: 116
  - noise mitigation, 2009 V1: 189
  - overview, 2012 V4: 67
  - protecting against, 2010 V2: 16
  - underground piping, 2012 V4: 208–209
- contractors
  - makeshift installations, 2009 V1: 254–257
  - quality requirements and, 2009 V1: 262
- Control of Pipeline Corrosion*, 2009 V1: 144
- control panels
  - clean gas systems, 2011 V3: 28
  - fire alarm, 2009 V1: 12
  - vacuum systems, 2010 V2: 171
- control systems in geothermal energy systems, 2009 V1: 123
- control valves
  - defined, 2012 V4: 200
  - medical gas systems, 2011 V3: 66–67
- controlled-flow storm-drainage systems, 2010 V2: 52–53
- controlled-substance spills, 2010 V2: 186
- controllers
  - chemical, 2011 V3: 127–131
  - defined, 2009 V1: 20
  - differential-pressure, 2011 V3: 132
  - for irrigation systems, 2011 V3: 95–96
- controls
  - in accessible shower compartments, 2009 V1: 112
  - in bathtubs, 2009 V1: 109
  - defined, 2009 V1: 20
  - on gas boosters, 2010 V2: 125
  - on water heaters, 2010 V2: 104–105
  - for pumps, 2012 V4: 99–100
  - for vacuum systems, 2010 V2: 171, 179, 2011 V3: 64
  - water level, fountains, 2011 V3: 102
- convection, 2011 V3: 191, 2012 V4: 103
- conventional angle valves, 2012 V4: 75
- conventional ball valves, 2012 V4: 75
- conventional disc globe valves, 2012 V4: 74
- converging seismic plates, 2009 V1: 148
- conversion factors and converting
  - Fahrenheit and Centigrade, 2009 V1: 37

- feet of head to pounds per square inch, 2009 V1: 2
- gas pressure to destinations, 2010 V2: 127, 130
- IP and SI, 2009 V1: 38–39, 2010 V2: 170, 2011 V3: 30
- measurements, 2009 V1: 33
- meters of head to pressure in kilopascals, 2009 V1: 2
- parts per million to grains per gallon, 2012 V4: 201
- vacuum acfm and scfm, 2010 V2: 166–167
- vacuum pressures, 2010 V2: 166
- water impurity measurements, 2010 V2: 191
- conveyance, storm water, 2010 V2: 46–47
- cooling compressors, 2011 V3: 174
- cooling fire areas, 2011 V3: 25
- cooling grease, 2012 V4: 154
- cooling loads (clg load, CLG LOAD, CLOAD), 2012 V4: 222
- cooling systems
  - direct connection hazards, 2012 V4: 161
  - solar, 2011 V3: 191
- cooling tower process wastewater, 2012 V4: 175
- cooling-tower water
  - corrosion inhibitors, 2009 V1: 140
  - exclusion from gray-water systems, 2010 V2: 21
  - Legionella pneumophila, 2010 V2: 108
  - monitoring, 2012 V4: 175
  - submerged inlet hazards, 2012 V4: 161
  - use of gray water in, 2010 V2: 21
  - waste heat usage, 2009 V1: 123
  - water treatments, 2010 V2: 216–217
- cooling vacuum pumps, 2010 V2: 171
- coordination disabilities, 2009 V1: 99
- coordination with other designers, 2010 V2: 50, 54
- COP (coefficient of performance), 2009 V1: 128
- copper
  - coefficient of linear expansion, 2012 V4: 211
  - corrosion, 2009 V1: 129
  - in electromotive series, 2009 V1: 132
  - in galvanic series, 2009 V1: 132
  - storm water, 2010 V2: 27
  - stress and strain figures, 2012 V4: 206
  - thermal expansion or contraction, 2012 V4: 207
- copper alloy piping, 2010 V2: 12–13
- copper-copper sulfite half-cells, 2009 V1: 132
- Copper Development Association, 2010 V2: 96
- Copper Development Association (CDA), 2009 V1: 32
- Copper Tube Handbook*, 2012 V4: 58, 59
- copper drainage tube, 2012 V4: 33–34, 40
- copper-nickel alloys, 2009 V1: 132
- copper-phosphorous-silver brazing (BCuP), 2012 V4: 34
- copper-phosphorus brazing, 2012 V4: 34
- copper piping
  - aboveground piping, 2010 V2: 12
  - bending, 2012 V4: 61
  - conserving energy, 2009 V1: 120
  - copper K piping, 2010 V2: 173
  - copper L piping, 2010 V2: 173
  - hangers and supports, 2012 V4: 65
  - laboratory gas systems, 2011 V3: 276
  - Legionella control and, 2010 V2: 111
  - mechanical joints, 2012 V4: 58–59
  - natural gas systems, 2010 V2: 122
  - pure-water system, 2011 V3: 49
  - radioactive waste systems, 2010 V2: 239
  - roughness, 2010 V2: 75
  - sprinkler systems, 2011 V3: 13
  - standards, 2012 V4: 68–69
  - tape wrapping, 2012 V4: 66
  - types, 2012 V4: 29–40, 32
  - velocity and, 2010 V2: 78
- copper plating, 2012 V4: 129
- copper-silver ionization, 2010 V2: 110, 111, 2012 V4: 199
- copper-sulfate electrodes, 2009 V1: 140
- Copper Tube Handbook*, 2012 V4: 58, 59
- copper tube size (CTS), 2012 V4: 42
- copper tubing, 2010 V2: 122, 2011 V3: 276
- copper water tube, 2012 V4: 29–40, 58, 122
- Copson, H.R., 2009 V1: 144
- cork
  - elastomer-cork mountings, 2012 V4: 142
  - speed and vibration control, 2012 V4: 138, 139
- corona-discharge generators, 2010 V2: 214
- corona-discharge ozone system, 2011 V3: 133
- corporation cocks, 2009 V1: 20
- corroded end of galvanic series, 2009 V1: 132
- corrosion
  - boilers, 2010 V2: 215
  - calcium carbonate and, 2010 V2: 196
  - cathodic protection, 2009 V1: 137–140
  - causes, 2010 V2: 195–196
  - coatings, 2009 V1: 136–137
  - control of, 2009 V1: 135–141, 2010 V2: 16, 160
  - cooling towers, 2010 V2: 217
  - corrosion cells, 2009 V1: 129, 130, 137
  - corrosion mitigation, 2009 V1: 142
  - corrosion potential, 2009 V1: 142
  - corrosion-resistant materials, 2009 V1: 135, 2010 V2: 14
  - corrosion-resistant sprinklers, 2009 V1: 29
  - corrosive wastes, 2010 V2: 13
  - deaeration and, 2010 V2: 199
  - defined, 2009 V1: 129, 142, 2012 V4: 129, 200
  - electromotive force series, 2009 V1: 134
  - factors in rate of, 2009 V1: 134–135
  - fatigue and fatigue limits, 2009 V1: 142
  - glossary, 2009 V1: 141–143
  - hot-water relief valves, 2010 V2: 106
  - impure water and, 2012 V4: 174
  - inhibitors, 2009 V1: 141
  - insulation and, 2012 V4: 107
  - introduction, 2009 V1: 129
  - oxygen and carbon dioxide, 2012 V4: 176
  - passivation, 2009 V1: 136
  - plastic, 2009 V1: 141
  - plastic water pipes, 2010 V2: 164
  - predicting water deposits and corrosion, 2010 V2: 196–197
  - prevention, 2009 V1: 142
  - protection, 2011 V3: 148
  - references, 2009 V1: 144
  - sacrificial anodes, 2009 V1: 137
  - specifications to prevent, 2009 V1: 256–258
  - storage tanks, 2011 V3: 84, 138, 148
  - total organic carbon and, 2010 V2: 193
  - types of, 2009 V1: 129–132
  - water mains, 2011 V3: 6
- Corrosion*, 2009 V1: 144
- Corrosion and Resistance of Metals and Alloys*, 2009 V1: 144

- Corrosion Causes and Prevention*, 2009 V1: 144
- Corrosion Control*, 2009 V1: 144
- Corrosion Engineering*, 2009 V1: 144
- corrosion fatigue, 2009 V1: 142
- Corrosion Handbook*, 2009 V1: 144
- corrosion mitigation, 2009 V1: 142
- corrosion potential, 2009 V1: 142
- corrosion prevention, 2009 V1: 142
- Corrosion Prevention for Practicing Engineers*, 2009 V1: 144
- corrosion-resistant materials, 2009 V1: 135, 2010 V2: 14
- Corrosion Resistant Materials Handbook*, 2011 V3: 89
- corrosion-resistant sprinklers, 2009 V1: 29
- corrosive atmospheres, insulation and, 2012 V4: 113
- corrosive gases, 2011 V3: 267
- corrosive wastes, 2010 V2: 13
  - double containment, 2012 V4: 56–57
  - drainage systems, 2011 V3: 42–43
  - high silicon pipe, 2012 V4: 53
  - stainless steel valves, 2012 V4: 77
- corrosives, 2009 V1: 20
- corrugated bends in pipes, 2012 V4: 61
- corrugated stainless steel tubing (CSST), 2012 V4: 56
- corrugated steel piping, 2010 V2: 75, 122–123, 2011 V3: 242
- cosmic radiation, 2010 V2: 237
- Cost Analysis phase in value engineering, 2009 V1: 229
  - costs and economic concerns
    - administrative and operation costs, 2009 V1: 208
    - collecting data on, 2009 V1: 217–218
    - construction costs, 2009 V1: 208
    - cost fitting, defined, 2009 V1: 249
    - cost information in value engineering, 2009 V1: 217–218
    - cost of goods, 2009 V1: 217
    - cost-to-function relationship, 2009 V1: 219
    - defined, 2009 V1: 209, 210, 217–218
    - development costs, 2009 V1: 208
    - economic values, 2009 V1: 209
    - engineering and design costs, 2009 V1: 208
    - estimating costs, 2009 V1: 85–90
    - idea development and estimated cost forms, 2009 V1: 234
    - labor costs, 2009 V1: 208
    - life-cycle costs, 2009 V1: 128
    - material costs, 2009 V1: 208
    - overhead, 2009 V1: 208
    - Pareto principle, 2009 V1: 218
    - quality engineering and, 2009 V1: 253
    - relationships, 2009 V1: 217
    - specific applications
      - air dryers, 2011 V3: 178
      - break tanks, 2012 V4: 166
      - cathodic protection costs, 2009 V1: 140
      - centralized or decentralized stills, 2012 V4: 192
      - chlorination, 2012 V4: 178
      - corrosion resistant materials, 2009 V1: 135
      - diatomaceous earth filters, 2012 V4: 182
      - double containment, 2012 V4: 56–57
      - feed water disinfection, 2010 V2: 222
      - flexible gas piping, 2010 V2: 122
      - fuel product dispensing systems, 2011 V3: 146
      - gas booster location, 2010 V2: 126
      - gas pressure, 2010 V2: 119
      - green plumbing benefits, 2012 V4: 234
      - hardness treatments, 2012 V4: 176
      - horizontal pressure sand filters, 2012 V4: 180
      - hot-water systems, 2010 V2: 97–98
      - insulation, 2012 V4: 106, 107, 110, 112
      - ion-exchange cartridges, 2010 V2: 208
      - ion-exchange resins, 2010 V2: 206, 207
      - iron and bronze valves, 2012 V4: 77
      - laboratory acid-waste drainage, 2010 V2: 232
      - noise mitigation products, 2009 V1: 203
      - plumbing noise mitigation, 2009 V1: 188
      - pure water piping systems, 2010 V2: 224
      - pure water storage systems, 2010 V2: 223
      - sanitary drainage systems, 2010 V2: 1
      - seismic protection costs, 2009 V1: 147
      - solar energy, 2011 V3: 189, 192, 193
      - special-waste drainage systems, 2010 V2: 228
      - utility costs, 2009 V1: 119
      - vacuum system piping, 2010 V2: 173–174
      - vibration control, 2012 V4: 143
      - water distillers, 2010 V2: 200
      - water softeners, 2012 V4: 188
      - water treatments, 2012 V4: 174
      - well construction, 2010 V2: 157, 164
  - in specifications, 2009 V1: 63
  - supporting details for, 2009 V1: 249
  - true costs of makeshift installations, 2009 V1: 263–264
  - types of, 2009 V1: 210, 217–218
  - value engineering process and, 2009 V1: 207
  - vs. prices, 2009 V1: 210
- cotton gin, creativity and, 2009 V1: 225
- coulombs (C)
  - corrosion, 2009 V1: 129
  - SI units, 2009 V1: 34
- coulombs per cubic meter (C/m<sup>3</sup>), 2009 V1: 34
- countdown timer delays, 2011 V3: 28
- counter-mounted kitchen sinks, 2012 V4: 11
- counter-mounted lavatories, 2012 V4: 10
- counter sinks, 2011 V3: 36
- counter zoning, 2011 V3: 28
- countercurrent regeneration, 2012 V4: 201
- couple action. *See* galvanic corrosion
- couples, defined, 2009 V1: 142
- couplings. *See* joints
- coverings. *See* jacketing
- covers, collector, defined, 2011 V3: 191
- CP (cellulose propionate), 2009 V1: 32
- CPC (Compound Parabolic Concentrator) system, 2011 V3: 196
- CPD (Certified Plumbing Designer), 2009 V1: 65
- CPE (chlorinated polyethylene), 2009 V1: 32
- CPI (Chemical and Petroleum Industry), 2009 V1: 14
- cprsr (compressors). *See* compressors
- CPSC (Consumer Product Safety Commission), 2011 V3: 106, 112
- CPVC (chlorinated polyvinyl chloride). *See* chlorinated polyvinyl-chloride (CPVC)
- CR (chloroprene rubber), 2009 V1: 32
- cracking, defined, 2009 V1: 142
- Craytor, J., 2010 V2: 29
- creativity
  - assisted and unassisted, 2009 V1: 227
  - creativity worksheets, 2009 V1: 226, 228
  - first phase in value engineering, 2009 V1: 209, 223–229

- questions for, 2009 V1: 227
- creep, 2009 V1: 20, 2010 V2: 12
- crevice-attack corrosion
  - crud traps in radioactive-waste piping, 2010 V2: 239, 240
  - defined, 2009 V1: 131, 142, 2010 V2: 196
  - reducing, 2009 V1: 136
- crimping tools, 2012 V4: 30
- critical air gaps, 2012 V4: 169
- critical care areas, 2011 V3: 36, 55
- critical flows, defined, 2009 V1: 2
- critical level, defined, 2009 V1: 20
- critical path functions, 2009 V1: 221
- critical points, 2009 V1: 20
- critical pressure, defined, 2011 V3: 184
- critical temperature, defined, 2011 V3: 184
- cross connections. *See also* back-siphonage; backflow
  - active control, 2012 V4: 164–166
  - air gaps, 2012 V4: 162–164
  - authorities having jurisdiction, 2012 V4: 168–169
  - backflow prevention, 2010 V2: 60
  - barometric loops, 2012 V4: 164
  - break tanks, 2012 V4: 166, 168
  - cold-water systems, 2010 V2: 60–61
  - control installation, 2012 V4: 166–168
  - control paradox, 2012 V4: 162
  - cross connection control programs, 2012 V4: 169
  - cross connection controls, defined, 2012 V4: 169
  - defined, 2009 V1: 20, 2012 V4: 169
  - field testing, 2012 V4: 168
  - flood hazard, 2012 V4: 167
  - glossary, 2012 V4: 169–171
  - health care facilities, 2011 V3: 46
  - medical gas pipe tests, 2011 V3: 74
  - overview, 2012 V4: 159
  - passive control techniques, 2012 V4: 162–164
  - product standards, 2012 V4: 168
  - quality control, 2012 V4: 168–169
  - reverse flow, causes, 2012 V4: 160–162
  - splashing, 2012 V4: 167
  - taking precautions against, 2010 V2: 27
  - types of prevention devices, 2010 V2: 60–61
  - vacuum breakers, 2012 V4: 164, 166, 167
  - water distribution hazards, 2012 V4: 161, 162
- cross-country pipe lines, 2009 V1: 139
- cross-flow filter media, 2010 V2: 191, 201
- cross-flow membrane filtration, 2012 V4: 201
- cross-linked polyethylene (PEX), 2009 V1: 32, 2012 V4: 48–49
- cross-linked polyethylene/aluminum/cross-linked polyethylene (PEX-AL-PEX), 2012 V4: 49
- cross-sections
  - ditches, 2011 V3: 242, 250
  - drains, 2010 V2: 2, 3
- cross valves, 2009 V1: 20
- crosses, defined, 2009 V1: 20
- crossovers, 2009 V1: 20
- crown vents, 2009 V1: 20
- crowns, 2009 V1: 20
- crud traps, 2010 V2: 196, 239, 240
- crutches, 2009 V1: 99
- cryogenic, defined, 2009 V1: 20
- cryogenic gases, 2011 V3: 267, 271
- cryogenic systems, 2012 V4: 54, 106
- cryogenic tanks, 2011 V3: 57
- CS (casein), 2009 V1: 32
- CS (Commercial Standards), 2009 V1: 32
- CSA. *See* Canadian Standards Association (CSA)
- CSC (Construction Specifications Canada) Uniformat, 2009 V1: 57–58
- CSI and CSI format. *See* Construction Specifications Institute (CSI)
- CSP (chlorine sulphonyl polyethylene), 2009 V1: 32
- CSST. *See* corrugated steel piping
- CSST (corrugated stainless steel tubing), 2012 V4: 56
- CTS (copper tube size), 2012 V4: 42
- CU FT (cubic feet), 2009 V1: 14, 2011 V3: 30
- cubes, calculating volume, 2009 V1: 4
- cubic feet (ft<sup>3</sup>, CU FT, CUFT, CFT), 2009 V1: 14, 2011 V3: 30
- cubic feet of minerals, 2012 V4: 201
- cubic feet per hour (cfh), 2011 V3: 172, 251
- cubic feet per minute (cfm, CFM), 2011 V3: 187. *See also* scfm, SCFM (standard cubic feet per minute)
  - compressed air systems, 2011 V3: 181
  - condensate estimates, 2011 V3: 167
  - converting to metric units, 2011 V3: 30
  - defined, 2010 V2: 135
  - medical vacuum systems, 2011 V3: 64
  - symbols for, 2009 V1: 14
  - vacuum measurements, 2010 V2: 166
- cubic feet per second, standard (scfs, SCFS), 2009 V1: 14
- cubic foot meters (cfms)
  - defined, 2010 V2: 135
  - vacuum measurements, 2010 V2: 166
- cubic meters, 2009 V1: 34
- cubic meters per kilogram, 2009 V1: 34
- cubic meters per minute, 2011 V3: 172
- cubic meters per second, 2009 V1: 34
- CUFT (cubic feet), 2011 V3: 30
- cUL (Underwriters Laboratories of Canada), 2009 V1: 41–42
- cultivated field, runoff, 2010 V2: 42
- cultured marble acrylic fixtures, 2012 V4: 1
- cultured marble fixtures, 2012 V4: 1
- cup service for drinking water, 2012 V4: 223
- cup sinks, 2011 V3: 36, 40, 41
- curb boxes, 2009 V1: 20
- curb inlets, 2009 V1: 20
- curb valves, 2009 V1: 20
- curies (c), 2010 V2: 237
- current
  - cathodic protection, 2009 V1: 137
  - in corrosion, 2009 V1: 129, 134
  - electromotive force series, 2009 V1: 134
  - large anode current requirements, 2009 V1: 139
  - measurements, 2009 V1: 33
- current good manufacturing practices (cGMP), 2009 V1: 14, 2010 V2: 224, 227
- cuspidors, dental, 2011 V3: 40, 2012 V4: 161
- custom-made grease interceptors, 2012 V4: 153
- cut-in sleeves, 2012 V4: 67
- cutting oils, 2010 V2: 12, 2012 V4: 61
- cutting short, 2012 V4: 129
- cutting threads, 2012 V4: 61

- CV (check valves). *See* check valves  
 CVOL (specific volume). *See* specific volume  
 cw (cold water). *See* cold water (CW)  
 CWA. *See* Clean Water Act  
 CWP (cold working pressure), 2012 V4: 83  
 CWR (chilled water return), 2009 V1: 8  
 CWS (chilled water supply), 2009 V1: 8  
 cyanide, 2011 V3: 87  
 cycle of concentration in cooling towers, 2010 V2: 216  
 cycles and cycle operation in water softeners, 2012 V4: 201  
 cyclopropane, 2011 V3: 55  
 cylinder banks, gas, 2011 V3: 267–268  
 cylinder-manifold-supply systems, 2011 V3: 57–61, 64, 65  
 cylinder snubbers, 2009 V1: 155  
 cylinders  
   calculating volume, 2009 V1: 4  
   carbon dioxide extinguishing systems, 2011 V3: 26  
   clean agent gas fire suppression, 2011 V3: 27  
   laboratory gas storage, 2011 V3: 267–268  
   regulators, 2011 V3: 271–272  
 cystoscopic rooms  
   fixtures, 2011 V3: 38  
   health care facilities, 2011 V3: 36  
   medical gas stations, 2011 V3: 52, 56
- D**  
 d (deci) prefix, 2009 V1: 34  
 D (difference or delta), 2009 V1: 14  
 D (drains). *See* drains  
 D (indirect drains), 2009 V1: 8  
 da (deka) prefix, 2009 V1: 34  
 Dalton's law, 2010 V2: 72  
 damage. *See* bedding and settlement; corrosion; creep;  
   hazards; scale and scale formation; seismic  
   protection; water damage  
 dampen, defined, 2009 V1: 20  
 damping  
   defined, 2012 V4: 137  
   in earthquakes, 2009 V1: 150, 177, 180  
 Darcy's law, 2009 V1: 2, 3, 2010 V2: 6, 74, 157–158  
 data storage for specifications programs, 2009 V1: 65  
 Database of State Incentives for Renewables and  
   Efficiency, 2011 V3: 190  
 databases of plumbing costs, 2009 V1: 85, 89  
 Daugherty, Robert L., 2010 V2: 19  
 Dawson, F.M., 2010 V2: 3, 19, 72  
 DB (dry-bulb temperature), 2009 V1: 21  
 dbt, DBT (dry-bulb temperature), 2009 V1: 21  
 DC (double containment systems), 2012 V4: 56–57  
 dc, DC (direct current), 2009 V1: 14, 137, 2010 V2: 209  
 DCV (double-check valves), 2009 V1: 14, 2011 V3: 215  
 DD (design development phase), 2009 V1: 58  
 DE (deionized water), 2009 V1: 8  
 DE (diatomaceous earth). *See* diatomaceous earth  
 DE/Perlite Performance Test Data, 2011 V3: 135  
 De Renzo, D.J., 2011 V3: 89  
 deactivation, defined, 2009 V1: 142  
 dead-end pressure, 2011 V3: 184  
 dead-end service in pressure-regulated valves, 2010 V2: 94  
 dead ends  
   centralized drinking-water cooler systems, 2012 V4: 223  
   defined, 2009 V1: 20  
   valves in, 2012 V4: 83  
 dead legs in pure water systems, 2010 V2: 224  
 dead loads on roof, 2010 V2: 51  
 dead-man abort stations, 2011 V3: 28  
 deadman installation, 2011 V3: 155  
 deadweight loads, 2012 V4: 129  
 deaeration, 2012 V4: 176  
 deaerators  
   boiler feed water, 2010 V2: 216  
   deaeration, defined, 2012 V4: 176  
   deaeration water treatment, 2010 V2: 199  
   pressure and vacuum, 2012 V4: 176  
   Provent deaerators, 2010 V2: 17–18  
   Sovent deaerators, 2010 V2: 17–18  
 dealkalizing treatment, 2010 V2: 199  
 dealloying, defined, 2009 V1: 142  
 decarbonation, 2010 V2: 199  
 decentralized distillation, 2012 V4: 192  
 deci prefix, 2009 V1: 34  
 decomposition potential, 2009 V1: 142  
 decontaminating radioactive waste piping, 2010 V2: 239  
 decontamination areas, 2011 V3: 39–41, 52  
 decorative pools, wastewater and, 2010 V2: 21  
 deep (dp, DP, DPTH). *See* depth  
 deep-bed sand filtration, 2010 V2: 201  
 deep ends of swimming pools, 2011 V3: 107  
 deep fill, building sewers and, 2010 V2: 14  
 deep seal traps, 2009 V1: 20  
 deep wells, 2010 V2: 155, 156, 161  
 deficiency reports, 2009 V1: 267–269  
 definitions. *See* glossaries  
 definitions section in specifications, 2009 V1: 63, 69  
 deflection  
   joints, 2012 V4: 57  
   natural frequencies and, 2012 V4: 138  
   steel spring isolators, 2012 V4: 139–142  
   thermal expansion and contraction, 2012 V4: 205  
 deformation, joints resistant to, 2012 V4: 57  
 deg., °, DEG (degrees), 2009 V1: 14  
 degasification, 2010 V2: 199, 2012 V4: 176, 184  
 degradation of pure water, 2010 V2: 223  
 degree of saturation, defined, 2011 V3: 187  
 degrees (deg., °, DEG), 2009 V1: 14  
 degrees Celsius, 2009 V1: 34, 2012 V4: 103  
 degrees Fahrenheit, 2012 V4: 103  
 degrees Kelvin (°K), defined, 2011 V3: 184  
 degrees Rankine (°R), defined, 2011 V3: 184  
 DEHA (diethylhydroxylamine), 2010 V2: 216  
 dehumidification, swimming pools, 2011 V3: 127  
 deionization, 2010 V2: 201. *See also* demineralizer  
   systems; service deionization  
 deionized water (DE), 2009 V1: 8, 2012 V4: 175  
 deka prefix, 2009 V1: 34  
 delay relays, 2011 V3: 28  
 delays in clean gas extinguishing systems, 2011 V3: 28  
 deliquescent dryers, 2011 V3: 178  
 deliquescent materials, 2009 V1: 20  
 delivery rooms. *See* birthing rooms  
 delivery section in specifications, 2009 V1: 63–64, 70  
 Dell'Isola, Alphonse J., 2009 V1: 252  
 Delphia method of evaluation, 2009 V1: 248  
 delta (diff., ), DIFF, D, DELTA, 2009 V1: 14

- delta t (temperature differential), 2009 V1: 128
- DELTP (pressure drops or differences). *See* pressure drops or differences
- deluge systems, 2009 V1: 28, 2011 V3: 9–10
- deluge valves, 2009 V1: 13, 2011 V3: 9–10
- demand
  - average flow rates for fixtures, 2012 V4: 186
  - centralized chilled water systems, 2012 V4: 222, 223
  - cold-water systems, 2010 V2: 73
  - defined, 2009 V1: 20, 2010 V2: 135
  - drinking fountains, 2012 V4: 222, 223
  - drinking water, 2010 V2: 159
  - estimating, 2010 V2: 83
  - estimation guide, 2012 V4: 187
  - fire demand, 2011 V3: 2
  - fire hydrant water demand, 2011 V3: 4
  - flow rates, 2011 V3: 222–225
  - gas appliances, 2010 V2: 116
  - hot water, 2009 V1: 128, 2010 V2: 97
  - hydropneumatic-tank systems, 2010 V2: 62, 64–65
  - medical air systems, 2011 V3: 62
  - medical gas systems, 2011 V3: 50, 51, 53, 57
  - medical school-laboratory water demand, 2011 V3: 46
  - natural gas, 2010 V2: 124, 130, 2011 V3: 256
  - natural gas systems, 2010 V2: 123, 129
  - pipe sizing and, 2010 V2: 75–76, 78
  - sizing water heaters, 2010 V2: 98–99
  - sprinkler systems, 2011 V3: 2–6, 13
  - vacuum systems, 2011 V3: 54, 65
  - water conservation and paybacks, 2009 V1: 118
  - water heater types and, 2010 V2: 101–104
  - water softeners and, 2012 V4: 185, 186
  - water treatment methods and, 2010 V2: 210
- demineralizer systems, 2010 V2: 199, 201
  - activated carbon, mixed bed deionization, 2012 V4: 199
  - cation and anion tanks, 2012 V4: 183
  - compared to distillation, 2012 V4: 176
  - compared to reverse osmosis, 2012 V4: 195
  - defined, 2012 V4: 182
  - for distillation, 2012 V4: 194
  - pure water systems, 2011 V3: 48
  - using with distillation, 2012 V4: 192
  - water softening pretreatment, 2012 V4: 187
- demographics in hot water demand classifications, 2010 V2: 99
- demolition work, in plumbing cost estimation, 2009 V1: 85
- Denoncourt, 2010 V2: 224
- dens, DENS (density). *See* density
- density (dens, DENS, RHO)
  - defined, 2009 V1: 20
  - gas, defined, 2011 V3: 184
  - grease particles, 2012 V4: 146–148
  - measurements, 2009 V1: 34
  - of natural gas, 2010 V2: 126
  - purified water, 2010 V2: 72–74
  - settling velocity and, 2012 V4: 178
- dental equipment, 2011 V3: 42, 52
- department connections, 2009 V1: 12
- departments having jurisdiction, 2009 V1: 20
- dependent functionality
  - defined, 2009 V1: 219
  - in FAST approach, 2009 V1: 221–223
- depolarization, defined, 2009 V1: 142
- depolarizing cathodes, 2009 V1: 134
- deposit attacks, 2009 V1: 142
- deposition corrosion, defined, 2009 V1: 142
- deposits from feed water, 2010 V2: 196. *See also* scale and scale formation; sediment; slime; sludge
- depth (dp, DE, DPTH)
  - grease interceptors, 2012 V4: 149
  - of liquids in septic tanks, 2010 V2: 146
  - of reflecting pools, 2011 V3: 100
  - of septic tanks, 2010 V2: 146
  - of soils, 2010 V2: 141
  - of wells, 2010 V2: 156
- depth filters, 2010 V2: 206, 2012 V4: 180
- derived units of measurement, 2009 V1: 34
- descriptive specifications, 2009 V1: 60–61
- desiccant air dryers, 2011 V3: 179
- desiccants, 2009 V1: 20
- design
  - alterations to buildings, 2009 V1: 265–266
  - ensuring good quality during, 2009 V1: 255
  - LEED (Leadership in Energy and Environmental Design), 2012 V4: 2
  - noise mitigation and, 2009 V1: 201–202
  - for people with disabilities, 2009 V1: 99
  - reducing corrosion, 2009 V1: 135–136
  - seismic, 2009 V1: 151, 180–182
  - sustainable, 2012 V4: 233
  - value engineering and, 2009 V1: 208
- design areas for sprinkler systems, 2011 V3: 12
- design (built-in) compression ratio, 2011 V3: 185
- design density, 2011 V3: 11–12
- design development phase (DD), 2009 V1: 58
- design elevations, 2012 V4: 129
- Design Information for Large Turf Irrigation Systems, 2011 V3: 96
- design loads, 2012 V4: 129
- Design of Hoffman Industrial Vacuum Cleaning Systems, 2010 V2: 186
- Design of Stormwater Filtering Systems, 2010 V2: 55
- design points, 2009 V1: 20
- design standards, 2009 V1: 61
- design storms, 2011 V3: 239
- design working head, 2012 V4: 101
- desolver tanks, 2010 V2: 210
- destruction phase in ozonation, 2010 V2: 214
- destructive forces in pipes. *See* water hammer
- details in projects, checklists, 2009 V1: 215
- detector-check water meters, 2010 V2: 60
- detectors, smoke, 2009 V1: 20
- detention periods
  - grease interceptors, 2012 V4: 149
  - treated water, 2010 V2: 198
- detention, storm drainage, 2010 V2: 47–48
- detergents
  - defined, 2009 V1: 141
  - factors in trap seal loss, 2010 V2: 37
  - high-expansion foam, 2011 V3: 25
  - in septic tanks, 2010 V2: 147
- deterioration, 2009 V1: 267–270
- Deutsches Institut für Normung (DIN), 2009 V1: 14
- developed length, 2009 V1: 20



- developers
  - perception of engineering, 2009 V1: 251
  - value engineering and, 2009 V1: 208
- development costs
  - defined, 2009 V1: 210
  - in value engineering, 2009 V1: 208
- Development phase in value engineering
  - activities, 2009 V1: 235–248
  - idea development and estimated cost forms, 2009 V1: 234
  - in process, 2009 V1: 209
  - sketches, 2009 V1: 246
- Development Presentation phase in value engineering, 2009 V1: 209
- deviations in measurements, 2009 V1: 33, 2012 V4: 129
- dew points
  - corrosion in pipes and, 2011 V3: 265
  - defined, 2009 V1: 20, 2011 V3: 173, 185, 265–266, 2012 V4: 109
  - lowering, 2011 V3: 178–179
  - medical gas system tests, 2011 V3: 76
  - monitors, 2011 V3: 63
  - pressure dew points, 2011 V3: 266
  - refrigerated air dryers, 2011 V3: 178
  - table, 2012 V4: 109
- dewatering pumps, 2012 V4: 98
- dewers, defined, 2011 V3: 268
- dezincification of brass, 2009 V1: 132, 2012 V4: 77
- DF. *See* drinking fountains (DF)
- dfu (drainage fixture units), 2009 V1: 14, 21
- DHEC (Department of Health and Environmental Control), 2010 V2: 112
- DI (deionization), 2010 V2: 201
- DI (distilled water), 2009 V1: 8
- DI (drainage inlets), 2009 V1: 14
- dia., DIA (diameters). *See* diameters
- diagnostic facilities, 2010 V2: 238
- dialogue in FAST approach, 2009 V1: 223
- dialysis machines, 2011 V3: 42, 2012 V4: 199
- dialysis rooms, 2011 V3: 39
- Diameter-Index Safety System (CGA V-5)*, 2011 V3: 76, 78
- diameters (dia., DIA)
  - defined, 2009 V1: 20
  - inside (ID), 2009 V1: 14
  - outside (OD), 2009 V1: 14
  - symbols for, 2009 V1: 14
- diaper changing stations, 2012 V4: 19
- diaphragm-actuated valves, 2011 V3: 125
- diaphragm gas meters, 2010 V2: 116–117
- diaphragm gauges, 2010 V2: 171
- diaphragm pumps, 2010 V2: 169, 2011 V3: 130
- diaphragm reciprocating compressors, 2011 V3: 174
- diaphragm tanks, 2011 V3: 26, 2012 V4: 209
- diaphragm valves, 2010 V2: 230, 2012 V4: 82
- diaphragms
  - defined, 2009 V1: 21
  - water-pressure regulators, 2012 V4: 80
- diatomaceous earth filtration. *See also* silica
  - advantages and disadvantages, 2010 V2: 218
  - diatomaceous earth filters, 2011 V3: 114, 119–122, 2012 V4: 181–182
  - regenerative alternative media filters, 2011 V3: 122
  - swimming pool usage, 2011 V3: 110
- diatoms, 2012 V4: 201
- dichlor, 2011 V3: 128
- die-cast metals, 2011 V3: 35
- dielectric fittings, 2009 V1: 21
- dielectric insulation, 2009 V1: 136, 140
- dielectric unions, 2011 V3: 139, 2012 V4: 62
- diesel drivers, 2011 V3: 22
- diesel engines, 2011 V3: 22
- diesel fuel, 2010 V2: 12
- diesel-oil systems
  - aboveground tank systems, 2011 V3: 147–149
    - connections and access, 2011 V3: 148
    - construction, 2011 V3: 147–148
    - corrosion protection, 2011 V3: 148
    - filling and spills, 2011 V3: 148
    - leak prevention and monitoring, 2011 V3: 148–149
    - materials, 2011 V3: 147–148
    - overflow prevention, 2011 V3: 148
    - product dispensing systems, 2011 V3: 149
    - tank protection, 2011 V3: 149
    - vapor recovery, 2011 V3: 149
    - venting, 2011 V3: 148
  - codes and standards, 2011 V3: 137
  - components, 2011 V3: 138
  - definitions and classifications, 2011 V3: 136–137
  - designing
    - installation considerations, 2011 V3: 154–156
    - pipng materials, 2011 V3: 149–151
    - pipng sizing, 2011 V3: 150–151
    - submersible pump sizing, 2011 V3: 151–152
    - testing, 2011 V3: 152–154
  - overview, 2011 V3: 136
  - references, 2011 V3: 156
  - resources, 2011 V3: 156
  - tank abandonment and removal, 2011 V3: 154
  - underground tank systems, 2011 V3: 139–140
    - leak detection and system monitoring, 2011 V3: 141–145
    - product dispensing systems, 2011 V3: 146–147
    - storage tanks, 2011 V3: 139–140
    - vapor recovery systems, 2011 V3: 145–146
- dietary services in health care facilities, 2011 V3: 36
- diethylhydroxylamine, 2010 V2: 216
- diff., DIFF (difference or delta), 2009 V1: 14
- difference (diff., (, DIFF, D, DELTA), 2009 V1: 14
- differential aeration cells, 2009 V1: 142
- differential changeover manifolds, 2011 V3: 271
- differential environmental conditions, corrosion by, 2009 V1: 132
- differential flow sensors, 2011 V3: 124
- differential gas regulators, 2010 V2: 117
- differential movement in earthquakes, 2009 V1: 152
- differential pressure
  - controllers, 2011 V3: 132
  - water-pressure regulators, 2012 V4: 80
- differential regulators, 2011 V3: 255
- differentials, defined, 2009 V1: 21
- difficulties in value engineering presentations, 2009 V1: 249
- diffusers, 2012 V4: 101
- diffusion aerators, 2010 V2: 198, 218
- diffusion-resistant valves, 2011 V3: 273
- digester gas, 2010 V2: 114

- digesting biosolids, 2012 V4: 240
- digestion, 2009 V1: 21
- digits, 2009 V1: 33
- dikes
  - for aboveground storage tanks, 2011 V3: 148–149
  - for hazardous waste areas, 2011 V3: 84
- dilution air, defined, 2010 V2: 135
- dilution, pollution and, 2011 V3: 81
- dimensions
  - in creativity checklist, 2009 V1: 227
  - defined, 2009 V1: 33
  - nominal, 2009 V1: 14
  - wheelchairs, 2009 V1: 100
- dimple/depth stops, 2012 V4: 58
- DIN (Deutsches Institut für Normung), 2009 V1: 14
- direct-acting, balanced-piston valves, 2012 V4: 82
- direct-acting, diaphragm-actuated valves, 2012 V4: 82
- direct-acting gas regulators, 2011 V3: 254
- direct-circulation solar systems, 2009 V1: 122
- direct connections, 2012 V4: 161
- direct-count epifluorescent microscopy, 2010 V2: 188
- direct current (dc, DC)
  - cathodic protection, 2009 V1: 137
  - in deionization, 2010 V2: 209
  - symbols for, 2009 V1: 14
- direct discharge of effluent, 2012 V4: 227
- direct fill ports, 2011 V3: 139–140
- direct-filtration package plants, 2010 V2: 218
- direct-fired gas water heaters, 2009 V1: 121, 2011 V3: 126
- direct-fired propane vaporizers, 2010 V2: 134
- direct-operated pressure-regulated valves, 2010 V2: 69–70
- direct-operated propane regulators, 2010 V2: 133
- direct pump water supplies, 2011 V3: 6
- directly-heated, automatic storage water heaters, 2010 V2: 101
- dirt cans for vacuum systems, 2010 V2: 179
- dirt in feed water, 2010 V2: 195
- dirty gas, 2011 V3: 252
- disabled individuals. *See* people with disabilities
- disc-type positive displacement meters, 2010 V2: 88
- disc water meters, 2010 V2: 59
- discharge characteristic fixture curves, 2010 V2: 3
- discharge coefficients, 2009 V1: 5
- discharge curves, 2011 V3: 211
- discharge permits, 2011 V3: 83
- discharge piping for vacuum cleaning systems, 2010 V2: 184
- discharge pressure, defined, 2011 V3: 185
- discharge rates in sizing bioremediation systems, 2012 V4: 229
- discharge temperature, defined, 2011 V3: 185
- discharge times in fire suppression, 2011 V3: 27
- discs
  - defined, 2009 V1: 21, 2012 V4: 89
  - globe valves, 2012 V4: 74–75
- discussions in FAST approach, 2009 V1: 223
- dished ends on tanks, 2011 V3: 139
- dishwashers
  - defined, 2009 V1: 21
  - direct connection hazards, 2012 V4: 161
  - fixture pipe sizes and demand, 2010 V2: 86
  - fixture-unit loads, 2010 V2: 3
  - grades of water for, 2012 V4: 199
  - graywater, 2012 V4: 238
  - grease interceptors and, 2012 V4: 154
  - health care facilities, 2011 V3: 39
  - hot water demand, 2010 V2: 99
  - water fixture unit values, 2011 V3: 206
  - water temperatures, 2011 V3: 47
- disinfecting. *See also* sterilization
  - codes for, 2009 V1: 43
  - cold-water systems, 2010 V2: 90–94
  - decontaminating infectious wastes, 2010 V2: 241–242
  - drinking water, 2010 V2: 160
  - feed water, 2010 V2: 195, 213
  - gray water, 2010 V2: 22, 27–28
  - septic tanks, 2010 V2: 148
  - small drinking water systems, 2010 V2: 218
  - wastewater, 2012 V4: 237
  - water systems, 2010 V2: 164
- Disinfection of Escherichia Coli by Using Water Dissociation Effect on Ion Exchange Membranes*, 2010 V2: 225
- disintegrations per second (dps), 2010 V2: 237
- dispenser pans, 2011 V3: 146
- dispensers
  - aboveground tanks, 2011 V3: 149
  - high-rate dispensers, 2011 V3: 151
  - multiple dispenser flow rates, 2011 V3: 151
- dispersed oil, 2010 V2: 244
- displacement
  - defined, 2009 V1: 21, 2011 V3: 185
  - in earthquakes, 2009 V1: 150
  - water meters, 2010 V2: 61
- disposal fields (sewage). *See* soil-absorption sewage systems
- disposal of grease
  - approved methods, 2012 V4: 157–158
  - bioremediation systems, 2012 V4: 228, 228–229
- disposal wells in geothermal energy, 2009 V1: 123
- disposals, 2009 V1: 21
- disposers. *See* food waste grinders
- DISS connectors, 2011 V3: 76
- dissociation, 2009 V1: 21
- dissolved air flotation, 2012 V4: 228
- dissolved elements and materials in water
  - dissolved gases, 2010 V2: 190, 199, 215
  - dissolved inorganics, 2010 V2: 193
  - dissolved iron, 2012 V4: 201
  - dissolved metals, 2011 V3: 87
  - dissolved minerals, 2010 V2: 215
  - dissolved oil, 2010 V2: 244
  - dissolved organics, 2010 V2: 201
  - dissolved oxygen, 2011 V3: 88
  - dissolved solids, 2010 V2: 193, 2012 V4: 201
  - laboratory grade water, 2012 V4: 197, 198
  - removing, 2012 V4: 176
- dissolved gases, 2009 V1: 21, 2010 V2: 190, 199, 215
- distances in standpipe systems, 2011 V3: 20–21
- distilled water (DI, DW)
  - applications, 2012 V4: 192–194
  - corrosion, 2009 V1: 141
  - decentralized or centralized, 2012 V4: 192
  - defined, 2012 V4: 175

- distillation compared to demineralizer systems, 2012 V4: 176
- distillation compared to reverse osmosis, 2012 V4: 199
- distillation treatment, 2010 V2: 199–201, 202–204
- distribution systems for water, 2012 V4: 193, 194
- feed water, 2012 V4: 194
- feedback purifiers, 2012 V4: 194
- health care facility stills, 2011 V3: 42
- laboratory grade water comparison, 2012 V4: 197
- overview, 2012 V4: 189
- producing, 2011 V3: 47–48
- purity monitors, 2012 V4: 193–194
- sizing equipment, 2012 V4: 192, 193
- storage reservoirs, 2012 V4: 193
- symbols for, 2009 V1: 8, 14
- types of equipment, 2012 V4: 192–194
- ultraviolet light, 2012 V4: 193
- distribution of wealth, 2009 V1: 218
- distribution piping, steam, 2011 V3: 159–161
- distribution subsystems, solar, defined, 2011 V3: 191
- distributors in water softeners, 2012 V4: 201
- disturbing forces, 2012 V4: 137
- disturbing frequency (fd), defined, 2012 V4: 137
- ditches, 2011 V3: 250
- divergent thinking in creativity, 2009 V1: 225
- diversity factor
  - compressed air tools, 2011 V3: 182
  - defined, 2009 V1: 21, 2010 V2: 135
  - health care facility systems, 2011 V3: 46
  - medical gas, 2011 V3: 51, 70
  - medical vacuum, 2011 V3: 51, 70
  - natural gas systems, 2011 V3: 252, 256
  - nitrogen systems, 2011 V3: 69, 70
  - nitrous oxide, 2011 V3: 70
  - oxygen, 2011 V3: 70
  - vacuum systems, 2010 V2: 176
- diverter plate, fountains, 2011 V3: 103
- diverters, spray accessories on sinks, 2012 V4: 13
- diving pools, 2011 V3: 107
- divinyl benzene, 2010 V2: 206
- division in SI units, 2009 V1: 35
- Divisions in MasterFormat 2004, 2009 V1: 58–60, 72–83
- DL. *See* distilled water
- DMH (drop manholes), 2009 V1: 14
- DN (dimensional, nominal), 2009 V1: 14
- DN (down), 2009 V1: 14
- DN (nominal diameter), 2010 V2: 165
- DNA materials, 2010 V2: 241, 2012 V4: 194
- dolomite limestone chips, 2010 V2: 235
- dome grates in shower rooms, 2010 V2: 11
- dome roof drains, 2010 V2: 52
- domestic booster pumps, 2012 V4: 97
- domestic sewage, 2009 V1: 21
- domestic systems. *See* domestic water supply; residential systems
- Domestic Water Heating Design Manual, 2010 V2: 96, 99, 2011 V3: 47
- domestic water meters, 2010 V2: 59–60
- domestic water supply
  - as source of plumbing noise, 2009 V1: 189
  - codes and standards, 2011 V3: 206
  - combined with fire-protection supply, 2011 V3: 218–220
  - defined, 2009 V1: 21
  - fixtures, usage reduction, 2012 V4: 236
  - health care facilities, 2011 V3: 46–49
  - irrigation, usage reduction, 2012 V4: 234
  - noise mitigation, 2009 V1: 190–193
  - overview, 2011 V3: 205–206
  - preliminary information, 2011 V3: 205
  - service components and design, 2011 V3: 208–217
    - backflow prevention, 2011 V3: 214–216
    - elevation differences, 2011 V3: 216
    - piping runs, 2011 V3: 214
    - strainer losses, 2011 V3: 216
    - taps, 2011 V3: 210–214
    - valves and fittings, 2011 V3: 214
    - water meters, 2011 V3: 216
    - water pressure, 2011 V3: 210
  - service connection, 2011 V3: 213, 214
  - system requirements, 2011 V3: 206–208
  - valves for, 2012 V4: 83–84
  - water fixture unit values, 2011 V3: 206
  - water mains, 2011 V3: 206
  - water utility letters, 2011 V3: 208, 259
- doors, accessibility and, 2009 V1: 104, 106
- dope, pipe, 2010 V2: 191
- dormant water freezing points (fp, FP), 2012 V4: 111
- doses of radiation, 2010 V2: 237
- dosimeters, 2010 V2: 237
- dosing tanks, 2009 V1: 21
- dot products, defined, 2009 V1: 85
- DOTn. *See* U.S. Department of Transportation (DOTn)
- double. *See also* entries beginning with dual-, multiple-, or two-
  - double-acting altitude valves, 2010 V2: 164
  - double-acting cylinders in compressors, 2011 V3: 174
  - double-acting devices, 2012 V4: 129
  - double-bolt pipe clamps, 2012 V4: 135
  - double-check valves (DCV)
    - assemblies, 2012 V4: 165, 169
    - defined, 2009 V1: 14
    - with intermediate atmospheric vents, 2012 V4: 169–170
    - water mains and, 2011 V3: 215
  - double-compartment sinks, 2012 V4: 11
  - double-contained piping systems, 2010 V2: 242, 2011 V3: 43, 145
  - double-contained tanks, 2011 V3: 139
  - double-containment systems, 2012 V4: 51, 56–57
  - double-disc check valves, 2012 V4: 77
  - double discs
    - defined, 2009 V1: 21
    - gate valves, 2012 V4: 74
  - double extra-strong steel pipe, 2012 V4: 37
  - double offsets, 2009 V1: 21
  - double-ported valves, 2009 V1: 21
  - double-seated pressure-regulated valves, 2010 V2: 69–70
  - double-stage gas regulators, 2011 V3: 272
  - double-sweep tees, 2009 V1: 21
  - double tees, 2012 V4: 5
  - double-wall piping, 2010 V2: 227
  - double-wall tanks, 2011 V3: 139
  - Dow Chemical Corp., 2010 V2: 224
  - down
    - defined, 2009 V1: 21

- symbol, 2009 V1: 14
- down flow, defined, 2012 V4: 201
- downfeed risers, 2012 V4: 221
- downspouts and leaders (l). *See also* vertical stacks
  - calculating flows, 2010 V2: 53
  - defined, 2009 V1: 21, 25
  - roof drainage systems, 2010 V2: 49
  - roof expansion and, 2010 V2: 49
  - roof leaders, 2010 V2: 49
- downstream, defined, 2009 V1: 21
- dp, DP (depth). *See* depth
- dps (disintegrations per second), 2010 V2: 237
- DPTH (depth). *See* depth
- draft hoods, 2010 V2: 135–136
- drag coefficients, 2012 V4: 146
- drag force, 2012 V4: 129
- drag, frictional, 2012 V4: 146
- drain bodies. *See* sumps and sump pumps
- drain cleaners in septic tanks, 2010 V2: 147
- drain fields. *See* soil-absorption sewage systems
- drain line carry tests, 2012 V4: 5
- drain tiles, 2010 V2: 143
- drain valves, 2011 V3: 95, 2012 V4: 201
- drain, waste, and vent pipes (DWV)
  - combination drain and vent, 2010 V2: 33
  - copper drainage tube, 2012 V4: 33–34
  - copper pipe, 2012 V4: 32
  - defined, 2009 V1: 22, 32, 2012 V4: 129
  - dimensions, 2012 V4: 38
  - DWV pattern schedule 40 plastic piping, 2010 V2: 13
  - glass pipe, 2012 V4: 35
  - plastic pipe, 2012 V4: 39
  - polypropylene, 2012 V4: 51
  - Provent systems, 2010 V2: 17–18
  - PVC pipe, 2012 V4: 49
  - Solvent systems, 2010 V2: 17–18
  - thermal expansion or contraction, 2012 V4: 205, 207–208
- drain, waste, and vent stacks (DWV)
  - copper, 2012 V4: 29
  - Provent systems, 2010 V2: 17–18
  - Solvent systems, 2010 V2: 17–18
- drainage (corrosion), defined, 2009 V1: 142
- drainage channels, irrigation systems and, 2010 V2: 24
- drainage fittings, 2009 V1: 21
- drainage fixture units (dfu), 2009 V1: 14, 21, 23. *See also* fixture units and unit values
- drainage inlets (DI), 2009 V1: 14
- drainage piping
  - copper pipe, 2012 V4: 29
  - double containment, 2012 V4: 56–57
  - glass pipe, 2012 V4: 35
  - nonreinforced concrete pipe, 2012 V4: 29
- drainage pumps, 2012 V4: 98–99
- drainage systems. *See also* specific types of drainage systems
  - air compressor systems, 2011 V3: 178
  - as source of plumbing noise, 2009 V1: 188–189
  - condensate, 2011 V3: 163–166
  - defined, 2009 V1: 21, 2010 V2: 1
  - drainage structures, defined, 2011 V3: 226
  - health care facilities, 2011 V3: 42–46
  - laboratories
    - acid-waste drainage, 2011 V3: 42–46
    - acid-waste metering, 2011 V3: 45
    - acid-waste solids interceptors, 2011 V3: 45
    - acidic-waste neutralization, 2011 V3: 43–44
    - corrosive-waste piping materials, 2011 V3: 46
    - discharge to sewers, 2011 V3: 43–44
    - sink traps, 2011 V3: 45–46
    - waste and vent piping, 2011 V3: 46
  - manholes, 2011 V3: 226–228
  - mitigating noise, 2009 V1: 189–190
  - pumps, 2012 V4: 98–99
  - storm water, 2011 V3: 249
- drainage, waste, and vents (DWV). *See* drain, waste, and vent
- drainback solar systems, 2009 V1: 122
- drainless water coolers, 2012 V4: 217
- drainline heat reclamation, 2009 V1: 123–126
- drains (D). *See also* building drains; horizontal drains; specific types of drains
  - butterfly valves, float-operated main, 2011 V3: 131
  - defined, 2009 V1: 21
  - grease interceptors, 2012 V4: 145
  - secondary containment areas, 2011 V3: 84
  - swimming pools, 2011 V3: 104–106, 112, 131–132
  - symbols for, 2009 V1: 11
  - water softeners, 2012 V4: 188
- drawdowns (wells), 2010 V2: 158, 161, 164
- drawings, plumbing. *See* plumbing drawings
- drawn temper (hard), 2012 V4: 29, 33
- drawoff installations. *See* specific kinds of interceptors
- drench equipment for emergencies, 2010 V2: 229
- drench showers, 2011 V3: 36, 41. *See also* emergency fixtures
- dressing facilities, 2011 V3: 110
- drift
  - defined, 2009 V1: 21
  - problems in seismic protection, 2009 V1: 184
- drilled anchor bolts, 2009 V1: 154, 184
- drilling wells, 2010 V2: 164
- drinking fountains (DF)
  - access to, 2009 V1: 101–105
  - centralized systems, 2012 V4: 222–224
  - estimating water usage, 2012 V4: 223–224
  - fixture pipe sizes and demand, 2010 V2: 86
  - graywater systems, 2009 V1: 126
  - health care facilities, 2011 V3: 36, 37, 40
  - minimum numbers of, 2012 V4: 20–23
  - office building usage, 2012 V4: 221
  - stand-alone water coolers, 2012 V4: 216
  - standards, 2012 V4: 2
  - submerged inlet hazards, 2012 V4: 161
  - swimming pool facilities, 2011 V3: 109, 110
  - symbols, 2009 V1: 14
  - types, 2012 V4: 13
  - water fixture unit values, 2011 V3: 206
  - wheelchair approaches, 2009 V1: 104
- drinking water
  - cross connections to nonpotable water, 2012 V4: 160
  - drinking water supply (DWS), 2009 V1: 8
  - drinking water supply recirculating (DWR), 2009 V1: 8
  - drinking water systems. *See* private water systems

- fountains vs. cup service, 2012 V4: 223
- health care facilities, 2011 V3: 46, 47
- material codes, 2009 V1: 43
- potable water, 2009 V1: 27, 2012 V4: 170, 174–175
- supply as source of plumbing noise, 2009 V1: 189
- system noise mitigation, 2009 V1: 190–193
- treatments for, 2010 V2: 218
- typical usage in offices, 2012 V4: 222, 223
- drinking-water coolers
  - access to, 2009 V1: 101–105
  - accessories, 2012 V4: 218–219
  - bottle fillers, 2012 V4: 219
  - centralized systems, 2012 V4: 222–224
  - compared to water chillers, 2012 V4: 215
  - defined, 2012 V4: 215
  - features, 2012 V4: 218–219
  - health care facilities, 2011 V3: 36
  - heating functions, 2012 V4: 218
  - installing, 2012 V4: 224
  - invention of, 2012 V4: 215
  - options, 2012 V4: 218–219
  - public areas in health care facilities, 2011 V3: 37
  - ratings, 2012 V4: 215–216
  - refrigeration systems, 2012 V4: 219–220
  - standards, 2012 V4: 2
  - stream regulators, 2012 V4: 219
  - types, 2012 V4: 13, 216–218
  - water conditioning for, 2012 V4: 220–221
  - wheelchair space around, 2009 V1: 104
- drip legs, condensate drainage, 2011 V3: 164
- drip pots, 2011 V3: 255
- drive points, 2010 V2: 157
- driven wells, 2010 V2: 157
- drives, variable-frequency (VFD), 2011 V3: 125–126
- droop, 2009 V1: 21, 2012 V4: 80
- drop elbows, 2009 V1: 21
- drop manholes (DMH), 2009 V1: 14, 21, 2011 V3: 228, 232
- drop nipples on pendant sprinklers, 2009 V1: 13
- drop tees, 2009 V1: 21
- drop tubes, 2011 V3: 140, 145
- drops, 2009 V1: 11, 21, 2011 V3: 139
- drops in pressure. *See* pressure drops or differences (PD, DELTP)
- drug rooms, 2011 V3: 38
- drum traps, 2011 V3: 46
- dry air
  - composition of, 2011 V3: 172, 264
  - properties, 2011 V3: 263
  - water vapor in, 2011 V3: 265
- dry-bulb temperature (dbt, DBT, DB), 2009 V1: 21, 2011 V3: 185, 2012 V4: 109, 112
- dry-chemical extinguishing systems, 2011 V3: 24–25, 28–29
- dry gas, 2011 V3: 185, 257
- dry hose stations, 2009 V1: 13
- dry ice, 2011 V3: 26
- dry nitrogen, 2011 V3: 257
- dry pendent sprinklers, 2009 V1: 29
- dry-pipe systems
  - accelerators, 2011 V3: 9
  - air compressors, 2011 V3: 8
  - combined dry-pipe and pre-action systems, 2011 V3: 10–11
  - defined, 2009 V1: 28
  - normal conditions, 2011 V3: 8
  - riser diagram, 2011 V3: 8
  - sprinklers, 2011 V3: 6–8
  - water delivery time frames, 2011 V3: 9
- dry-pipe valves, 2009 V1: 13, 21
- dry-pit pumps, 2012 V4: 98
- dry-powder extinguishing systems, 2011 V3: 24
- dry pumps, 2010 V2: 173
- dry standpipe systems, 2011 V3: 20
- dry standpipes, 2009 V1: 13, 30
- dry-storage water softeners, 2010 V2: 210
- dry units, defined, 2011 V3: 185
- dry upright sprinklers, 2009 V1: 29
- dry-vacuum cleaning systems (DVC), 2009 V1: 9, 2010 V2: 178, 186
- dry-weather flows, 2009 V1: 21
- dry wells (leaching wells), 2011 V3: 249–250
- dryers in laundry facilities, 2011 V3: 39
- du Moulin, G.C., 2010 V2: 224
- dual. *See also* entries beginning with double-, multiple-, or two-
  - dual-bed deionization (two-step), 2010 V2: 206, 207
  - dual check valve assemblies, 2012 V4: 163, 166, 169
  - dual check valves with atmospheric vents, 2012 V4: 163
  - dual-flush water closets, 2009 V1: 127, 2010 V2: 2
  - dual fuel devices, 2009 V1: 21
  - dual-gas booster systems, 2010 V2: 120
  - dual-height water coolers, 2012 V4: 217
  - dual vents (common vents), 2009 V1: 19. *See also* common vents
  - dual water-supply systems, 2011 V3: 46
- ductile action of building systems, 2009 V1: 174
- ductile iron grates, 2010 V2: 13
- ductile iron piping
  - characteristics, 2012 V4: 26, 29
  - hangers, 2012 V4: 122
  - pressure classes, 2012 V4: 28, 29
  - radioactive waste and, 2010 V2: 239
  - sizing, 2011 V3: 242
  - standards, 2012 V4: 68
- ducts. *See* vents and venting systems
- Duffie, J.A., 2011 V3: 203
- dug wells, 2010 V2: 156
- Dumfries Triangle and Occoquan-Woodbridge Sanitary District, 2010 V2: 29
- dump loads, 2011 V3: 47
- Dunleavy, M., 2010 V2: 224
- duplex. *See also* entries beginning with double-, dual-, or two-
  - duplex air compressors, 2011 V3: 63
  - duplex bed pressure swing dryers, 2011 V3: 179
  - duplex manifolds, 2011 V3: 60, 61
  - duplex sump pump systems, 2010 V2: 8
  - duplex vacuum pump arrangements, 2010 V2: 173, 178
- duration
  - defined, 2009 V1: 22
  - rainfall, 2010 V2: 53, 2011 V3: 241–242
  - rainfall charts, 2011 V3: 244–248
- Durham systems, 2009 V1: 22

- durion, 2009 V1: 22
- duriron pipe (high silicon), 2012 V4: 53
- dust, as air contaminant, 2011 V3: 265
- duty cycles, 2009 V1: 22, 2011 V3: 182, 183
- duty-cycling controls, 2011 V3: 62, 65
- DVC (dry vacuum cleaning), 2009 V1: 9, 2010 V2: 178, 186
- DW. *See* distilled water (DI, DW)
- dwelling. *See* buildings
- DWG (drawings), 2009 V1: 14. *See also* plumbing drawings
- DWR (drinking water supply recirculating), 2009 V1: 8
- DWS (drinking water supply), 2009 V1: 8
- DWV. *See* drain, waste, and vent pipes (DWV); drain, waste, and vent stacks (DWV)
- dye tests, 2012 V4: 5, 8
- dyes in gray water, 2010 V2: 27
- dynamic air compressors, 2011 V3: 62, 174
- dynamic force (dynamic loading), 2012 V4: 129
- dynamic head, 2010 V2: 161
- dynamic loads, 2012 V4: 129
- dynamic properties of piping, defined, 2009 V1: 185
- dynamic response (K) to ground shaking, 2009 V1: 149, 152
- dynamic viscosity
- converting to SI units, 2009 V1: 38
  - measurements, 2009 V1: 34
- dyne, converting to SI units, 2009 V1: 38
- dysentery, 2012 V4: 200
- E**
- E (roughness). *See* roughness of pipes
- E (volts). *See* volts
- e. coli bacteria, 2010 V2: 27, 43
- E (exa) prefix, 2009 V1: 34
- early flame knockdown, 2011 V3: 23
- earth loads
- bioremediation pretreatment systems, 2012 V4: 230
  - defined, 2009 V1: 22
  - protecting against, 2010 V2: 16
- earthquake protection of plumbing equipment. *See* seismic protection
- Earthquake Resistance of Buildings*, 2009 V1: 185
- Earthquake Resistant Design Requirements Handbook*, 2009 V1: 185
- Eaton, Herbert N., 2010 V2: 4
- eccentric fittings, 2009 V1: 22
- eccentric plug valves, 2012 V4: 77
- eccentric reducers, 2009 V1: 10
- economic concerns. *See* costs and economic concerns
- economic values, 2009 V1: 209
- economizers
- drinking water coolers, 2012 V4: 220
  - gas systems, 2011 V3: 272
- ECTFE (ethylenechlorotrifluoroethylene), 2009 V1: 32
- Eddy, 2010 V2: 154
- edge distances, problems in seismic protection, 2009 V1: 184
- edr, EDR (equivalent direct radiation), 2009 V1: 38
- educating public on graywater systems, 2010 V2: 27–28
- educational facilities. *See* schools
- eff, EFF (efficiency). *See* efficiency
- effective openings, 2009 V1: 22, 2012 V4: 170
- effective pressure, 2010 V2: 94
- effects in multi-effect distillation, 2010 V2: 200
- effects of earthquakes, 2009 V1: 148–149
- efficiency (eff, EFF)
- energy, 2012 V4: 241
  - grease interceptors, 2012 V4: 150
  - heat transfer, 2011 V3: 162
  - pumps, 2012 V4: 93–94
  - thermal, 2009 V1: 128
  - water softeners, 2012 V4: 188
- efficiency quotient (Eq), defined, 2012 V4: 137
- effluent. *See also* private onsite wastewater treatment systems (POWTS)
- bioremediation pretreatment. *See* bioremediation pretreatment systems
  - chemicals in special-waste effluent, 2010 V2: 228
  - defined, 2009 V1: 22, 2012 V4: 201
  - estimating sewage quantities, 2010 V2: 150–152
  - layers of in septic tanks, 2010 V2: 145
  - pumps, 2012 V4: 98
  - samples of radioactive waste effluent, 2010 V2: 240
  - special-waste drainage systems, 2010 V2: 227
  - temperature of special-waste effluent, 2010 V2: 228
  - treatment of sewage effluent, 2010 V2: 145
- Effluent Guideline program, 2011 V3: 82–83
- Egozy, 2010 V2: 224
- EJ (expansion joints). *See* expansion joints
- EJCDC (Engineers Joint Contract Documents Committee), 2009 V1: 57
- ejector pumps and pits, 2009 V1: 22, 2011 V3: 228–229
- ejectors
- defined, 2010 V2: 8
  - in sanitary drainage systems, 2010 V2: 8–9
- EL (elevation). *See* elevation
- elastic limits, 2009 V1: 22
- elastic rebound theory, 2009 V1: 148
- elastic vibration in pipes, 2009 V1: 6
- elasticity
- flexural modulus of, 2012 V4: 205
  - plastic pipes, 2006 V4: 50
- elastomeric insulation
- defined, 2012 V4: 105
  - elastomer-cork mountings, 2012 V4: 142
  - heat loss, 2012 V4: 107
  - vibration insulation, 2012 V4: 139
- elastomeric seals or gaskets
- reinforced concrete pipe, 2012 V4: 29
  - slip expansion joints, 2012 V4: 207
  - water closets, 2012 V4: 5
- elastomers, 2009 V1: 22, 32
- elbow lugs, 2012 V4: 129
- elbow offsets, 2012 V4: 206
- elbows
- angle valves and, 2012 V4: 75
  - ells, 2009 V1: 22
  - risers up or down, 2009 V1: 10–11
- elderly
- aging disabilities, 2009 V1: 99
  - fixtures and, 2009 V1: 99
  - in hot water demand classifications, 2010 V2: 99
- electric arc welding, 2012 V4: 61
- electric capacitance measurements, 2009 V1: 34
- electric charge density measurements, 2009 V1: 34

- electric fire pumps, 2011 V3: 22
- electric hot-water heaters, 2009 V1: 120
- electric inductance, 2009 V1: 34
- electric irrigation valves, 2011 V3: 94
- electric permeability measurements, 2009 V1: 34
- electric permittivity measurements, 2009 V1: 34
- electric resistance, 2009 V1: 34
- electric-resistance welding (ERW), 2012 V4: 37
- electric resistivity measurements, 2009 V1: 34
- electric solenoid level-sensing systems, 2011 V3: 132
- electric vaporizers, 2011 V3: 57
- electric water heaters, 2010 V2: 100–101
- electrical bonding, 2010 V2: 125
- electrical components in gas boosters, 2010 V2: 125
- electrical engineers, 2011 V3: 29
- electrical equipment
  - fires, 2011 V3: 25
  - installation of pipe and, 2012 V4: 25
- electrical leakage, 2012 V4: 117
- electricity
  - conversion factors, 2009 V1: 35
  - electric current, 2012 V4: 62
  - measurements, 2009 V1: 34
  - off-peak power savings, 2009 V1: 119
- electrochemical equivalents in corrosion, 2009 V1: 129
- Electrochemical Society, 2009 V1: 142
- electrodeionization, 2010 V2: 209–210
- electrodes
  - in conductivity meters, 2012 V4: 183
  - defined, 2009 V1: 142
- electrofusion joining, 2012 V4: 61
- electro galvanization, 2012 V4: 130
- electrolysis. *See also* galvanic action
  - defined, 2009 V1: 22, 2012 V4: 130
  - dezincification of brass, 2012 V4: 77
- electrolytes
  - defined, 2009 V1: 22, 129, 142, 2010 V2: 187
  - specific resistance, 2010 V2: 192
- electromagnetic radiation, 2010 V2: 237, 2012 V4: 195
- electrometric compression liners, 2012 V4: 36
- electromotive force (emf, EMF)
  - electromotive force series, 2009 V1: 134
  - measurements, 2009 V1: 34
- electromotive force series, 2009 V1: 134, 142
- electron microscopes, 2011 V3: 40, 42, 47, 52
- electronegative potential, 2009 V1: 142
- electronic grade water, 2012 V4: 39, 52
- electronic pressure differential switches, 2012 V4: 181
- electronic product level gauges, 2011 V3: 149
- electronic tank gauging, 2011 V3: 142
- electronics-grade water, 220, 2010 V2: 219
- electroplating
  - defined, 2012 V4: 130
  - wastewater treatment, 2011 V3: 86
- electropositive potential, 2009 V1: 142
- electroregeneration, 2010 V2: 210
- elemental bromine, 2011 V3: 131
- elements in water, 2010 V2: 189
- elev., ELEV (elevation). *See* elevation
- elevated water storage tanks, 2010 V2: 162
- elevated water supplies, 2010 V2: 65–66, 2011 V3: 6
- elevation (elev., EL, ELEV)
  - adjustments for vacuum, 2010 V2: 166–167, 185
  - air compressors and, 2011 V3: 63
  - air pressure corrections, 2011 V3: 264
  - altitude valves, 2010 V2: 163–164
  - compressed air and, 2011 V3: 171
  - defined, 2012 V4: 130
  - medical vacuum systems and, 2011 V3: 64
  - natural gas and, 121, 2010 V2: 117
  - pressure drops and, 2010 V2: 84
  - pressure losses and, 2011 V3: 216
  - regional requirements for plumbing installations, 2009 V1: 262
  - in sprinkler hydraulic calculations, 2011 V3: 13
  - symbols for, 2009 V1: 14
- elevation pressure, 2010 V2: 94
- elevator shafts
  - medical gas piping and, 2011 V3: 68
  - protection systems, 2011 V3: 29
- ellipses, calculating area, 2009 V1: 4
- ells (elbows), 2009 V1: 22. *See also* elbows
- elongated bowls on water closets, 2012 V4: 3
- elutriation, 2009 V1: 22
- embedding, defined, 2012 V4: 130
- embedments, problems in seismic protection, 2009 V1: 184
- emergency equipment for acid spills, 2010 V2: 229, 231
- emergency fixtures
  - emergency eyewashes, 2012 V4: 17–18
  - emergency showers, 2012 V4: 17–18
  - standards, 2012 V4: 2
- emergency gas shutoffs, 2010 V2: 121
- Emergency Planning and Community Right-To-Know Act (EPCRA) (SARA Title III), 2011 V3: 137
- emergency power for fire pumps, 2011 V3: 22
- emergency rooms
  - fixtures, 2011 V3: 36, 38
  - medical gas stations, 2011 V3: 52, 56
  - medical vacuum, 2011 V3: 54
  - water demand, 2011 V3: 46
- emergency showers, 2011 V3: 36, 41
- emergency shutoffs for fuel dispensers, 2011 V3: 146
- emergency tank vents, 2011 V3: 148
- e.m.f. series, 2009 V1: 134, 142
- emissivity, defined, 2011 V3: 191
- emittance, defined, 2011 V3: 191
- emitters in irrigation systems, 2010 V2: 25
- Empire State Building, 2012 V4: 117
- emulsions, 2010 V2: 244
- enameled cast iron fixtures
  - defined, 2012 V4: 1
  - health care facilities, 2011 V3: 35
  - standards, 2012 V4: 2
- enameled floor drains, 2010 V2: 15
- enameled sediment buckets, 2010 V2: 13
- encephalitis, 2010 V2: 49
- enclosed impellers, 2012 V4: 93, 98
- enclosures for showers, 2009 V1: 112
- encoder remote-readout gas meters, 2010 V2: 116
- end connections, 2009 V1: 22
- end-head flows, 2011 V3: 13
- end-suction pumps, 2009 V1: 23, 2011 V3: 21, 122–123
- end-use water restrictions, 2009 V1: 118
- endotoxins, 2010 V2: 188, 194, 2012 V4: 201

## energy

- alternate energy sources, 2009 V1: 121–126
- conservation. *See* conserving energy
- conversion factors, 2009 V1: 35
- defined, 2009 V1: 128, 2011 V3: 185
- efficiency, green plumbing, 2012 V4: 52, 241
- measurements, 2009 V1: 34
- non-SI units, 2009 V1: 34
- nondepletable, 2009 V1: 128
- recovered, 2009 V1: 128
- requirements, wastewater management, 2012 V4: 241
- solar. *See* solar energy
- use, 2011 V3: 188
- energy code list of agencies, 2009 V1: 42
- energy conservation. *See* conserving energy
- energy efficiency. *See* conserving energy
- Energy Efficiency and Renewable Energy web site, 2011 V3: 203
- Energy Policy Act (EPACT), 2009 V1: 117, 127, 2012 V4: 2, 8, 9, 11
- Energy Policy and Conservation Act (EPCA), 2009 V1: 117
- Energy Saving and the Plumbing System*, 2009 V1: 128
- Energy Star web site, 2011 V3: 203
- energy transport subsystem, defined, 2011 V3: 191
- enflurane, 2011 V3: 66
- Engineered Controls International, Inc., 2010 V2: 137
- engineered drawings, 2012 V4: 130
- engineered dry-chemical systems, 2011 V3: 24
- engineered hanger assemblies, 2012 V4: 130
- Engineered Plumbing Design*, 2009 V1: 39, 2010 V2: 55
- Engineered Plumbing Design II*, 2010 V2: 96
- engineered plumbing systems, 2009 V1: 22
- engineering and design costs, 2009 V1: 208
- Engineering Manual of the War Department*, 2010 V2: 55
- Engineering Resource Binder*, 2009 V1: 206
- Engineers Joint Contract Documents Committee (EJCDC), 2009 V1: 57
- engineers of record, 2009 V1: 253
- engines, earthquake protection for, 2009 V1: 157
- enthalpy (H), 2011 V3: 185
- entrainment ratios, 2011 V3: 185
- entropy (S), 2009 V1: 34, 2011 V3: 186
- environmental concerns. *See* green building and plumbing
- environmental conditions
  - corrosion by, 2009 V1: 132
  - hangers and supports and, 2012 V4: 115, 117
- environmental impacts
  - propane, 2010 V2: 131
  - solar energy, 2011 V3: 189
- Environmental Protection Agency. *See* U.S. Environmental Protection Agency
- environs (facilities with radiation), 2010 V2: 237
- EP (epoxy, epoxides), 2009 V1: 32
- EPA. *See* U.S. Environmental Protection Agency
- The EPA Effluent Guidelines Series (EPA 440)*, 2011 V3: 89
- EPA protocol gases, 2011 V3: 266
- EPACT (Energy Policy Act), 2009 V1: 117, 127
- EPCA (Energy Policy and Conservation Act), 2009 V1: 117
- EPCRA (Emergency Planning and Community Right-To-Know Act) (SARA Title III), 2011 V3: 137
- EPDM (ethylene-propylene diene monomer), 2009 V1: 32, 2012 V4: 30, 83, 84
- epicenters of earthquakes, 2009 V1: 147
- epm (equivalents per million), 2010 V2: 191
- EPM (ethylene propylene terpolymer), 2009 V1: 32
- epoxy, 2009 V1: 32
  - as thermoset, 2012 V4: 39
  - coatings, 2009 V1: 136, 2011 V3: 150
  - fiberglass pipe and, 2012 V4: 53
  - valve coatings, 2012 V4: 83
- epsom salt, 2012 V4: 173. *See also* magnesium sulfate
- equations
  - absolute, atmospheric, and gauge pressure, 2012 V4: 159
  - acfm to scfm, 2011 V3: 62
  - air receiver sizing, 2011 V3: 177–178
  - anode expected life, 2009 V1: 138
  - areas and volumes, 2009 V1: 3–5
  - Bernoulli's equation, 2009 V1: 5–6
  - bioremediation system size, 2012 V4: 229
  - Boyle's law, 2010 V2: 65, 2012 V4: 211–213
  - calculating seismic forces, 2009 V1: 179–180
  - chemical formulas, 2012 V4: 173
  - clean agent weight, 2011 V3: 27
  - coefficients of expansion, 2012 V4: 211
  - Colebrook formula, 2010 V2: 74–75
  - condensate estimates, 2011 V3: 167
  - corrosion rates, 2009 V1: 134
  - CPC solar system, 2011 V3: 196
  - Darcy's Law, 2009 V1: 2, 3, 2010 V2: 6, 74
  - drinking fountain requirements, 2012 V4: 223–224
  - drinking water usage and refrigeration loads, 2012 V4: 222
  - Faraday's Law, 2009 V1: 134
  - fixture flow rates and water softeners, 2012 V4: 187
  - fixture vent design, 2010 V2: 38
  - flash steam, 2011 V3: 157–159
  - flow at outlets, 2009 V1: 3, 5
  - flow capacity in vertical stacks, 2010 V2: 3
  - flow from outlets, velocity of, 2009 V1: 6
  - flow rates, 2009 V1: 1
  - freezing in pipes, 2012 V4: 112–113
  - friction head, 2009 V1: 6, 2010 V2: 61–63
  - friction head loss, 2009 V1: 2
  - gas cylinder capacity, 2011 V3: 268
  - gas expansion and contraction, 2012 V4: 211–213
  - gas laws, 2010 V2: 126
  - gas pressures, 2011 V3: 279
  - gas temperatures, 2011 V3: 279
  - gravity circulation, 2009 V1: 5
  - grease interceptors, 2012 V4: 146–148, 155–156
  - Hazen-Williams formula, 2009 V1: 2, 2010 V2: 6, 73
  - hot-water systems, 2010 V2: 100–101
  - hydrant flow tests, 2011 V3: 4
  - hydraulic shock, 2009 V1: 6
  - insulation and heat loss, 2012 V4: 112–113
  - International System of Units (SI), 2009 V1: 1
  - Joukowski's formula, 2010 V2: 70–71
  - kinetic energy, 2009 V1: 2
  - Manning formula
    - alternative sewage-disposal systems, 2010 V2: 144
    - open-channel flow, 2009 V1: 1, 2010 V2: 6
    - sloping drains, 2010 V2: 7
  - maximum allowable strain, 2012 V4: 205
  - medical gas pipe sizing, 2011 V3: 68–69



- mixing flows of water, 2009 V1: 118
- natural gas pipe sizing, 2010 V2: 130
- Newton's equation, 2012 V4: 146
- Ohm's Law, 2009 V1: 134
- pipe expansion and contraction, 2009 V1: 3, 2012 V4: 205–206
- plumbing cost estimation, 2009 V1: 85–90
- potential energy, 2009 V1: 2
- pump affinity laws, 2009 V1: 6
- pump efficiency, 2009 V1: 6–7
- pump head, 2010 V2: 61–63
- pump head/capacity curves, 2012 V4: 95–97
- rainfall concentration and intensity, 2010 V2: 44
- Rational Method, 2010 V2: 43
- Rational Method formulas, 2009 V1: 7, 2011 V3: 238–239
- references, 2009 V1: 39
- Reynold's number, 2009 V1: 2, 2012 V4: 146
- sizing conveyance piping, 2010 V2: 47
- soil resistivity, 2009 V1: 138
- solar energy, 2011 V3: 193
- Spitzglass formula, 2009 V1: 7, 2010 V2: 130
- sprinkler demand, 2011 V3: 13
- sprinkler design density, 2011 V3: 12
- sprinkler end-head pressures, 2011 V3: 13
- SRTA absorbers, 2011 V3: 195–196
- stack terminal velocity and length, 2009 V1: 3
- steady-state heat balance equations, 2010 V2: 100
- steam velocity, 2011 V3: 159
- Stoke's law, 2012 V4: 146, 178
- storm drainage, 2009 V1: 7
- storm drainage collection inlets and outlets, 2010 V2: 46
- tank volume, 2012 V4: 147
- terminal velocity and terminal length, 2010 V2: 1–2
- thermal efficiency, 2011 V3: 194–195
- thermal expansion and contraction, 2012 V4: 205–206
- vacuum system demand, 2011 V3: 65
- value, worth and cost, 2009 V1: 208
- velocity head, 2009 V1: 5
- vent piping length, 2009 V1: 3
- vent stack sizing, 2010 V2: 36–37
- vibration transmission, 2012 V4: 138–139
- water balance, 2010 V2: 21–22
- water expansion, 2012 V4: 209–211
- water flow in pipes, 2009 V1: 2
- water heating, swimming pools, 2011 V3: 126
- water mass and volume, 2010 V2: 67–68
- water vapor transmission, 2012 V4: 104
- well equilibrium equations, 2010 V2: 157–158
- Weymouth formula, 2009 V1: 7, 2010 V2: 130
- equilibrium equations for wells, 2010 V2: 157–158
- equipment
  - as source of plumbing noise, 2009 V1: 189
  - defined, 2009 V1: 185
  - noise mitigation, 2009 V1: 194–201
  - quality support systems for, 2009 V1: 258
  - section in specifications, 2009 V1: 71
  - seismic protection, 2009 V1: 153–158
  - suspended, 2009 V1: 259
- Equipment for Swimming Pools, Spas, Hot Tubs, and Other Recreational Water Facilities (NSF/ANSI 50)*, 2011 V3: 111, 122
- Equipment Handbook*, ASHRAE, 2011 V3: 204
- equivalent air, defined, 2011 V3: 186
- equivalent direct radiation (edr, EDR)
  - EDR hot water, 2009 V1: 38
  - EDR steam, 2009 V1: 38
- equivalent length
  - compressed air piping, 2011 V3: 182
  - defined, 2010 V2: 136
  - medical gas piping, 2011 V3: 68
  - natural gas piping, 2010 V2: 129
- equivalent run, 2009 V1: 22
- equivalent static force, calculating, 2009 V1: 174
- equivalent weight, 2010 V2: 188, 189
- equivalents per million, 2010 V2: 191
- erected elevations, 2012 V4: 130
- erosion, 2009 V1: 22, 2011 V3: 49, 91, 161, 2012 V4: 173
- erosion corrosion, 2010 V2: 195
- erosion feeders, 2011 V3: 130
- ERW (electric-resistance welding), 2012 V4: 37
- essential facilities, defined, 2009 V1: 185
- estates, septic tank systems for, 2010 V2: 149
- estimating calculations, solar energy, 2011 V3: 193
- estimating costs. *See also* costs and economic concerns
  - factors in estimates, 2009 V1: 89–90
  - idea development and estimated cost forms, 2009 V1: 234
  - overestimating, 2009 V1: 218
  - per-area costs, 2009 V1: 89
  - per-fixture or per-accessory estimates, 2009 V1: 88
  - plumbing cost estimation, 2009 V1: 85–90
  - software for cost estimation, 2009 V1: 89
  - in value engineering, 2009 V1: 235
- estimating medical gas and vacuum stations, 2011 V3: 50–51, 52–53
- Estimating wastewater loading rates using soil morphological descriptions*, 2010 V2: 55
- Estimation of Soil Water Properties, Transactions of the American Society of Agricultural Engineers*, 2010 V2: 55
- ethane, 2010 V2: 114
- ethylene glycol, 2009 V1: 141
- ethylene-propylene diene monomer (EPDM), 2009 V1: 32, 2012 V4: 30, 84
- ethylene propylene terpolymet, 2009 V1: 32
- ethylenechlorotrifluoroethylene, 2009 V1: 32
- EVAC stations, 2011 V3: 52–53
- Evaluation phase in value engineering
  - activities, 2009 V1: 229–235
  - checklists, 2009 V1: 230–231
  - comparing functions, 2009 V1: 235
  - functional evaluation worksheets, 2009 V1: 236–247
  - idea evaluation checklist, 2009 V1: 245
  - in process, 2009 V1: 209
  - second creativity, cost, and evaluation analysis, 2009 V1: 235
- evaporation (evap, EVAP)
  - staged, 2010 V2: 200
  - storage tanks, 2011 V3: 154
- evaporative coolers. *See* cooling-tower water
- evaporative cooling, defined, 2011 V3: 186
- evaporators (evap, EVAP)
  - centralized chilled water systems, 2012 V4: 221

- distillation, 2011 V3: 48
- drinking water coolers, 2012 V4: 220
- flushing in stills, 2012 V4: 193
- evapotranspiration
  - defined, 2009 V1: 22
  - irrigation, 2011 V3: 96
  - sewage treatment, 2010 V2: 145
- events, storm, 2010 V2: 42
- exa prefix, 2009 V1: 34
- exact conversions, 2009 V1: 33
- exam/treatment rooms
  - fixtures, 2011 V3: 38
  - health care facilities, 2011 V3: 36
  - medical gas stations, 2011 V3: 52
  - medical vacuum, 2011 V3: 54
- examination section in specifications, 2009 V1: 64, 71
- excavation
  - labor productivity rates, 2009 V1: 87–88
  - plumbing cost estimation, 2009 V1: 85
- excess air, defined, 2010 V2: 136
- excess flow gas valves, 2010 V2: 118
- excess pressure pumps, 2009 V1: 23
- excess water pressure, 2010 V2: 68–70
- excessive costs, value engineering and, 2009 V1: 208
- exchange capacity of resins, 2010 V2: 206
- exchangers in distillers, 2010 V2: 200
- Execution section in specifications, 2009 V1: 63, 71
- exfiltration, 2009 V1: 22
- exhaust
  - filters on vacuum systems, 2010 V2: 172
  - from vacuum, 2010 V2: 174
  - gas cabinets, 2011 V3: 270
  - gas venting systems, 2010 V2: 118
  - pressure loss in vacuum systems, 2010 V2: 184
  - vacuum exhaust pipe sizing, 2010 V2: 178
  - vacuum system piping, 2010 V2: 169, 2011 V3: 65
  - vacuum system stacks, 2011 V3: 65
- exhausted cartridges in ion exchange, 2010 V2: 208
- exhausters (dry-pipe systems), 2011 V3: 8
- exhausters (vacuum)
  - air-bleed controls, 2010 V2: 179
  - defined, 2010 V2: 179
  - locating, 2010 V2: 181
  - sizing, 2010 V2: 184
- exhaustion, defined, 2012 V4: 201
- existing work
  - defined, 2009 V1: 22
  - surveying existing buildings, 2009 V1: 265–270
- exp, EXP (expansion). *See* expansion
- expanded air in vacuums, 2010 V2: 168
- expanded perlite, 2012 V4: 107
- expanded system volumes, 2012 V4: 209
- expansion (exp, EXP, XPAN)
  - aboveground piping, 2012 V4: 207–208
  - ABS pipes, 2012 V4: 51
  - anchors, 2012 V4: 62
  - as source of plumbing noise, 2009 V1: 189
  - backflow prevention and, 2010 V2: 61
  - buildings, 2011 V3: 50
  - calculating pipe expansion, 2009 V1: 3
  - Capitol Dome, Washington, D.C., 2012 V4: 117
  - converting to SI units, 2009 V1: 38
  - copper, 2012 V4: 211
  - defined, 2012 V4: 205
  - expansion tanks, 2012 V4: 209–213
  - fiberglass pipe, 2012 V4: 53
  - foam extinguishing agents, 2011 V3: 25
  - future expansion of compressed air systems, 2011 V3: 182
  - glass pipe, 2012 V4: 35
  - hangers and supports, 2012 V4: 116
  - HDPE pipe, 2012 V4: 48
  - hot-water systems and, 2010 V2: 106–107
  - insulation, 2012 V4: 113
  - linear expansion in PVC pipe, 2012 V4: 49
  - materials expansion, 2012 V4: 211
  - pipes, 2012 V4: 67
  - plastic pipe, 2012 V4: 50
  - PP-R pipe, 2012 V4: 52
  - protecting against pipe expansion, 2010 V2: 16
  - PVDF pipe, 2012 V4: 52
  - sanitary drainage systems, 2010 V2: 16
  - stainless steel, 2012 V4: 56
  - storage tanks and piping, 2011 V3: 153
  - thermal expansion loops, 2009 V1: 152
  - thermal expansion tanks, 2010 V2: 106
  - water expansion formulas, 2012 V4: 209–211
  - water-pressure regulators, 2012 V4: 80
- expansion bends, 2010 V2: 16
- expansion hook plates, 2012 V4: 65
- expansion joints (EJ)
  - anchoring, 2012 V4: 62
  - defined, 2009 V1: 22
  - DWV pipes, 2012 V4: 207–208
  - roofs, 2010 V2: 49
  - spacing, 2012 V4: 207
  - symbols for, 2009 V1: 10
  - thermal expansion and, 2010 V2: 16, 2012 V4: 206–207
  - types of, 2012 V4: 63, 207
  - use of, 2012 V4: 67
- expansion loops
  - bracing and, 2009 V1: 161
  - defined, 2009 V1: 22
  - loops and offsets, 2012 V4: 206
  - protecting against thermal expansion, 2010 V2: 16
  - use of, 2012 V4: 67
- expansion tanks, 2010 V2: 67–68
  - air cushion expansion and contraction, 2012 V4: 211–213
  - effects of, 2012 V4: 210
  - materials expansion, 2012 V4: 211
  - overview, 2012 V4: 209
  - sizing, 2012 V4: 209, 212
- expert costs, 2009 V1: 218
- explosion-proof water coolers, 2012 V4: 217
- explosions
  - explosion-proof (XP) construction, 2010 V2: 125
  - explosion-relief devices for vacuums, 2010 V2: 179
  - fire-protection systems, 2011 V3: 24
  - hot-water heaters, 2010 V2: 97
  - nitric acid, 2010 V2: 232
- exposed ends of piping, 2012 V4: 25
- extended-coverage sidewall sprinklers, 2009 V1: 29
- extended handles, 2012 V4: 85

- extension riser clamps, 2012 V4: 130
  - external energy, defined, 2011 V3: 185
  - external water treatments, 2012 V4: 174
  - extinguishing systems, 2009 V1: 12
  - extra-hazard occupancies
    - defined, 2009 V1: 28–29, 2011 V3: 2
    - deluge systems, 2011 V3: 9–10
    - firefighting hose streams, 2011 V3: 225
    - portable fire extinguishers, 2011 V3: 29
  - extra-heavy cast-iron soil pipe (XH), 2012 V4: 25–26
  - extra-heavy gaskets, 2012 V4: 57
  - extra-heavy piping, 2009 V1: 22
  - extra materials section in specifications, 2009 V1: 64, 71
  - extra-strong steel pipe, 2012 V4: 37
  - extractors in laundry facilities, 2011 V3: 39
  - extruded steel piping, 2012 V4: 37
  - eye nuts, 2012 V4: 120
  - eye rods, 2012 V4: 130
  - eye sockets, 2012 V4: 124, 130
  - eyeball fittings, fountains, 2011 V3: 102
  - eyewashes for emergencies, 2010 V2: 229, 2011 V3: 36, 41, 2012 V4: 17–18
- F**
- °F, F (Fahrenheit), 2009 V1: 14, 30, 37
  - F (farads), 2009 V1: 34
  - f (femto) prefix, 2009 V1: 34
  - F (fire-protection water supply). *See* fire-protection systems
  - f to f, F TO F (face to face), 2009 V1: 22
  - f-chart sizing method, solar energy, 2011 V3: 196
  - F/m (farads per meter), 2009 V1: 34
  - fabricated steel parts, 2012 V4: 130
  - fabrication, defined, 2012 V4: 130
  - fabrication section in specifications, 2009 V1: 71
  - fabricators, 2012 V4: 130
  - face-to-face dimensions, defined, 2009 V1: 22
  - face washes, 2011 V3: 36, 41
  - Facility Piping System Handbook, 2010 V2: 96, 137, 186, 224, 246, 2011 V3: 156
  - Facility Piping Systems Handbook*, 2010 V2: 55
  - factories
    - numbers of fixtures for, 2012 V4: 20
    - water consumption, 2012 V4: 187
  - factory-beaded pipe, 2012 V4: 61
  - Factory Mutual Research Corporation (FM)
    - abbreviation for, 2009 V1: 32
    - FM Global, 2010 V2: 115
    - publications (discussed)
      - air compressors in dry-pipe systems, 2011 V3: 8
      - design density requirements, 2011 V3: 11
      - seismic protection recommendations, 2009 V1: 177
      - valve standards, 2012 V4: 73, 87
    - publications (listed)
      - Factory Mutual (FM) Loss Prevention Data Sheets*, 2011 V3: 218
      - Global Loss Prevention Data Sheet 6-4: Oil and Gas-fired Single-burner Boilers*, 2010 V2: 117–118
  - Fahrenheit (°F, F)
    - conversion factors, 2009 V1: 37
    - defined, 2009 V1: 30
    - symbols for, 2009 V1: 14
  - fail-safe mixing valves, 2012 V4: 18
  - Failsafe Neutralization of Wastewater Effluent*, 2010 V2: 246
  - failure values of anchors, 2009 V1: 184
  - Fair Housing Accessibility Guidelines*, 2009 V1: 98
  - fairly-rough piping, 2010 V2: 81
  - fairly-smooth piping, 2010 V2: 80
  - fall-off pressure, 2012 V4: 80
  - falloff pressure, 2010 V2: 94
  - Fallon, Carlos, 2009 V1: 252
  - false alarms for sprinkler systems, 2011 V3: 6
  - families, in hot water demand classifications, 2010 V2: 99
  - fan pressurization tests, 2011 V3: 28
  - Faraday's Law, 2009 V1: 129, 134
  - farads, 2009 V1: 34
  - farads per meter, 2009 V1: 34
  - farm animal water consumption, 2012 V4: 187
  - FAST approach to function analysis, 2009 V1: 219–223
  - fats, oils, and grease (FOG). *See also* grease interceptors
    - bioremediation systems, 2012 V4: 227
    - disposal systems, 2012 V4: 145, 152
    - exclusion from wastewater systems, 2010 V2: 21
    - fats in kitchens, 2011 V3: 39
    - grease traps, defined, 2009 V1: 24
    - grease waste drains, 2012 V4: 227
    - interceptors. *See* grease interceptors
    - recombined FOG (fats, oil, and grease), 2012 V4: 227
    - removing grease, 2012 V4: 157–158
  - faucets
    - accessible shower compartments, 2009 V1: 112
    - as source of plumbing noise, 2009 V1: 189
    - backflow prevention, 2012 V4: 12–13
    - centersets, 2012 V4: 10
    - defined, 2009 V1: 22
    - flow rates, 2012 V4: 9, 12
    - health care facilities, 2011 V3: 35
    - leakage, 2009 V1: 126
    - LEED 2009 baselines, 2010 V2: 25
    - low flow, 2009 V1: 127–128
    - noise mitigation, 2009 V1: 193–194
    - patient rooms, 2011 V3: 37
    - reduced water usage, 2009 V1: 118
    - reducing flow rates, 2009 V1: 126
    - residential kitchen sinks, 2012 V4: 11
    - self-metering, 2012 V4: 12
    - sinks, 2009 V1: 109
    - standards, 2012 V4: 2
    - types of, 2012 V4: 12–13
    - wasted water, 2009 V1: 128
    - water usage reduction, 2012 V4: 236
  - faults and fault zones, 2009 V1: 148
  - FC (flexible connectors). *See* flexible connectors
  - FCO (floor cleanouts), 2009 V1: 11
  - FD (floor drains with p-traps), 2009 V1: 11. *See also* floor drains (FD)
  - FDA (Food and Drug Administration), 2010 V2: 220, 224, 227
  - FDS (FOG disposal systems), 2012 V4: 145
  - FE (fire extinguishers), 2009 V1: 14. *See also* under fire-protection systems
  - features, defined, 2009 V1: 33
  - fecal coliform bacteria
    - storm water, 2010 V2: 27

- fecal matter. *See* black-water systems; effluent
- federal agencies. *See* specific agencies under “US”
- Federal Energy Management Improvement Act (FEMIA), 2009 V1: 117
- Federal Food, Drug and Cosmetic Act, 2010 V2: 218
- Federal Register (FR)*, 2011 V3: 82
- federal specifications (FS), 2009 V1: 32, 2012 V4: 225
- Fédération Internationale de Natation Amateur (FINA), 2011 V3: 104
- feed-gas treatment units in ozone generators, 2010 V2: 214
- feed systems, swimming pools, 2011 V3: 127–131
- feed water
- condensate as, 2012 V4: 194
  - defined, 2010 V2: 187
  - distillation, 2012 V4: 194
  - pure-water systems, 2010 V2: 219
  - raw water, defined, 2012 V4: 174
  - raw water as cooling water for stills, 2012 V4: 194
- feedback purifiers, 2012 V4: 194
- feet (ft, FT)
- converting to metric units, 2011 V3: 30
  - converting to SI units, 2009 V1: 38
  - feet per minute (fpm, FPM), 2009 V1: 14, 2011 V3: 30
  - feet per second (fps, FPS), 2009 V1: 14
  - foot-pounds (ft-lb, FT LB), 2009 V1: 14
  - of head, converting, 2009 V1: 2
  - symbols for, 2009 V1: 14
- female threads, 2009 V1: 22
- FEMIA (Federal Energy Management Improvement Act), 2009 V1: 117
- femto prefix, 2009 V1: 34
- Ferguson, Bruce K., 2010 V2: 55
- ferric chloride, 2012 V4: 178
- ferric hydroxide, 2010 V2: 189
- ferric iron, 2010 V2: 189, 2012 V4: 201
- ferric oxide, 2012 V4: 173
- ferric sulfate, 2012 V4: 175, 178
- ferritic stainless steel, 2012 V4: 54
- ferrous bicarbonate, 2010 V2: 189
- ferrous carbonate, 2012 V4: 173
- ferrous iron, 2010 V2: 189, 2012 V4: 201
- ferrous oxide, 2012 V4: 173
- ferrous pipes, 2011 V3: 101
- FF (full-flow conditions), 2009 V1: 1
- FHR (fire hose racks), 2009 V1: 14
- FHV (fire hose valves), 2009 V1: 14
- fiber piping, 2010 V2: 75
- fiber stress in bending, 2012 V4: 205
- fiberglass cloth, skrim, and kraft paper (FSK), 2012 V4: 108
- fiberglass filters, 2011 V3: 273
- fiberglass fixtures, 2012 V4: 1
- fiberglass insulation
- chilled drinking-water systems, 2012 V4: 222
  - freezing points and, 2012 V4: 112–113
  - heat loss, 2012 V4: 106, 107
  - piping, 2012 V4: 105
  - tank insulation, 2012 V4: 110
- fiberglass lagging, 2012 V4: 109
- fiberglass pipe hangers, 2012 V4: 122
- fiberglass-reinforced plastic (FRP)
- cold water systems, 2010 V2: 94
  - exposed piping on storage tanks, 2011 V3: 148
  - fixtures, 2012 V4: 1
  - fuel product dispensing, 2011 V3: 150
  - liquid fuel tanks, 2011 V3: 138
  - plastic pipe, 2012 V4: 53
  - storage tanks, 2011 V3: 147, 155
  - sulfuric acid and, 2011 V3: 85
  - velocity, 2011 V3: 151
  - VOCs and, 2010 V2: 190
- fiberglass-reinforced polyester, 2012 V4: 230
- fiberglass-reinforced storage tanks
- aboveground storage tanks, 2011 V3: 147
  - hazardous wastes, 2011 V3: 84
  - high-purity water, 2010 V2: 223
  - liquid fuel tanks, 2011 V3: 138
  - storage tanks, 2011 V3: 155
- field-beaded pipe, 2012 V4: 61
- field checklists, 2009 V1: 95–96
- field-devised installations, 2009 V1: 254–257
- field-formed concrete grease interceptors, 2012 V4: 153
- field orders, 2009 V1: 57
- field quality control section in specifications, 2009 V1: 64, 72
- field testing cross-connection controls, 2012 V4: 168
- fill
- sewers, 2010 V2: 14–15
  - types of, around building sewers, 2010 V2: 14–15
- fill hoses, 2011 V3: 140
- fill port assemblies (tanks), 2011 V3: 140
- fill ports, 2011 V3: 148
- fill valves, propane tanks, 2010 V2: 133
- filling
- aboveground tank systems, 2011 V3: 148
  - underground liquid fuel tanks, 2011 V3: 139–140
- Filling in the Missing Rainfall Data*, 2010 V2: 55
- film-forming fluoroprotein foams, 2011 V3: 25
- film-processing areas, 2011 V3: 42, 47
- films
- carbonate, 2009 V1: 140
  - film formation in rate of corrosion, 2009 V1: 135
  - sodium hexametaphosphate, 2009 V1: 140
  - sodium silicate, 2009 V1: 140
- filter-ag, 2012 V4: 201
- filter alum, 2010 V2: 199
- filter beds
- defined, 2012 V4: 179
  - problems, 2012 V4: 181
- filter cloths, 2012 V4: 181
- filter intakes, 2011 V3: 62
- filters and filtration
- air compressors, 2011 V3: 180
  - air filters, 2012 V4: 193
  - backsplash cycles, 2012 V4: 180
  - backwashing, 2012 V4: 180, 181
  - chilled drinking-water systems, 2012 V4: 222
  - compressed air systems, 2011 V3: 180
  - defined, 2009 V1: 22, 2012 V4: 175, 179–182, 201
  - diatomaceous earth filters, 2012 V4: 181–182
  - filter elements or media, 2009 V1: 22
  - filtration water systems, 2011 V3: 48
  - fuel dispensers, 2011 V3: 146
  - gas line filters, 2011 V3: 252
  - gravity filters, 2012 V4: 179–180
  - gray water, 2010 V2: 25–27

- infectious waste systems, 2010 V2: 241
- iron filters, 2012 V4: 186
- laboratory gas systems, 2011 V3: 273
- Legionella control, 2010 V2: 110–111
- membrane filtration and separation, 2010 V2: 211–213
- microorganisms, 2010 V2: 214
- nanofiltration, 2012 V4: 199
- oil spills, 2010 V2: 245, 246
- organic removal filters, 2012 V4: 194
- pressure filters, 2012 V4: 180
- pure water systems, 2010 V2: 221
- rainwater, 2012 V4: 237–238
- regenerative alternative media filters, 2011 V3: 122
- small drinking water systems, 2010 V2: 218
- storm drainage treatment, 2010 V2: 48
- swimming pools
  - diatomaceous earth filters, 2011 V3: 119–122
  - filter media rate, 2011 V3: 111
  - high-rate sand filters, 2011 V3: 117–118
  - return piping, 2011 V3: 113
  - types, 2011 V3: 114
  - vacuum sand filters, 2011 V3: 118–119
- turbidity and, 2012 V4: 175, 178
- utility water, 2010 V2: 215
- vacuum systems, 2010 V2: 172, 179
- water quality and, 2010 V2: 159–160
- water treatment, 2010 V2: 201–204, 2012 V4: 179–182
- FINA (Fédération Internationale de Natation Amateur), 2011 V3: 104
- final checklists, 2009 V1: 96
- fine sands
  - graywater irrigation systems and, 2010 V2: 25
  - irrigating, 2011 V3: 91
- fine vacuum, 2010 V2: 165
- finger entrapment in swimming pools, 2011 V3: 105
- finish coats, 2009 V1: 136
- Finnemore, E. John, 2010 V2: 19
- fire departments, 2011 V3: 205
- fire extinguishers (FE), 2009 V1: 14. *See also* under fire-protection systems
- fire hose racks (FHR), 2009 V1: 14
- fire hose valves (FHV), 2009 V1: 14
- fire hydrants. *See* hydrants
- fire loads, 2011 V3: 2
- fire marshals, 2011 V3: 137, 205
- Fire Protection Handbook*, 2011 V3: 30
- fire-protection systems. *See also* sprinkler systems (fire protection)
  - alarms
    - electric gongs, 2011 V3: 7
    - fire alarm control panels, 2009 V1: 12, 2011 V3: 28
    - fire alarm systems, 2009 V1: 22
  - codes and standards, 2009 V1: 42–43
  - detection, 2011 V3: 9, 27
  - extinguishers, 2009 V1: 13
  - fire department connections, 2009 V1: 12, 22
  - fire extinguishers, 2011 V3: 28–29
  - fire hazards
    - defined, 2009 V1: 22
    - evaluation, 2011 V3: 2
    - fire loads and resistance ratings, 2011 V3: 2
    - flammable or volatile liquids, 2010 V2: 12, 244–246
    - oxygen storage areas, 2011 V3: 59
  - fire lines
    - defined, 2009 V1: 23
    - fire-line water meters, 2010 V2: 60
  - fire mains, 2011 V3: 6
  - fire-protection engineers, 2011 V3: 29
  - fire pumps, 2009 V1: 12, 23, 2011 V3: 21–22, 217
  - firefighting equipment, 2009 V1: 13
  - firefighting water drainage, 2010 V2: 243–244
  - flow tests, 2011 V3: 3–4
  - hydrants, 2009 V1: 12, 23, 2011 V3: 220–221
  - other trades and, 2011 V3: 29
  - overview, 2011 V3: 1
  - references, 2011 V3: 30
  - sanitary systems and, 2010 V2: 16
  - seismic protection, 2009 V1: 177
  - special extinguishing systems, 2011 V3: 22–29
    - carbon-dioxide systems, 2011 V3: 26
    - clean agent fire-suppression systems, 2011 V3: 26–28
    - dry-chemical extinguishing systems, 2011 V3: 23–24
    - dry-powder extinguishing systems, 2011 V3: 24
    - elevator shaft protection systems, 2011 V3: 29
    - foam extinguishing systems, 2011 V3: 25–26
    - overview, 2011 V3: 22–23
    - water mist extinguishing systems, 2011 V3: 24–25
    - water spray fixed extinguishing systems, 2011 V3: 24
    - wet chemical extinguishing systems, 2011 V3: 24
  - sprinkler systems. *See* sprinkler systems (fire protection)
  - standpipe systems, 2011 V3: 18, 20–21
  - symbols, 2009 V1: 12–13
  - terminology, 2009 V1: 16–21
  - water lines, 2012 V4: 32
  - water supply for
    - building water supply, 2011 V3: 218–220
    - codes and standards, 2011 V3: 218
    - fire risers, 2011 V3: 12
    - flow rates, 2011 V3: 222–225
    - graphs, 2011 V3: 5
    - guard posts, 2011 V3: 220
    - hydrants, 2011 V3: 220–221
    - hydraulic calculations, 2011 V3: 13
    - joint restrainers, 2011 V3: 221
    - overview, 2011 V3: 218
    - piping system layout, 2011 V3: 6
    - post indicator valves, 2011 V3: 220–221
    - preliminary information, 2011 V3: 205
    - quantity and availability, 2011 V3: 2–6
    - reliability, 2011 V3: 6
    - sizing system, 2011 V3: 221–225
    - standpipe systems, 2011 V3: 21, 2012 V4: 161
    - symbols for water supply (F), 2009 V1: 8
    - tank capacity, 2011 V3: 225
    - valves, 2012 V4: 87–88
    - water demands, 2010 V2: 159, 162
- fire resistance, insulation and, 2012 V4: 104–105, 106
- Fire Resistant Tanks for Flammable and Combustible Liquids (UL 2080)*, 2011 V3: 147
- fire-retardant jackets for pipes, 2012 V4: 56

*Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Conversions, Maintenance, and Operation*, 2010 V2: 137

fire sprinklers. *See* sprinkler systems (fire protection)  
 fire suppression pumps, 2012 V4: 98, 100  
 fire suppression, underground tank systems, 2011 V3: 146–147  
 fire triangle, 2011 V3: 22–23  
 fires  
   classes of, 2011 V3: 2  
   fire triangle, 2011 V3: 22–23  
   growth rate, 2011 V3: 2  
 firm gas services, 2011 V3: 251  
 first aid kits, 2011 V3: 135  
 first-degree burns, 2010 V2: 111  
 first-stage propane regulators, 2010 V2: 132  
 first-stage relief valves, 2011 V3: 274  
 fissures in filter beds, 2012 V4: 181  
 fittings. *See also specific types of fittings*  
   ABS pipe, 2012 V4: 51  
   codes and standards, 2009 V1: 44  
   compressed air, 2011 V3: 181–182  
   compression, 2009 V1: 23  
   copper and bronze, 2012 V4: 30, 39–40  
   copper drainage tubes, 2012 V4: 33, 40  
   copper pipe, 2012 V4: 39–40  
   cross-linked polyethylene, 2012 V4: 49  
   defined, 2009 V1: 23  
   dielectric unions or flanges, 2012 V4: 62  
   domestic pressure drops and, 2011 V3: 214  
   ductile iron water and sewer pipe, 2012 V4: 31  
   earthquake damage, 2009 V1: 152  
   earthquake protection, 2009 V1: 158  
   equivalent lengths for natural gas, 2010 V2: 123  
   erosion, 2011 V3: 161  
   flanged, 2009 V1: 23  
   fountain and pool safety, 2011 V3: 101  
   friction loss and, 2010 V2: 90–91  
   glass pipe, 2012 V4: 36, 41–43  
   grab bars, 2009 V1: 112–114  
   high silicon (duriron) pipe, 2012 V4: 53  
   hub and spigot, 2012 V4: 25–26  
   hubless pipe and fittings, 2012 V4: 26  
   installing insulation, 2012 V4: 110  
   medical gas tube, 2012 V4: 34  
   natural gas pipes, 2011 V3: 256  
   plastic pipes, 2012 V4: 48  
   polypropylene pipe, 2012 V4: 51–52  
   PVC piping, 2012 V4: 49, 52  
   PVDF pipe, 2012 V4: 52  
   radioactive waste systems, 2010 V2: 240  
   screwed fittings, 2009 V1: 152  
   seamless copper water tube, 2012 V4: 30, 39–40  
   stainless steel pipe, 2012 V4: 56  
   standards, 2012 V4: 2  
   tank manways, 2011 V3: 139  
   thermal contraction and expansion failures, 2012 V4: 206  
   types of, 2012 V4: 1  
   vacuum cleaning systems, 2010 V2: 179  
   weight of, 2012 V4: 115  
   welded, 2012 V4: 61

Fitzgerald, 2009 V1: 144  
 fixed compression ratio, defined, 2011 V3: 186  
 fixed costs, in plumbing cost estimation, 2009 V1: 85  
 fixed floor-mounted equipment, 2009 V1: 153–157  
 fixed liquid level gauges, propane tanks, 2010 V2: 133  
 fixed shower heads, 2009 V1: 112  
 fixed suspended equipment, 2009 V1: 157  
 fixture branches, 2009 V1: 23  
 fixture carriers, 2009 V1: 23  
 fixture drains  
   defined, 2009 V1: 23  
   discharge characteristics, 2010 V2: 3  
   flow in, 2010 V2: 2  
   flow rate in, 2009 V1: 3  
   simultaneous use of fixtures, 2010 V2: 3, 4  
 fixture supplies, 2009 V1: 23  
 fixture supply, defined, 2010 V2: 94  
 fixture traps, distance from vent connections, 2010 V2: 32–34  
 fixture units and unit values  
   abbreviations for, 2009 V1: 14  
   cold-water system demand, 2010 V2: 75–76  
   conversion to gpm, 2010 V2: 85, 2011 V3: 209, 226  
   drainage fixture units (dfu), 2009 V1: 23  
   forms for charting, 2010 V2: 86  
   governing fixtures, 2010 V2: 84–89  
   maximum for vertical stacks, 2010 V2: 4  
   minimum sizes of pipes for fixtures, 2010 V2: 86  
   pipe sizing and, 2010 V2: 83  
   sanitary drainage system loads, 2010 V2: 3  
   sizing bioremediation pretreatment systems, 2012 V4: 229  
   slope of drains, 2010 V2: 6–7, 7–8  
   steady flow in horizontal drains, 2010 V2: 8–9  
   water fixture units (wfu), 2009 V1: 23  
   water hammer and, 2010 V2: 72–73  
 fixture vent design, 2010 V2: 38–39  
 fixture vents, types, 2010 V2: 32–34  
 fixtures and fixture outlets. *See also specific types of fixtures (water closets, showers, etc.)*  
   accessibility standards, 2012 V4: 2  
   as source of plumbing noise, 2009 V1: 189  
   batteries of fixtures, 2009 V1: 18  
   building requirement tables, 2012 V4: 20–23  
   codes and standards, 2009 V1: 43–44  
   cold-water system demand, 2010 V2: 75–76  
   defined, 2012 V4: 1  
   domestic water supply and, 2011 V3: 208  
   fixture inventories, 2012 V4: 229  
   fixture isolation, 2012 V4: 170  
   flow rates for water softeners, 2012 V4: 186  
   health care facilities, 2011 V3: 35–42  
   installation productivity rates, 2009 V1: 88  
   laboratory acid-waste drainage systems, 2010 V2: 235  
   LEED (Leadership in Energy and Environmental Design), 2010 V2: 25, 2012 V4: 2  
   materials, 2012 V4: 1–2  
   minimum numbers of, 2012 V4: 20–23  
   noise mitigation, 2009 V1: 193–194  
   per-fixture cost estimation, 2009 V1: 88  
   plumbing cost estimation, 2009 V1: 85  
   plumbing fixtures, defined, 2009 V1: 26

- reduced water usage, 2009 V1: 118
- reducing flow rates, 2009 V1: 126
- sizing vents, 2010 V2: 35–37
- soft water for, 2012 V4: 185
- standards, 2012 V4: 2
- swimming pools and water attractions, 2011 V3: 109
- types of, 2012 V4: 1
- water fixture unit values, 2011 V3: 206
- water-saving fixtures, 2009 V1: 118
- flame arresters, 2011 V3: 141
- flame-retardant pipe (FRPP), 2012 V4: 51
- flammability of gases, 2011 V3: 267
- Flammable and Combustible Liquids Code (NFPA 30)*, 2010 V2: 115, 2011 V3: 88, 136, 148, 149, 156
- flammable, defined, 2009 V1: 23
- flammable gases
  - defined, 2011 V3: 76, 266
  - flash arresters, 2011 V3: 273
  - monitoring, 2011 V3: 275–276
  - table, 2011 V3: 267
- flammable or volatile liquids, 2010 V2: 12, 244–246, 2011 V3: 136
- flanged ells, 2010 V2: 93
- flanged end connections, 2009 V1: 23
- flanged tees, 2010 V2: 93
- flanges
  - assembling flanged joints, 2012 V4: 60
  - defined, 2009 V1: 23
  - dielectric unions or flanges, 2012 V4: 62
  - flange ends, 2009 V1: 23
  - flange faces, 2009 V1: 23
  - flanged bonnets, 2012 V4: 88
  - flanged connections, 2012 V4: 66
  - flanged end connections, 2012 V4: 79–80
  - gaskets, 2012 V4: 63
  - problems in seismic protection, 2009 V1: 184
- flared ends on valves, 2012 V4: 79
- flared fittings, 2012 V4: 39
- flash arresters, laboratory gas systems, 2011 V3: 273
- flash attacks, 2009 V1: 136, 143
- flash fires, 2011 V3: 10
- flash flood runoff patterns, 2010 V2: 43
- flash points
  - defined, 2009 V1: 23, 2011 V3: 76, 136
  - foam extinguishing systems and, 2011 V3: 25
  - liquid fuels, 2011 V3: 136
- flash steam, 2011 V3: 157–159, 166
- flash tanks, 2011 V3: 166
- flashing, 2009 V1: 23
- flashing flanges, 2010 V2: 16
- flashing L flanges, 2010 V2: 16
- flashing rings, 2010 V2: 11, 16, 52
- flat head curves, 2012 V4: 101
- flat-plate collectors, 2011 V3: 190, 193–195
- flat-plate solar collectors, 2009 V1: 121
- flat roof drains, 2010 V2: 52
- flat-spray irrigation sprinklers, 2011 V3: 94
- flexibility
  - couplings, 2012 V4: 63
  - hangers and supports, 2012 V4: 116
  - vibration control and, 2012 V4: 143
- flexible bubbleblers, 2012 V4: 218–219
- flexible connectors (FC)
  - noise mitigation and, 2009 V1: 201, 205
  - symbols for, 2009 V1: 10
  - vibration control devices, 2009 V1: 205
- flexible gas piping, 2010 V2: 122
- flexible hose connections, 2010 V2: 124–125, 2012 V4: 13
- flexible plastic piping, 2011 V3: 150, 2012 V4: 208
- flexural modulus of elasticity, 2012 V4: 205
- flexural offsets or loops, 2012 V4: 205, 206
- flexural strength of plastic pipe, 2012 V4: 50
- float gauges
  - propane tanks, 2010 V2: 133
- float-operated main drain butterfly valves, 2011 V3: 131
- float traps, 2011 V3: 162
- float-type level controls, 2010 V2: 163
- float valves, 2009 V1: 23, 2010 V2: 64, 2012 V4: 194
- floatation, 2009 V1: 24
  - devices for oil spills, 2010 V2: 246
  - of oil in spills, 2010 V2: 246
  - sumps or wet wells, 2011 V3: 236
- floatation vibration isolation, 2009 V1: 157
- floating ball devices in tanks, 2011 V3: 141
- floating velocity, 2012 V4: 146
- floc, 2010 V2: 198, 2012 V4: 201
- flocculation, 2010 V2: 198, 2012 V4: 149
- flood hazard cross-connection controls, 2012 V4: 167
- flood level rims, 2009 V1: 23, 2012 V4: 170
- flooded, defined, 2009 V1: 23
- flooding
  - mosquitoes, 2010 V2: 49
  - runoff patterns, 2010 V2: 43
- flooding factors
  - clean agent gas fire suppression, 2011 V3: 28
  - rainfall, 2011 V3: 240–241
  - underground storage tanks and, 2011 V3: 138
- floor cleanouts (FCO), 2009 V1: 11
- floor drains (FD)
  - acid-resistant floor drains, 2010 V2: 15
  - blood-type, 2011 V3: 38
  - chemical-waste systems, 2010 V2: 243
  - components, 2010 V2: 10
  - fire-suppression drainage and, 2010 V2: 243–244
  - fixture-unit loads, 2010 V2: 3
  - floor leveling around, 2010 V2: 16
  - food-preparation areas, 2011 V3: 39
  - grate open areas, 2010 V2: 10
  - grease interceptors and, 2012 V4: 154
  - health care facilities, 2011 V3: 36, 40
  - infectious and biological waste systems, 2010 V2: 242
  - kitchen areas, 2010 V2: 15–16
  - with p-traps, 2009 V1: 11
  - public areas in health care facilities, 2011 V3: 37
  - radioactive waste systems, 2010 V2: 240
  - rated discharge, 2012 V4: 229
  - sanitary drainage systems, 2010 V2: 10–11
  - standards, 2012 V4: 2
  - submerged inlet hazards, 2012 V4: 161
  - swimming pool bathhouses, 2011 V3: 110
  - types, 2012 V4: 17
  - waterproofing, 2010 V2: 15–16
- floor inlets, swimming pools, 2011 V3: 135
- floor-mounted back-outlet water closets, 2012 V4: 3

- floor-mounted bidets, 2012 V4: 17
- floor-mounted urinals, 2012 V4: 9
- floor-mounted vibration-isolated equipment, 2009 V1: 157–158
- floor-mounted water closets, 2012 V4: 3, 5
- floor sinks, 2010 V2: 10–11, 15, 2012 V4: 229
- floors
  - bathhouses, 2011 V3: 110
  - design considerations in seismic protection, 2009 V1: 180
  - leveling, 2010 V2: 16
  - motions in earthquakes, 2009 V1: 151
  - noise mitigation, 2009 V1: 190, 191
  - noise mitigation design, 2009 V1: 202
  - shaking in earthquakes, 2009 V1: 152
- flotation
  - custom-made grease interceptors, 2012 V4: 153
  - density and particle size, 2012 V4: 148
  - factors in, 2012 V4: 147–148
  - grease separation, 2012 V4: 147–148
  - grease skimming devices, 2012 V4: 151
  - turbulence and, 2012 V4: 150
- flotation basins, 2012 V4: 147–148
- flow. *See also* flow rates
  - at outlet, 2009 V1: 3
  - building drains, 2010 V2: 2
  - critical flows, defined, 2009 V1: 2
  - equalization in graywater treatment, 2010 V2: 25
  - fixture drains, 2009 V1: 3, 2010 V2: 2
  - flow pressure, 2009 V1: 23, 2010 V2: 94
  - flow pressure drop, 2010 V2: 94
  - hydraulic jumps in, 2010 V2: 2, 6, 2010 V2: 35
  - open-channel flow, 2009 V1: 1, 2010 V2: 6
  - outlet velocity, 2009 V1: 6
  - rate of flow, calculating, 2009 V1: 1
  - Rational Method, 2010 V2: 43
  - stacks, 2010 V2: 1–2
  - steady flow, 2010 V2: 6
  - surging flows, 2010 V2: 5
  - symbols for, 2009 V1: 11
  - velocity of uniform flow, 2009 V1: 1
  - water flow in pipes, calculating, 2009 V1: 2
- flow control
  - bioremediation pretreatment systems, 2012 V4: 229
  - grease interceptors, 2012 V4: 154–155
  - swimming pools, 2011 V3: 114–115, 125–126
- flow diversity factors (gas systems), 2010 V2: 121
- flow hydrants, 2011 V3: 3
- flow meters
  - compressed air systems, 2011 V3: 177
  - laboratory gas systems, 2011 V3: 275
- flow rates
  - air flow in vacuum pressure, 2010 V2: 165
  - altitude and, 2010 V2: 167
  - at outlets, 2009 V1: 5
  - capacity, 2009 V1: 19, 34
  - coagulation and, 2012 V4: 179
  - cold-water systems, 2010 V2: 69–70, 73
  - compressed air systems
    - air compressors, 2011 V3: 179
    - air-consuming devices, 2011 V3: 180
    - measurements, 2011 V3: 172, 187
    - tools and equipment, 2011 V3: 180
  - conserving energy, 2009 V1: 118
  - conversion factors, 2009 V1: 36
  - defined, 2012 V4: 201
  - domestic water supply, 2011 V3: 206
  - drinking fountains, 2012 V4: 221
  - emergency showers and eyewashes, 2012 V4: 18
  - faucets, 2012 V4: 12
  - filtration and, 2012 V4: 179, 180
  - fire-protection demand, 2011 V3: 222–225
  - fixture drains, 2009 V1: 3
  - fixture rate averages, 2012 V4: 186
  - fluctuating flows in horizontal drains, 2010 V2: 5
  - fountain systems, 2011 V3: 100
  - freezing points and, 2012 V4: 112–113
  - fuel product dispensers, 2011 V3: 146
  - gas boosters, 2010 V2: 125, 127
  - gas meters, 2010 V2: 116–117
  - grease interceptors, 2012 V4: 149, 155
  - high-rate dispensers, 2011 V3: 151
  - hydrants, 2011 V3: 210
  - kitchen sinks, 2012 V4: 11
  - laboratory gas systems, 2011 V3: 279
  - lavatories, 2012 V4: 9
  - liquid fuel piping, 2011 V3: 150–151
  - measurements, 2009 V1: 34, 2010 V2: 166
  - medical air, 2011 V3: 69
  - medical gas, 2011 V3: 51
  - medical oxygen, 2011 V3: 68–69
  - medical vacuum, 2011 V3: 69, 73
  - natural gas systems, 2010 V2: 127–128, 2011 V3: 256
  - nitrogen, 2011 V3: 64, 69
  - nitrous oxide, 2011 V3: 69
  - pump capacity, 2009 V1: 6
  - pump head/capacity curves, 2012 V4: 95–97
  - rate of flow, calculating, 2009 V1: 1
  - reducing for fixtures, 2009 V1: 126
  - resin bead regeneration, 2010 V2: 207
  - retention periods and, 2012 V4: 147
  - RPZ discharge, 2010 V2: 60–61
  - sand filters, 2012 V4: 180
  - sewage life stations, 2011 V3: 236
  - showers, 2012 V4: 13
  - sizing gas systems, 2011 V3: 278
  - special-waste drainage systems, 2010 V2: 228
  - sprinkler hydraulic calculations, 2011 V3: 12
  - steam, 2011 V3: 159–161
  - submersible fuel pumps, 2011 V3: 151–152
  - swimming pools, 2011 V3: 111, 112
  - tables, 2011 V3: 14–17
  - urinals, 2012 V4: 8
  - vacuum cleaning systems, 2010 V2: 181
  - vacuum exhauster sizing, 2010 V2: 184
  - vacuum systems, 2010 V2: 166, 174
  - valves and fittings, 2010 V2: 95
  - water closets, 2012 V4: 6
  - water coolers, 2012 V4: 215–216
  - water fountains, 2009 V1: 101
  - water heater types and, 2010 V2: 101–104
  - water-pressure regulators, 2012 V4: 80
  - water softeners, 2012 V4: 185–186, 186
  - weirs and waterfalls, 2011 V3: 100
  - wells, 2010 V2: 164



- flow regulators, 2012 V4: 201
- flow restrictors, 2009 V1: 118
- flow sensors, swimming pools, 2011 V3: 114–115, 124–125
- flow switches (FS), 2009 V1: 10
- flow tests
  - equations, 2011 V3: 4
  - fire-protection systems, 2011 V3: 3–4
  - hydrants, 2011 V3: 210
  - medical gas systems, 2011 V3: 74
- flow-through periods for grease interceptors, 2012 V4: 147
- FlowGuard Gold Connection, 2009 V1: 206
- flowing pressure. *See* residual pressure
- Flowserve, 2010 V2: 96
- fluctuating flows in horizontal drains, 2010 V2: 5
- flue gases, 2010 V2: 119, 136
  - venting, 2010 V2: 118–119
- flues, 2009 V1: 24
- Fluid Mechanics with Engineering Applications*, 2010 V2: 19
- flumes, 2011 V3: 134
- fluoride, 2010 V2: 160, 190
- fluorine, 2010 V2: 189
- fluorine rubber, 2009 V1: 32
- fluoroprotein-mixed chemical concentrates, 2011 V3: 25
- flurine rubber, 2009 V1: 32
- flush controls
  - urinals, 2009 V1: 108
  - water closet and toilet accessibility, 2009 V1: 106
  - water closet requirements, 2009 V1: 108
- flush sprinklers, 2009 V1: 29
- flush tanks, 2010 V2: 75–76
- flush valves. *See also* flushometer valves
  - defined, 2009 V1: 24
  - fixture units and, 2010 V2: 75–76
  - noise mitigation, 2009 V1: 198
  - vacuum breakers, 2012 V4: 166
  - wasted water and, 2009 V1: 127
- flushing
  - cold-water systems, 2010 V2: 90–91
  - compressed air systems, 2011 V3: 183
  - laboratory gas systems, 2011 V3: 280
  - performance testing, 2012 V4: 4–5
  - resin beds, 2010 V2: 208
  - in reverse osmosis, 2012 V4: 196
  - urinal tests, 2012 V4: 8
  - water closet system types, 2012 V4: 6–8
  - water conservation and toilets, 2012 V4: 2
  - water systems, 2010 V2: 164
- flushing rim sinks, 2010 V2: 86
- flushing rims, 2010 V2: 15
- flushing-type floor drains, 2009 V1: 24
- flushometer tanks, 2012 V4: 3, 6–7
- flushometer valves
  - defined, 2009 V1: 24, 2012 V4: 3, 7–8, 170
  - sanitation and, 2010 V2: 15
  - urinals, 2012 V4: 8–9
- flushometer water closets, 2012 V4: 3, 6–8
- flux (filtration)
  - defined, 2012 V4: 201
  - membrane productivity, 2010 V2: 221
  - natural osmosis, 2010 V2: 211
  - reverse osmosis, 2012 V4: 196
- flux (soldering), 2012 V4: 59
  - defined, 2009 V1: 24
  - laboratory gas joints, 2011 V3: 277
  - standards, 2012 V4: 30
- fly ash, 2012 V4: 230
- FM. *See* Factory Mutual Research Corporation (FM)
- FMRC (Factory Mutual). *See* Factory Mutual Research Corporation (FM)
- foam extinguishing systems, 2011 V3: 25–26, 29
- foam noise isolation, 2009 V1: 194
- Foam-water Sprinkler Systems and Foam-water Spray Systems (NFPA 16)*, 2011 V3: 30
- foam-water sprinklers, 2011 V3: 25
- foamed elastomer insulation, 2012 V4: 107
- foamed plastic insulation, 2012 V4: 106, 111
- FOG (fats, oil, and grease). *See* fats, oils, and grease (FOG)
- FOG disposal systems (FDS), 2012 V4: 145
- fog nozzles, 2010 V2: 230
- fogging in swimming pools, 2011 V3: 108
- Follow-up phase in value engineering, 2009 V1: 209
- Fontana, Mars G., 2009 V1: 144
- Food and Drug Administration (FDA), 2010 V2: 220, 224, 227, 2012 V4: 70
- food dyes in gray water, 2010 V2: 27
- food-processing areas and kitchens
  - drains, 2010 V2: 15–16
  - fixture pipe sizes and demand, 2010 V2: 86
  - flexible gas connections, 2010 V2: 124
  - gas demands for appliances, 2010 V2: 116
  - gas efficiency, 2010 V2: 115
  - health care facility fixtures, 2011 V3: 39
  - medical gas piping and, 2011 V3: 68
  - numbers of fixtures for, 2012 V4: 20
  - rates of sewage flows, 2010 V2: 151
  - sanitation, 2010 V2: 15
  - sewage estimates, 2010 V2: 151
  - typical graywater demand, 2010 V2: 24
  - water fixture-unit values, 2011 V3: 206
  - water temperatures, 2011 V3: 47
- food-processing plants, 2010 V2: 218
- food solids removal in bioremediation systems, 2012 V4: 228
- food waste grinders (disposals), 2010 V2: 152
  - bioremediation systems and, 2012 V4: 228
  - defined, 2009 V1: 21
  - fixture-unit loads, 2010 V2: 3
  - grease interceptors and, 2012 V4: 154, 157
  - sink outlets and, 2012 V4: 11
- foot (FT), 2009 V1: 14. *See also* feet (ft, FT)
- foot basins, 2010 V2: 99
- foot controls on faucets, 2011 V3: 35
- foot head (ft.hd), 2009 V1: 14
- foot pedals
  - nitrogen systems, 2011 V3: 64
  - water coolers, 2012 V4: 218
- foot-pounds (ft-lb, FT LB), 2009 V1: 14
- foot valves, 2009 V1: 24, 2010 V2: 92
- footing drains (subsoil drains, SSD), 2009 V1: 8, 24, 30
- footings of buildings
  - defined, 2009 V1: 24
- FOR (fuel oil return), 2009 V1: 8
- force
  - conversion factors, 2009 V1: 35

- factors in seismic force calculations, 2009 V1: 174–177
- measurements, 2009 V1: 34
- in seismic design, 2009 V1: 182
- in vibration transmission, 2012 V4: 137
- force mains, 2009 V1: 24
  - defined, 2011 V3: 229
  - illustrated, 2011 V3: 234–235
  - manholes, 2011 V3: 226
  - sanitary sewer systems, 2011 V3: 225
  - sewage lift stations, 2011 V3: 236
- forced-air-cooled compressors, 2012 V4: 220
- forced-air vaporizers, 2011 V3: 57
- forced convection, defined, 2011 V3: 191
- forced distortions of piping, 2009 V1: 152
- forced drainage (corrosion), defined, 2009 V1: 143
- forcing functions in earthquakes, 2009 V1: 150
- forcing pipes, 2012 V4: 25
- forest, runoff, 2010 V2: 42
- forged clevises, 2012 V4: 130
- formazin turbidity unit, 2010 V2: 193
- forms. *See* checklists and forms
- formula rooms, 2011 V3: 36
- formulas. *See* equations
- forward approaches and reaches
  - approaches for wheelchairs, 2009 V1: 102
  - drinking fountains and water coolers, 2009 V1: 99
  - reach for wheelchairs, 2009 V1: 99–101, 103
- FOS (fuel oil supply), 2009 V1: 8
- fossil fuel use, 2011 V3: 188
- fouling factor, 2009 V1: 24
- fouling of water, 2010 V2: 195, 217, 2011 V3: 162
- Foundation for Cross-Connection Control and Hydraulic Research, 2011 V3: 216
- foundations of pumps, 2010 V2: 158, 161
- fountains
  - codes and standards, 2011 V3: 100–101
  - direct connections, 2012 V4: 161
  - drinking. *See* drinking fountains
  - equipment location, 2011 V3: 98–99
  - interactive, 2011 V3: 100
  - overview, 2011 V3: 98
  - pool design, 2011 V3: 98
  - pumps, 2011 V3: 99
  - safety, 2011 V3: 100
  - sump pumps, 2011 V3: 100–102
  - surface skimmer, 2011 V3: 102
  - wastewater in, 2010 V2: 21
- four-way braces, 2012 V4: 130
- FOV (fuel oil vents), 2009 V1: 8
- FPM (fluorine rubber), 2009 V1: 32
- fpm, FPM (feet per minute), 2009 V1: 14, 2011 V3: 30
- fps, FPS (feet per second), 2009 V1: 14
- FR (Federal Register), 2011 V3: 82
- fracture rooms, 2011 V3: 36, 39
- framing drawings for facilities, 2011 V3: 35
- framing steel, 2012 V4: 130
- Francis formula, 2011 V3: 100
- Frankel, Michael, 2010 V2: 55, 96, 137, 186, 224, 246, 2011 V3: 156
- Franzini, Joseph B., 2010 V2: 19
- Frederick, Ralph H., 2010 V2: 55
- free air
  - defined, 2011 V3: 186
  - properties, 2011 V3: 171, 263, 264
  - water vapor in, 2011 V3: 172–173
- free board, 2012 V4: 201
- free convection, defined, 2011 V3: 191
- free-floating oils, 2011 V3: 88
- free oil, 2010 V2: 244
- free residuals, 2012 V4: 177
- free-standing surge vessels, 2011 V3: 116
- free-standing water coolers, 2012 V4: 216, 218
- free vibration, 2009 V1: 150
- free water surface, 2012 V4: 170
- freeboard in ditches, 2011 V3: 250
- freestanding siamese fire-department connections, 2009 V1: 12
- freestanding sprinklers in irrigation, 2011 V3: 93
- freezing points (fp, FP)
  - insulation and, 2012 V4: 112–113
  - plastic pipe, 2012 V4: 48
  - prevention calculations, 2012 V4: 112–113
  - regional requirements for plumbing installations, 2009 V1: 262
- freezing, preventing in cleanouts, 2010 V2: 9
- freezing temperatures
  - calculations for, 2012 V4: 112–113
  - chilled drinking-water systems, 2012 V4: 221
  - dry-pipe sprinkler systems and, 2011 V3: 6, 7
  - frost lines, 2011 V3: 218, 220
  - ice and oxygen storage, 2011 V3: 57
  - ice as part of total load, 2012 V4: 115
  - ice inside water storage tanks, 2010 V2: 162
  - insulation and, 2012 V4: 112–113
  - irrigation system valves and, 2011 V3: 95
  - testing of cold-water systems, 2010 V2: 90
  - water meters and, 2010 V2: 59
  - well heads and, 2010 V2: 158–159
- Freije, M., 2010 V2: 108–109
- french drains, 2009 V1: 24
- frequencies (Hz, HZ)
  - defined, 2012 V4: 137
  - disturbing vibrations, 2012 V4: 137
  - frequency ratios in vibration control, 2012 V4: 138–139
  - measurements, 2009 V1: 34
  - natural frequency of resilient mounted systems, 2012 V4: 137
- frequency of ion regeneration cycles, 2010 V2: 208
- fresh-air inlets, 2009 V1: 24
- fresh water makeup, swimming pools, 2011 V3: 116, 132–133
- friction clamps, 2011 V3: 221
- friction factor, 2009 V1: 24
- friction head
  - calculating, 2009 V1: 6
  - centralized drinking-water cooler systems, 2012 V4: 223
  - defined, 2012 V4: 101
- friction loads, 2012 V4: 130
- friction losses in flow
  - bends in pipe and, 2012 V4: 61
  - calculating friction head loss, 2009 V1: 2
  - compressed air, 2011 V3: 72–73, 181
  - compressed air systems, 2011 V3: 181
  - examples for pipe sizing, 2010 V2: 87–89

fuel dispensers, 2011 V3: 151  
 Hazen-Williams formula, 2009 V1: 2, 2010 V2: 73  
 liquid fuel piping, 2011 V3: 151  
 medical air, 2011 V3: 63, 69, 72–73  
 medical gas piping, 2011 V3: 68  
 medical vacuum systems, 2011 V3: 69, 73  
 natural gas systems, 2010 V2: 127–128, 2011 V3: 256  
 nitrogen systems, 2011 V3: 69, 71  
 nitrous oxide, 2011 V3: 69, 71  
 oxygen, 2011 V3: 68–69, 71  
 pipe pressure and, 2010 V2: 78–84  
 pressure and, 2010 V2: 87  
 reduced pressure zones, 2010 V2: 61–63  
 sizing pipes and, 2010 V2: 78–84  
 submersible fuel pumps, 2011 V3: 151  
 vacuum cleaning systems, 2010 V2: 181–184, 184  
 vacuum exhauster sizing, 2010 V2: 184  
 valves and threaded fittings, 2010 V2: 90–91  
 vent systems, 2010 V2: 35  
 water in pipes, tables, 2012 V4: 225  
 water mains, 2011 V3: 6  
 well pumps, 2010 V2: 161  
 front-end documents, 2009 V1: 57, 58  
 frost. *See* freezing temperatures  
 frost lines, 2011 V3: 218, 220  
 frostproof devices, 2009 V1: 24  
 FRP. *See* fiberglass-reinforced plastic  
 FRPP (flame-retardant pipe), 2012 V4: 51  
 FS (federal specifications), 2009 V1: 32  
 FS (flow switches), 2009 V1: 10  
 FSK (fiberglass cloth, skrim and kraft paper), 2012 V4: 108  
 ft, FT (feet). *See* feet  
 ft-lb, FT LB (foot-pounds), 2009 V1: 14  
 FT<sup>3</sup> (cubic feet), 2009 V1: 14  
 ft.hd (foot head), 2009 V1: 14  
 FTUs (formazin turbidity units), 2010 V2: 193  
 fu values. *See* fixture units and unit values  
 fuel double containment systems, 2012 V4: 39  
 fuel gas codes, list of agencies, 2009 V1: 42  
*Fuel Gas Piping*, 2010 V2: 136  
 fuel-gas piping systems. *See also* diesel-oil systems;  
     gasoline systems  
     fuel gas, defined, 2010 V2: 136  
     glossary, 2010 V2: 135–136  
     liquefied petroleum gas, 2010 V2: 131–135, 135  
     methane, 2009 V1: 122  
     natural gas systems, 2010 V2: 113–131, 2012 V4: 32, 34  
 fuel, in fire triangle, 2011 V3: 22–23  
 fuel islands, 2011 V3: 146  
 fuel loads (fire hazards), 2011 V3: 2  
 fuel oil  
     calculation, solar energy and, 2011 V3: 190  
     copper pipe, 2012 V4: 32  
     fuel oil return (FOR), 2009 V1: 8  
     fuel oil supply (FOS), 2009 V1: 8  
     fuel oil vents (FOV), 2009 V1: 8  
     pipe bracing, 2009 V1: 158, 159  
 fuel-storage tanks, 2011 V3: 154  
 full-flow conditions (FF), 2009 V1: 1  
 full port (100% area), 2012 V4: 89  
 full-port ball valves, 2011 V3: 67, 2012 V4: 75  
 fully recessed water coolers, 2012 V4: 217–218, 218

fully-sprinklered spaces, 2009 V1: 12  
 fume hoods, 2010 V2: 240  
 fumes, hazardous. *See also* gases  
     acid-waste drainage systems, 2011 V3: 42  
     acids, 2010 V2: 229, 231  
     in soil profiles, 2011 V3: 144  
     vent piping, 2011 V3: 46  
     VOCs, 2010 V2: 190  
 fuming grade sulfuric acid, 2010 V2: 230  
 Function Analysis phase in value engineering  
     defined, 2009 V1: 218–223  
     FAST approach, 2009 V1: 219–223  
     function definitions forms, 2009 V1: 219–224, 222  
     in process, 2009 V1: 209  
     rules, 2009 V1: 218–223  
 Function phase in value engineering, 2009 V1: 209  
 Functional Analysis System Technique (FAST), 2009 V1:  
     219–223  
 functions  
     basic or secondary, 2009 V1: 219  
     comparing in evaluation phase, 2009 V1: 235  
     cost-to-function relationship, 2009 V1: 219  
     defined, 2009 V1: 218  
     evaluation checklists, 2009 V1: 230–231  
     in evaluation phase, 2009 V1: 229  
     in FAST approach, 2009 V1: 223  
     interrelationships, 2009 V1: 219  
     levels of importance, 2009 V1: 218  
     ranking and comparing, 2009 V1: 235  
     sketches of, 2009 V1: 232–233  
     specific and dependent, 2009 V1: 219  
     two-word expressions, 2009 V1: 218  
 fundamental corrosion cells, defined, 2009 V1: 129  
*Fundamentals Handbook*, 2011 V3: 169, 204  
*Fundamentals of Underground Corrosion Control*, 2009  
     V1: 144  
 fungi, 2010 V2: 188, 195  
 funnel-type drains, 2010 V2: 243, 2011 V3: 42  
 furring-out requirements for roofs, 2010 V2: 51  
 fusible link sprinklers, 2011 V3: 6  
 fusion-joint plastic piping systems, 2011 V3: 46  
 future expansion of compressed air systems, 2011 V3: 182

## G

G (giga) prefix, 2009 V1: 34  
 G (low-pressure gas), 2009 V1: 8  
 G pipes, 2012 V4: 32, 34  
 ga, GA (gauges). *See* gauges  
 GACs (granulated carbon filters), 2010 V2: 218, 221. *See also* activated carbon filtration  
 gages (ga, GA, GAGE). *See* gauges  
 gal, GAL (gallons). *See* gallons (gal, GAL)  
 gallons (gal, GAL)  
     converting to metric units, 2011 V3: 30  
     converting to SI units, 2009 V1: 38  
     gallons per day (gpd, GPD), 2009 V1: 14  
     gallons per hour (gph, GPH), 2009 V1: 14, 38, 2010 V2:  
         98–99  
     gallons per minute (gpm), 2009 V1: 14, 2010 V2: 85, 156  
         converting to fixture units, 2011 V3: 209, 226  
         converting to metric units, 2011 V3: 30  
         estimating demand, 2010 V2: 76

- pressure and, 2010 V2: 73, 74
  - grains per gallon (gpg), 2010 V2: 191
  - symbols for, 2009 V1: 14
- galvanic action, 2009 V1: 24, 2012 V4: 66. *See also*
  - electrolysis
- galvanic anodes, 2009 V1: 137–139
- galvanic cells, defined, 2009 V1: 143
- galvanic corrosion, 2009 V1: 130, 143, 256, 2010 V2: 195
- galvanic series of metals
  - defined, 2009 V1: 143
  - dielectric insulation and, 2009 V1: 136
  - listing, 2009 V1: 132
- galvanized coatings, 2009 V1: 136
- galvanized-iron piping, 2010 V2: 13, 78
- galvanized-steel piping, 2010 V2: 122
  - aboveground piping, 2010 V2: 12
  - fuel product dispensing and, 2011 V3: 150
  - vacuum systems, 2010 V2: 173
- galvanizing, defined, 2009 V1: 24, 2012 V4: 130
- galvomag alloy, 2009 V1: 132
- gamma ray radiation, 2010 V2: 236–237, 237
- gang hangers, 2012 V4: 130
- garages, sediment buckets and, 2010 V2: 11
- garbage can washers, 2012 V4: 161
- garbage disposers. *See* food waste grinders
- garnet in filters, 2010 V2: 201
- Garrett, Laurie, 2010 V2: 55
- gas. *See* gases; medical gas systems; natural gas systems;
  - specific types of gases
- gas boosters, 2010 V2: 119, 125–128
- gas cabinets, 2011 V3: 268–270
- gas chlorinators, 2012 V4: 177
- gas contamination in air, 2011 V3: 265
- gas expansion and contraction, 2012 V4: 211–213
- gas-fired water heaters
  - conserving energy, 2009 V1: 121
  - defined, 2009 V1: 120
  - efficiency, 2010 V2: 97–98
  - net efficiency of, 2009 V1: 121
- gas horsepower, defined, 2011 V3: 186
- gas laws, 2010 V2: 126
- gas logs, defined, 2010 V2: 136
- gas meters, 2010 V2: 115–117
- gas mixers, laboratory gas systems, 2011 V3: 276
- gas piping codes, 2009 V1: 42
- gas piping systems. *See also* fuel-gas piping systems;
  - gasoline systems; liquefied petroleum gas; natural gas systems
- bracing, 2009 V1: 159
- defined, 2009 V1: 185
- gas cocks, 2009 V1: 9
- gas line earthquake-sensitive valves, 2009 V1: 153
- gas main inspection checklist, 2009 V1: 95
- gas pressure regulators, 2010 V2: 136, 2011 V3: 254–255
- gas stops (gas cocks), 2009 V1: 9
- gas trains, 2010 V2: 136, 2011 V3: 255
- gas vents (GV), 2009 V1: 8
  - high-pressure (HG), 2009 V1: 8
  - line filters, 2011 V3: 252–254
  - low-pressure (G), 2009 V1: 8
  - medium-pressure (MG), 2009 V1: 8
  - operating pressure, 2010 V2: 115
  - plastic pipes, 2012 V4: 42
  - services at laboratory outlets, 2011 V3: 41–42
  - Spitzglass formula, 2009 V1: 7, 2010 V2: 130
  - Weymouth formula, 2010 V2: 130
- gas regulator relief vents, 2010 V2: 117–118
- gas regulators, 2010 V2: 119–121
- gas-shielded welding, 2012 V4: 61
- gas stations, 2011 V3: 147
- gas stripping, 2010 V2: 194
- gas systems
  - medical gas levels, 2011 V3: 34–35
  - tank abandonment and removal, 2011 V3: 154
- gas-train vents, 2010 V2: 117–118
- gas-transfer vacuum pumps, 2010 V2: 169
- Gas Utilization Equipment for Large Boilers*, 2010 V2: 115
- gas venting, 2010 V2: 118–119, 136
- gas warmers, 2011 V3: 275
- gas water heating, 2011 V3: 126
- gaseous (clean agent) fire suppression systems, 2011 V3: 26–28
- gases. *See also* fuel-gas piping systems; liquefied petroleum
  - gas; natural gas systems
  - as fluids, 2011 V3: 171
  - combustion properties, 2010 V2: 114
  - contamination in compressed air, 2011 V3: 174
  - dissolved gases in water, 2010 V2: 190
  - grades of, 2011 V3: 267
  - hazardous, 2010 V2: 229
  - heavier-than-air, 2010 V2: 134–135
  - laboratory gas systems. *See* laboratory gas systems
  - nitrous fumes, 2010 V2: 232
  - sulfuric acid, 2010 V2: 232
  - volatile organic compounds, 2010 V2: 190
- gaskets
  - defined, 2012 V4: 63
  - fire-protection water supply, 2011 V3: 221
  - fuel piping, 2011 V3: 150
  - special-waste systems, 2010 V2: 228
- gasoline, 2010 V2: 12, 2011 V3: 136, 149
- gasoline blends, 2011 V3: 136, 149
- gasoline systems
  - aboveground tank systems, 2011 V3: 147–149
    - connections and access, 2011 V3: 148
    - construction, 2011 V3: 147–148
    - corrosion protection, 2011 V3: 148
    - filling and spills, 2011 V3: 148
    - leak prevention and monitoring, 2011 V3: 148–149
    - materials, 2011 V3: 147–148
    - overflow prevention, 2011 V3: 148
    - product dispensing systems, 2011 V3: 149
    - tank protection, 2011 V3: 149
    - vapor recovery, 2011 V3: 149
    - venting, 2011 V3: 148
  - codes and standards, 2011 V3: 137
  - components, 2011 V3: 138
  - definitions and classifications, 2011 V3: 136–137
  - designing
    - installation considerations, 2011 V3: 154–156
    - piping materials, 2011 V3: 149–151
    - piping sizing, 2011 V3: 150–151
    - submersible pump sizing, 2011 V3: 151–152
    - testing, 2011 V3: 152–154

- overview, 2011 V3: 136
- references, 2011 V3: 156
- resources, 2011 V3: 156
- underground tank systems, 2011 V3: 139–140
  - leak detection and system monitoring, 2011 V3: 141–145
  - product dispensing systems, 2011 V3: 146–147
  - storage tanks, 2011 V3: 139–140
  - vapor recovery systems, 2011 V3: 145–146
- valves, 2012 V4: 87
- gate valves (GV), 2009 V1: 9, 2010 V2: 92, 95, 230
  - defined, 2012 V4: 89
  - fire-protection systems, 2012 V4: 87–88
  - high-pressure steam service, 2012 V4: 86–87
  - high-rise service, 2012 V4: 88
  - hot and cold water supply service, 2012 V4: 83
  - illustrated, 2012 V4: 73
  - low-pressure steam systems, 2012 V4: 85
  - medium-pressure steam service, 2012 V4: 86
  - noise mitigation, 2009 V1: 194
  - stems, 2012 V4: 79
- gauges (ga, GA, GAGE)
  - Boyle's law, 2012 V4: 211–213
  - fuel product level gauging, 2011 V3: 148, 149
  - gauge pressure, 2010 V2: 165, 2011 V3: 186
  - hazardous materials, 2011 V3: 84
  - laboratory gas systems, 2011 V3: 273
  - medical gas systems, 2011 V3: 67
  - pressure, 2011 V3: 172
  - propane tanks, 2010 V2: 133
- gear pumps, 2010 V2: 162
- Geiger-Mueller counters, 2010 V2: 237
- gel-coated plastic fixtures, 2012 V4: 1
- general conditions in contract documents, 2009 V1: 56
- General Conditions of the Contract for Construction*, 2009 V1: 56
- General Conference of Weights and Measures (CGPM), 2009 V1: 32, 33
- general corrosion, 2009 V1: 143, 2010 V2: 195
- General Electric Company, 2009 V1: 207
- general laboratory-grade water, 2010 V2: 218
- General phase in value engineering, 2009 V1: 209
- General section in specifications, 2009 V1: 62–63
- general service system valves, 2012 V4: 85–86
- generalized total costs, 2009 V1: 217
- generally-accepted standards, defined, 2009 V1: 24
- Geoghegan, R.F., 2010 V2: 246
- geography
  - cost estimates and, 2009 V1: 90
  - in plumbing cost estimation, 2009 V1: 86
- geological stability of sites, 2010 V2: 24
- geothermal energy, 2009 V1: 122–123
- Get Your Process Water to Come Clean*, 2010 V2: 225
- GFCI (government furnished, contractor installed), 2009 V1: 64
- giga prefix, 2009 V1: 34
- gland bushing, 2012 V4: 89
- glass borosilicate piping, 2010 V2: 13, 14, 75
- glass-bulb sprinklers, 2011 V3: 6
- glass-fiber pads, 2009 V1: 198
- glass fixtures, 2012 V4: 1
- glass-foam insulation, 2012 V4: 106
- glass-lined pipes, 2011 V3: 49
- glass piping
  - characteristics, 2012 V4: 34–35
  - expansion, 2012 V4: 35
  - fittings, 2012 V4: 36, 41–43
  - hangers, 2012 V4: 122
  - joints, 2012 V4: 61
  - roughness, 2010 V2: 78
  - special wastes, 2010 V2: 234, 239
  - standards, 2012 V4: 68–69
- glass washers
  - demineralized water, 2011 V3: 48
  - health care facilities, 2011 V3: 36, 39
  - laboratory rooms, 2011 V3: 41
  - pure water systems for, 2011 V3: 48
- glauber's soda, 2012 V4: 173
- glazed fixture surfaces, 2012 V4: 1
- Glidden, R., 2010 V2: 186
- Global Loss Prevention Data Sheet 6-4: Oil and Gas-fired Single-burner Boilers*, 2010 V2: 117–118
- globe-style lift check valves, 2012 V4: 76–77
- globe valves (GLV), 2009 V1: 9, 2010 V2: 92, 95
  - defined, 2012 V4: 74–75, 89
  - high-pressure steam service, 2012 V4: 87
  - hot and cold water supply service, 2012 V4: 83–84
  - low-pressure steam systems, 2012 V4: 85–86
  - medium-pressure steam service, 2012 V4: 86
  - stems, 2012 V4: 79
- glossaries
  - cold water systems, 2010 V2: 94–95
  - compressed air systems, 2011 V3: 183–187
  - conserving energy, 2009 V1: 128
  - corrosion, 2009 V1: 141–143
  - cross connections, 2012 V4: 169–171
  - fuel-gas systems, 2010 V2: 135–136
  - hangers and supports, 2012 V4: 125–136
  - health care facilities, 2011 V3: 76–78
  - industrial wastewater, 2011 V3: 81–82
  - insulation, 2012 V4: 103
  - measurement units, 2009 V1: 33
  - plumbing terminology, 2009 V1: 16–21
  - pumps, 2012 V4: 100–102
  - references for, 2009 V1: 39
  - seismic protection, 2009 V1: 185
  - solar energy, 2011 V3: 190–193
  - valve terminology, 2012 V4: 88–90
  - vibration and vibration isolation, 2012 V4: 137
  - water conditioning, 2012 V4: 199–203
- glove boxes, 2010 V2: 240
- GLSP (good large-scale production), 2010 V2: 241
- glues, 2010 V2: 191, 2012 V4: 51
- GLV (globe valves). *See* globe valves (GLV)
- GMP (good manufacturing practice), 2009 V1: 14
- gold, 2009 V1: 132
- good engineering practice, 2010 V2: 228
- good large-scale production (GLSP), 2010 V2: 241
- good manufacturing practice (GMP), 2009 V1: 14
- good value, defined, 2009 V1: 209
- goods, costs of, 2009 V1: 217
- gooseneck spouts, 2012 V4: 13
- Gorry, M., 2010 V2: 224
- governing fixtures, 2010 V2: 84–89

- government furnished, contractor installed (GFCl), 2009 V1: 64
- gpd, GPD (gallons per day), 2009 V1: 14
- gpg (grains per gallon). *See* grains per gallon (gpg)
- gph, GPH (gallons per hour), 2009 V1: 14
- gpm (gallons per minute)
- converting to fixture units, 2010 V2: 85, 2011 V3: 209, 226
  - converting to metric units, 2011 V3: 30
  - orifice size and, 2011 V3: 5
  - symbols for, 2009 V1: 14
  - wells, 2010 V2: 156
- gr, GR (grains). *See* grains
- grab bars
- ambulatory accessible toilet compartments, 2009 V1: 107
  - bath tub accessibility, 2009 V1: 109
  - clearance, 2009 V1: 114
  - health care facilities, 2011 V3: 37
  - shower stalls, 2009 V1: 112–114
  - standards for, 2009 V1: 106
  - water closet and toilet accessibility, 2009 V1: 106
- grab rings, 2012 V4: 57
- grades
- defined, 2009 V1: 24
  - maintaining for piping, 2012 V4: 25
- grains (gr, GR)
- converting to SI units, 2009 V1: 38
  - grains per gallon, 2010 V2: 191
- grains capacity
- defined, 2012 V4: 201
  - water softeners, 2012 V4: 187
- grains per gallon (gpg), 2010 V2: 191
- converting parts per million to, 2012 V4: 201
  - defined, 2012 V4: 201
  - water softener capacity, 2012 V4: 187
- granulated carbon filters, 2010 V2: 221. *See also* activated carbon filtration
- granulated carbon filters (GAC), 2010 V2: 218
- granule tests, 2012 V4: 5
- graphic conventions in plumbing drawings, 2009 V1: 100
- graphite, 2009 V1: 132, 2012 V4: 60, 67, 173
- graphite anodes, 2009 V1: 139
- graphitic corrosion, 2009 V1: 143
- graphitization
- cast iron, 2009 V1: 132
  - defined, 2009 V1: 143
- graphs, water supply, 2011 V3: 5
- grass filter strips, 2010 V2: 48
- grassed area, runoff, 2010 V2: 42
- grates
- grate open areas for floor drains, 2010 V2: 11
  - materials for, 2010 V2: 13
  - sanitary drainage systems, 2010 V2: 11
  - swimming pools, 2011 V3: 104–106, 112
- grating, 2009 V1: 24
- gravel, 2009 V1: 24, 2010 V2: 25, 42
- gravel upheaval, 2012 V4: 181
- gravimetric measurement of solids, 2010 V2: 193
- gravitational acceleration units, 2009 V1: 1
- gravitational constants (g, G), 2009 V1: 1, 2012 V4: 146
- gravity
- acceleration of water, 2010 V2: 1–2
  - forces in earthquakes, 2009 V1: 180
  - loads, 2009 V1: 145
  - gravity circulation, 2009 V1: 5
  - gravity drainage, 2010 V2: 228
  - gravity drops, 2011 V3: 139
  - gravity filters, 2012 V4: 179–180
  - gravity flotation, 2012 V4: 228
  - gravity-flow systems, 2012 V4: 53, 194
  - gravity flushes, 2012 V4: 6
  - gravity grease interceptors (GGIs), 2012 V4: 145, 153
  - gravity separators in oil spills, 2010 V2: 245–246
  - gravity sewers, 2010 V2: 144
  - gravity tank systems
    - fire-protection connections, 2011 V3: 217, 219
    - fire-protection water supply, 2011 V3: 225
    - operation of, 2010 V2: 65–66
    - suction piping and, 2010 V2: 163
  - gravity water filters, 2010 V2: 159
- Gray, G.D., 2010 V2: 29
- graywater. *See also* storm water; wastewater
- defined, 2010 V2: 21
  - horizontal distances, 2010 V2: 26
  - LEED certification, 2010 V2: 21
  - water balance, 2010 V2: 21–23
- graywater systems
- amount of generated gray water, 2010 V2: 21
  - benefits of water reuse, 2009 V1: 126
  - codes and standards, 2010 V2: 22
  - contents, 2012 V4: 239
  - cross connections, 2012 V4: 159
  - designing for supply and consumption, 2010 V2: 24–45
  - economic analysis of, 2010 V2: 26–27
  - health care facilities, 2011 V3: 46, 47
  - introduction, 2010 V2: 21
  - precautions, 2010 V2: 27
  - public concerns and acceptance, 2010 V2: 27–28
  - reasons for using, 2010 V2: 21
  - reclaimed water, 2009 V1: 126
  - references, 2010 V2: 29
  - sources of, 2012 V4: 238
  - system description and components, 2010 V2: 22
  - treatment systems, 2010 V2: 25–27, 2012 V4: 236–237
- GRDs (grease/oil recovery devices), 2012 V4: 145, 151–152
- grease. *See* fats, oils, and grease (FOG)
- grease-extracting hoods, 2012 V4: 154
- grease interceptors
- bioremediation, 2012 V4: 152
  - bioremediation systems and, 2012 V4: 227
  - codes and standards, 2009 V1: 43, 2012 V4: 154, 156–157
  - commercial kitchen sinks and, 2012 V4: 11–12
  - custom-made, 2012 V4: 153
  - defined, 2009 V1: 24
  - design characteristics
    - flotation factors, 2012 V4: 147–148
    - flow-through periods, 2012 V4: 147
    - practical design, 2012 V4: 150
    - retention periods, 2012 V4: 147
  - design example, 2012 V4: 148–149
  - field-formed concrete, 2012 V4: 153
  - flow control, 2012 V4: 154–155
  - FOG disposal systems, 2012 V4: 152
  - formulas for operation, 2012 V4: 146–148, 155–156

- gravity (GGIs), 2012 V4: 145, 153
  - hydromechanical (HGIs), 2012 V4: 145, 150–151, 157
  - operation and maintenance, 2012 V4: 157–158
  - overview, 2012 V4: 145
  - removing grease, 2012 V4: 157–158
  - sanitary drainage systems, 2011 V3: 226
  - separators, 2012 V4: 151
  - sizing, 2012 V4: 155–156
  - types of
    - automatic computer-controlled units, 2012 V4: 151–152
    - automatic power-operated units, 2012 V4: 151–152
    - custom-made units, 2012 V4: 153
    - manually operated units, 2012 V4: 150–151
    - semiautomatic units, 2012 V4: 151
  - grease/oil removal devices (GRDs), 2012 V4: 145, 151–152
  - grease separators, 2012 V4: 151
  - grease traps
    - bioremediation systems and, 2012 V4: 227
    - codes, 2009 V1: 43
    - commercial kitchen sinks and, 2012 V4: 11–12
    - defined, 2009 V1: 24
  - green building and plumbing
    - biosolids, 2012 V4: 238–240
    - economic benefits, 2012 V4: 234
    - economic growth, 2012 V4: 233
    - energy efficiency, 2012 V4: 241
    - irrigation, 2012 V4: 234
    - LEED (Leadership in Energy and Environmental Design), 2012 V4: 2, 233, 233–234, 241
    - pumps, 2012 V4: 99
    - quality perceptions and, 2009 V1: 263
    - sustainable design, 2012 V4: 233
    - vacuum-operated waste transport system, 2012 V4: 236
    - wastewater management, 2012 V4: 236–237
  - green sands, 2010 V2: 205
  - Greene, Norbert D., 2009 V1: 144
  - Greening Federal Facilities Guide*, 2009 V1: 126
  - Gribbin, PE, John. E., 2010 V2: 55
  - gridded systems, fire mains, 2011 V3: 6
  - grinder pumps
    - defined, 2009 V1: 24
    - drainage pumps, 2012 V4: 98
    - in sewage tanks, 2010 V2: 144
  - grooved butterfly valves, 2012 V4: 76
  - grooved wheel and bar benders, 2012 V4: 61
  - Grossel, S.F., 2010 V2: 246
  - ground failure, 2009 V1: 149
  - ground floor space. *See* clear floor space
  - ground-motion time history, 2009 V1: 150
  - ground-mounted water storage tanks, 2010 V2: 162
  - ground ruptures, 2009 V1: 149
  - ground shaking, 2009 V1: 149–150, 152
  - ground water
    - carbon dioxide in, 2012 V4: 176
    - feed water for pure water systems, 2010 V2: 220
    - graywater irrigation systems and, 2010 V2: 21
    - monitoring, 2011 V3: 143–144
    - need for treatment, 2012 V4: 173–174
    - private water systems, 2010 V2: 155
    - storage tanks and, 2011 V3: 154
    - storm drainage detention, 2010 V2: 47
    - swimming pool locations and, 2011 V3: 107
    - underground tanks and, 2011 V3: 138
  - grounding gas systems, 2010 V2: 125
  - groundspace for wheelchairs. *See* clear floor space
  - groundwater, 2009 V1: 24
  - Groundwater Contamination from Stormwater Infiltration*, 2010 V2: 55
  - groundwater, 2010 V2: 188
  - group washups, 2012 V4: 10
  - grouts in wells, 2010 V2: 158
  - growth rate of fires, 2011 V3: 2
  - guaranty bonds, 2009 V1: 56
  - guard posts for hydrants, 2011 V3: 220
  - Guide to Federal Tax Incentives for Solar Energy*, 2011 V3: 190
  - Guidelines for Seismic Restraints of Mechanical Systems*, 2009 V1: 180, 185
  - guides (pipe), 2009 V1: 24, 2012 V4: 130
  - Gut Feel Index, 2009 V1: 235–248
  - gutters (pools), 2011 V3: 113–114, 116–117
  - gutters (roofs), 2009 V1: 24
  - GV (gas vents), 2009 V1: 8
  - GV (gate valves), 2009 V1: 9, 2010 V2: 230
  - gymnasiums, 2010 V2: 99
  - gypsum, 2012 V4: 173
  - gypsum board, lining with lead, 2010 V2: 238
- ## H
- h (hecto) prefix, 2009 V1: 34
  - H (henrys), 2009 V1: 34
  - h (hours), 2009 V1: 34
  - h (velocity head), 2009 V1: 5
  - H-I alloy, 2009 V1: 132
  - H/m (henrys per meter), 2009 V1: 74
  - ha (hectares), 2009 V1: 34
  - hair entanglement in drains, 2011 V3: 104, 112
  - hair strainers, 2011 V3: 114, 124
  - Halar, 2009 V1: 32, 2011 V3: 49
  - half-circle rotary sprinklers, 2011 V3: 94
  - half-dome ends on tanks, 2011 V3: 139
  - half-full conditions (HF), 2009 V1: 1
  - half lives, defined, 2010 V2: 238
  - Hall grades of gases, 2011 V3: 267
  - halogenated agents, 2011 V3: 26, 29, 66, 76
  - halogens, 2010 V2: 109–110
  - halon 1211, 2011 V3: 26
  - halon 1301, 2009 V1: 24, 2011 V3: 26
  - halothane, 2011 V3: 66
  - hammer. *See* water hammer
  - hand-held extinguishers, 2011 V3: 23
  - hand-held shower heads, 2009 V1: 112
  - hand tools for vacuum cleaning systems, 2010 V2: 180
  - hand trenching, labor productivity rates, 2009 V1: 87–88
  - hand wheels, 2012 V4: 89
  - Handbook for Mechanical Engineers*, 2009 V1: 2, 3, 5, 39
  - Handbook of Applied Hydrology*, 2010 V2: 55
  - Handbook of Corrosion Resistant Pipeline*, 2011 V3: 89
  - Handbook of Fundamentals*, 2009 V1: 2, 5, 6, 39
  - handicapped individuals. *See* people with disabilities
  - handle extensions (ball valves), 2012 V4: 75, 85
  - handling section in specifications, 2009 V1: 63–64, 70
  - hands-free controls on sinks, 2011 V3: 35, 37

- hands-free water coolers, 2012 V4: 218
- hands-off automatic (HOA), 2009 V1: 14
- handwashing lavatories, 2011 V3: 36, 39, 47
- hanger assemblies, 2012 V4: 130
- hanger drawings, 2012 V4: 128
- hanger loads. *See* pipe loads; support and hanger loads
- hanger rod fixtures, 2012 V4: 119
- hanger rods, 2012 V4: 130
- hangers. *See* supports and hangers
- hanging rolls, 2012 V4: 119
- hard conversions, 2009 V1: 33
- hard-temper tubing, 2010 V2: 13, 2011 V3: 68
- hardness ions, 2012 V4: 176
- hardness of water
  - boiler feed water, 2010 V2: 216
  - defined, 2012 V4: 201
  - degrees of hardness, 2010 V2: 189
  - grains exchange capacity, 2012 V4: 187
  - hardness leakage, 2012 V4: 188, 201–202
  - ion exchange treatment, 205–211, 2010 V2: 201
  - maximum levels of, 2012 V4: 185
  - pH and alkalinity, 2010 V2: 196
  - private water systems, 2010 V2: 160
  - scaling and, 2012 V4: 173–174
  - temporary and permanent hardness, 2012 V4: 176
  - water softener treatments, 2010 V2: 210, 2012 V4: 176
- Harris, Nigel, 2010 V2: 186
- Hastelloy B, 2010 V2: 232
- Hastelloy C, 2009 V1: 132
- haunches, 2009 V1: 24
- Haws, Luther, 2012 V4: 215
- Hazardous and Solid Waste Amendments of 1984* (Public Law 98), 2011 V3: 137
- hazardous materials, emergency fixtures and, 2012 V4: 17
- hazardous wastes
  - defined, 2011 V3: 81
  - permits, 2011 V3: 83
- hazards
  - accidental acid spills, 2010 V2: 229
  - chemical material safety data sheets, 2011 V3: 83
  - classes of hazard occupancies, 2009 V1: 28–29, 2011 V3: 13
  - closed hot-water systems, 2012 V4: 209
  - cold-water systems, 2010 V2: 59
  - controlled substance spills, 2010 V2: 186
  - direct connections, 2012 V4: 161
  - exposed piping and accessibility, 2009 V1: 109
  - fire hazards, 2009 V1: 22, 2011 V3: 2
  - flammable and volatile liquids, 2010 V2: 244–246
  - gas boosters, 2010 V2: 125
  - gases in septic tanks, 2010 V2: 148
  - graywater systems, 2010 V2: 27–28
- hazardous gases, 2010 V2: 229
- hazardous materials, defined, 2011 V3: 81–82
  - hazardous substances, defined, 2011 V3: 81
  - hazardous wastes, defined, 2011 V3: 81
  - hot-water systems, 2010 V2: 97, 108–111
  - insulation, 2012 V4: 112
  - propane, 2010 V2: 131
  - propane tanks, 2010 V2: 133–134
  - radiation, 2010 V2: 237
  - radioactive waste-drainage systems, 2010 V2: 239
  - sanitary precautions for wells, 2010 V2: 159
  - types of acids, 2010 V2: 230–232
  - vacuum cleaning system issues, 2010 V2: 186
  - water distribution, cross-connections, 2012 V4: 161, 162
- Hazen-Williams formula
  - defined, 2009 V1: 2, 2010 V2: 6
  - pipe sizing and, 2010 V2: 73
- HB (hose bibbs), 2009 V1: 10, 14
- HCFCs (hydrochlorofluorocarbons), 2011 V3: 27
- hd, HD (head). *See* pressure (PRESS, PRES, P)
- HDPE (high density polyethylene), 2009 V1: 32, 2011 V3: 256, 2012 V4: 42, 48
- head (hd, HD), 2009 V1: 24, 2012 V4: 101. *See also* pressure (PRESS, PRES, P)
- head coefficient, 2012 V4: 101
- head loss, 2009 V1: 24. *See also* pressure drops or differences (PD, DELTP)
- headers, 2009 V1: 24
- headroom around pipes, 2012 V4: 25
- headwall gas systems, 2011 V3: 51, 55
- health care facilities
  - defined, 2011 V3: 33–34, 76
  - drainage systems, 2011 V3: 42–46
  - fixtures and equipment, 2011 V3: 35–42
  - glossary, 2011 V3: 76–78
  - Legionella control in, 2010 V2: 108–111
  - medical gas and vacuum systems, 2011 V3: 50–76
  - plumbing overview, 2011 V3: 35
  - references, 2011 V3: 78
  - resources, 2011 V3: 78
  - selection process, 2011 V3: 35
  - water-supply systems, 2011 V3: 46–49
- Health-Care Facilities (NFPA 99)*, 2011 V3: 63, 64, 69
- health codes, swimming pools, 2011 V3: 106
- health hazards. *See* hazards
- hearing disabilities, 2009 V1: 99
- heart-and-lung machines, 2011 V3: 42
- heat (HT)
  - compression, 2011 V3: 179
  - conversion factors, 2009 V1: 35
  - defined, 2011 V3: 186, 2012 V4: 103
  - distillation and, 2012 V4: 192
  - in fire triangle, 2011 V3: 22–23
  - grease interceptors, 2012 V4: 154
  - heat detectors, 2011 V3: 29
  - latent, 2009 V1: 128, 2011 V3: 157, 162
  - measurements, 2009 V1: 34
  - plastic corrosion, 2009 V1: 141
  - protecting against, 2010 V2: 16
  - sensible, 2009 V1: 128, 2011 V3: 157, 162
  - thermal, defined, 2011 V3: 188–189
  - water-heater heat recovery, 2010 V2: 100–101
- heat-activated air dryers, 2011 V3: 179
- heat and flush method, 2010 V2: 109–110
- heat distortion of plastic pipe, 2012 V4: 50
- heat drying biosolids, 2012 V4: 240
- Heat Exchange Institute, 2010 V2: 178
- heat exchangers and exchange systems
  - air dryers, 2011 V3: 176, 178
  - condensate estimates, 2011 V3: 167–169
  - corrosion inhibitors, 2009 V1: 141
  - defined, 2009 V1: 24



- geothermal energy, 2009 V1: 122–123
- heat exchanger loop gas booster systems, 2010 V2: 120, 127
- solar systems, 2009 V1: 122, 2011 V3: 191, 201
- for vacuum pumps, 2010 V2: 171
- waste heat usage, 2009 V1: 123–126
- heat expansion. *See* expansion
- heat fusion joints
  - defined, 2012 V4: 61
  - heat-fused socket joints, 2010 V2: 232
  - PEX piping, 2012 V4: 49
  - special wastes and, 2011 V3: 42
- heat gain (HG, HEATG)
  - storage tanks, 2012 V4: 224
  - water systems, 2012 V4: 222
- heat loss (HL, HEATL)
  - calculating, 2012 V4: 112–113
  - fiberglass insulation and, 2012 V4: 105
  - insulation thickness, 2012 V4: 106, 107, 110
  - water heater location and, 2009 V1: 120
- heat pumps
  - solar, defined, 2011 V3: 191
  - solar energy systems, 2011 V3: 203
  - waste heat usage, 2009 V1: 123
- heat recovery systems, 2009 V1: 123–126, 2011 V3: 127
- heat-trace systems, 2009 V1: 24, 2010 V2: 105–106
- heat transfer (Q)
  - coefficients, 2012 V4: 104
  - defined, 2009 V1: 24
  - efficiency, 2011 V3: 162
  - medium, 2011 V3: 191
  - scaling and, 2012 V4: 174
- heat-up method, condensate drainage, 2011 V3: 163–164
- heated water. *See* hot-water systems
- heaters (HTR), 2009 V1: 14. *See also* water heaters
- HEATG (heat gain). *See* heat gain
- heating engineers, 2011 V3: 29
- heating feed water
  - for microbial control, 2010 V2: 214
  - for pure water systems, 2010 V2: 221
- heating hot water return (HHWR), 2009 V1: 9
- heating hot water supply (HHWS), 2009 V1: 9
- heating systems
  - HVAC. *See* HVAC systems
  - solar, defined, 2011 V3: 191
- heating, ventilation, and air-conditioning systems. *See* HVAC systems
- heating water. *See* water heaters
- heavier-than-air gases, 2010 V2: 134–135
- heavy brackets, 2012 V4: 130
- heavy clay loams, 2011 V3: 91
- heavy equipment earthquake recommendations, 2009 V1: 153–157
- heavy metals, 2011 V3: 87, 2012 V4: 198. *See also* names of specific metals
- heavy process gas service, 2011 V3: 251–252
- heavy process service gas, 2010 V2: 114
- hectares, 2009 V1: 34
- hecto prefix, 2009 V1: 34
- heel inlets on traps, 2010 V2: 15
- heel-proof grates, 2010 V2: 11
- heel-proof strainers, 2010 V2: 52
- height (hgt, HGT, HT)
  - grab bars for accessibility, 2009 V1: 106
  - laundry equipment, 2009 V1: 115
  - sinks, 2009 V1: 109
  - toilet seats, 2009 V1: 106
- helium, 2011 V3: 55, 270
- hemodialysis. *See* dialysis machines
- Henriques, F.C., Jr., 2010 V2: 111
- henrys, 2009 V1: 34
- Henry's law, 2010 V2: 72
- henrys per meter, 2009 V1: 34
- HEPA filters, 2010 V2: 172, 179, 242
- herbicides, 2010 V2: 27, 147
- Hersey Meters Co., 2010 V2: 96
- hertz, 2009 V1: 14, 34
- Hesser, Henry H., 2010 V2: 186
- HET (high-efficiency toilets), 2009 V1: 127
- hexametaphosphate, 2010 V2: 160
- HF (half-full conditions), 2009 V1: 1
- HFCs (hydrochlorofluorocarbons), 2011 V3: 27
- HG (heat gain). *See* heat gain
- HG (high-pressure gas), 2009 V1: 8
- hgt, HGT (height). *See* height
- HHWR (heating hot water return), 2009 V1: 9
- HHWS (heating hot water supply), 2009 V1: 9
- high-backflow hazard, 2011 V3: 215
- high-capacity resins, 2012 V4: 202
- high-capacity wells, 2010 V2: 156
- high-demand classifications, 2010 V2: 99, 100
- high-density polyethylene (HDPE), 2009 V1: 32, 2011 V3: 256
- high-efficiency toilets (HET), 2009 V1: 127
- high-energy beta radiation, 2010 V2: 237
- high-expansion foam extinguishers, 2011 V3: 25
- high-grade water, 2012 V4: 176
- high-hazard fires, 2011 V3: 2
- high-hose retrievers, 2011 V3: 146
- high-level water tank alarms, 2011 V3: 84
- high-piled storage, 2011 V3: 225
- high-pressure carbon dioxide systems, 2011 V3: 26
- high pressure compressed air (HPCA), 2009 V1: 9
- high-pressure condensate (HPC), 2009 V1: 9
- high-pressure cutouts, 2012 V4: 221
- high-pressure cylinders, 2011 V3: 50
- high-pressure gas (HG), 2009 V1: 8
- high-pressure gas systems, 2011 V3: 271–272, 276
- high-pressure nitrogen systems, 2011 V3: 63–64
- high-pressure propane regulators, 2010 V2: 132
- high-pressure relief devices, 2012 V4: 196
- high-pressure steam (hps, HPS), 2009 V1: 9, 2012 V4: 86–87
- high-pressurization air drying, 2011 V3: 178
- high purity, defined, 2012 V4: 202
- high-purity gas, 2011 V3: 270–276
- high-purity water. *See* water purification
- high-radiation areas, 2010 V2: 237, 239
- high-rate dispensers, 2011 V3: 151
- high-rate sand filters, 2011 V3: 117–118
- high-rise buildings. *See* large buildings
- high-silicon cast iron piping, 2010 V2: 13, 14, 2011 V3: 42, 46
- high-silicon iron anodes, 2009 V1: 139
- high-silicon iron piping, 2012 V4: 53, 68, 71

- high-suds detergents, 2010 V2: 37
- high-temperature hot water (hthw, HTHW), 2012 V4: 87
- high-to-low pressure loss in vacuum systems, 2010 V2: 174
- high vacuum, 2010 V2: 172, 176
- high-velocity jetted well digging, 2010 V2: 157
- high-volume sprinklers in irrigation, 2011 V3: 92
- high winds, 2012 V4: 117
- highest order functions, 2009 V1: 221
- Hillman, 2009 V1: 185
- hinge pins, 2012 V4: 89
- hinged pipe clamps, 2012 V4: 130
- hip baths, 2011 V3: 38
- history
  - of drinking fountains, 2012 V4: 215
  - of earthquake damage, 2009 V1: 152–153
  - of fire-protection systems, 2011 V3: 1
- HOA (hands-off automatic), 2009 V1: 14
- Hodnott, Robert M., 2009 V1: 185
- Hoffman Industries, 2010 V2: 186
- hoists for immersion baths, 2011 V3: 38
- hold-down straps on storage tanks, 2011 V3: 155
- holding rooms, 2011 V3: 56
- holes
  - in coatings, 2009 V1: 136
  - for perc tests, 2010 V2: 141
- holidays
  - in coatings, 2009 V1: 136, 2011 V3: 153, 155
  - in labor costs, 2009 V1: 86
- hollow-fiber modules
  - in cross-flow filtration, 2010 V2: 212
  - in reverse osmosis, 2010 V2: 194, 211–212
- Holtan, H.N., 2010 V2: 55
- homogeneity in rate of corrosion, 2009 V1: 134
- horizontal branch hangers and supports, 2012 V4: 65
- horizontal distances for graywater system elements, 2010 V2: 26
- horizontal drains
  - cross-sections of, 2010 V2: 2
  - fixture loads, 2010 V2: 6, 8–9
  - flow in, 2010 V2: 2
  - hydraulic jumps in, 2010 V2: 6
  - minimum slope of piping, 2010 V2: 7–8
  - sloping drains in sanitary drainage systems, 2010 V2: 5–8
  - steady flow in, 2010 V2: 6
- horizontal end-suction centrifugal pumps, 2011 V3: 122–123
- horizontal high-rate sand filters, 2011 V3: 118
- horizontal loads of piping, 2009 V1: 177, 178–179
- horizontal movement of pipes, 2012 V4: 118
- horizontal natural frequencies, 2012 V4: 138
- horizontal pipe attachments, 2012 V4: 119
- horizontal pipes or fittings, 2009 V1: 24
- horizontal pressure-media filters, 2010 V2: 201, 2012 V4: 180
- horizontal pumps
  - defined, 2009 V1: 23
  - split-case pumps, 2009 V1: 23, 2011 V3: 21
- horizontal travelers, 2012 V4: 121, 130
- horizontal turbine meters, 2010 V2: 88
- horizontal velocity, 2012 V4: 147
- horsepower (hp, HP)
  - brake horsepower (bhp, BHP), 2009 V1: 6
  - converting to SI units, 2009 V1: 38
  - defined, 2011 V3: 186, 2012 V4: 101
  - symbols for, 2009 V1: 14
- hose bibb vacuum breakers, 2012 V4: 163, 170
- hose bibbs (HB), 2009 V1: 10, 14, 24, 2011 V3: 39
- hose connection vacuum breakers, 2012 V4: 166
- hose demand, 2011 V3: 13
- hose outlets, 2009 V1: 12
- hose stations, dry, 2009 V1: 13
- hose streams in firefighting, 2011 V3: 225
- hose thread outlets, 2012 V4: 13
- hose valves, 2011 V3: 20
- hoses
  - bed pans, 2011 V3: 40
  - compressed air pipe sizing, 2011 V3: 181–182
  - compressed air systems, 2011 V3: 181–182
  - fuel dispensers, 2011 V3: 146
  - fuel storage tanks, 2011 V3: 140
  - medical gas tubing, 2011 V3: 69
  - retrievers, 2011 V3: 146
  - vacuum cleaning hose capacity, 2010 V2: 180
  - vacuum cleaning systems. *See* tubing
- hospitals, 2010 V2: 15, 99, 109. *See also* health care facilities
  - defined, 2011 V3: 33
  - distilled water use, 2012 V4: 189, 192
  - drinking fountain usage, 2012 V4: 223
  - fixtures, 2012 V4: 20, 22
  - water consumption, 2012 V4: 187
- hot dip galvanization, 2012 V4: 130
- hot elevations, 2012 V4: 130
- hot fluids
  - glass piping and, 2012 V4: 35
  - hangers and supports for, 2012 V4: 119
  - piping for, 2012 V4: 118
- hot hanger locations, 2012 V4: 130
- hot loads, 2012 V4: 131
- hot settings, 2012 V4: 131
- hot shoes, 2012 V4: 131
- hot tubs, 2011 V3: 111
- hot-vapor atmospheric vents, 2009 V1: 9
- hot water, defined, 2009 V1: 25
- hot water recirculating (HWR), 2009 V1: 8
- hot-water returns, 2009 V1: 8, 14
- hot-water supply (HW)
  - heating hot water supply, 2009 V1: 8
  - high-temperature hot-water service, 2012 V4: 87
  - piping, 2012 V4: 52
  - potable water, 2011 V3: 47
  - symbols for, 2009 V1: 8, 14
  - temperature ranges for expansion or contraction, 2012 V4: 205
- hot-water systems
  - avoiding standby losses, 2009 V1: 119
  - circulation systems, 2010 V2: 105
  - codes and standards, 2010 V2: 112
  - conserving energy, 2009 V1: 117–120, 119, 120
  - corrosion rates, 2009 V1: 134
  - earthquake damage, 2009 V1: 152
  - equations, 2010 V2: 100–101
  - exposed piping and accessibility, 2009 V1: 109

- heat loss, 2012 V4: 110
- high-temperature systems, 2012 V4: 87
- hot-water properties, 2010 V2: 107
- hot-water temperatures, 2009 V1: 112, 2010 V2: 101, 102–104, 2011 V3: 39, 47
- introduction, 2010 V2: 97–98
- Legionella pneumophila*, 2010 V2: 108–111
- maintaining temperatures, 2010 V2: 105–106
- mixed-water temperatures, 2010 V2: 101
- noise mitigation, 2009 V1: 191
- pipe codes, 2009 V1: 45
- relief valves, 2010 V2: 106
- safety and health concerns, 2010 V2: 108–111
- scalding water, 2010 V2: 111
- sizing water heaters, 2010 V2: 98–99
- solar, 2011 V3: 196–199
- temperature ranges for expansion or contraction, 2012 V4: 205
- thermal efficiency, 2010 V2: 107–108
- thermal expansion, 2010 V2: 106–107, 2012 V4: 205
- types of domestic systems, 2009 V1: 120
- valves for, 2012 V4: 83–84, 87
- waste heat usage, 2009 V1: 123–126
- water heater heat recovery, 2010 V2: 100–101
- water heaters, 2010 V2: 101–105
- hot-water temperatures
  - accessible shower compartments, 2009 V1: 112
  - charts, 2010 V2: 102–104
  - health care facilities, 2011 V3: 39, 47
  - high-temperature hot water, 2012 V4: 87
  - maintaining temperatures, 2010 V2: 105–106
  - mixed-water temperatures, 2010 V2: 101
  - ranges for expansion or contraction, 2012 V4: 205
  - scalding water, 2010 V2: 111
- hotels
  - drinking fountain usage, 2012 V4: 223
  - grease interceptors, 2012 V4: 145
  - hot water demand, 2010 V2: 99
  - numbers of fixtures for, 2012 V4: 21
  - septic tanks, 150, 2010 V2: 149
  - vacuum calculations for, 2010 V2: 180
  - water consumption, 2012 V4: 187
- hourly data in sizing water heaters, 2010 V2: 99
- hours (h, HR), 2009 V1: 34
- house drains. *See* building drains
- house pumps, 2010 V2: 66
- house tanks, 2010 V2: 65–66, 68
- house traps. *See* building traps
- houses. *See* buildings
- housing project sewers, 150, 2010 V2: 149
- housings
  - for gas boosters, 2010 V2: 125
  - for gas filters, 2011 V3: 252
- HOW logic path, 2009 V1: 223, 224
- How to Design Spencer Central Vacuum Cleaners*, 2010 V2: 186
- hp, HP (horsepower). *See* horsepower
- HPC (high-pressure condensate), 2009 V1: 9
- HPCA (high pressure compressed air), 2009 V1: 9
- hps, HPS (high-pressure steam), 2009 V1: 9
- HR (hours), 2009 V1: 34
- HT (heat). *See* heat
- HT (height). *See* height
- hthw, HTHW (high-temperature hot water). *See* hot-water temperatures
- HTR (heaters), 2009 V1: 14. *See also* water heaters
- hub-and-spigot piping and joints. *See also* bell-and-spigot joints and piping
  - acid wastes and, 2011 V3: 46
  - as compression joints, 2012 V4: 57
  - cast-iron soil pipe, 2012 V4: 25–27, 27–29
  - defined, 2009 V1: 25
  - sanitary piping, 2010 V2: 12
- hub ends on valves, 2012 V4: 80
- Hubbard baths, 2010 V2: 99
- Hubbard Enterprises-HOLDRITE, 2009 V1: 206
- hubless outlet drain body, 2010 V2: 14
- hubless piping
  - bracing cast-iron pipe, 2009 V1: 170
  - cast-iron soil pipe, 2012 V4: 26, 29
  - hubless, defined, 2009 V1: 25
  - riser bracing for hubless pipes, 2009 V1: 171
  - sanitary piping, 2010 V2: 12
  - shielded hubless coupling, 2012 V4: 57
- HUD (Housing and Urban Development), 2009 V1: 97, 99
- Huff, Winston, 2010 V2: 29
- human body, need for water, 2012 V4: 215
- humidity, 2009 V1: 25, 2011 V3: 186
- hungry water. *See* distilled water
- Hunter, Roy B., 2010 V2: 3, 95–96
- Hunter's Curve, 2010 V2: 76
- Hurricane filters, 2010 V2: 201
- hurricanes, 2009 V1: 262, 2012 V4: 117
- hutene, 2010 V2: 114
- HVAC engineers, 2011 V3: 29
- HVAC systems
  - copper pipes, 2012 V4: 32
  - defined, 2012 V4: 131
  - exhaust ducts, 2010 V2: 184
  - glass pipes, 2012 V4: 35
  - piping, 2012 V4: 52
  - steel pipe, 2012 V4: 36
  - symbols for, 2009 V1: 14
- HW. *See* hot-water supply (HW)
- HWR (hot water recirculating), 2009 V1: 8, 14
- hybrid cross connection break tanks, 2012 V4: 166
- hybrid gas system configurations, 2010 V2: 122
- hybrid pressure gas pipe sizing method, 2010 V2: 130
- hybrid vaporizers, 2011 V3: 57
- hydrant wrenches, 2011 V3: 3
- hydrants
  - butt caps, 2011 V3: 3, 210
  - coefficients of discharge, 2011 V3: 3–4
  - defined, 2009 V1: 23, 25
  - fire-protection water supply, 2011 V3: 220–221
  - flow tests, 2011 V3: 3–4, 210
  - guards, 2011 V3: 220
  - outlets, 2011 V3: 4
  - public hydrants, 2009 V1: 12
  - wall hydrants, 2009 V1: 10, 12
- hydraulic design of sprinkler systems, 2011 V3: 11–13
- hydraulic equipment direct connection hazards, 2012 V4: 161
- Hydraulic Institute, 2010 V2: 96

*Hydraulic Institute Standards for Centrifugal, Rotary, and Reciprocating Pumps*, 2011 V3: 123, 135

hydraulic irrigation valves, 2011 V3: 94

hydraulic jumps in flow, 2010 V2: 2, 6, 35

*Hydraulic loading rates for soil absorption systems based on wastewater quality*, 2010 V2: 55

hydraulic mean depth of flow, 2009 V1: 1

hydraulic pipe benders, 2012 V4: 61

hydraulic pressure differential switches, 2012 V4: 181

hydraulic radii (R), 2009 V1: 1

hydraulic shock. *See* water hammer

hydraulic snubbers, 2012 V4: 131

hydraulic sway braces, 2012 V4: 131

hydraulically remote, 2009 V1: 25

*Hydraulics and Hydrology for Stormwater Management*, 2010 V2: 55

hydraulics of wells, 2010 V2: 157–158

hydrazine, 2010 V2: 216

*Hydro 35* (National Weather Service), 2011 V3: 239

hydrobromic acid, 2010 V2: 232

hydrocarbons
 

- classifications, 2011 V3: 136–137
- contamination in compressed air, 2011 V3: 174
- medical gas system tests, 2011 V3: 76

hydrochloric acid
 

- cation regenerants, 2012 V4: 183
- formation and removal, 2012 V4: 177
- formula, 2012 V4: 173
- from cation exchange, 2012 V4: 184
- in laboratory wastes, 2010 V2: 232
- in regeneration, 2010 V2: 199, 207
- in water chemistry, 2010 V2: 189

hydrochlorofluorocarbons (HCFCs), 2011 V3: 27

hydrodynamics, 2012 V4: 159

hydrogen, 2010 V2: 114, 189, 205, 229
 

- formula, 2012 V4: 173
- generating, 2011 V3: 270
- in pH balance, 2011 V3: 85
- removing, 2011 V3: 273

hydrogen embrittlement, 2009 V1: 143

hydrogen film buildup, 2009 V1: 129

hydrogen fluoride, 2011 V3: 27

hydrogen ions, 2012 V4: 173

hydrogen overvoltage, 2009 V1: 143

hydrogen peroxide, 2010 V2: 213, 2011 V3: 49

hydrogen-sodium ion exchange plants, 2012 V4: 184

hydrogen sulfide, 2010 V2: 122, 190, 198, 199
 

- defined, 2012 V4: 202
- formula, 2012 V4: 173

hydrographs, storm drainage, 2010 V2: 43

hydromechanical grease interceptors (HGIs), 2012 V4: 145, 150–151, 157

Hydronics Institute, 2011 V3: 169

hydrophilic air filters, 2012 V4: 193

hydrophobic air filters, 2012 V4: 193

hydropneumatic-tank systems, 2010 V2: 62, 64–65, 162

hydroquinone, 2010 V2: 216

hydrostatic fundamentals, 2012 V4: 159–160

hydrostatic loads, 2012 V4: 131

hydrostatic locks, 2012 V4: 131

hydrostatic monitoring systems, 2011 V3: 143

hydrostatic pressure, 2010 V2: 4

hydrostatic relief valves, 2011 V3: 112–113

hydrostatic test loads, 2012 V4: 131

hydrostatic tests, 2011 V3: 153, 2012 V4: 131

hydrotherapeutic showers, 2010 V2: 99

hydrotherapy immersion baths, 2011 V3: 38

hydroxide salts, 2012 V4: 183

hydroxides, 2010 V2: 189, 2011 V3: 85

hydroxyl, 2010 V2: 205, 214, 229

hygienic insulation jackets, 2012 V4: 108

Hypalon, 2009 V1: 32

hyperbaric pressures, 2011 V3: 76, 77

hyperchlorination, 2010 V2: 110

hypobaric pressures, 2011 V3: 76

hypochlorite solutions, 2012 V4: 178

hypochlorous acid, 2012 V4: 177

Hz (hertz), 2009 V1: 14, 34

Hz, HZ (frequencies), 2009 V1: 34

## I

I-beams, 2012 V4: 64

IAPMO. *See* International Association of Plumbing and Mechanical Officials (IAPMO)

IBBM (iron body bronze mounted), 2009 V1: 14

IBC (International Building Code), 2011 V3: 137

ICBO (International Conference of Building Officials), 2009 V1: 185

ICC (International Code Council), 2009 V1: 52

ice. *See* freezing temperatures

ice dispensers, 2012 V4: 218

ice makers, 2009 V1: 199, 2011 V3: 36, 2012 V4: 161

icfm (inlet cubic feet per minute)
 

- dynamic air compressors, 2011 V3: 62
- medical air compressors, 2011 V3: 62
- vacuum piping systems, 2010 V2: 166

ID (inside diameters), 2009 V1: 14

idea evaluation checklists, 2009 V1: 230–231

idea generators, 2009 V1: 227

ideal gas law, 2010 V2: 64

identifying parts of graywater systems, 2010 V2: 22, 27

IE (invert elevations), 2009 V1: 14

i.e. (that is), 2009 V1: 15

ignition (torch) testing, 2012 V4: 1

IIC (Impact Isolation Class), 2009 V1: 188

IIR (isobutene isoprene rubber), 2009 V1: 32

illegal connections to water meters, 2010 V2: 59

Illinois Plumbing Code, 2010 V2: 108–109

illuminance
 

- conversion factors, 2009 V1: 36
- measurements, 2009 V1: 34

*Illustrated National Plumbing Code Design Manual*, 2010 V2: 50, 55

imaginary costs, 2009 V1: 218

imaging-science facilities, 2010 V2: 238

immersion baths, 2011 V3: 36, 38, 40

immersion heaters, 2012 V4: 151

immersion-type vacuum separators, 2010 V2: 179

immiscible liquids, 2009 V1: 25, 2010 V2: 187

impact applications, neoprene and, 2012 V4: 139

impact heads in sprinkler systems, 2011 V3: 93

Impact Isolation Class (IIC), 2009 V1: 188

impact noise (structure-borne sound), 2009 V1: 187

impact type flow sensors, 2011 V3: 124

- impaired individuals. *See* people with disabilities
- impellers
  - defined, 2009 V1: 25
  - diameters, 2009 V1: 6
  - in equations, 2012 V4: 94–95
  - pumps, 2012 V4: 91
- imperviousness factor, 2011 V3: 239
- impingement attack corrosion, 2009 V1: 131, 143
- Implementation Follow-up phase in value engineering, 2009 V1: 209
- Implementation Presentation phase in value engineering, 2009 V1: 209
- importance
  - assigning in function analysis, 2009 V1: 218
  - of equipment or systems in seismic force calculations, 2009 V1: 177
- impoundment basins, 2011 V3: 149
- impressed current systems, 2009 V1: 137, 139
- impurities
  - defined, 2009 V1: 25
  - in water. *See* water impurities
- in. *See* inches
- in. Hg (inches of mercury), 2010 V2: 165, 167
- in-line filters, 2011 V3: 63
- in-line pumps, 2009 V1: 23
- in.hr (inches per hour), 2009 V1: 14
- inch-pound units (IP)
  - converting, 2010 V2: 170, 2011 V3: 30
  - flow rates and pressure measurements, 2011 V3: 172
  - symbols for, 2009 V1: 14
  - use of, 2010 V2: 165
- inches
  - converting to metric units, 2011 V3: 30
  - converting to SI units, 2009 V1: 38
  - of mercury (in. Hg), 2009 V1: 38, 2010 V2: 165, 167
  - per hour (in./h), 2009 V1: 14, 2011 V3: 91
  - symbols for, 2009 V1: 14
- incineration systems, 2009 V1: 122
- income, in hot water demand classifications, 2010 V2: 99
- inconel, 2009 V1: 132, 2012 V4: 108
- independent functions in FAST approach, 2009 V1: 223
- independent head, 2012 V4: 101
- indicated horsepower, defined, 2011 V3: 186
- indirect-circulation solar systems, 2009 V1: 122
- indirect discharges, 2011 V3: 83, 2012 V4: 227
- indirect drains (D), 2009 V1: 8
- indirect-fired propane vaporizers, 2010 V2: 134
- indirect-fired water heaters, 2010 V2: 104
- indirect waste pipes, 2009 V1: 25, 2012 V4: 12, 170
- indirect waste receptors, 2010 V2: 15–16, 2012 V4: 17. *See also* floor sinks
- indirect water heating, 2011 V3: 126–127
- individual aerobic waste treatment plants, 2010 V2: 150
- Individual Home Wastewater Characterization and Treatment, 2010 V2: 154
- individual vents, 2009 V1: 25. *See also* revent pipes
- indoor gas boosters, 2010 V2: 126
- indoor swimming pools, 2011 V3: 108. *See also* swimming pools
- induced siphonage, 2009 V1: 25
- industrial acid-waste drainage systems
  - acid-waste treatment, 2010 V2: 235
  - continuous acid-waste treatment systems, 2010 V2: 236
  - defined, 2010 V2: 229
  - health and safety concerns, 2010 V2: 229–230
  - large facilities, 2010 V2: 235
  - types of acids, 2010 V2: 230–232
- industrial chemical-waste systems, 2010 V2: 243
- industrial facilities
  - distilled water use, 2012 V4: 189
  - firefighting demand flow rates, 2011 V3: 224
  - firefighting water drainage, 2010 V2: 243–244
  - hot water demand, 2010 V2: 99
  - numbers of fixtures for, 2012 V4: 20, 22
  - pipng systems, 2012 V4: 131
  - propane tanks, 2010 V2: 133–134
  - radiation in, 2010 V2: 238
  - water content in wastes, 2011 V3: 91
- industrial laundries, 2012 V4: 185
- Industrial Plumbing Code (IPC), 2009 V1: 14
- Industrial Risk Insurers (IRI), 2009 V1: 14, 2010 V2: 115, 117, 2011 V3: 11
- industrial service gas, 2010 V2: 114
- industrial waste
  - defined, 2009 V1: 25
  - pretreatment of, 2012 V4: 227
- industrial wastewater treatment
  - codes and standards, 2011 V3: 88
  - definitions, 2011 V3: 81–82
  - designing systems, 2011 V3: 83–84
  - government publications, 2011 V3: 89
  - industry and technical handbooks, 2011 V3: 89
  - overview, 2011 V3: 81
  - permits, 2011 V3: 82–83
  - references, 2011 V3: 88
  - regulatory framework, 2011 V3: 82–83
  - resources, 2011 V3: 89
  - system elements, 2011 V3: 85–88
- inert gases, 2009 V1: 25, 2011 V3: 27, 266
- Inert Gases: Argon, Nitrogen and Helium (CGA P-9)*, 2011 V3: 74, 78
- inert materials, 2011 V3: 48
- inertia
  - conversion factors, 2009 V1: 36
  - measurements, 2009 V1: 34
- inerting atmospheres, 2011 V3: 26
- infant bathtubs, 2011 V3: 36, 38
- infectious and biological waste systems. *See also* disinfecting; microorganisms
  - biosafety levels, 2010 V2: 241
  - codes and standards, 2010 V2: 241
  - components, 2010 V2: 242
  - introduction, 2010 V2: 240–241
  - liquid-waste decontamination systems, 2010 V2: 241–242
- infectious disease rooms, 2011 V3: 47
- infiltration, 2009 V1: 25
  - storm drainage, 2010 V2: 48
- inflexibility, creativity and, 2009 V1: 225
- inflow, defined, 2009 V1: 25
- influent, 2012 V4: 202
- Information phase in value engineering, 2009 V1: 209–218
- information sources in value engineering, 2009 V1: 209–210, 216

- infrared butt fusion joints, 2012 V4: 61–62
- infrared controls on faucets and fixtures, 2009 V1: 128
- infrared radiation, defined, 2011 V3: 191
- Ingersoll-Rand Company, 2010 V2: 136
- inhibitors (corrosion), 2009 V1: 141, 143
- initial pressure in water-pressure regulators, 2012 V4: 80
- initial system volumes, 2012 V4: 209
- initial vacuum pressure, 2010 V2: 183
- injectable pharmaceuticals, 2012 V4: 199
- ink tests, 2012 V4: 5, 8
- inlet cubic feet per minute (icfm), 2010 V2: 166, 2011 V3: 62
- inlet filters, 2009 V1: 25
- inlet piping, compressed air systems, 2011 V3: 182
- inlet pressure, defined, 2011 V3: 186
- inlet temperature, defined, 2011 V3: 186
- inlet times, 2011 V3: 242
- inlet valves, 2012 V4: 202
- inlets. *See also* outlets; stations
  - gas or vacuum. *See* stations
  - inlet filters on vacuum systems, 2010 V2: 171
  - inlet inverts on septic tanks, 2010 V2: 146
  - inlet pressure in cold-water systems, 2010 V2: 69
  - inlet pressure in gas boosters, 2010 V2: 128
  - inlet times, 2011 V3: 242, 249
  - number of in vacuum systems, 2010 V2: 174
  - for storage tanks, 2010 V2: 163
  - storm drainage collection systems, 2010 V2: 46
  - submerged, 2012 V4: 161
  - swimming pools, 2011 V3: 135
  - for vacuum cleaning systems, 2010 V2: 179, 180, 183, 184
  - in vacuum sizing calculations, 2010 V2: 174, 176
- inline lift check valves, 2012 V4: 76–77
- inline shutoff valves, 2011 V3: 67
- innovations, 2009 V1: 262
- inorganic salts, 2012 V4: 199
- inorganic substances, 2009 V1: 25
- input motion of earthquakes, 2009 V1: 150
- inputs, 2009 V1: 25
- insecticides, storm water, 2010 V2: 27
- insert boxes, 2012 V4: 131
- insert nuts, 2012 V4: 131
- inserts, 2012 V4: 59–60, 119, 131
- inside-caulk drains, 2010 V2: 13
- inside-caulk outlets, 2010 V2: 13
- inside diameters (ID), 2009 V1: 14, 2011 V3: 139
- insolation, defined, 2011 V3: 191
- inspecting. *See also* cleanouts
  - conditions of existing buildings, 2009 V1: 267–270
  - hazardous waste systems, 2011 V3: 84
  - sewage-disposal systems, 2010 V2: 153
- installation
  - anchor bolts, seismic problems, 2009 V1: 184
  - appearance of, 2009 V1: 262–263
  - bioremediation pretreatment systems, 2012 V4: 231
  - cross-connection controls, 2012 V4: 166–168
  - ensuring high quality with detailed specs, 2009 V1: 253–254
  - estimating productivity rates, 2009 V1: 88
  - flow sensors, 2011 V3: 124–125
  - gas meters, 2010 V2: 115–116
  - grab bars, 2009 V1: 113
  - installation costs, 2009 V1: 217
  - insulation on valves and fittings, 2012 V4: 110
  - lavatories, 2012 V4: 10
  - liquid fuel storage systems, 2011 V3: 154–156
  - makeshift or substandard, 2009 V1: 254–257
  - medical gas piping, 2011 V3: 67–68
  - pressure-regulated valves, 2010 V2: 69–70
  - pumps, 2012 V4: 100
  - section in specifications, 2009 V1: 71
  - showers, 2012 V4: 13
  - storage tank checklist, 2011 V3: 155–156
  - tank insulation, 2012 V4: 110
  - urinals, 2012 V4: 9
  - water closets, 2012 V4: 5–6
  - water coolers, 2012 V4: 224
  - water-pressure regulators, 2012 V4: 82
  - water treatment, 2012 V4: 202
- Installation/Maintenance of Private Fire Mains (FM 3-10)*, 2011 V3: 218
- Installation of Centrifugal Fire Pumps (NFPA 20)*, 2011 V3: 21
- Installation of Closed-head Foam-water Sprinkler Systems (NFPA 16A)*, 2011 V3: 30
- Installation of Private Fire Service Mains and Their Appurtenances (NFPA 24)*, 2011 V3: 30, 218
- Installation of Sprinkler Systems (NFPA 13)*, 2011 V3: 2, 11, 225
- Installation of Standpipe and Hose Systems (NFPA 14)*, 2011 V3: 18
- Installation of Underground Gasoline Tanks and Piping at Service Stations (API 1615)*, 2011 V3: 156
- instantaneous water heaters, 2009 V1: 25, 2010 V2: 101–104
- institutional facilities
  - estimating sewage quantities, 2010 V2: 151
  - grease interceptors, 2012 V4: 145
  - numbers of fixtures for, 2012 V4: 20, 22–23
  - piping systems, 2012 V4: 131
  - septic tank systems for, 150, 2010 V2: 149
- instructions to bidders, 2009 V1: 56
- instrument sterilizers, 2011 V3: 39, 40
- instruments, nitrogen-pressure-driven, 2011 V3: 64
- Insulated Aboveground Tanks for Flammable and Combustible Liquids (UL 2085)*, 2011 V3: 137
- insulated pipe supports, 2012 V4: 131
- insulating cement, 2012 V4: 106
- insulation
  - chilled drinking-water systems, 2012 V4: 222
  - confined spaces, 2012 V4: 113
  - dielectric insulation, 2009 V1: 136
  - economic issues, 2012 V4: 112–113
  - in geothermal energy systems, 2009 V1: 123
  - hangers and supports and, 2012 V4: 118, 119
  - hot-water systems, 2009 V1: 118
  - insulation protection saddles, 2012 V4: 131
  - noise insulation, 2010 V2: 13–14
  - pipe. *See* pipe insulation
  - pure water systems, 2010 V2: 223
  - short-circuiting installations, 2009 V1: 140
  - solar energy systems, 2011 V3: 203
  - storage and handling, 2012 V4: 113
  - tanks, 2012 V4: 110
  - thickness and energy conservation, 2009 V1: 118

- valves and fittings, 2012 V4: 110
- insurance
  - carriers, 2011 V3: 1, 27, 205
  - certificates, 2009 V1: 56
  - in labor costs, 2009 V1: 86
- intake silencers on compressors, 2011 V3: 175
- integral attachments, 2012 V4: 131
- integral two-stage propane regulators, 2010 V2: 133
- intensity (luminous), 2009 V1: 34
- intensity-duration-frequency curves, 2011 V3: 239, 244–248
- intensity, rainfall, 2010 V2: 44–46
- intensive-care rooms
  - fixtures, 2011 V3: 38
  - health care facilities, 2011 V3: 36
  - medical gas stations, 2011 V3: 52, 56
- interactive fountains, 2011 V3: 100
- interceptors, 2009 V1: 25. *See also* specific kinds of interceptors
- intercooling, defined, 2011 V3: 186
- interface controls for medical gas systems, 2011 V3: 67
- intergranular corrosion, 2010 V2: 195
- interlocking, gas boosters and, 2010 V2: 127
- interlocks for gas shutoffs, 2010 V2: 118
- intermediate chambers in dry-pipe systems, 2011 V3: 8
- intermediate coats, 2009 V1: 136
- intermediate gas regulators, 2011 V3: 255
- intermediate hangers, 2012 V4: 64
- intermediate-level sprinklers, 2009 V1: 29
- intermittent flow in fixtures, 2012 V4: 186
- intermittent sand filters, 2010 V2: 150
- internal energy, defined, 2011 V3: 185
- Internal Revenue Service (IRS) web site, 2011 V3: 203
- internal water treatments, 2012 V4: 174
- International Agency for Research on Cancer (IARC), 2011 V3: 119
- International Amateur Swimming Federation (FINA), 2011 V3: 104
- International Association of Plumbing and Mechanical Officials (IAPMO), 2009 V1: 52, 2010 V2: 29
  - manhole standards, 2012 V4: 230
  - prefabricated grease interceptor standards, 2012 V4: 145*Uniform Plumbing Code. See Uniform Plumbing Code*
- International Boiler and Pressure Vessel Code*, 2011 V3: 88
- International Building Code (IBC)*, 2009 V1: 174, 2011 V3: 137
- International Code Council (ICC), 2009 V1: 52, 2010 V2: 29, 96
- International Fuel Gas Code*, 2010 V2: 115
- International Conference of Building Officials (ICBO), 2009 V1: 185
- International Fuel Gas Code*, 2010 V2: 115, 118, 121, 125
- International Plumbing Code*, 2009 V1: 206, 2010 V2: 29
  - graywater, 2010 V2: 22
  - hydromechanical grease interceptors, 2012 V4: 157
  - required plumbing fixtures, 2012 V4: 18
  - single occupant toiler rooms, 2012 V4: 19
  - vent sizing, 2010 V2: 39–40
- International Safety Equipment Association (ISEA), 2009 V1: 52
- International Standards Organization
  - Laboratory Tests on Noise Emission from Appliances and Equipment Used in Water Supply Installations*, 2009 V1: 193, 206
- international swimming meets, 2011 V3: 107
- International System of Units (SI)
  - conversion factors, 2009 V1: 38–39
  - converting, 2009 V1: 38, 2010 V2: 170, 2011 V3: 30
  - equations, 2009 V1: 1
  - listing, 2009 V1: 33–39
  - non-SI units, 2009 V1: 34
  - prefixes and symbols, 2009 V1: 34
  - pressure and flow rate measurements, 2011 V3: 187
  - style and use, 2009 V1: 34–35, 2010 V2: 165
- interrelationships of functions, 2009 V1: 219, 223
- interruption fuel-gas service, 2010 V2: 114
- interruption gas services, 2011 V3: 251
- interstage relief valves, 2011 V3: 274
- interstitial monitoring, 2011 V3: 143
- interstitial spaces in tanks, 2011 V3: 139, 148
- intravenous injections, 2012 V4: 192
- Introduction to Storm Water, 2010 V2: 46, 55
- inventory control in storage tanks, 2011 V3: 142–143
- invert elevations, 2009 V1: 14
- invertebrates, 2010 V2: 188
- inverted, defined, 2012 V4: 131
- inverted bucket traps, 2011 V3: 162–163
- inverts
  - defined, 2009 V1: 25
  - on septic tanks, 2010 V2: 146
- Investigation phase in value engineering, 2009 V1: 209, 235–248
- inward projecting pipes, 2010 V2: 93
- iodine, 2010 V2: 110
- iodine 131, 2010 V2: 238
- ion-exchange and removal systems, 2010 V2: 201–211
  - cartridges, 2012 V4: 194
  - continuous deionization, 2010 V2: 209–210
  - defined, 2012 V4: 202
  - design considerations, 2010 V2: 210–211
  - internal structure, 2012 V4: 183–184
  - ion exchange with acid addition, 2012 V4: 184
  - ion exchange with chloride dealkalizer, 2012 V4: 184
  - regenerable ion exchange, 2010 V2: 205
  - regeneration cycle, 2010 V2: 206–208
  - resins, 2010 V2: 205–206, 2012 V4: 183
  - service deionization, 2010 V2: 208–209
  - small drinking water systems, 2010 V2: 218
  - sodium cycle, 2012 V4: 176
  - total dissolved solids and, 2010 V2: 194
  - trace metal removal, 2011 V3: 87
  - water softening, 2010 V2: 210, 2012 V4: 182–189, 184
- ionization, copper-silver, 2010 V2: 11, 110, 2012 V4: 199
- ionized salts (NaCl), 2011 V3: 47, 2012 V4: 175
- ions
  - defined, 2009 V1: 25, 143, 2012 V4: 182, 202
  - in electromotive force series, 2009 V1: 134
  - in pH values, 2010 V2: 229
- Iowa Institute of Hydraulic Research, 2010 V2: 72
- IP units, 2009 V1: 14, 2010 V2: 165, 170, 2011 V3: 30, 172
- IPC. *See* International Plumbing Code
- IPC vent sizing, 2010 V2: 39–40
- IPS. *See* iron pipe size (IPS)

- IPS outlet drain body, 2010 V2: 14
- IPS outlets, 2010 V2: 13
- IR (polyisopryne), 2009 V1: 32
- IRI. *See* Industrial Risk Insurers (IRI)
- iron
- corrosion, 2009 V1: 129, 2012 V4: 176
  - defined, 2012 V4: 202
  - in electromotive force series, 2009 V1: 132
  - ferric ion formula, 2012 V4: 173
  - ferrous oxide formula, 2012 V4: 173
  - in galvanic series, 2009 V1: 132
  - removing, 2010 V2: 198
  - sludge and, 2010 V2: 195
  - in soils, 2010 V2: 141
  - in water, 2010 V2: 160, 189
- iron bacteria, 2010 V2: 188
- iron body bronze mounted (IBBM), 2009 V1: 14
- iron coagulants, 2010 V2: 199
- iron filters, 2012 V4: 186
- iron oxide, 2009 V1: 129
- iron oxide films, 2009 V1: 134
- iron pipe size (IPS), 2009 V1: 14, 2012 V4: 42, 51
- iron piping
- corrosion, 2009 V1: 129, 2012 V4: 176
  - ductile iron water and sewer pipe, 2012 V4: 26, 29
- iron valves, 2012 V4: 77
- irradiation (insolation), instantaneous, 2011 V3: 191
- irradiation treatment of water, 2010 V2: 160, 213, 218, 222, 223
- irregularity of shapes in velocity, 2012 V4: 146
- irrigation
- graywater, 2010 V2: 22
- Irrigation Association, 2011 V3: 96
- irrigation systems
- design information, 2011 V3: 96
  - graywater systems and, 2010 V2: 24–25, 27
  - green plumbing, 2012 V4: 234
  - lawn sprinkler submerged inlet hazards, 2012 V4: 161
  - methods, 2011 V3: 92
  - overview, 2011 V3: 91
  - rain shutoff devices, 2011 V3: 96
  - rainwater harvesting, 2009 V1: 126
  - references, 2011 V3: 96
  - resources, 2011 V3: 96–97
  - sample information sheet, 2011 V3: 97
  - soil considerations, 2011 V3: 91
  - system components, 2011 V3: 92–96
  - water metering and, 2011 V3: 95–96
  - water quality and requirements, 2011 V3: 91
  - water supply, 2011 V3: 96
- ISEA (International Safety Equipment Association), 2009 V1: 52
- island venting, 2011 V3: 46
- island vents, 2010 V2: 34
- isoascorbic acid, 2010 V2: 216
- isobaric processes, 2009 V1: 25
- isobutene isoprene rubber, 2009 V1: 32
- isochoric processes, 2009 V1: 25
- isolating copper pipes, 2009 V1: 256, 258
- isolating medical gas zones, 2011 V3: 66
- isolating noise
- drainage system components, 2009 V1: 190
  - pipes and piping, 2009 V1: 190–193
  - quality and, 2009 V1: 263
- isolation rooms, 2011 V3: 36, 47, 52
- isolation valves, 2011 V3: 50
- isolation, vibration
- isolation springs, 2009 V1: 158
  - isolators within hangers, 2009 V1: 158
- isolators, 2009 V1: 194, 2012 V4: 139–142
- isosceles triangles, calculating area, 2009 V1: 4
- isothermal processes, 2009 V1: 25
- isotopes, 2010 V2: 236–237, 238
- Izod impact, 2012 V4: 50
- ## J
- J (joules), 2009 V1: 34
- J/K (joules per kelvin), 2009 V1: 34
- J/kg K (joules per kg per kelvin), 2009 V1: 34
- jacketing
- coverings for insulation, 2012 V4: 106–109
  - defined, 2012 V4: 131
  - insulation, 2012 V4: 104
  - pipe insulation, 2012 V4: 104, 106–109
  - preformed plastic jackets for valves and fittings, 2012 V4: 110
  - types of
    - all-service jackets, 2012 V4: 108
    - aluminum jackets, 2012 V4: 108
    - stainless steel, 2012 V4: 108
  - vapor barriers, 2012 V4: 112
- Jackson turbidity units (JTUs), 2010 V2: 193
- jam packing, 2012 V4: 89
- janitors' closets, 2011 V3: 36, 2012 V4: 12
- Janoschek, R., 2010 V2: 224
- Jayawardena, N., 2010 V2: 224
- JCAHO (Joint Commission for the Accreditation of Hospitals Organization), 2010 V2: 108–109, 111, 2011 V3: 35, 51
- jet pumps, 2010 V2: 157
- jetted wells, 2010 V2: 157
- job preparation checklists, 2009 V1: 91–92
- jockey pumps, 2009 V1: 23, 2011 V3: 22
- Joint Commission for the Accreditation of Hospitals Organization (JCAHO), 2010 V2: 108–109, 111, 2011 V3: 35, 51
- joint responsibilities for drinking water purity, 2012 V4: 170
- joints
- acid-waste systems, 2010 V2: 232
  - chemical-waste systems, 2010 V2: 242
  - compressed air systems, 2011 V3: 176
  - couplings, 2009 V1: 20
  - deflection, 2012 V4: 57
  - earthquake damage to, 2009 V1: 152
  - earthquake protection and, 2009 V1: 160
  - inspection, 2011 V3: 69, 74
  - labor productivity rates, 2009 V1: 87, 88
  - laboratory gas systems, 2011 V3: 277
  - materials
    - ABS pipe, 2012 V4: 51
    - aluminum pipe, 2012 V4: 54
    - bronze joints and fittings, 2012 V4: 30, 39–40
    - cast-iron hubless pipes, 2012 V4: 26
    - cast-iron soil pipes, 2012 V4: 25–26



- codes and standards, 2009 V1: 43
  - copper drainage tubes, 2012 V4: 33, 40
  - copper joints, 2012 V4: 30, 39–40
  - copper water tube, 2012 V4: 30, 58
  - CPVC piping, 2012 V4: 51
  - cross-linked polyethylene, 2012 V4: 49
  - cross-linked polyethylene/aluminum/cross-linked polyethylene (PEX-AL-PEX), 2012 V4: 49
  - ductile iron water and sewer pipe, 2012 V4: 31
  - fiberglass pipe, 2012 V4: 53
  - glass pipe, 2012 V4: 36, 41–43, 61
  - glass pipe joints, 2012 V4: 61
  - high silicon (duriron) pipe, 2012 V4: 53
  - lead and oakum joints, 2012 V4: 57
  - plastic joints, 2012 V4: 59–60
  - plastic pipe, 2012 V4: 48
  - polypropylene pipe, 2012 V4: 51–52
  - polypropylene-random pipe, 2012 V4: 52
  - PVC pipe, 2012 V4: 52
  - PVC piping, 2012 V4: 49
  - PVDF pipe, 2012 V4: 52
  - reinforced concrete pipe, 2012 V4: 29
  - seamless copper pipe, 2012 V4: 39–40
  - stainless steel pipe, 2012 V4: 56
  - steel pipe, 2012 V4: 37
  - medical gas tubing, 2011 V3: 69, 2012 V4: 34
  - natural gas systems, 2010 V2: 124, 2011 V3: 257
  - pure-water systems, 2011 V3: 48–49
  - radioactive waste systems, 2010 V2: 239
  - resistance coefficients, 2010 V2: 92
  - restrainers, 2011 V3: 221
  - sanitary drainage systems, 2010 V2: 13–14
  - special-waste drainage systems, 2010 V2: 228
  - specifications to prevent failures, 2009 V1: 256–258
  - thermal expansion and, 2012 V4: 206–207
  - types of
    - ball joints, 2012 V4: 63
    - beadless butt fusion, 2012 V4: 62
    - bonded joints and cathodic protection, 2009 V1: 140
    - brazing, 2012 V4: 58
    - caulked joints, 2010 V2: 15, 2012 V4: 57
    - compression joints, 2012 V4: 57
    - dielectric unions or flanges, 2012 V4: 62
    - electrofusion joining, 2012 V4: 61
    - expansion joints, 2010 V2: 16, 49, 2012 V4: 62, 206–207
    - fill and pipe joints, 2010 V2: 13
    - flanged joints, 2012 V4: 60, 66
    - flexible couplings, 2012 V4: 63
    - heat-fused socket joints, 2010 V2: 232
    - infrared butt fusion, 2012 V4: 61–62
    - lead and oakum joints, 2012 V4: 57
    - mechanical couplings, 2012 V4: 63
    - mechanical joints, 2012 V4: 57, 58–59
    - nonrigid couplings, 2009 V1: 180
    - plastic pipe joints, 2012 V4: 59–60
    - press or push connect, 2012 V4: 58
    - roll groove, 2012 V4: 58
    - sanitary, 2011 V3: 48–49
    - screwed mechanical joints, 2010 V2: 232
    - shielded hubless coupling, 2012 V4: 57
    - socket fusion, 2012 V4: 61
    - soldered, 2012 V4: 58
    - thread cutting, 2012 V4: 61
    - threaded, 2012 V4: 60–61
    - welded, 2012 V4: 61
    - welded joints, 2012 V4: 58
    - welded joints in radioactive waste systems, 2010 V2: 239
  - joist hangers, 2012 V4: 126
  - Joukowski's formula, 2010 V2: 70–71
  - joules, 2009 V1: 34
  - joules per kelvin, 2009 V1: 34
  - joules per kg per kelvin, 2009 V1: 34
  - JTUs (Jackson turbidity units), 2010 V2: 193
  - Judgment phase in value engineering, 2009 V1: 209
  - judgmentalism, 2009 V1: 227
  - juveniles. *See* children, fixtures and
- ## K
- k*, K (conductivity), 2009 V1: 33, 2012 V4: 103
  - K (dynamic response to ground shaking), 2009 V1: 149, 152
  - K (Kelvin), 2009 V1: 14, 30
  - k (kilo) prefix, 2009 V1: 34
  - K factor (coefficient of permeability), 2010 V2: 158
  - K factor (conductivity), 2012 V4: 103
  - K factor (sprinkler heads), 2011 V3: 13
  - K piping. *See* Type K copper
  - Kalinske, A.A., 2010 V2: 19, 72
  - Kaminsky, G., 2010 V2: 246
  - Kaufman, Jerry J., 2009 V1: 252
  - kcal (kilocalories), 2012 V4: 103
  - KE (kinetic energy), 2009 V1: 2, 5
  - Kelvin (K), 2009 V1: 14, 30, 33, 2011 V3: 184
  - kerosene, 2010 V2: 12, 2011 V3: 136
  - keyboards, inflexible thinking and, 2009 V1: 225
  - kg (kilograms). *See* kilograms
  - kg/m (kilograms per meter), 2009 V1: 34
  - kg/m<sup>2</sup> (kilograms per meter squared), 2009 V1: 34
  - kg/m<sup>3</sup> (kilograms per meter cubed), 2009 V1: 34
  - kg/ms (kilogram-meters per second), 2009 V1: 34
  - kg/s (kilograms per second), 2009 V1: 34
  - kidney dialysis. *See* dialysis machines
  - kill tanks, 2010 V2: 241–242
  - kilo prefix, 2009 V1: 34
  - kilocalories
    - converting to SI units, 2009 V1: 38
    - defined, 2012 V4: 103
  - kilograms (kg)
    - defined, 2009 V1: 33
    - kilograms per cubic meter, 2009 V1: 34
    - kilograms per meter, 2009 V1: 34
    - kilograms per meter squared, 2009 V1: 34
    - kilograms per second, 2009 V1: 34
  - kilometers (km)
    - converting to SI units, 2009 V1: 39
    - kilometers per hour, 2009 V1: 34
  - kilopascals (kPa)
    - converting meters of head loss to, 2009 V1: 2
    - converting to psi, 2011 V3: 30
    - in SI units, 2011 V3: 187
    - vacuum pump ratings, 2010 V2: 167
    - vacuum work forces, 2010 V2: 166
  - kiloponds, converting to SI units, 2009 V1: 38

kilowatt hours (kWh, KWH), 2009 V1: 15, 34  
 kilowatts (kW, KW), 2009 V1: 14  
 kinematic viscosity  
   converting to SI units, 2009 V1: 38  
   measurements, 2009 V1: 34  
   water temperature variations, 2010 V2: 73, 74, 77  
 Kinematic Viscosity Centistokes, 2011 V3: 137  
 kinetic energy (KE)  
   calculating, 2009 V1: 2  
   defined, 2011 V3: 185  
   velocity head and, 2009 V1: 5  
 kinetically-operated aerobic bioremediation systems, 2012 V4: 228  
 King, Thomas R., 2009 V1: 252  
 kip, KIP (thousand pounds), 2009 V1: 15  
*Kirk-Othmer Encyclopedia of Chemical Technology*, 2011 V3: 89  
 kitchen faucets, 2010 V2: 25  
 kitchen sinks  
   faucets, 2012 V4: 12  
   fixture-unit loads, 2010 V2: 3  
   grease interceptors, 2012 V4: 145  
   hot water demand, 2010 V2: 99  
   symbols, 2009 V1: 15  
   types, 2012 V4: 10–12  
 kitchens. *See* food-processing areas and kitchens  
 Klein, S.A., 2011 V3: 204  
 km/h (kilometers per hour), 2009 V1: 34  
 knee braces, 2012 V4: 131  
 knee space for wheelchairs, 2009 V1: 99–101  
 knockout pots in vacuum systems, 2010 V2: 171  
 Konen, Thomas K., 2010 V2: 29  
 Kortright Centre for Conservation web site, 2011 V3: 203  
 kPa (kilopascals). *See* kilopascals  
 Kreider, J.F., 2011 V3: 204  
 Kreith, J., 2011 V3: 203  
 KS. *See* kitchen sinks  
 Kullen, Howard P., 2009 V1: 144  
 kW, KW (kilowatts), 2009 V1: 14  
 kWh, KWH (kilowatt hours), 2009 V1: 15, 34, 2011 V3: 193  
 KYNAR piping, 2011 V3: 49

## L

l (leader). *See* downspouts and leaders  
 L (length). *See* length  
 L (liters). *See* liters  
 L/min (liters per minute), 2011 V3: 187  
 L piping. *See* Type L copper  
 L/s (liters per second), 2011 V3: 187  
 L-shaped bath seats, 2009 V1: 114  
 LA (laboratory compressed air), 2009 V1: 8  
 labels  
   labeled, defined, 2009 V1: 25  
   labeled fire pumps, 2011 V3: 21  
   medical gas tubing, 2011 V3: 69, 74  
   medical gas valves, 2011 V3: 67  
   parts of graywater systems, 2010 V2: 27  
 labor and materials payment bonds, 2009 V1: 56  
 labor costs  
   defined, 2009 V1: 210  
   factors in, 2009 V1: 86  
   ongoing and one-time, 2009 V1: 217

overtime, 2009 V1: 86  
 in plumbing cost estimation, 2009 V1: 85  
 productivity rates, 2009 V1: 87–88  
 in take-off estimating method, 2009 V1: 86  
 true costs of makeshift installations, 2009 V1: 263–264  
 in value engineering, 2009 V1: 208  
 labor rooms  
   fixtures, 2011 V3: 39  
   health care facilities, 2011 V3: 36  
   medical gas stations, 2011 V3: 52, 56  
 laboratories  
   acid-waste drainage systems, 2010 V2: 229, 2011 V3: 42–46  
   acid-waste treatment, 2010 V2: 235, 2011 V3: 43–44  
   continuous acid-waste treatment systems, 2010 V2: 236  
   discharge to sewers, 2011 V3: 43–44  
   health and safety concerns, 2010 V2: 229–230  
   large facilities, 2010 V2: 235  
   metering, 2011 V3: 45  
   piping and joint material, 2010 V2: 232–234  
   sink traps, 2011 V3: 45–46  
   solids interceptors, 2011 V3: 45  
   system design considerations, 2010 V2: 234–235  
   types of acids, 2010 V2: 230–232  
   waste and vent piping, 2011 V3: 46  
 classroom water demand, 2011 V3: 46  
 compressed air use factors, 2011 V3: 182  
 defined, 2011 V3: 76  
 direct connection hazards, 2012 V4: 161  
 distilled water use, 2012 V4: 189  
 emergency eyewash and showers, 2011 V3: 36, 41  
 fixtures and pipe sizing, 2010 V2: 228  
 gas service outlets, 2011 V3: 41–42  
 gas systems. *See* laboratory gas systems  
 grades of water for, 2012 V4: 197–199  
 in health care facilities, 2011 V3: 36, 41–42  
 infectious waste systems, 2010 V2: 240–241  
 lab animals, 2010 V2: 241  
 medical gas stations, 2011 V3: 52  
 natural gas systems, 2010 V2: 121  
 plastic pipes, 2012 V4: 39  
 pure water systems for, 2010 V2: 218–219, 2011 V3: 48  
 radioactive isotopes in, 2010 V2: 235  
 sinks as submerged inlet hazards, 2012 V4: 161  
 vacuum systems  
   codes and standards, 2010 V2: 172  
   diversity factor calculations for vacuums, 2010 V2: 176  
   leakage, 2010 V2: 177, 178  
   piping, 2010 V2: 173  
   pump assemblies, 2010 V2: 173  
   sizing, 2010 V2: 174–176  
   vacuum-pump systems, 2011 V3: 65  
   water systems filtration, 2010 V2: 201  
 laboratory compressed air (LA), 2009 V1: 8  
 laboratory gas systems  
   cleaning and sterilizing pipes, 2011 V3: 277  
   codes and standards, 2011 V3: 263  
   components  
   alarms, 2011 V3: 275

- compressor inlet piping, 2011 V3: 280
- cylinders, 2011 V3: 267–268
- dewers, 2011 V3: 268
- distribution system components, 2011 V3: 270–276
- filters and purifiers, 2011 V3: 273
- flash arresters, 2011 V3: 273
- flow meters, 2011 V3: 275
- gas cabinets, 2011 V3: 268–270
- gas mixers, 2011 V3: 276
- gas warmers, 2011 V3: 275
- gauges, 2011 V3: 273
- joints, 2011 V3: 277
- pipes and piping, 2011 V3: 276–280
- purge devices, 2011 V3: 275
- shutoff valves, 2011 V3: 274
- valves, 2011 V3: 273–274
- generating gases, 2011 V3: 270
- grades of gases, 2011 V3: 267
- overview, 2011 V3: 263
- pipe sizing, 2011 V3: 277–280
- pressure, 2011 V3: 276
- sizing, 2011 V3: 275–276
- specialty gas classifications, 2011 V3: 266–267
- storage and generation, 2011 V3: 267–270
- testing and purging, 2011 V3: 280
- toxic and flammable gas monitoring, 2011 V3: 275–276
- laboratory grade water, 2012 V4: 197–199
- laboratory outlets, 2009 V1: 25
- laboratory service panels, 2010 V2: 121
- Laboratory Testing on the Noise Emitted by Valves, Fittings, and Appliances Used in Water Supply Installations*, 2009 V1: 206
- Laboratory Tests on Noise Emission by Appliances and Equipment Used in Water Supply Installations*, 2009 V1: 193
- laboratory vacuum (LV), 2009 V1: 9, 2010 V2: 170
- LaCrosse encephalitis, 2010 V2: 49
- ladders
  - aboveground storage tanks, 2011 V3: 148
  - swimming pools, 2011 V3: 134–135
- lagging (pipe wrappings), 2012 V4: 109
- lagoons, 2010 V2: 150
- lakes, 2010 V2: 24
- LAL test, 2010 V2: 188
- laminar flow devices, 2011 V3: 35
- laminar flow in pipes, 2009 V1: 2, 2010 V2: 74
- landscaping irrigation. *See* irrigation systems
- landslides, 2009 V1: 149
- lanes in swimming pools, 2011 V3: 107
- Langelier saturation index (LSI), 2010 V2: 196, 2011 V3: 128
- Langelier, W.F., 2010 V2: 196
- lap joint welds, 2012 V4: 58
- Laque, F.L., 2009 V1: 144
- large buildings
  - acid-waste systems, 2010 V2: 235
  - fixture drainage loads, 2010 V2: 3
  - high-rise buildings, 2010 V2: 126
  - large private sewage-disposal systems, 150, 2010 V2: 149
  - pipe expansion and contraction, 2012 V4: 207
  - Provent single-stack plumbing systems, 2010 V2: 17–18
  - Sovent single-stack plumbing systems, 2010 V2: 17–18
  - valves in systems, 2012 V4: 88
- large-drop sprinklers, 2009 V1: 29
- large-scale biohazard facilities, 2010 V2: 241
- latent heat (LH, LHEAT), 2009 V1: 128, 2011 V3: 157, 162
- lateral and longitudinal motion, 2012 V4: 116–117, 118
- lateral and longitudinal sway bracing, 2009 V1: 175–176, 178–179, 2012 V4: 131
- lateral force
  - calculating for seismic protection, 2009 V1: 174
  - defined, 2009 V1: 185
- lateral lines, 2011 V3: 78
- lateral sewers, 2009 V1: 25
- lateral stability
  - defined, 2012 V4: 131
  - of suspended equipment, 2009 V1: 157
- laundry machines. *See* laundry systems and washers
- laundry sinks or trays, 2009 V1: 15, 2012 V4: 12
- laundry systems and washers
  - accessibility, 2009 V1: 115
  - clothes washer fixture-unit loads, 2010 V2: 3
  - fixture pipe sizes and demand, 2010 V2: 86
  - gray water use, 2009 V1: 126, 2010 V2: 21
  - health care facilities, 2011 V3: 36, 39
  - hot water demand, 2010 V2: 99
  - laundry sinks and clothes washers, 2012 V4: 12
  - laundry tray fixture-unit loads, 2010 V2: 3
  - noise mitigation, 2009 V1: 199, 200
  - rates of sewage flows, 2010 V2: 152
  - submerged inlet hazards, 2012 V4: 161
  - suds problems, 2010 V2: 37–38
  - waste heat usage, 2009 V1: 123
  - water fixture unit values, 2011 V3: 206
  - water softening, 2012 V4: 185
  - water temperatures, 2011 V3: 47
- lavatories (lav). *See also* sinks and wash basins
  - abbreviations for, 2009 V1: 15
  - accessibility, 2009 V1: 108–109
  - chase size, 2012 V4: 10
  - faucets and overflows, 2012 V4: 10, 12
  - fixture pipe sizes and demand, 2010 V2: 86
  - fixture-unit loads, 2010 V2: 3
  - flow rates, 2012 V4: 9
  - graywater systems, 2009 V1: 126, 2010 V2: 23
  - health care facilities, 2011 V3: 35, 36, 40
  - hot water demand, 2010 V2: 99
  - installation requirements, 2012 V4: 10
  - LEED 2009 baselines, 2010 V2: 25
  - minimum numbers of, 2012 V4: 20–23
  - noise mitigation, 2009 V1: 198
  - patient rooms, 2011 V3: 37
  - poor installations of, 2009 V1: 259
  - recovery rooms, 2011 V3: 39
  - reduced water usage, 2009 V1: 118
  - shapes and sizes, 2012 V4: 9–10
  - standards, 2012 V4: 2
  - submerged inlet hazards, 2012 V4: 161
  - swimming pool facilities, 2011 V3: 109
  - temperatures, 2011 V3: 47
  - typical graywater supply, 2010 V2: 23–24
  - typical use, 2010 V2: 23
- Law of Inverse Proportions, 2009 V1: 218
- lawn imperviousness factors, 2011 V3: 239

- lawn sprinkler supply (LS), 2009 V1: 8
- lawn sprinklers. *See* irrigation systems; sprinkler systems (irrigation)
- lawsuits
  - moisture problems, 2009 V1: 263
  - noise-related, 2009 V1: 263
  - plumbing noise, 2009 V1: 187
- layer-type dezincification, 2009 V1: 131
- layers of effluent in septic tanks, 2010 V2: 145
- layers of fill, 2010 V2: 14
- lb, LBS (pounds). *See* pounds
- leaching trenches. *See* soil-absorption sewage systems
- leaching wells (dry wells), 2011 V3: 249–250
- lead
  - corrosion, 2009 V1: 129
  - in electromotive force series, 2009 V1: 132
  - in galvanic series, 2009 V1: 132
  - joint seals, 2012 V4: 26
  - in older plumbing system solder, 2012 V4: 220
  - storm water, 2010 V2: 27
- lead-absorbant filters, 2012 V4: 221
- lead and oakum joints, 2012 V4: 57
- lead-free legislation, 2012 V4: 225
- lead-free solders, 2012 V4: 59
- lead-lined concrete blocks, 2010 V2: 238
- lead-lined lath for plaster, 2010 V2: 238
- lead piping, 2010 V2: 75
- lead shielding on radioactive drainage systems, 2010 V2: 238
- lead-tin solders, 2009 V1: 132
- leaders. *See* downspouts and leaders; vertical stacks
- Leadership in Energy and Environmental Design (LEED), 2009 V1: 32
- leaf design filters, 2012 V4: 181–182
- leakage
  - clean agent gas fire suppression, 2011 V3: 27
  - compressed air systems, 2011 V3: 183
  - electrical leakage, 2012 V4: 117
  - eliminating, 2009 V1: 126
  - gas cabinets, 2011 V3: 268
  - leaking oil into water, 2010 V2: 244–246
  - propane tanks, 2010 V2: 133–134
  - waste anesthetic gas management, 2011 V3: 66
  - water conservation and, 2009 V1: 117
- leakage detection
  - aboveground tank systems, 2011 V3: 148–149
  - chemical wastes, 2010 V2: 243
  - connectors, 2011 V3: 148–149
  - industrial waste, 2011 V3: 84
  - infectious waste drainage systems, 2010 V2: 241
  - ion exchange systems, 2010 V2: 210
  - special-waste drainage systems, 2010 V2: 227
  - underground liquid fuel storage tanks, 2011 V3: 141–145
- leakage detection cables, 2012 V4: 56
- leakage tests
  - cold-water systems, 2010 V2: 90
  - private water systems, 2010 V2: 164
  - storage tanks, 2011 V3: 152–154
  - vacuum systems, 2010 V2: 177, 178
- LEED (Leadership in Energy and Environmental Design), 2009 V1: 32, 263
- LEED 2009 baselines, plumbing fixtures, 2010 V2: 25
  - overview, 2012 V4: 2
  - rating system, 2012 V4: 233–234
  - solar energy credits, 2011 V3: 190
  - wastewater reuse certification, 2010 V2: 21
  - water savings credits, 2012 V4: 241
- leg baths, 2010 V2: 99, 2011 V3: 36, 38, 40
- leg clearances
  - drinking fountains and water coolers, 2009 V1: 104
  - toilet and bathing rooms, 2009 V1: 105
- Legionella pneumophila, 2010 V2: 97, 108–111, 2011 V3: 196, 2012 V4: 199
- Legionellae Control in Health Care Facilities*, 2010 V2: 108–109
- legislation regarding people with disabilities, 2009 V1: 98–99
- legs in piping systems, 2011 V3: 48
- legs on tanks
  - cast-iron tank legs, 2009 V1: 154
  - problems in seismic protection, 2009 V1: 182, 183
- Lehr, Valentine A., 2010 V2: 29
- LEL gases (lower explosive level), 2011 V3: 266
- length (lg, LG, L)
  - conversion factors, 2009 V1: 35
  - in measurements, 2009 V1: 33
  - of stacks, 2009 V1: 3
  - total developed length in pipes, 2012 V4: 206, 207
  - of vent piping, 2009 V1: 3
- letters of service requests (gas), 2010 V2: 114
- Level 1, 2, and 3 gas and vacuum systems, 2011 V3: 34–35
- level control systems, 2011 V3: 131–133
- level control valves, 2012 V4: 82
- Level I vacuum systems, 2011 V3: 78
- Level III alarm systems, 2011 V3: 76
- Level III vacuum systems, 2011 V3: 78
- level-sensing systems, 2011 V3: 131–133
- level sensors
  - hazardous materials, 2011 V3: 84
  - tank gauges, 2011 V3: 141
- leveling bolts, 2012 V4: 142
- levels in water tanks, 2010 V2: 163
- levels of radiation, 2010 V2: 237
- Lewis, G.N., 2009 V1: 142
- LF (linear feet), 2009 V1: 15
- lg, LG (length). *See* length
- LH (latent heat), 2009 V1: 128
- LHEAT (latent heat), 2009 V1: 128
- life-cycle costs, 2009 V1: 128
- life hooks, 2011 V3: 135
- life rings, 2011 V3: 135
- life safety in fire protection, 2011 V3: 1
- lift check valves, 2012 V4: 76, 89
- lift station pumps, 2012 V4: 98
- lifts of fill, 2010 V2: 14
- light brackets, 2012 V4: 131
- light conversion factors, 2009 V1: 36
- light energy, defined, 2011 V3: 188–189
- light hazard occupancies
  - defined, 2009 V1: 29, 2011 V3: 2
  - firefighting hose streams, 2011 V3: 225
  - portable fire extinguishers, 2011 V3: 29
- light heating oil, 2011 V3: 136
- light process gas service, 2011 V3: 251–252
- light service gas, 2010 V2: 114

- light wall pipe (Schedule 10), 2012 V4: 37
- lighting protection, 2010 V2: 125
- lights, underwater, 2011 V3: 135
- lightwall pipes, 2011 V3: 13
- lime (calcium carbonate). *See* scale and scale formation
- lime-soda method of water softening, 2010 V2: 160, 210
- lime stabilization, biosolids, 2012 V4: 240
- limestone
  - calcium carbonate, 2012 V4: 173
  - defined, 2012 V4: 202
- limestone chips, 2010 V2: 235
- limit stops, 2012 V4: 131
- limited-care facilities, 2011 V3: 34, 76
- limited-discharge roof drains, 2011 V3: 250
- limiting conditions in seismic protection, 2009 V1: 183, 184
- limulus amoebocyte lysate test, 2010 V2: 188
- Lin, S.H., 2010 V2: 225
- Linaweaver, F.P., 2010 V2: 29
- line-pressure sensors, 2011 V3: 67
- line regulators, 2011 V3: 254
- linear acceleration
  - conversion factors, 2009 V1: 35
  - measurements, 2009 V1: 34
- linear expansion
  - in ABS pipe, 2012 V4: 51
  - in fiberglass pipe, 2012 V4: 53
  - linear coefficients of thermal expansion, 2012 V4: 207
  - of materials, 2012 V4: 211
  - in PVC pipe, 2012 V4: 49
- linear feet (lin ft, LF), 2009 V1: 15
- linear velocity measurements, 2009 V1: 34
- lined steel
  - storage tanks and hazardous wastes, 2011 V3: 84
  - sulfuric acid and, 2011 V3: 85
- linen holding areas, 2011 V3: 36
- liners, defined, 2012 V4: 131
- lining materials for dug wells, 2010 V2: 156
- Linstedt, K.C., 2010 V2: 154
- lint interceptors, 2011 V3: 39
- lint strainers, 2011 V3: 114, 124
- liquefaction, 2009 V1: 149
- liquefied petroleum gas (LPG). *See also* fuel-gas piping systems
  - abbreviations for, 2009 V1: 15
  - codes and standards, 2009 V1: 43
  - defined, 2010 V2: 136
  - design considerations, 2010 V2: 134–135
  - environmental impacts, 2010 V2: 131
  - gas boosters, 2010 V2: 125–128
  - glossary, 2010 V2: 135–136
  - overview, 2010 V2: 131
  - physical properties, 2010 V2: 113
  - piping, 2012 V4: 32, 34
  - pressures, 2010 V2: 115
  - propane regulators, 2010 V2: 132–133
  - sizing systems, 2010 V2: 135
  - sniffer systems, 2010 V2: 135
  - specific gravity, 2010 V2: 131
  - storage, 2010 V2: 131–134
  - valves for systems, 2012 V4: 87
  - vaporization requirements, 2010 V2: 134
- Liquefied Petroleum Gas Code (NFPA 58)*, 2010 V2: 115, 132–133, 137
- liquid contamination in compressed air, 2011 V3: 173, 264–265
- liquid fuel systems. *See* diesel-oil systems; gasoline systems
- liquid monitoring, 2011 V3: 143
- liquid oxygen (LO2, LOX)
  - defined, 2011 V3: 77
  - fire hazards, 2011 V3: 57
  - medical gas systems, 2011 V3: 58
  - symbol, 2009 V1: 8
- liquid petroleum, 2011 V3: 136
- liquid piston compressors, 2011 V3: 175
- liquid ring compressors, 2011 V3: 62, 175
- liquid ring pumps, 171, 2010 V2: 169, 170, 173
- liquid solar systems, 2011 V3: 192
- liquid waste
  - decontamination systems, 2010 V2: 241–242
  - defined, 2009 V1: 25
  - levels in septic tanks, 2010 V2: 146
- liquid withdrawal valves
  - propane tanks, 2010 V2: 133
- liquids, vacuuming, 2010 V2: 178
- listed, defined, 2009 V1: 25
- listing agencies, 2009 V1: 25
- listings, product, cross-connection control, 2012 V4: 168
- liters
  - converting to gallons units, 2011 V3: 30
  - converting to SI units, 2009 V1: 38
  - liters per minute (L/min, Lpm), 2010 V2: 166, 2011 V3: 187
  - liters per second (L/s), 2011 V3: 187
  - non-SI units, 2009 V1: 34
- live loads on roofs, 2010 V2: 51
- lm (lumens), 2009 V1: 34
- LO (lubricating oil), 2009 V1: 8, 2010 V2: 12
- LO2 (liquid oxygen). *See* liquid oxygen
- load adjustment scales, 2012 V4: 131
- load bolts or pins, 2012 V4: 131
- load couplings, 2012 V4: 131
- load indicators, 2012 V4: 131
- load rates, storm water infiltration, 2010 V2: 48
- load ratings
  - carbon steel threaded hanger rods, 2012 V4: 122
  - concrete inserts, 2012 V4: 129
  - defined, 2012 V4: 131
  - hangers and supports, 2012 V4: 124
  - suspended equipment supports, 2009 V1: 258
- load scales, 2012 V4: 132
- load variations, 2012 V4: 132
- loading influences for bioremediation, 2012 V4: 229
- loading tables
  - fixture-unit values in drainage systems, 2010 V2: 3
  - vertical stacks, 2010 V2: 4
- loads. *See also* pipe loads; support and hanger loads
  - computer analysis of loads, 2009 V1: 180
  - connected loads, defined, 2010 V2: 136
  - design considerations in seismic protection, 2009 V1: 180–182
  - horizontal loads of piping, 2009 V1: 177
  - live loads on roof, 2010 V2: 51
  - load factors, defined, 2009 V1: 25

pipe supports, 2012 V4: 115–116  
 settlement loads, 2009 V1: 180  
 sway bracing, 2009 V1: 178–179  
 vertical seismic load, 2009 V1: 177  
 loams, 2011 V3: 91  
 local alarms, 2011 V3: 76. *See also* area alarms  
 local application systems (carbon dioxide), 2011 V3: 26  
 local authorities, 2010 V2: 24, 227  
 local barometric pressure in vacuums, 2010 V2: 166  
 local rainfall rate tables, 2010 V2: 57  
 localized corrosion, 2010 V2: 195  
 location of piping, earthquake protection and, 2009 V1: 159  
 locations of hangers. *See* cold hanger location; hot hanger locations  
 lock-out regulators, 2011 V3: 255  
 lock-up periods, 2012 V4: 132  
 locker rooms, 2011 V3: 36  
 Loevenguth, 2009 V1: 185  
 long runs in vacuum cleaning systems, 2010 V2: 185  
 long-turn tee-wyes, 2010 V2: 4  
 longest length gas pipe sizing method, 2010 V2: 130  
 longitudinal bracing  
   defined, 2009 V1: 185, 2012 V4: 132  
   longitudinal and transverse bracing, 2009 V1: 173  
   longitudinal brace points, 2009 V1: 160  
   longitudinal-only bracing, 2009 V1: 173  
   seismic protection, 2009 V1: 165  
   sway bracing, 2009 V1: 178  
 longitudinal forces, 2009 V1: 185  
 longitudinal motion  
   expansion and contraction, 2012 V4: 207  
   hangers and supports, 2012 V4: 116–117, 118  
*Looking to Treat Wastewater? Try Ozone*, 2010 V2: 225  
 loop systems  
   expansion loops, 2012 V4: 206  
   fire mains, 2011 V3: 6  
 loop vents, 2009 V1: 26, 31, 2010 V2: 32, 33, 2011 V3: 46  
 LOV (lubricating oil vents), 2009 V1: 8  
 low-alkalinity water, 2012 V4: 184  
 low backflow hazard, 2011 V3: 215  
 low-demand classifications, 2010 V2: 100  
 low-expansion borosilicate glass, 2012 V4: 35  
 low-expansion foams, 2011 V3: 25  
 low-extractable PVC piping, 2012 V4: 52–53  
 low-flow fixtures  
   low-flow control valves, 2011 V3: 95  
   low-flush toilets and water closets, 2009 V1: 126  
   water conservation estimates, 2009 V1: 117  
 low-flow shutdown systems, 2010 V2: 63  
 low-flow toilets  
   fixture drain flow, 2010 V2: 2  
 low-flush toilets and water closets, 2009 V1: 126  
 low-pressure carbon dioxide systems, 2011 V3: 26  
 low-pressure condensate (LPC), 2009 V1: 9  
 low-pressure cutouts, 2012 V4: 221  
 low-pressure gas (G), 2009 V1: 8  
 low-pressure gas cutoffs, 2010 V2: 118  
 low-pressure natural gas systems, 2010 V2: 113–125  
 low-pressure steam (lps, LPS), 2009 V1: 9, 2012 V4: 85–86  
 low-pressure tanks, 2011 V3: 136  
 low-suction-pressure switches, 2010 V2: 63  
 low-temperature foam, 2011 V3: 25

lower explosive level gases (LEL), 2011 V3: 266  
 lower order functions, 2009 V1: 221  
 Lowther plate units, 2010 V2: 214  
*LP-Gas Serviceman's Manual*, 2010 V2: 137  
 LPC (low-pressure condensate), 2009 V1: 9  
 lpg. *See* liquefied petroleum gas  
 Lpm (liters per minute). *See* liters  
 lps, LPS (low-pressure steam), 2009 V1: 9, 2012 V4: 85–86  
 LS (lawn sprinkler supply), 2009 V1: 8  
 LSI (Langelier saturation index), 2010 V2: 196  
 LT. *See* laundry sinks or trays  
 lubricated plug valves, 2012 V4: 77  
 lubricating oil (LO), 2009 V1: 8, 2010 V2: 12, 2012 V4: 60  
 lubricating oil vents (LOV), 2009 V1: 8  
 lubrication, direct connection hazards and, 2012 V4: 161  
 lubricators in compressed air systems, 2011 V3: 184  
 lug plates, 2012 V4: 125  
 lug style valves, 2012 V4: 76  
 lugs, 2012 V4: 125, 132  
 lumens, 2009 V1: 34  
 luminance measurements, 2009 V1: 34  
 luminous flux, 2009 V1: 34  
 luminous measurements, 2009 V1: 34  
 lux, 2009 V1: 34  
 LV (laboratory vacuum), 2009 V1: 9  
 LWDS (liquid-waste decontamination systems), 2010 V2: 241–242  
 lx (lux), 2009 V1: 34  
 lye. *See* sodium hydroxide (lye or caustic soda)

## M

m (meters). *See* meters (measurements)  
 M alkalinity, 2010 V2: 189  
 M piping. *See* Type M copper  
 M (mega) prefix, 2009 V1: 34  
 m (milli) prefix, 2009 V1: 34  
 m/s (meters per second), 2009 V1: 34  
 m/s<sup>2</sup> (meters per second squared), 2009 V1: 34  
 m<sup>2</sup> (meters squared), 2009 V1: 34  
 m<sup>2</sup>/s (meters squared per second), 2009 V1: 34  
 m<sup>3</sup> (cubic meters), 2009 V1: 34  
 m<sup>3</sup>/kg (cubic meters per kilogram), 2009 V1: 34  
 m<sup>3</sup>/min (cubic meters per minute), 2011 V3: 172  
 m<sup>3</sup>/s (cubic meters per second), 2009 V1: 34  
 MΩ (mega ohms), 2012 V4: 191  
 MA. *See* medical compressed air  
 macadam pavement runoff, 2010 V2: 42  
 MacHatton, J.G., 2010 V2: 154  
 machine trenching, labor productivity rates, 2009 V1: 87–88  
 magnesia, 2012 V4: 173  
 magnesite, 2012 V4: 173  
 magnesium  
   corrosion, 2009 V1: 129  
   defined, 2012 V4: 202  
   dry-power extinguishing systems, 2011 V3: 24  
   in electromotive force series, 2009 V1: 132  
   in galvanic series, 2009 V1: 132  
   in hardness, 2012 V4: 183  
   laboratory grade water, 2012 V4: 198  
   lifespan of anodes, 2009 V1: 138  
   nanofiltration, 2012 V4: 199

- sacrificial anodes, 2009 V1: 137
- in water, 2010 V2: 189, 190
- water hardness and, 2012 V4: 176
- zeolite process and, 2010 V2: 160
- magnesium alloys, 2009 V1: 132
- magnesium bicarbonate, 2010 V2: 190, 2012 V4: 173
- magnesium carbonate, 2010 V2: 189, 190, 196, 2012 V4: 173
- magnesium chloride, 2010 V2: 190
- magnesium hydroxide, 2010 V2: 189
- magnesium oxide, 2012 V4: 173
- magnesium salts, 2012 V4: 176
- magnesium sulfate, 2010 V2: 189, 2012 V4: 173
- magnetic drive meters, 2010 V2: 88
- magnetic field strength measurements, 2009 V1: 34
- magnetic flux density, 2009 V1: 34
- magnetic flux measurements, 2009 V1: 34
- magnetism, conversion factors, 2009 V1: 35
- magnetostrictive tank gauging, 2011 V3: 142
- main drain piping, swimming pools, 2011 V3: 112, 132
- main relief valves, 2011 V3: 22
- main shut-off valves, 2011 V3: 66
- main vents, 2009 V1: 26, 2010 V2: 37
- mains. *See also* water mains
  - defined, 2009 V1: 26, 2011 V3: 78
  - fire mains, 2011 V3: 6
  - force mains, 2011 V3: 225, 229, 234–235
  - natural gas mains, 2011 V3: 256
  - pipe, 2009 V1: 12
  - thermal expansion and contraction, 2012 V4: 206
- maintenance
  - costs, 2009 V1: 217
  - fountains and pools, 2011 V3: 98
  - grease interceptors, 2012 V4: 157–158
  - pumps, 2012 V4: 99
  - section in specifications, 2009 V1: 63–64, 71
  - stills, 2012 V4: 191, 198
  - storm drainage, 2010 V2: 48–49
- maintenance hot-water temperatures, 2010 V2: 105–106
- major or prime costs, 2009 V1: 217
- makeshift installations, 2009 V1: 254–257, 263–264
- makeup, 2009 V1: 128
- makeup water systems, 2012 V4: 224
- malleable (mall), defined, 2009 V1: 26
- malleable iron rings, 2012 V4: 119
- malleable iron valves, 2012 V4: 77
- malls, 2010 V2: 24
- Management of Small Waste Flows*, 2010 V2: 29
- Manas, Vincent T., 2010 V2: 55
- manganese, 2010 V2: 160, 198, 2012 V4: 173
- manholes
  - acid manholes, 2011 V3: 231
  - acid-waste systems, 2010 V2: 233, 235
  - bioremediation pretreatment systems, 2012 V4: 230
  - chemical-waste systems, 2010 V2: 243
  - cleanouts, 2011 V3: 234
  - defined, 2009 V1: 26
  - drop manholes, 2011 V3: 228, 232
  - grease interceptors, 2012 V4: 153
  - MH abbreviation, 2009 V1: 15
  - precast manholes, 2011 V3: 226, 230
  - sampling manholes, 2011 V3: 45
  - sanitary sewer systems, 2011 V3: 226–228, 230
  - shallow manholes, 2011 V3: 228, 232
  - spacing, 2011 V3: 233
  - steps and covers, 2011 V3: 228
  - storm drainage, 2010 V2: 48–49
  - venting, 2011 V3: 228, 233
  - waterproof manholes, 2011 V3: 228, 233
- manifolds
  - compressed air, 2011 V3: 61
  - laboratory high-purity gas systems, 2011 V3: 270–271
  - nitrogen systems, 2011 V3: 64, 65
  - nitrous oxide systems, 2011 V3: 59–60, 61
  - oxygen, 2011 V3: 57, 59, 60
  - purging, 2011 V3: 275
- manmade environmental conditions, 2012 V4: 118
- Manning formula
  - alternative sewage-disposal systems, 2010 V2: 144
  - circular pipes, 2011 V3: 226
  - ditches, 2011 V3: 250
  - grease flow control devices, 2012 V4: 155
  - open-channel flow, 2009 V1: 1, 2010 V2: 6, 7
  - sloping drains, 2010 V2: 7, 2011 V3: 224
  - storm-drainage pipes, 2011 V3: 242
- manual butterfly valves, 2011 V3: 125
- manual chlorinators, 2012 V4: 178
- manual-control irrigation valves, 2011 V3: 94
- manual controls on ion exchangers, 2012 V4: 183
- manual dry standpipe systems, 2011 V3: 20
- manual flushometer valves, 2012 V4: 7
- manual grease interceptors, 2012 V4: 151
- Manual of Practice*
  - introduction, 2009 V1: 55
  - section shell outline, 2009 V1: 68–72
  - Uniformat, 2009 V1: 58
- Manual of Septic Tank Practice*, 2010 V2: 152
- Manual on the Design and Construction of Sanitary and Storm Sewers*, 2010 V2: 55
- manual overflow prevention, 2011 V3: 148
- manual overrides, 2011 V3: 94
- manual pull stations, 2011 V3: 24
- manual release stations, 2011 V3: 28
- manual tank gauging, 2011 V3: 142
- manual trap primers, 2010 V2: 11
- manual wet standpipe systems, 2011 V3: 20
- manufacturers
  - noise mitigation features of products, 2009 V1: 202–203, 205–206
  - in specifications, 2009 V1: 64, 71
- Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
  - ball valve standards, 2012 V4: 84, 85, 88
  - bronze valve standards, 2012 V4: 83, 84, 85, 86
  - butterfly valve standards, 2012 V4: 84, 85, 88
  - cast iron check valve standards, 2012 V4: 84
  - cast iron valve standards, 2012 V4: 83, 86, 88
  - check valve standards, 2012 V4: 87
  - gate valve standards, 2012 V4: 83, 85, 86
  - globe valve standards, 2012 V4: 86, 87
  - medical gas tube standards, 2012 V4: 34
  - MSS abbreviation, 2009 V1: 32, 52
  - swing check valve standards, 2012 V4: 88
  - valve standards, 2012 V4: 73
- manufacturing facilities, 2011 V3: 81, 2012 V4: 223

- manways in tanks, 2011 V3: 139, 145, 150, 2012 V4: 230
- maps
  - frost lines, 2011 V3: 218
  - seismic risk maps, 2009 V1: 145–146
  - soils, 2010 V2: 140
- marble acrylic fixtures, 2012 V4: 1
- marble as calcium carbonate, 2012 V4: 173
- marble fixtures, 2012 V4: 1
- mark-ups, in plumbing cost estimation, 2009 V1: 85–86, 86
- markets
  - in creativity checklist, 2009 V1: 227
  - sanitation in, 2010 V2: 15
- markings, corrosion and, 2009 V1: 136
- Marks, Lionel S., 2009 V1: 1, 2, 3, 5, 39
- marsh gas, 2012 V4: 173
- martensitic stainless steel, 2012 V4: 54
- Maryland Department of the Environment, 2010 V2: 55
- Maryland Stormwater Design Manual, 2010 V2: 55
- mass
  - conversion factors, 2009 V1: 36
  - mass per unit area measurements, 2009 V1: 34
  - mass per unit length measurements, 2009 V1: 34
  - in measurements, 2009 V1: 33
  - non-SI units, 2009 V1: 34
- mass flow, 2010 V2: 166
- mass flow meters, 2011 V3: 177, 275
- mass flow rates (mfr, MFR), 2009 V1: 34
- massive soil structure, 141, 2010 V2: 140
- master alarms
  - defined, 2011 V3: 76
  - medical gas systems, 2011 V3: 50, 67, 75
- master plumbers, 2009 V1: 26
- MasterFormat
  - comparisons and changes in 2004, 2009 V1: 59–60
  - defined, 2009 V1: 58
  - specifications sections, 2009 V1: 62–65
- MasterFormat 2004, 2009 V1: 58–60, 72–83
- MasterFormat expansion task team (MFETT), 2009 V1: 58
- MasterFormat Level Four (1995), 2009 V1: 68–69
- MasterFormat Level One (1995), 2009 V1: 66
- MasterFormat Level Three (1995), 2009 V1: 68
- MasterFormat Level Two (1995), 2009 V1: 66–68
- Masterspec, 2009 V1: 65
- mastic, 2012 V4: 106
- mat zones in grease interceptors, 2012 V4: 147
- material costs
  - defined, 2009 V1: 210
  - in plumbing cost estimation, 2009 V1: 85
  - in take-off estimating method, 2009 V1: 86
  - in value engineering, 2009 V1: 208
- material safety data sheets, 2009 V1: 15
  - industrial wastes, 2011 V3: 83
  - laboratory gas, 2011 V3: 263
- materials. *See also* specific materials or system fixtures
  - detail/product/material specification checklist, 2009 V1: 215
  - fixtures, 2012 V4: 1–2
  - materials section in specifications, 2009 V1: 64, 71
  - ongoing and one-time costs, 2009 V1: 217
  - in plumbing cost estimation, 2009 V1: 85
  - quality choices, 2009 V1: 254
  - sprinkler system piping (fire protection), 2011 V3: 20
  - storm-drainage systems, 2011 V3: 238
  - value engineering questions, 2009 V1: 209
- materials expansion, 2012 V4: 211
- materials section in specifications, 2009 V1: 64, 71
- maximum allowable stress and strain, 2012 V4: 205–206
- maximum considered earthquake motion, 2009 V1: 147
- maximum design flow, 2010 V2: 127
- maximum discharge pressure, defined, 2011 V3: 186
- maximum discharge rates, 2009 V1: 5
- maximum flow rates for fixtures, 2012 V4: 186
- maximum outlet pressure in gas boosters, 2010 V2: 128
- maximum probably demand, 2009 V1: 26
- maximum resistance values, 2010 V2: 192–193
- mbars (millibars), 2010 V2: 166
- mc (millicuries), 2010 V2: 237
- McAlister, Roy, 2011 V3: 203
- McClelland, Nina I., 2010 V2: 154
- MCE (maximum considered earthquake motion), 2009 V1: 147
- Mcf, MCF (thousand cubic feet), 2009 V1: 15
- McSweeney, D.P., 2010 V2: 186
- MDPE (medium density) 2406 pipe, 2012 V4: 42
- MEA (New York City Materials and Equipment Acceptance Division), 2012 V4: 88
- meadow, runoff, 2010 V2: 42
- measurable nouns in function analysis, 2009 V1: 218, 219
- measurement units
  - compressed air, 2011 V3: 187
  - converting, 2011 V3: 30
  - flow rates, 2010 V2: 166
  - International System of Units, 2009 V1: 33–39
  - microorganisms, 2010 V2: 188
  - non-SI units, 2009 V1: 34
  - pressure, 2011 V3: 187
  - pure water, 2011 V3: 47
  - radiation, 2010 V2: 237
  - types of conversions, 2009 V1: 33
  - units and symbols, 2009 V1: 33
  - usage of, 2010 V2: 165–166
  - vacuum pressure, 2010 V2: 166
  - water impurities, 2010 V2: 191
- measuring tank leakage, 2011 V3: 141–145
- Measuring Water Purity by Specific Resistance*, 2010 V2: 225
- mechanical aerators, 2010 V2: 198
- mechanical areas
  - fountain equipment location, 2011 V3: 98–99
  - sediment buckets, 2010 V2: 11
  - trap primers in drains, 2010 V2: 12
- mechanical clarifiers, 2012 V4: 179
- mechanical code agencies, 2009 V1: 42
- mechanical couplings, 2012 V4: 63
- mechanical efficiency, 2011 V3: 186, 2012 V4: 101
- mechanical emulsions, 2011 V3: 88
- Mechanical Engineering Reference Manual*, 2010 V2: 136
- mechanical equipment rooms (MER), 2009 V1: 15
- mechanical foam extinguishers, 2011 V3: 25–26
- mechanical joints, 2009 V1: 160, 2011 V3: 42, 221, 2012 V4: 57, 58–59
- mechanical pump seals, 2012 V4: 92
- mechanical rooms
  - as source of plumbing noise, 2009 V1: 188
  - earthquake protection, 2009 V1: 158



- mechanical rotary-type vacuum pumps, 2010 V2: 169
- mechanical snubbers, 2012 V4: 132
- mechanical steam traps, 2011 V3: 162
- mechanical sway bracing, 2012 V4: 132
- mechanical tank gauging, 2011 V3: 142
- mechanically-dispersed oil, 2010 V2: 244
- Meckler, Milton, 2009 V1: 39
- media (biofilms), 2012 V4: 229
- media rate, filter, 2011 V3: 111
- medical air systems. *See also* medical compressed air (MA)
  - color coding, 2011 V3: 55
  - concentrations, 2011 V3: 76
  - defined, 2011 V3: 76–77
  - medical compressed air (MA)
    - altitude and, 2011 V3: 63
    - compressors, 2011 V3: 50, 77
    - storage, 2011 V3: 61–64
    - surgical use, 2011 V3: 56
    - symbol, 2009 V1: 8
    - system description, 2011 V3: 61–62
  - peak demand, 2011 V3: 53
  - pipe sizing, 2011 V3: 68–69
  - stations, 2011 V3: 51, 52–53
  - testing, 2011 V3: 75–76
- medical cabinets, 2009 V1: 105
- medical compressed air (MA)
  - altitude and, 2011 V3: 63
  - compressors, 2011 V3: 50, 77
  - storage, 2011 V3: 61–64
  - surgical use, 2011 V3: 56
  - symbol, 2009 V1: 8
  - system description, 2011 V3: 61–62
- medical gas systems
  - certification, 74–76, 2011 V3: 69
  - codes and standards, 2011 V3: 76
  - color coding, 2011 V3: 51, 55
  - design checklist, 2011 V3: 50
  - dispensing equipment, 2011 V3: 51–54
  - diversity factors, 2011 V3: 70
  - earthquake bracing for, 2009 V1: 158
  - gas flow rates, 2011 V3: 51
  - gas storage, 2011 V3: 57–61
  - health care facilities, 2011 V3: 50–76
  - levels, 2011 V3: 34–35
  - number of stations, 2011 V3: 51
  - pipng, 2011 V3: 68–76
  - system control valves, 2011 V3: 66–67
  - typical storage layout, 2011 V3: 58
  - valves for, 2012 V4: 85
  - warning systems, 2011 V3: 67
  - waste anesthetic gas management, 2011 V3: 65–66
- medical-gas tube, 2011 V3: 69, 74, 2012 V4: 33–34
- medical-grade water, 2012 V4: 52
- medical laboratories. *See* health care facilities; laboratories
- medical schools. *See* health care facilities
- medical vacuum (MV), 2009 V1: 9
- medical waste systems. *See* infectious and biological waste systems
- Medicare taxes, in labor costs, 2009 V1: 86
- medicine sinks, 2011 V3: 38
- medium-backflow hazard, 2011 V3: 215
- medium brackets, 2012 V4: 132
- medium-demand classifications, 2010 V2: 99, 100
- medium-expansion foams, 2011 V3: 25
- medium-pressure condensate (MPC), 2009 V1: 9
- medium-pressure gas (MG), 2009 V1: 8, 2010 V2: 113–125
- medium-pressure steam (mps, MPS), 2009 V1: 9, 2012 V4: 86
- medium vacuum, 2010 V2: 165
- mega-ohm-cm, 2010 V2: 193, 2012 V4: 175
- mega-ohms (MΩ), 2012 V4: 191
- mega prefix, 2009 V1: 34
- membrane filtration
  - cross-flow filters, 2010 V2: 201, 213
  - graywater systems, 2010 V2: 25
  - in health care facilities, 2011 V3: 48
  - membrane flux, 2010 V2: 211
  - membrane productivity, 2010 V2: 221
  - membrane selection in reverse osmosis, 2010 V2: 213
  - nanofiltration, 2012 V4: 199
  - overview, 2010 V2: 211–213
  - pure water systems, 2010 V2: 221
  - reverse osmosis, 2010 V2: 211–213, 2012 V4: 195–197
  - tangential-flow filters, 2010 V2: 201
  - total dissolved solids and, 2010 V2: 194
  - types of membranes, 2012 V4: 199
- membrane flux, 2010 V2: 211
- membrane productivity, 2010 V2: 221
- Membrane Technologies in the Power Industry*, 2010 V2: 224
- membranes in waterproofing, 2010 V2: 16
- memory metal couplings, 2011 V3: 69
- MER (mechanical equipment rooms), 2009 V1: 15
- mercantile facilities, 2012 V4: 21
- mercury vapor lamps, 2010 V2: 213, 2012 V4: 195
- Mermel, H., 2010 V2: 246
- Meslar, H.W., 2010 V2: 246
- metal flashing on roof drains, 2010 V2: 49
- metal isolation, 2009 V1: 258
- metal-to-metal valve seating, 2012 V4: 74
- metallic hose, 2012 V4: 143
- metallic inert gas (MIG), 2012 V4: 61
- metallic pipes. *See also* specific metals
  - bedding, 2011 V3: 225–226, 227
  - pure-water systems, 2011 V3: 49
- metals. *See also* specific metals
  - corrosion losses, 2009 V1: 129
  - galvanic series table, 2009 V1: 132
  - metallic coatings, 2009 V1: 136
  - removing in effluent, 2012 V4: 227
- Metcalf, 2010 V2: 154
- meter-reading equipment, 2010 V2: 116
- meter set assemblies, 2010 V2: 136
- meters (gas)
  - installation, 2010 V2: 115–116
  - meter-reading equipment, 2010 V2: 116
  - outlet pressures, 2010 V2: 115
- meters (general devices)
  - acid wastes, 2011 V3: 45
  - fuel dispensers, 2011 V3: 146
  - natural gas, 2010 V2: 115–177, 2011 V3: 252, 254
- meters (measurements)
  - converting units, 2011 V3: 30
  - meters, 2009 V1: 34
  - meters of head, 2009 V1: 2

- meters per second, 2009 V1: 34
- meters per second squared, 2009 V1: 34
- meters squared, 2009 V1: 34
- meters squared per second, 2009 V1: 34
- meters (water)
  - domestic cold water systems, 2010 V2: 59–60
  - flow pressure loss tables, 2010 V2: 61
  - irrigation, 2011 V3: 95–96
  - irrigation systems and, 2011 V3: 95–96
  - meter readings, 2012 V4: 186
  - pressure and, 2010 V2: 84
  - pressure losses, 2011 V3: 216
- methane, 2010 V2: 114, 2012 V4: 173. *See also* fuel-gas piping systems
- Method for Measuring the Minimum Oxygen Concentration to Support Candle-like Combustion of Plastics (ASTM D2863)*, 2011 V3: 77
- Methods of Estimating Loads in Plumbing Systems*, 2010 V2: 95–96
- methoxyflurane, 2011 V3: 66
- methyl orange alkalinity, 2010 V2: 189
- Metric Conversion Act, 2009 V1: 33
- metric hangers, 2012 V4: 132
- metric tons, 2009 V1: 34
- metric units. *See* International System of Units
- Meyers, Vance A., 2010 V2: 55
- Meyrick, C.E., 2010 V2: 225
- MFETT (MasterFormat expansion task team), 2009 V1: 58
- mfr, MFR (mass flow rates), 2009 V1: 34
- MG (medium-pressure gas), 2009 V1: 8
- mg/L (milligrams per liter), 2010 V2: 191
- MGD (million gallons per day), 2009 V1: 15
- MH (manholes). *See* manholes
- mho (specific conductivity), 2010 V2: 193
- micro prefix, 2009 V1: 34
- microbial growth and control. *See also* bacteria; microorganisms; viruses
  - cooling towers, 2010 V2: 217
  - drinking water, 2010 V2: 217
  - feed water, 2010 V2: 220
  - pure water systems, 2010 V2: 222
  - utility water, 2010 V2: 215
  - water softeners, 2010 V2: 210, 211
  - water treatments, 2010 V2: 213–214
- microbiological fouling of water, 2010 V2: 195, 217
- microbiological laboratories, 2010 V2: 241. *See also* laboratories
- micrometers, vacuum units, 2010 V2: 166
- micromhos, 2010 V2: 193
- microns, converting to SI units, 2009 V1: 39
- microorganisms. *See also* bacteria; microbial growth and control; viruses
  - biofilms, 2012 V4: 228
  - bioremediation systems, 2012 V4: 228
  - chlorination systems, 2012 V4: 177–178
  - infectious waste drainage systems, 2010 V2: 240–241
  - laboratory grade water, 2012 V4: 198
  - pure water systems, 2010 V2: 222, 2011 V3: 49
  - ultraviolet light and, 2012 V4: 194
  - water analysis of, 2010 V2: 188
  - water treatments, 2010 V2: 213–214, 218
- microscopes, electron, 2011 V3: 40, 42, 47, 52
- microsiemens ( $\mu\text{S}$ ), 2012 V4: 191
- MIG (metallic inert gas), 2012 V4: 61
- miles
  - converting to SI units, 2009 V1: 39
  - miles per hour (mph, MPH), 2009 V1: 15
- Miles, Lawrence D., 2009 V1: 252
- mill galvanization, 2012 V4: 132
- Millepore filters, 2010 V2: 194
- milli prefix, 2009 V1: 34
- millibars (mbar)
  - converting to SI units, 2009 V1: 39
  - vacuum units, 2010 V2: 166
- millicuries (mc), 2010 V2: 237
- milligrams per liter (mg/L), 2010 V2: 191
- millimeters
  - converting to inches, 2011 V3: 30
  - converting to SI units, 2009 V1: 39
- million gallons per day (MGD), 2009 V1: 15
- millirems (mrem), 2010 V2: 237
- Mills, Lawrence E., 2009 V1: 209
- min (minutes), 2009 V1: 34
- min., MIN (minimum), 2009 V1: 15
- mineral fiber blankets, 2012 V4: 107
- mineral salts, 2010 V2: 194, 196, 2012 V4: 176, 182
- mineral solids, 2010 V2: 195
- minerals
  - removing from water, 2012 V4: 182
  - in water, 2012 V4: 176, 182
- minimum (min., MIN), 2009 V1: 15
- minimum design flow, 2010 V2: 127
- Minimum Design Loads for Buildings and Other Structures*, 2009 V1: 147, 174, 185
- minimum outlet pressure in gas boosters, 2010 V2: 128
- Minimum Property Standards (HUD), 2009 V1: 99
- Minnesota Urban Small Sites Best Management Practice Manual*, 2010 V2: 42, 55
- minor backflow hazards, 2011 V3: 215
- minutes, 2009 V1: 34
- mirrors, 2009 V1: 105
- misaligned wells, pumps for, 2010 V2: 161
- miscellaneous gases, 2011 V3: 77
- mist, 2009 V1: 26
- mist eliminators, 2010 V2: 200
- mitigating noise
  - drainage systems, 2009 V1: 189–190
  - fixtures and fixture outlets, 2009 V1: 193–194
  - valves, pumps and equipment, 2009 V1: 194–201
  - water distribution system noise mitigation, 2009 V1: 190–193
- MIUS Technology Evaluation: Collection, Treatment and Disposal of Liquid Wastes*, 2010 V2: 154
- mixed-bed deionization (single-step), 2010 V2: 206, 208, 2011 V3: 48
- mixed flow, 2012 V4: 101
- mixed-flow pumps, 2012 V4: 91
- mixes in specifications, 2009 V1: 71
- mixing faucets, 2011 V3: 37
- mixing flows of water
  - conserving energy, 2009 V1: 118
  - mixed-water temperatures, 2010 V2: 101
- mixing stations, 2011 V3: 39
- mock-ups, 2009 V1: 264

- moderate backflow hazard, 2011 V3: 215  
*Modern Vacuum Practice*, 2010 V2: 186  
 modifications section in project manual, 2009 V1: 57  
 modulating valves, pneumatically operated main drain, 2011 V3: 131–132  
 Moffat, R., 2010 V2: 186  
 moisture problems, 2009 V1: 263  
 molded elastomer mounting, 2012 V4: 142  
 mole (mol), 2009 V1: 33  
 molecular sieve filters, 2011 V3: 273  
 molecular weights of elements, 2010 V2: 189  
 molybdenum-alloyed chromium-nickel steels, 2012 V4: 56  
 moments of inertia  
   calculating, 2012 V4: 205  
   conversion factors, 2009 V1: 36  
   measurements, 2009 V1: 34  
 momentum measurements, 2009 V1: 34  
 Monel, 2009 V1: 132, 2012 V4: 108  
 monitor-type intermediate gas regulators, 2011 V3: 255  
 monitoring  
   aboveground tank systems, 2011 V3: 148–149  
   defined, 2009 V1: 26  
   ground water, 2011 V3: 143–144  
   underground liquid fuel storage tanks, 2011 V3: 141–145  
 monobed demineralizers, 2012 V4: 183  
 monovalent ions  
   laboratory grade water, 2012 V4: 198  
   nanofiltration, 2012 V4: 199  
 Montgomery, R.H., 2011 V3: 203  
 monthly inventory tank tightness testing, 2011 V3: 143  
 Montreal Protocol, 2011 V3: 26  
 Moody, L.F., 2010 V2: 74  
 mop basins or sinks, 2009 V1: 199, 2010 V2: 23, 2011 V3: 36, 37, 2012 V4: 12  
 morgues and mortuaries, 2010 V2: 15  
 Moritz, A.R., 2010 V2: 111  
 mosquitoes, 2010 V2: 49  
 motels. *See* hotels  
 motion  
   in creativity checklist, 2009 V1: 227  
   in earthquakes, 2009 V1: 149–150  
 motor compressors, 2012 V4: 219  
*Motor Fuel Dispensing Facilities and Repair Garages Code (NFPA 30A)*, 2011 V3: 137  
 motor lubrication oil, 2011 V3: 136  
 motor-operated filter bag shakers, 2010 V2: 179  
 motor-operated valves, 2009 V1: 9  
 motors  
   earthquake protection, 2009 V1: 157  
   pump motor controls, 2010 V2: 63–64  
 mounting. *See also* installation  
   elastomer-cork mountings, 2012 V4: 142  
   fire extinguishers, 2011 V3: 29  
   natural frequency and, 2012 V4: 138  
   resilient mounts. *See* resilient mounts  
   water closets, 2012 V4: 3  
 movable gas appliances, 2010 V2: 124–125  
 MPC (medium-pressure condensate), 2009 V1: 9  
 mph, MPH (miles per hour), 2009 V1: 15  
 MPS (medium-pressure steam supply), 2009 V1: 9  
 mrem (millerems), 2010 V2: 237  
 MSDS (material safety data sheets), 2009 V1: 15, 2011 V3: 83  
 MSS. *See* Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)  
 MU (viscosity), 2009 V1: 2, 34, 2011 V3: 136–137  
 mudballing in filters, 2012 V4: 181  
 Mudge, Arthur E., 2009 V1: 252  
 muds in feed water, 2010 V2: 195  
 mufflers on vacuum systems, 2011 V3: 64  
 multi-cell vertical high-rate sand filters, 2011 V3: 118  
 multi-effect distillation, 2010 V2: 200, 204, 2012 V4: 192  
 multi-family buildings. *See* apartment buildings  
 multi-graded sand filtration, 2010 V2: 201  
 multi-stage pumps, 2012 V4: 101  
 multi-turn valves, 2012 V4: 73  
 multimedia depth filters, 2012 V4: 180  
 multimedia filtration, 2010 V2: 201, 221  
 multiple. *See also* entries beginning with double-, multi-, or two-  
   multiple-compartment septic tanks, 2010 V2: 147  
   multiple-degree-of-freedom systems, 2009 V1: 150, 151  
   multiple-family dwellings. *See* apartment buildings  
   multiple-gang-service outlets, 2011 V3: 51  
   multiple pressure-regulated valve installation, 2010 V2: 69–70  
   multiple-pump systems, 2010 V2: 63  
   multiple supports, 2012 V4: 132  
   multiple-tray waterfall aerators, 2010 V2: 198  
   multiplication in SI units, 2009 V1: 35  
   multipurpose dry chemicals, 2011 V3: 23, 29  
   multistage pumps, 2012 V4: 97  
   multistory buildings. *See* large buildings  
   multivalent ions, 2012 V4: 198  
   municipal sewers. *See* public sewers  
   municipal water supply  
   city water, 2009 V1: 19  
   cross connections and, 2012 V4: 160  
   fire-protection connections, 2011 V3: 217  
   irrigation usage, 2011 V3: 96  
   sprinkler systems, 2011 V3: 2–3  
   types of, 2011 V3: 6  
   water mains and pressure, 2011 V3: 206  
   municipalities, rainfall, 2010 V2: 57  
   muriatic acid, 2010 V2: 207, 232, 2012 V4: 173. *See also* hydrochloric acid  
 Musgrave, G.W., 2010 V2: 55  
 mussels, 2010 V2: 188  
 MV (medical vacuum), 2009 V1: 9
- ## N
- n (nano) prefix, 2009 V1: 34  
 N (newtons), 2009 V1: 34  
 n c, N C (normally closed), 2009 V1: 15  
 n i c, N I C (not in contract), 2009 V1: 15  
 N m (newton-meters), 2009 V1: 34  
 n o, N O (normally open), 2009 V1: 15  
 N<sub>2</sub> (nitrogen). *See* nitrogen (N<sub>2</sub>)  
 N<sub>2</sub>O (nitrous oxide), 2009 V1: 9  
 NACE (National Association of Corrosion Engineers), 2009 V1: 140, 144  
 NACE Basic Corrosion Course, 2009 V1: 144  
 NACE Standard RP-01, 2009 V1: 140

- NaCl (ionized salts), 2011 V3: 47
- nails, protecting against, 2010 V2: 16
- NAIMA (North American Insulation Manufacturers Association), 2009 V1: 118
- Nalco Chemical Co., 2010 V2: 225
- Nalco Water Handbook, 2010 V2: 225
- nameplates (propane tanks), 2010 V2: 132
- nano prefix, 2009 V1: 34
- nanofilter membranes, 2010 V2: 191, 201, 211, 213
- nanofiltration (NF), 2012 V4: 199
- naphtha, 2010 V2: 12
- National Association of Corrosion Engineers (NACE), 2009 V1: 140, 144
- National Association of Plumbing-Heating-Cooling Contractors. *See* Plumbing-Heating-Cooling Contractors–National Association (PHCC-NA)
- National Board of Boiler and Pressure Vessel Inspectors (NBBPVI), 2010 V2: 106
- National Bureau of Standards, 2009 V1: 15, 2010 V2: 18–19
  - electromotive force series, 2009 V1: 142
  - publications, 2010 V2: 95–96
  - stack capacities study, 2010 V2: 4
- National Committee for Clinical Laboratory Standards, Inc. (NCCLS), 2010 V2: 220
- National Easter Seal Society, 2009 V1: 97
- National Electrical Code*, 2010 V2: 125
- National Electrical Code (NEC), 2010 V2: 112
- National Electrical Manufacturers Association (NEMA), 2009 V1: 15
  - NEMA 4 listing, 2010 V2: 125
  - NEMA 4X listing, 2010 V2: 106
  - NEMA 12 listing, 2010 V2: 125
  - NEMA Class 1, Division 1, Group D listing, 2010 V2: 125
- National Energy Conservation Policy Act, 2009 V1: 117
- National Fire Alarm and Signaling Code (NFPA 72)*, 2011 V3: 28, 30
- National Fire Protection Association, Inc.
  - designing systems and, 2011 V3: 1
  - gas approvals, 2010 V2: 114
  - list of standards, 2009 V1: 53
  - NFPA abbreviation, 2009 V1: 15, 32
  - publications (discussed)
    - air compressors in dry-pipe systems, 2011 V3: 8
    - design density requirements, 2011 V3: 11
    - firefighting water tanks, 2010 V2: 162
    - flame testing standards, 2012 V4: 105
    - hot-water system standards, 2010 V2: 112
    - liquefied petroleum pipe sizing, 2010 V2: 135
    - medical gas station guidelines, 2011 V3: 51
    - pipe and fittings standards, 2012 V4: 68–71
    - propane tank specifications, 2010 V2: 132
    - sprinkler piping, 2009 V1: 177
    - stationary fire pump standards, 2012 V4: 98
  - publications (listed), 2009 V1: 39
    - NFPA Fire Protection Handbook*, 2011 V3: 30
    - NFPA Standard no. 10: Standard for Portable Fire Extinguishers*, 2011 V3: 28, 30
    - NFPA Standard no. 11: Standard for Low-, Medium-, and High-Expansion Foam*, 2011 V3: 25, 30
    - NFPA Standard no. 12: Carbon Dioxide Extinguishing Systems*, 2011 V3: 26, 30
    - NFPA Standard no. 12A: Halon 1301 Fire Extinguishing Systems*, 2011 V3: 27, 28, 30
    - NFPA Standard no. 13: Installation of Sprinkler Systems*, 2009 V1: 185, 2011 V3: 2, 11, 30, 225
    - NFPA Standard no. 13D: Standard for the Installation of Sprinkler Systems in One-and Two-Family Dwellings and Manufactured Homes*, 2011 V3: 18
    - NFPA Standard no. 13R: Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, 2011 V3: 18
    - NFPA Standard no. 14: Installation of Standpipe and Hose Systems*, 2011 V3: 18, 30
    - NFPA Standard no. 15: Water Spray Fixed Systems for Fire Protection*, 2011 V3: 24, 30
    - NFPA Standard no. 16: Installation of Foam-water Sprinkler and Foam-water Spray Systems*, 2011 V3: 30
    - NFPA Standard no. 16A: Installation of Closed-head Foam-water Sprinkler Systems*, 2011 V3: 30
    - NFPA Standard no. 17: Dry Chemical Extinguishing Systems*, 2011 V3: 23, 30
    - NFPA Standard no. 17A: Standard for Wet Chemical Extinguishing Agents*, 2011 V3: 24
    - NFPA Standard no. 20: Installation of Stationary Fire Pumps for Fire Protection*, 2011 V3: 21, 30
    - NFPA Standard no. 24: Installation of Private Fire Service Mains and Their Appurtenances*, 2011 V3: 30, 218
    - NFPA Standard no. 30: Flammable and Combustible Liquids Code*, 2011 V3: 88, 136, 148, 149, 156
    - NFPA Standard no. 30A: Motor Fuel Dispensing Facilities and Repair Garages*, 2011 V3: 137, 156
    - NFPA Standard no. 50: Standard for Bulk Oxygen Systems at Consumer Sites*, 2011 V3: 57, 78
    - NFPA Standard no. 51: Standard for the Design and Installation of Oxygen-fuel Gas Systems for Welding, Cutting, and Allied Processes*, 2010 V2: 137
    - NFPA Standard no. 51B: Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2010 V2: 136
    - NFPA Standard no. 54: National Fuel Gas Code*, 117, 118, 121, 137, 2010 V2: 115, 2011 V3: 251, 256
    - NFPA Standard no. 55: Compressed Gases and Cryogenic Fluids Code*, 2011 V3: 263
    - NFPA Standard no. 58: Liquefied Petroleum Gas Code*, 2010 V2: 115, 132–133, 137
    - NFPA Standard no. 59: Utility LP-Gas Plant Code*, 2010 V2: 137
    - NFPA Standard no. 70: National Electrical Code*, 2010 V2: 125
    - NFPA Standard no. 72: National Fire Alarm and Signaling Code*, 2011 V3: 28, 30

- NFPA Standard no. 88A: Standard for Parking Structures*, 2010 V2: 115
- NFPA Standard no. 99: Standard for Health-care Facilities*, 2011 V3: 51, 63, 64, 69, 76, 78, 263
- NFPA Standard no. 255: Standard Method of Test of Surface Burning Characteristics of Building Materials*, 2011 V3: 69
- NFPA Standard no. 291: Recommended Practice for Fire Flow Testing and Marking of Hydrants*, 2011 V3: 3, 30
- NFPA Standard no. 329: Recommended Practice for Handling Releases of Flammable and Combustible Liquids and Gases*, 2011 V3: 137
- NFPA Standard no. 385: Standard for Tank Vehicles for Flammable and Combustible Liquids*, 2011 V3: 137
- NFPA Standard no. 484: Combustible Metals*, 2011 V3: 30
- NFPA Standard no. 505: Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Conversions, Maintenance, and Operation*, 2010 V2: 137
- NFPA Standard no. 750: Water Mist Fire Protection Systems*, 2011 V3: 25, 30
- NFPA Standard no. 2001: Clean Agent Extinguishing Systems*, 2011 V3: 27, 28, 30
- web site, 2011 V3: 78, 89
- National Formulary (NF) USP nomographs, 2010 V2: 218
- National Fuel Gas Code (NFPA 54)*, 117, 118, 121, 137, 2010 V2: 115
- natural gas system design, 2011 V3: 251
- pipe materials, 2011 V3: 256
- National Ground Water Association (NGWA), 2010 V2: 164
- National Institutes of Health, 2010 V2: 172, 241
- National Oceanic and Atmospheric Administration (NOAA), 2009 V1: 15, 2010 V2: 42, 55, 2011 V3: 239
- national pipe thread (NPT), 2009 V1: 15
- National Plumbing Code*, 2009 V1: 15
- National Plumbing Code, Illustrated*, 2010 V2: 55
- National Pollutant Discharge Elimination System (NPDES), 2011 V3: 81, 82
- National Sanitation Foundation (NSF)
- abbreviation, 2009 V1: 32
- domestic water piping and fittings, 2012 V4: 25
- drinking water standard, 2012 V4: 53
- Equipment for Swimming Pools, Spas, Hot Tubs, and Other Recreational Water Facilities (NSF/ANSI 50)*, 2011 V3: 111, 122
- hot-water system requirements, 2010 V2: 112
- list of standards, 2009 V1: 53
- potable water standard, 2012 V4: 53
- National Society of Professional Engineers (NSPE), 2009 V1: 56, 57
- National Standard Plumbing Code*, 2010 V2: 115
- National Swimming Pool Foundation (NSPF), 2011 V3: 104, 122
- National Technical Information Service (NTIS), 2011 V3: 89
- National Water Research Institute, 2012 V4: 195
- National Weather Service (NWS), 2010 V2: 42
- Hydro 35*, 2011 V3: 239
- natural drainage (corrosion), 2009 V1: 143
- natural frequency (fn), defined, 2012 V4: 138
- natural frequency of vibration control materials, 2012 V4: 138, 140–141
- natural gas. *See* fuel-gas piping systems; natural gas systems
- natural gas systems
- altitude factors, 2010 V2: 117, 121
- appliance demand table, 2010 V2: 116
- appliances, 118, 2010 V2: 116
- approvals, 2010 V2: 114
- codes and standards, 2010 V2: 115, 2011 V3: 251
- compressed gas fires, 2011 V3: 25
- compressed gases, defined, 2011 V3: 171
- defined, 2011 V3: 263
- demand in multiple family dwellings, 2010 V2: 123, 124, 130
- design considerations, 2010 V2: 126–127
- efficiency, 2010 V2: 115
- equivalent lengths for valves and fittings, 2010 V2: 123
- gas expansion and contraction, 2012 V4: 211–213
- glossary, 2010 V2: 135–136
- grounding, 2010 V2: 125
- high-rise buildings and, 2010 V2: 126
- laboratory usage, 2010 V2: 121
- liquefied petroleum gas, 2010 V2: 131–135
- low and medium pressure systems, 2010 V2: 113–125
- NG abbreviation, 2009 V1: 15
- operating pressures, 2010 V2: 115
- overview, 2011 V3: 251
- physical properties of gas and propane, 2010 V2: 113
- pipe sizing, 2010 V2: 123, 128–131, 2011 V3: 256
- preliminary information, 2011 V3: 205
- pressure, 2010 V2: 119–121
- sample gas utility letter, 2011 V3: 252, 261
- site utility planning, 2011 V3: 251–257
- sizing methods, 2010 V2: 130–131
- specific gravity, 2010 V2: 126, 131
- system components, 2011 V3: 252–255
- control valves, 2010 V2: 118
- drip pots, 2011 V3: 255
- fittings and joints, 2010 V2: 124
- flexible hose connections, 2010 V2: 124–125
- gas boosters, 2010 V2: 125–128
- gas line filters, 2011 V3: 252–254
- gas meters, 2011 V3: 254
- gas pressure regulators, 2011 V3: 254–255
- gas regulator relief vents, 2010 V2: 117–118
- materials, 2010 V2: 121–125
- meters, 2010 V2: 115–117, 2011 V3: 254
- natural gas pipes, 2012 V4: 32, 34
- piping, 2010 V2: 122
- pressure control valves, 2010 V2: 117–118
- pressure regulating valves, 2010 V2: 118
- regulator relief vents, 2010 V2: 121
- storage tanks, 2010 V2: 131–134
- tubing, 2010 V2: 122–124
- testing and purging, 2011 V3: 257
- types of, 2010 V2: 113–114
- types of services, 2011 V3: 251–252
- venting systems, 2010 V2: 118–119

- natural gas water heaters. *See* gas-fired water heaters
- natural osmosis, 2010 V2: 211
- natural period of vibration, 2009 V1: 150
- Natural Resources Canada, 2011 V3: 204
- Natural Resources Defense Council, 2011 V3: 81
- natural soil, building sewers and, 2010 V2: 14
- natural water, 2010 V2: 187, 2012 V4: 202. *See also* feed water
- Naturally Occurring Arsenic in Well Water in Wisconsin*, 2010 V2: 29
- naturally-vented multiple tray aerators, 2010 V2: 198
- naval rolled brass, 2009 V1: 132
- NBBPVI (National Board of Boiler and Pressure Vessel Inspectors), 2010 V2: 106
- NBR (acrylonitrile butadiene rubber), 2011 V3: 150
- NBS (National Bureau of Standards). *See* National Bureau of Standards
- NC (noise criteria), 2012 V4: 137
- NCCLS (National Committee for Clinical Laboratory Standards, Inc.), 2010 V2: 220
- NEC (National Electrical Code), 2010 V2: 112
- negative gauge pressure, 2010 V2: 166
- negative pressure. *See* vacuum
- negativity in value engineering presentations, 2009 V1: 249
- negligent acts, 2012 V4: 170
- negligible movement, 2012 V4: 132
- NEMA (National Electrical Manufacturers Association), 2009 V1: 15
- NEMA 4 listing, 2010 V2: 125
- NEMA 4X listing, 2010 V2: 106
- NEMA 12 listing, 2010 V2: 125
- NEMA Class 1, Division 1, Group D listing, 2010 V2: 125
- neoprene, 2009 V1: 32
  - compression gaskets, 2012 V4: 26
  - gaskets, 2011 V3: 46, 2012 V4: 57
  - hanger isolators, 2009 V1: 203
  - noise mitigation, 2009 V1: 190
  - pad isolators, 2009 V1: 204
  - vibration control, 2012 V4: 138, 139
- nephelometric test, 2010 V2: 193
- nephelometric turbidity units (NTUs), 2010 V2: 193, 2012 V4: 175
- net positive suction head (NPSH), 2010 V2: 162, 2012 V4: 96, 101
- neutralizing acid, 2012 V4: 176
- neutralizing acid in waste water
  - discharge from laboratories, 2011 V3: 42–44
  - health care facility systems, 2011 V3: 42–44
  - laboratories, 2011 V3: 43–44
  - methods of treatment, 2010 V2: 235
  - sizing tanks, 2011 V3: 44
  - solids interceptors, 2011 V3: 45
  - tank and pipe materials, 2011 V3: 85–87
  - types of acids, 2010 V2: 230–232
- neutralizing tanks, 2011 V3: 43–44
- neutrons, 2010 V2: 236–237
- New York City, ultra-low-flow toilets in, 2009 V1: 127
- New York City Materials and Equipment Acceptance Division (MEA), 2012 V4: 88
- New York State Department of Environmental Conservation
  - Technology for the Storage of Hazardous Liquids*, 2011 V3: 89
  - web site, 2011 V3: 89
- newer buildings, 2012 V4: 137
- newton-meters, 2009 V1: 34
- newtons, 2009 V1: 34
- Newton's equation, 2012 V4: 146
- NF (nanofiltration), 2012 V4: 199
- NF nomographs, 2010 V2: 218
- NFPA. *See* National Fire Protection Association, Inc.
- NFPP (nonflame pipe), 2012 V4: 51
- NG. *See* natural gas systems
- NGWA (National Ground Water Association), 2010 V2: 164
- ni-resist cast iron, 2009 V1: 132
- ni-resist irons, 2009 V1: 132
- Nibco Inc., 2010 V2: 96
- niche lights, swimming pools, 2011 V3: 135
- nickel
  - corrosion, 2009 V1: 129
  - electromotive force series, 2009 V1: 132
  - galvanic series, 2009 V1: 132
  - plastic corrosion and, 2009 V1: 141
  - in stainless steel, 2012 V4: 1
- nickel-bronze grates, 2010 V2: 13, 15
- Nine Dots exercise, 2009 V1: 225, 252
- nipped-up sprinklers, 2009 V1: 13
- nitrites, 2010 V2: 189, 190
  - defined, 2012 V4: 202
  - water hardness and, 2012 V4: 176
- nitric acid, 2009 V1: 136, 2010 V2: 232
- nitrifying bacteria, 2010 V2: 188
- nitrile butadiene (Buna-N), 2011 V3: 150, 2012 V4: 75, 84
- nitrile rubber. *See* nitrile butadiene
- nitrogen (N<sub>2</sub>)
  - as contaminant in air, 2011 V3: 265
  - color coding outlets, 2011 V3: 55
  - control cabinets, 2011 V3: 56
  - cylinder supplies, 2011 V3: 58, 65
  - defined, 2011 V3: 77
  - dry nitrogen, 2011 V3: 257
  - formula, 2012 V4: 173
  - gas blankets in water tanks, 2010 V2: 223
  - generating, 2011 V3: 270
  - high-pressure dispensing equipment, 2011 V3: 56–57
  - laboratory outlets, 2011 V3: 41–42
  - medical gas pipe sizing, 2011 V3: 69, 70, 71
  - medical gas stations, 2011 V3: 52–53
  - medical gas storage, 2011 V3: 63–64, 65
  - oil-free, 2012 V4: 34
  - purging vacuum pumps, 2010 V2: 171
  - in raw water, 2010 V2: 190
  - storm water, 2010 V2: 27
  - surgical use, 2011 V3: 56
  - symbol, 2009 V1: 9
  - testing concentrations, 2011 V3: 75
  - testing laboratory gas systems, 2011 V3: 280
  - in water chemistry, 2010 V2: 189
- nitrogen NF, 2011 V3: 61, 77
- nitrous fumes, 2010 V2: 232
- nitrous oxide (N<sub>2</sub>O)
  - color coding outlets, 2011 V3: 55
  - cylinder supplies, 2011 V3: 58

- defined, 2011 V3: 77
- medical gas pipe sizing, 2011 V3: 69, 71
- medical gas storage, 2011 V3: 59–60, 61
- reductions from solar energy use, 2011 V3: 189
- surgical use, 2011 V3: 57
- symbol, 2009 V1: 9
- testing concentrations, 2011 V3: 75
- waste anesthetic gas management, 2011 V3: 66
- nL/min (normal liters per minute), 2011 V3: 187
- nm<sup>3</sup>/min (normal cubic meters per minute), 2011 V3: 172
- no-flow pressure in pressure-regulated valves, 2010 V2: 94
- no-hub joints, earthquake protection and, 2009 V1: 160
- no-hub outlet drain body, 2010 V2: 14
- no-hub outlets, 2010 V2: 13
- no., NO (numbers), 2009 V1: 15
- no observed adverse effect level, 2011 V3: 27
- NOAA (National Oceanic and Atmospheric Administration), 2009 V1: 15, 2010 V2: 42
  - NOAA, *National Weather Service 5-60 Minute Precipitation Frequency for the Eastern and Central United States*, 2010 V2: 55
  - rainfall records, 2011 V3: 239
- NOAEL (no observed adverse effect level), 2011 V3: 27
- Noble, Duncan, 2011 V3: 204
- noble potential, defined, 2009 V1: 143
- noise. *See* acoustics in plumbing systems
- noise criteria (NC), 2012 V4: 137
- nominal diameter (DN), 2010 V2: 165
- nominal pipe size (NPS), 2009 V1: 15, 2010 V2: 165, 2012 V4: 49
- nominal size, defined, 2012 V4: 132
- nominal values, 2009 V1: 33
- nominal volume of piping, 2012 V4: 211
- non-agreement states, 2010 V2: 238
- non-ambulatory disabilities, 2009 V1: 99
- non-aqueous liquid wastes, 2011 V3: 81
- non-carbonic salts, 2012 V4: 176
- non-circular grab bars, 2009 V1: 112
- non-clog pumps, 2012 V4: 98
- non-continuous joints, 2009 V1: 140
- non-depletable energy sources, 2009 V1: 128
- Nondiscrimination on the Basis of Disability by Public Accommodations and in Commercial Facilities*, 2009 V1: 98
- non-electrolytes, 2010 V2: 187
- non-ferrous metals, 2012 V4: 61
- non-flammable medical gas, 2011 V3: 50
- Non-flammable Medical Gas Piping Systems (CSA Z305.1)*, 2011 V3: 78
- non-flammable pipe, 2012 V4: 51, 56
- non-impact applications, 2012 V4: 139
- non-integral attachment, 2012 V4: 132
- non-looped piping systems, 2011 V3: 12
- non-lubricated plug valves, 2012 V4: 77, 87
- non-measurable nouns in function analysis, 2009 V1: 218
- non-metallic coatings, 2009 V1: 136
- non-oxidizing chemicals in microbial control, 2010 V2: 213
- non-oxidizing piping, 2010 V2: 239
- non-pathogenic organisms, 2012 V4: 177
- non-porous piping, 2010 V2: 239
- non-porous soils, 2011 V3: 96
- non-potable cold water (NPCW), 2009 V1: 9
- non-potable hot water (NPHW), 2009 V1: 9
- non-potable hot water return (NPHWR), 2009 V1: 9
- non-potable water systems. *See* graywater systems
- non-pumping wells, 2010 V2: 157–158
- non-puncturing membrane flashing, 2010 V2: 16
- non-reactive silica, 2010 V2: 190
- non-reinforced concrete pipe, 2012 V4: 29
- non-rigid couplings, 2009 V1: 180
- non-rising stems on valves (NRS), 2012 V4: 79
- non-SI units, 2009 V1: 34
- non-sprinklered spaces, 2009 V1: 12
- Non-structural Damage to Buildings, 2009 V1: 185
- non-tilting grates, 2010 V2: 11
- non-vitreous china fixtures
  - defined, 2012 V4: 1
  - standards, 2012 V4: 2
- non-volatile substances, 2012 V4: 191
- normal air, defined, 2011 V3: 186
- normal, compared to standard, 2011 V3: 187
- normal cubic meters per minute (nm<sup>3</sup>/min), 2011 V3: 172
- normal liters per minute (nL/min), 2011 V3: 187
- normal pressure, 2009 V1: 26
- normally closed (n c, N C), 2009 V1: 15
- normally open (n o, N O), 2009 V1: 15
- North American Insulation Manufacturers Association (NAIMA), 2009 V1: 118
- not in contract (n i c, N I C), 2009 V1: 15
- not to scale (NTS), 2009 V1: 15
- nouns in function analysis, 2009 V1: 218, 219, 225
- nourishment stations in health care facilities, 2011 V3: 36
- nozzles
  - defined, 2009 V1: 29
  - dry-chemical systems, 2011 V3: 23
  - fountains, 2011 V3: 100
  - fuel dispensers, 2011 V3: 146
  - irrigation sprinklers, 2011 V3: 93
  - pressure, 2011 V3: 210
  - pressure flow tables, 2011 V3: 3, 5
  - sprinklers, 2011 V3: 6
- NPC. *See* National Plumbing Code
- NPCW (non-potable cold water), 2009 V1: 9
- NPDES (National Pollutant Discharge Elimination System), 2011 V3: 81, 82
- NPHW (non-potable hot water), 2009 V1: 9
- NPHWR (non-potable hot water return), 2009 V1: 9
- NPS (nominal pipe size), 2009 V1: 15, 2010 V2: 165
- NPSH (net positive suction head), 2010 V2: 63, 162, 2012 V4: 96, 101
- NPT (national pipe thread), 2009 V1: 15
- NRC (Nuclear Regulatory Commission), 2010 V2: 237, 238
- NSF. *See* National Sanitation Foundation (NSF)
- NSPE (National Society of Professional Engineers), 2009 V1: 56, 57
- NSPF (National Swimming Pool Foundation), 2011 V3: 122
- NTIS (National Technical Information Service), 2011 V3: 89
- NTS (not to scale), 2009 V1: 15
- NTUs (nephelometric turbidity units), 2010 V2: 193, 2012 V4: 175
- nuclear power plants
  - regulatory requirements, 2010 V2: 235
  - seismic protection, 2009 V1: 148

Nuclear Regulatory Commission, 2010 V2: 237, 238  
 numbers (no., NO, N)  
   in CSI format, 2009 V1: 59  
   in measurements, 2009 V1: 33  
   of swimmers, 2011 V3: 106  
   symbol, 2009 V1: 15  
 numerical weights in value engineering, 2009 V1: 235  
 nurse stations, 2011 V3: 36  
 nurseries  
   fixtures for, 2011 V3: 37–38  
   health care facilities, 2011 V3: 36  
   medical gas stations, 2011 V3: 52, 56  
   sinks, 2011 V3: 40  
 nursing homes, 2011 V3: 33–34. *See also* health care facilities  
 Nussbaum, O.J., 2010 V2: 225  
 nuts, 2012 V4: 131  
 NWS (National Weather Service), 2010 V2: 42

**O**

O-rings, 2012 V4: 30  
 O<sub>2</sub>. *See* oxygen (O<sub>2</sub>, OX)  
 oakum seals, 2012 V4: 26, 57  
 objectives in FAST approach, 2009 V1: 221  
 obstructions to wheelchairs, 2009 V1: 103, 104  
 OC (on center), 2009 V1: 15  
 occupancy, defined, 2009 V1: 26  
 occupancy classification (sprinkler systems), 2009 V1: 28–29, 2011 V3: 2, 13  
 occupancy of pools, 2011 V3: 106–107  
 occupants  
   in hot water demand classifications, 2010 V2: 99  
   loads of buildings, 2012 V4: 20–23  
   perception of quality and, 2009 V1: 263  
 Occupational Safety and Health Administration (OSHA), 2009 V1: 15, 2010 V2: 232, 2011 V3: 136  
 ocean water, irrigation systems and, 2010 V2: 25  
 OD (outside diameters), 2009 V1: 15  
 odor  
   gas pressure regulators and, 2010 V2: 118  
   odor control in drinking water, 2010 V2: 160, 217  
 OEM (original equipment manufacturers), 2009 V1: 15  
 OFCI (owner furnished, contractor installed), 2009 V1: 64  
 off-peak power usage, 2009 V1: 119  
 office buildings  
   drinking fountain usage, 2012 V4: 222, 223  
   hot water demand, 2010 V2: 99  
   numbers of fixtures for, 2012 V4: 20, 22  
 Office of Statewide Health Planning and Development (OSHPD), 2009 V1: 185  
 offset connection strainers, 2011 V3: 124  
 offset stack thermal expansion or contraction, 2012 V4: 207–208  
 offset stacks, 2010 V2: 5, 37  
 offsets  
   defined, 2009 V1: 26, 2012 V4: 132  
   expansion offsets, 2012 V4: 206  
   use of, 2012 V4: 67  
 offshore facilities, 2009 V1: 139  
 ohm-centimeter units (Ω-cm), 2011 V3: 47, 2012 V4: 175  
 ohm-meters, 2009 V1: 34  
 OHMS (resistance or resistors), 2009 V1: 34, 2012 V4: 202

Ohm's Law, 2009 V1: 134  
 oil. *See also* fats, oils, and grease (FOG)  
   as seal liquid in liquid ring pumps, 2010 V2: 171  
   contamination in compressed air, 2011 V3: 173  
   intercepting in acid-waste systems, 2010 V2: 235  
   intercepting in sanitary drainage systems, 2010 V2: 12  
   neoprene and, 2012 V4: 139  
   oil-water separation, 2011 V3: 88  
   removing from gases, 2011 V3: 273  
   separating with ultrafiltration, 2012 V4: 199  
   skimming, 2011 V3: 88  
   spills and containment, 2010 V2: 244–246  
   vegetable oil, 2010 V2: 10  
 oil contamination in air, 2011 V3: 265  
 oil-free compressors, 2011 V3: 61, 174  
 oil interceptors, 2010 V2: 12, 244  
 oil-mist filters in vacuums, 2010 V2: 171  
 oil of vitriol. *See* sulfuric acid  
*Oil Pollution Prevention (40 CFR 112) (SCCC)*, 2011 V3: 137  
 oil-removal filters, 2011 V3: 180  
 oil systems. *See* diesel-oil systems; gasoline systems  
 oil-wet solids, 2010 V2: 244  
 oilless compressors, 2011 V3: 61  
 oilless pumps, 2010 V2: 169  
 older buildings, 2012 V4: 137  
 oleums, 2010 V2: 230  
 on center (OC), 2009 V1: 15  
 on-site facility treatment systems. *See* special-waste drainage systems  
 On-Site Renewables Tax Incentives, 2011 V3: 190  
 On Site Wastewater Facilities for Small Communities and Subdivisions, 2010 V2: 154  
 on-site water reclamation. *See* graywater systems  
 once-thru-oil pumps, 2010 V2: 171  
 one-compartment sinks, 2012 V4: 11  
 one-occupant toilet rooms, 2012 V4: 21  
 one-piece water closets, 2012 V4: 3  
 one-stage distillation, 2010 V2: 200  
 one-time costs, 2009 V1: 217  
 one-wall tanks, 2011 V3: 139  
 ongoing costs, 2009 V1: 217  
 oocysts, 2011 V3: 122  
 open air, 2009 V1: 26  
 open-channel flow, 2009 V1: 1, 2010 V2: 6  
 open-circuit potential, defined, 2009 V1: 143  
 open proprietary specifications, 2009 V1: 62  
 open solar systems, 2011 V3: 192  
 open sprinklers, 2009 V1: 29  
 open-type base pumps, 2010 V2: 158  
 open-web steel joists in pipe bracing, 2009 V1: 169  
 openings for tool access. *See* access; cleanouts  
 operating costs, 2009 V1: 217  
 operating efficiency of water softeners, 2012 V4: 188  
 operating loads on pipes, 2012 V4: 132  
 operating rooms  
   articulated ceiling medical gas systems, 2011 V3: 56  
   fixtures, 2011 V3: 38–39  
   medical gas stations, 2011 V3: 52, 56  
   medical vacuum, 2011 V3: 54  
   water demand, 2011 V3: 46  
 operational pressure tests, 2011 V3: 75  
 operators of vacuum systems, 2010 V2: 180



- oral surgery equipment, 2011 V3: 42, 52
- orbital welding, 2011 V3: 277
- orbital welding process, 2010 V2: 239
- orders in creativity checklist, 2009 V1: 227
- ordinary hazard occupancies
  - defined, 2009 V1: 29, 2011 V3: 2
  - firefighting hose streams, 2011 V3: 225
  - portable fire extinguishers, 2011 V3: 29
- ordinary lobe pumps, 2010 V2: 169
- organic chemicals
  - laboratory grade water, 2012 V4: 198
  - removal in effluent, 2012 V4: 227
- organic free water, 2010 V2: 219
- organic material vibration control, 2012 V4: 138
- organic materials in water, 2011 V3: 47, 2012 V4: 177
- organic polyelectrolytes, 2010 V2: 199
- organic removal filters, 2012 V4: 194
- organisms in water, 2010 V2: 188–189, 2012 V4: 199. *See also* microorganisms
- orifices
  - on hydrants, 2011 V3: 5
  - on nozzles, 2011 V3: 5
- original equipment manufacturers (OEM), 2009 V1: 15
- ornamental sprinklers, 2009 V1: 29
- orthotolidin tests, 2010 V2: 91
- OSHA (Occupational Safety and Health Administration), 2009 V1: 15, 2010 V2: 232, 2011 V3: 136
- OSHPD (Office of Statewide Health Planning and Development), 2009 V1: 185, 2012 V4: 132
- osmosis, defined, 2010 V2: 211
- osmotic pressure, 2010 V2: 211, 2012 V4: 196
- OS&Y (outside screw and yoke), 2012 V4: 83, 89
- Otis, Richard J., 2010 V2: 154
- OTO pumps, 2010 V2: 169, 171
- Otten, Gerald, 2010 V2: 225
- Otto plate units, 2010 V2: 214
- ounces (oz, OZ)
  - converting to SI units, 2009 V1: 39
  - symbols for, 2009 V1: 15
- out-of-sequence work conditions, cost estimates for projects and, 2009 V1: 90
- outdoor gas booster installation, 2010 V2: 126
- outdoor swimming pools, 2011 V3: 108. *See also* swimming pools
- outfall sewers, 2009 V1: 26
- outgasing, 2011 V3: 277
- outlet pressures
- outlet pressure regulators, 2011 V3: 10
- standpipe systems, 2011 V3: 21
- outlet valves, 2012 V4: 202
- outlets. *See also* inlets; stations
  - flow rates at outlets, 2009 V1: 3, 5
  - gas or vacuum. *See* stations
  - pressure in cold-water systems, 2010 V2: 69
  - septic tanks, 2010 V2: 146
  - storm drainage collection systems, 2010 V2: 46
  - symbols for, 2009 V1: 11
  - velocity of flow from outlets, 2009 V1: 6
- outpatient-services rooms, 2011 V3: 36, 46
- output, 2009 V1: 26
- outside diameters (OD), 2009 V1: 15
- outside screw and yoke (OS&Y), 2012 V4: 83, 89
- outside the box thinking, 2009 V1: 225
- outstanding value, defined, 2009 V1: 209
- overall system thermal efficiency, 2009 V1: 128
- overengineering, perception of, 2009 V1: 251
- overestimating needs, 2009 V1: 218
- overflow prevention, 2011 V3: 84, 148
- overflow
  - for bathtubs, 2012 V4: 16
  - fittings, fountains, 2011 V3: 102
  - for lavatories, 2012 V4: 10
  - rates for grease interceptors, 2012 V4: 149
  - storm drains. *See* secondary storm-drainage systems
- overflow roof drains, 2009 V1: 26
- overhead
  - costs in value engineering, 2009 V1: 208, 217
  - in plumbing cost estimation, 2009 V1: 85
- overhead equipment. *See* suspended equipment
- overheating protection in solar systems, 2009 V1: 122
- overheating vacuum exhausters, 2010 V2: 179
- overland flow rates for sites, 2011 V3: 239, 240, 242
- overlap in toilet accessibility, 2009 V1: 105
- overspray areas in irrigation, 2011 V3: 96
- overtime labor costs, in take-off estimating method, 2009 V1: 86
- overturning, preventing, 2009 V1: 153, 183
- overvoltage, defined, 2009 V1: 143
- owner furnished, contractor installed (OFICI), 2009 V1: 64
- owners
  - perception of engineering, 2009 V1: 251
  - quality requirements and, 2009 V1: 262
  - value engineering and, 2009 V1: 208
- OX (oxygen). *See* oxygen (O<sub>2</sub>, OX)
- oxidants, 2009 V1: 26
- oxidation
  - joints resistant to, 2012 V4: 57
  - ozone molecules and, 2012 V4: 194
- oxidation, defined, 2009 V1: 143
- oxidation reduction potential (ORP), 2011 V3: 129
- oxidizing chemicals in microbial control, 2010 V2: 213
- oxidizing gases, 2011 V3: 77, 266
- OXY/ACR pipes, 2012 V4: 32
- OXY/MED pipes, 2012 V4: 32
- oxyacetylene welding, 2012 V4: 61
- oxygen (O<sub>2</sub>, OX)
  - bulk oxygen systems, 2011 V3: 57–59, 59
  - color coding outlets, 2011 V3: 55
  - corrosion process, 2009 V1: 134, 2010 V2: 190
  - cylinder-manifold supply systems, 2011 V3: 59, 60, 61
  - defined, 2011 V3: 77
  - in fire triangle, 2011 V3: 22–23
  - formula, 2012 V4: 173
  - high contents in water, 2012 V4: 176
  - medical gas pipe sizing, 2011 V3: 68–69, 70, 71
  - medical gas stations, 2011 V3: 51, 52–53
  - medical gas storage, 2011 V3: 57–61
  - medical gas systems, 2011 V3: 50
  - medical reserve supply, 2011 V3: 58
  - oxygen USP, 2011 V3: 61, 77
  - oxygenated water, 2010 V2: 160
  - reducing with carbon dioxide, 2011 V3: 27
  - removing, 2010 V2: 199, 2012 V4: 176
  - saturation with, 2010 V2: 197

surgical use, 2011 V3: 56  
 symbols for, 2009 V1: 8, 15  
 testing concentrations, 2011 V3: 75  
 in water, 2010 V2: 189  
 oxygen concentration cells, 2009 V1: 143  
 oxygen-delivery equipment, 2011 V3: 77  
 oxygen-enriched atmospheres, 2011 V3: 77  
 oxygen index, 2011 V3: 77  
 oxygen scavengers, 2010 V2: 216  
 oxygen toxicity, 2011 V3: 77  
 oz, OZ (ounces), 2009 V1: 15, 39  
 ozonation  
   cooling tower water, 2010 V2: 217  
   feed water, 2010 V2: 220  
   Legionella and, 2010 V2: 111  
   pure water systems, 2010 V2: 222  
   small drinking water systems, 2010 V2: 218  
   swimming pools, 2011 V3: 133  
   water treatments, 2010 V2: 160, 214, 2012 V4: 194–195  
 ozone  
   generators, 2010 V2: 214  
   layer, 2011 V3: 26  
   water treatments, 2012 V4: 194–195

**P**

P (pressure). *See* pressure  
 P & ID (piping and instrumentation diagrams), 2009 V1: 15  
 P alkalinity, 2010 V2: 189  
 P (peta) prefix, 2009 V1: 34  
 p (pico) prefix, 2009 V1: 34  
 p-traps  
   floor drains with, 2009 V1: 11  
   laboratory sinks, 2011 V3: 45–46  
 Pa (pascals), 2009 V1: 34  
 PA (pipe anchors), 2009 V1: 10  
 PA (polyamide), 2009 V1: 32  
 Pa s (pascal-seconds), 2009 V1: 34  
 packed-bed, activated-carbon filters, 2010 V2: 201  
 packed tower aeration, 2010 V2: 218  
 packing, defined, 2012 V4: 89, 101  
 packing glands, 2012 V4: 89  
 packing material in vacuum deaerators, 2010 V2: 199  
 packing nuts, 2012 V4: 89  
 pad elastomer isolation, 2012 V4: 139  
 padding for glass pipe, 2012 V4: 35  
 paddle wheel type flow sensors, 2011 V3: 124  
 PAEK (polyaryletherketone), 2009 V1: 32  
 pain, thresholds of, 2010 V2: 111  
 painted propane tanks, 2010 V2: 132  
 paints in septic tanks, 2010 V2: 147  
 Pair, Claude H., 2011 V3: 96  
 palladium filters, 2011 V3: 273  
 panels, lining with lead, 2010 V2: 238  
 panic buttons, 2010 V2: 121  
 paper diatomaceous earth filters, 2012 V4: 181  
 paper towel clogs, 2010 V2: 11  
 paraffin, 2010 V2: 12  
 paragraph numbering in CSI format, 2009 V1: 59  
 parallel approaches for wheelchairs, 2009 V1: 99–101, 102  
 parallel gas system configurations, 2010 V2: 122

parallel installation of pressure-regulated valves, 2010 V2: 69–70, 2012 V4: 82  
 parallel pump systems, 2012 V4: 97, 101  
 parapet wall scuppers, 2010 V2: 49, 52  
 Parekh, B.S., 2010 V2: 225  
 Pareto principle, 2009 V1: 218, 249  
 Pareto, Vilfredo, 2009 V1: 218  
 Park, Richard, 2009 V1: 252  
 Parmalee heads, 2011 V3: 1  
 partial pressures law, 2010 V2: 72  
 partially-sprinklered spaces, 2009 V1: 12  
 participation in value engineering presentations, 2009 V1: 249  
 particle settling rates, 2012 V4: 178  
 particulate radiation, 2010 V2: 237  
 particulate silica, 2010 V2: 190  
 particulates  
   contamination in air, 2011 V3: 265  
   contamination in compressed air, 2011 V3: 174  
   testing for, 2011 V3: 280  
   in water, 2010 V2: 187, 193  
 parts per million (ppm, PPM), 2009 V1: 15, 2010 V2: 191  
   converting to grains per gallon, 2012 V4: 201  
   defined, 2012 V4: 202  
   water purity, 2011 V3: 47, 2012 V4: 175  
 party walls, 2009 V1: 202  
 pascal-seconds, 2009 V1: 34  
 pascals, 2009 V1: 34  
 passivation, 2009 V1: 136  
 passive, defined, 2009 V1: 143  
 passive control, cross-connections, 2012 V4: 162–164  
 passive solar systems, 2011 V3: 192  
 passive solar water heaters, 2009 V1: 122  
 passive verbs in function analysis, 2009 V1: 218  
 paste sealants, 2012 V4: 60  
 pasteurizing biosolids, 2012 V4: 240  
 pathogenic organisms, 2012 V4: 177  
 pathogens, 2010 V2: 139, 188  
 patient rooms  
   bathing areas, 2011 V3: 36  
   fixtures for, 2011 V3: 37  
   health care facilities, 2011 V3: 37  
   medical gas stations, 2011 V3: 53, 56  
   medical vacuum, 2011 V3: 54  
   patient head wall stations, 2011 V3: 56  
 patient vacuum (VAC), 2011 V3: 77  
 Paul, D., 2010 V2: 225  
 paved areas  
   imperviousness factors, 2011 V3: 239  
   runoff, 2010 V2: 42  
   storm drainage, 2010 V2: 41  
 PB (polybutylene). *See* polybutylene (PB)  
 PC (polycarbonate), 2009 V1: 32  
 PCTFE (polychlorotrifluoroethylene), 2009 V1: 32  
 PCUs (platinum cobalt units), 2010 V2: 193  
 PD (pressure drops or differences). *See* pressure drops or differences  
 PD (pump discharge lines), 2009 V1: 8  
 PDAP (polydiallyl phthalate), 2009 V1: 32  
 PDI (Plumbing and Drainage Institute). *See* Plumbing and Drainage Institute (PDI)  
 PE (polyethylene). *See* polyethylene (PE)

- PE (potential energy), 2009 V1: 2, 5
- PE-AL-PE (polyethylene/aluminum/polyethylene), 2012 V4: 69
- pea gravel backfill, 2011 V3: 155
- Peabody, A.W., 2009 V1: 144
- peak consumption in gas boosters, 2010 V2: 128
- peak demand
  - flushometer valves and, 2012 V4: 7
  - medical air, 2011 V3: 53, 62
  - medical gas, 2011 V3: 50
  - swimming pools, 2011 V3: 106
  - urinals, 2012 V4: 8–9
  - vacuum systems, 2011 V3: 65
  - water softeners, 2012 V4: 185
- peak flow, Rational Method, 2010 V2: 43
- peak horsepower, defined, 2011 V3: 186
- peak loads, 2009 V1: 26
- peak shaving, 2010 V2: 47
- PEEK (polyether etherketone), 2009 V1: 32
- pendent sprinklers, 2009 V1: 13, 29
- penetration of irrigation water, 2011 V3: 91, 96
- people with disabilities
  - ambulatory-accessible toilet compartments, 2009 V1: 106
  - ANSI 117.1-1998, 2009 V1: 99–115
  - bathing rooms, 2009 V1: 104–105
  - bathtub and shower seats, 2009 V1: 114–115
  - bathtub design, 2009 V1: 109–110
  - design for, 2009 V1: 99
  - drinking fountains and water coolers, 2009 V1: 101–105
  - exposed piping and accessibility, 2009 V1: 109
  - fixture design standards and, 2012 V4: 2
  - grab bars, 2009 V1: 106
  - history of design and construction standards, 2009 V1: 97–98
  - introduction to plumbing for, 2009 V1: 97
  - laundry equipment, 2009 V1: 115
  - lavatories and sinks, 2009 V1: 108–109
  - legislation, 2009 V1: 98–99
  - references, 2009 V1: 115
  - shower compartments, 2009 V1: 110–112
  - swimming pool facilities, 2011 V3: 107, 110, 134–135
  - urinal design, 2009 V1: 108
  - water closets and toilets, 2009 V1: 105–108, 2012 V4: 4
  - water coolers for, 2012 V4: 217–218
- per-area costs, 2009 V1: 89
- per-fixture estimations, cost estimations, 2009 V1: 88
- percent transmissibility (T), defined, 2012 V4: 137
- perception of engineers, 2009 V1: 251
- perchloric acid, 2010 V2: 232
- percolation
  - defined, 2009 V1: 26
  - rates for soils, 2010 V2: 139–142
- perfect vacuums, 2010 V2: 165, 2011 V3: 172
- perfluorocarbons (PFCs), 2011 V3: 27
- perforated strap irons, 2012 V4: 65
- performance bonds, 2009 V1: 56
- performance criteria in specifications, 2009 V1: 63, 69
- performance factor efficiency, solar, 2011 V3: 191
- Performance Requirements for Automatic Compensating Valves for Individual Showers and Tub/Shower Combinations*, 2010 V2: 105
- Performance Requirements for Automatic Temperature Control Mixing Valves*, 2010 V2: 105
- Performance Requirements for Water Temperature Limiting Devices*, 2010 V2: 105
- performance specifications, 2009 V1: 61
- performance tests. *See* testing
- perfluoroalkoxy, 2009 V1: 32
- perimeter diking, 2011 V3: 84
- peristaltic pumps, 2011 V3: 129–130
- perlite, 2011 V3: 121, 122
- perlite insulation, 2012 V4: 107
- permanent hardness, 2012 V4: 176
- permanganate of potash, 2012 V4: 173
- permeability
  - coefficient of (K factor), 2010 V2: 158
  - converting to SI units, 2009 V1: 39
  - permeable strata in soils, 2010 V2: 141
- permeance, converting to SI units, 2009 V1: 39
- permits
  - industrial wastewater, 2011 V3: 82–83
  - RCRA hazardous waste, 2011 V3: 83
- Perry's Chemical Engineer's Handbook*, 2011 V3: 89
- personnel protection, insulation and, 2012 V4: 103, 111, 112
- persons with disabilities. *See* people with disabilities
- pesticides in septic tanks, 2010 V2: 147
- peta prefix, 2009 V1: 34
- petroleum-based fuel systems. *See* diesel-oil systems; gasoline systems
- petroleum hydrocarbons in storm water, 2010 V2: 27
- petroleum products, 2011 V3: 136–137
- PEX (cross-linked polyethylene), 2009 V1: 32, 2012 V4: 48–49, 69
- PEX-AL-PEX (cross-linked polyethylene/aluminum/cross-linked polyethylene), 2012 V4: 49, 69
- PF (phenol formaldehyde), 2009 V1: 32
- PFA (perfluoroalkoxy), 2009 V1: 32
- PFCs (perfluorocarbons), 2011 V3: 27
- PG (pressure gauges with gauge cocks), 2009 V1: 10
- pH
  - acid wastes, 2010 V2: 235
  - adjustments to waste, 2010 V2: 227–228, 2012 V4: 227
  - alkalinity and, 2010 V2: 189
  - boiler feed water, 2010 V2: 216
  - in corrosion rates, 2009 V1: 134
  - defined, 2009 V1: 143, 2012 V4: 202
  - discharge from laboratories, 2011 V3: 42–44
  - feed water for pure water systems, 2010 V2: 221
  - industrial wastewater systems, 2011 V3: 85–87
  - limits for sanitary drainage systems, 2011 V3: 46
  - measuring, 2010 V2: 192
  - predicting water deposits, 2010 V2: 196–197
  - saturation, 2010 V2: 196
  - swimming pools, 2011 V3: 127–131
  - values in waste, 2010 V2: 229
- pH Control of Chemical Waste*, 2010 V2: 246
- pharmaceutical facilities, 2011 V3: 81, 2012 V4: 192
- pharmaceutical pure water, 2010 V2: 219, 2012 V4: 52
- Pharmaceutical Water, 2010 V2: 224, 225
- pharmaceutical water pipe, 2012 V4: 39
- pharmacies
  - bio-pure water, 2011 V3: 48
  - fixtures, 2011 V3: 38

- health care facilities, 2011 V3: 36
- medical gas stations, 2011 V3: 53
- Phase 1 and 2 vapor recovery, 2011 V3: 137, 145–146, 148, 149
- PHCC-NA. *See* Plumbing-Heating-Cooling Contractors–National Association (PHCC-NA)
- phenol formaldehyde, 2009 V1: 32
- phenolics
  - as thermoset, 2012 V4: 39
  - ion exchange resins, 2012 V4: 183
- phenolphthalein alkalinity, 2010 V2: 189
- Philadelphia systems, 2010 V2: 18, 39
- phosphates, 2009 V1: 140, 2010 V2: 189
- phosphoric acid, 2010 V2: 189, 232
- phosphorus, 2010 V2: 189
- phosphorus 32, 2010 V2: 238
- phosphorus, storm water, 2010 V2: 27
- photo laboratories, 2012 V4: 161
- photographic badges for radiation levels, 2010 V2: 237
- photolytic oxidation, 2010 V2: 194
- photostat equipment, 2012 V4: 161
- photovoltaics, defined, 2011 V3: 188–189
- physical characteristics of drinking water, 2010 V2: 217
- physical condition surveys, 2009 V1: 267–270
- physical therapy rooms, 2011 V3: 36, 38
- physically challenged people. *See* people with disabilities
- physics laboratories, 2010 V2: 171. *See also* laboratories
- PIB (polyisobutylene), 2009 V1: 32
- pico prefix, 2009 V1: 34
- pilot-operated gas regulators, 2011 V3: 254
- pilot-operated pressure-regulated valves, 2010 V2: 69
- pilot-operated valves, 2012 V4: 82
- pilot-valve discs, 2011 V3: 6
- pints, converting to SI units, 2009 V1: 39
- pipe anchors (PA), 2009 V1: 10
- pipe-applied vacuum breakers, 2012 V4: 163
- pipe attachments, 2012 V4: 132
- pipe braces. *See* bracing
- pipe channels, 2012 V4: 132
- pipe clamps, 2012 V4: 120, 132
- pipe clips, 2012 V4: 120, 132
- pipe-covering protection saddle, 2012 V4: 132
- pipe cutters, 2012 V4: 61
- pipe dope, 2010 V2: 191, 2012 V4: 60
- pipe elevations. *See* after cold pull elevation; design elevations
- pipe friction pressure drop, 2010 V2: 94
- pipe glue, 2010 V2: 191
- pipe guides, 2009 V1: 10
- pipe hanger assemblies, 2012 V4: 132
- pipe hanger drawings, 2012 V4: 132
- pipe hanger loads. *See* pipe loads; support and hanger loads
- pipe hanger locations. *See* cold hanger location; hot hanger locations
- pipe hanger plans and plan locations, 2012 V4: 132
- pipe hangers. *See* supports and hangers
- pipe insulation
  - cleaning and sterilization, 2012 V4: 104
  - damage, 2012 V4: 113
  - design considerations, 2012 V4: 113
  - expansion of pipes and insulation, 2012 V4: 113
  - glossary, 2012 V4: 103
  - high-density inserts, 2012 V4: 105, 110
  - installing on valves and fittings, 2012 V4: 110
  - insulation shields, 2012 V4: 132
  - insulation thickness, 2012 V4: 106, 107, 110–112
  - jacketing, 2012 V4: 106–109
  - noise, 2012 V4: 113
  - purposes, 2012 V4: 103
  - smoke and fire requirements, 2012 V4: 104–105
  - storage and handling, 2012 V4: 113
  - supports and hangers, 2012 V4: 104, 105, 110
  - types of, 2012 V4: 104–106
    - calcium silicate, 2012 V4: 106
    - cellular glass, 2012 V4: 106
    - elastomeric, 2012 V4: 105
    - fiberglass, 2012 V4: 105
    - foamed plastic, 2012 V4: 106
    - insulating cement, 2012 V4: 106
    - lagging, 2012 V4: 109
    - plastic jackets, 2012 V4: 108
    - wire mesh, 2012 V4: 108
  - water vapor and, 2012 V4: 103
  - weight of, 2012 V4: 115
- pipe joints
  - acid-waste systems, 2010 V2: 232
  - chemical-waste systems, 2010 V2: 242
  - fill and, 2010 V2: 14
  - heat-fused socket joints, 2010 V2: 232
  - inspection, 2011 V3: 69, 74
  - material codes and standards, 2009 V1: 43
  - natural gas systems, 2011 V3: 257
  - pure-water systems, 2011 V3: 48–49
  - radioactive waste systems, 2010 V2: 239
  - restrainers, 2011 V3: 221
  - sanitary, 2011 V3: 48–49
  - screwed mechanical joints, 2010 V2: 232
  - special-waste drainage systems, 2010 V2: 228
  - thermal expansion and, 2010 V2: 16
  - welded joints, 2010 V2: 239
- pipe loads
  - cold loads, 2012 V4: 129
  - deadweight loads, 2012 V4: 129
  - design loads, 2012 V4: 129
  - dynamic loads, 2012 V4: 129
  - friction loads, 2012 V4: 130
  - hot loads, 2012 V4: 131
  - hydrostatic loads, 2012 V4: 131
  - operating loads, 2012 V4: 132
  - seismic loads, 2012 V4: 134
  - thermal loads, 2012 V4: 135
  - thrust loads, 2012 V4: 135
  - trip-out loads, 2012 V4: 135
  - water hammer loads, 2012 V4: 136
  - wind loads, 2012 V4: 136
- pipe nipple codes, 2009 V1: 43
- pipe openings, 2012 V4: 133
- pipe racks, 2012 V4: 133
- pipe rollers, 2012 V4: 121
- pipe rolls, 2012 V4: 133
- pipe saddle supports, 2012 V4: 133
- pipe shafts, 2011 V3: 68
- pipe shoes, 2012 V4: 133

- pipe sleeve hangers or supports, 2012 V4: 133
- pipe sleeves, 2009 V1: 153, 2012 V4: 66–67, 123–125, 133
- pipe slides, 2012 V4: 121, 133
- pipe solvents, 2010 V2: 191
- pipe straps, 2012 V4: 133
- pipe supports. *See* supports and hangers
- pipe system loads. *See* pipe loads
- pipe unions, 2012 V4: 65
- pipes and piping. *See also* sizing; specific kinds of piping or piping functions
  - accessories
    - anchors, 2012 V4: 59–60, 62
    - gaskets, 2012 V4: 63
    - hangers and supports. *See* supports and hangers
    - pipe sleeves, 2012 V4: 66–67
    - pipe unions, 2012 V4: 65
    - service connections for water piping, 2012 V4: 67
  - applications
    - centralized drinking-water cooler systems, 2012 V4: 222–223
    - chilled drinking-water systems, 2012 V4: 222
    - compressed air systems, 2011 V3: 176, 182–183
    - condensate drainage, 2011 V3: 165
    - corrosive wastes, 2011 V3: 46
    - distilled water, 2012 V4: 193
    - exposed piping on storage tanks, 2011 V3: 148
    - fire-protection systems, 2011 V3: 6, 28
    - fountains, 2011 V3: 101–102
    - high-pressure condensate, 2011 V3: 166
    - laboratory gas systems, 2011 V3: 276–280, 277–280
    - laboratory waste and vent piping, 2011 V3: 46
    - liquid fuel systems, 2011 V3: 149–151
    - medical gas systems, 2011 V3: 68–76
    - natural gas, 2010 V2: 121–125, 123, 126, 128–131, 2011 V3: 256–257
    - propane, 2010 V2: 135
    - pure-water systems, 2011 V3: 48–49
    - roof drains and pipes, 2010 V2: 49
    - sewage life stations, 2011 V3: 236
    - sprinkler systems, 2011 V3: 9, 12–13, 13–14, 20
    - steam, 2011 V3: 159–161
    - swimming pools, 2011 V3: 113
    - vacuum piping, 2010 V2: 174–178
  - bedding, 2011 V3: 225–226, 227
  - bending, 2012 V4: 61
  - calculating water capacity per foot, 2011 V3: 9
  - cleaning and covering exposed ends, 2012 V4: 25
  - codes and standards, 2009 V1: 42–45
  - computer analysis of piping systems, 2009 V1: 180
  - corrosion, 2009 V1: 141
  - cost estimation, 2009 V1: 85
  - damage to pipes, 2012 V4: 25
  - defined, 2011 V3: 78
  - draining, 2012 V4: 25
  - erosion, 2011 V3: 161
  - hazardous waste incompatibilities, 2011 V3: 83–84, 84
  - installation requirements, 2012 V4: 25
  - insulation. *See* pipe insulation
  - joints. *See* joints
  - leakage, 2009 V1: 126
  - loads. *See* pipe loads
  - materials expansion, 2012 V4: 211
  - monitoring leakage, 2011 V3: 145
  - noise mitigation, 2009 V1: 190–193, 195
  - nominal volumes, 2012 V4: 211
  - openings, 2012 V4: 133
  - pipe schedules, 2011 V3: 12, 14
  - piping symbols, 2009 V1: 7–15
  - pitch, 2011 V3: 165
  - protection, 2009 V1: 255
  - resonance and vibration transmission, 2012 V4: 143
  - roughness, 2010 V2: 78
  - seismic protection, 2009 V1: 145, 158–179
  - size. *See* sizing
  - snaking in trenches, 2012 V4: 208, 209
  - specifications, 2012 V4: 25
  - standards and codes, 2012 V4: 68–71
  - temperature classification, 2012 V4: 118
  - thermal expansion and contraction, 2012 V4: 67
    - aboveground piping, 2012 V4: 207–208
    - underground piping, 2012 V4: 208–209
  - tightness testing, 2011 V3: 153
  - total developed length, 2012 V4: 206, 207
  - total loads, 2012 V4: 115–116
  - types
    - acrylonitrile butadiene styrene (ABS), 2012 V4: 51
    - aluminum, 2012 V4: 54
    - brass (copper alloy) pipe, 2010 V2: 13
    - cast-iron soil pipe, 2012 V4: 25–26
    - chlorinated polyvinyl-chloride (CPVC), 2010 V2: 190, 2011 V3: 49, 2012 V4: 39, 50, 51
    - concrete pipe. *See* concrete piping
    - copper drainage tube, 2012 V4: 33–34, 40, 58
    - copper pipe. *See* copper piping
    - copper water tube, 2012 V4: 29–40
    - cross-linked polyethylene (PEX), 2012 V4: 48–49
    - cross-linked polyethylene/aluminum/cross-linked polyethylene (PEX-AL-PEX), 2012 V4: 49
    - double containment, 2012 V4: 51, 56–57
    - ductile iron water and sewer pipe. *See* ductile iron piping
    - ferrous, 2011 V3: 101
    - fiberglass pipe (FRP), 2012 V4: 53
    - glass pipe, 2010 V2: 234, 239, 2012 V4: 34–36
    - high silicon (duriron), 2012 V4: 53
    - lead piping, 2010 V2: 75
    - low extractable PVC, 2012 V4: 52
    - medical gas tubing, 2011 V3: 69, 74, 2012 V4: 33–34
    - plastic. *See* plastic piping
    - polybutylene pipes, 2012 V4: 39, 41–42, 50
    - polyethylene/aluminum/polyethylene (PE-AL-PE), 2012 V4: 49
    - polypropylene (PP), 2012 V4: 51–52
    - polypropylene-random, 2012 V4: 52
    - polyvinyl chloride (PVC), 2010 V2: 190, 2012 V4: 39, 49, 50
    - polyvinylidene fluoride (PVDF), 2012 V4: 52
    - reinforced thermosetting resin pipe (RTRP), 2012 V4: 53
    - special purpose piping, 2012 V4: 54–56
    - stainless steel, 2012 V4: 54–56
    - steel pipe. *See* steel piping
    - Teflon, 2012 V4: 52
    - thermoplastic piping, 2012 V4: 208

- vitrified clay piping, 2010 V2: 75, 243, 2011 V3: 242, 2012 V4: 53, 54
- unintended uses, 2012 V4: 116
- water flow tables, 2011 V3: 14–17
- piping and instrumentation diagrams (P & IDs), 2009 V1: 15
- Piping Handbook*, 2010 V2: 136
- piston displacement, defined, 2011 V3: 186
- piston reciprocating compressors, 2011 V3: 174
- piston-style water hammer arresters, 2010 V2: 72, 74
- pistons
  - balanced-piston valves, 2012 V4: 82
  - in water-pressure regulators, 2012 V4: 80
- pit-type fire-department connections, 2009 V1: 12
- pitch
  - defined, 2009 V1: 26
  - pipe, 2011 V3: 165
  - pitch down or up, 2009 V1: 11
  - radioactive waste systems, 2010 V2: 240
  - special-waste drainage systems, 2010 V2: 228
  - vacuum cleaning systems, 2010 V2: 186
- pitcher fillers, 2012 V4: 218
- pitless adapters, 2010 V2: 158, 159
- pitot pressure, 2011 V3: 4, 5, 210
- pitot tubes, 2011 V3: 3–4, 210
- pitting, defined, 2009 V1: 143
- pitting corrosion, 2009 V1: 130, 2010 V2: 195, 2012 V4: 173–174
- PIV (post indicator valves), 2009 V1: 15, 2011 V3: 220–221
- PL (Public Laws). *See* Public Laws
- plain air chambers, 2010 V2: 73
- plane angles, 2009 V1: 34, 36
- plans. *See* construction contract documents; plumbing drawings
- plantings, types of, 2011 V3: 96
- plaster, lining with lead, 2010 V2: 238
- plaster of paris, 2012 V4: 173
- plaster traps, 2011 V3: 39
- plastic fixtures
  - standards, 2012 V4: 2
  - types of, 2012 V4: 1
- plastic insulation, 2012 V4: 106
- plastic jackets, 2012 V4: 108
- Plastic Pipe Institute (PPI)
  - Thermal Expansion and Contraction in Plastic Piping Systems*, 2009 V1: 206
- plastic piping
  - as source of plumbing noise, 2009 V1: 188
  - bedding, 2011 V3: 225–226, 227
  - codes, 2009 V1: 43
  - corrosion, 2009 V1: 141, 2010 V2: 164
  - electrofusion joints, 2012 V4: 61
  - fittings, 2012 V4: 48
  - fuel product dispensing and, 2011 V3: 150
  - gas piping, 2011 V3: 256, 257
  - hangers, 2012 V4: 122
  - joints, 2012 V4: 48, 59–60
  - laboratory wastes, 2011 V3: 46
  - Manning formula and, 2011 V3: 242
  - natural gas systems, 2010 V2: 123–124
  - polyolefin piping, 2012 V4: 49
  - porous surfaces, 2012 V4: 193
  - roughness, 2010 V2: 78
  - sanitary drainage systems, 2010 V2: 12–13
  - standards, 2012 V4: 69–71
  - thermoplastic piping, 2012 V4: 208
  - types, 2012 V4: 39–53
  - water hammer and, 2010 V2: 71–72
- plastic pumps, 2011 V3: 123
- plastic wraps on toilet seats, 2012 V4: 4
- plate and frame modules in reverse osmosis, 2010 V2: 211–212
- plate lugs. *See* lugs
- plate tectonics, 2009 V1: 148
- plates for anchoring, 2012 V4: 125
- platform diving, 2011 V3: 107
- plating
  - defined, 2012 V4: 133
  - demineralized water and, 2012 V4: 177
- plating solutions, 2009 V1: 141
- platinum, 2009 V1: 132
- platinum cobalt units (PCUs), 2010 V2: 193
- platy soils, 141, 2010 V2: 140
- plenum-rated areas, 2009 V1: 259, 262
- plot plans, irrigation systems and, 2010 V2: 24
- plug angle valves, 2012 V4: 75
- plug disc valves, 2012 V4: 74
- plug-type dezincification, 2009 V1: 131
- plug valves (PV), 2009 V1: 9, 15
  - defined, 2012 V4: 77
  - hot-water service, 2012 V4: 87
  - liquefied petroleum gas systems, 2012 V4: 87
- plumber's friends, 2012 V4: 161
- plumbing
  - appliances, 2009 V1: 26
  - appurtenances, 2009 V1: 26
  - code agencies, 2009 V1: 42
  - cost estimation, 2009 V1: 85–90
  - defined, 2009 V1: 26
  - designs, 2009 V1: 92–94
  - fittings. *See* fittings
  - fixtures. *See* fixtures
  - plumbing systems defined, 2009 V1: 26
  - specifications. *See* specifications
  - symbols, 2009 V1: 7–15
  - terminology, 2009 V1: 16–21
- Plumbing and Drainage Institute (PDI), 2010 V2: 96
  - abbreviation for, 2009 V1: 32
  - bioremediation system standards, 2012 V4: 231
  - grease interceptor standards, 2012 V4: 228, 231
  - hydromechanical grease interceptors, 2012 V4: 145
  - list of standards, 2009 V1: 53
  - PDI symbols for water hammer arresters, 2010 V2: 72–74
- Plumbing and Piping Industry Council (PPIC), 2009 V1: 160
- Plumbing Appliance Noise Measurements*, 2009 V1: 206
- plumbing codes, defined, 2012 V4: 170. *See also* codes and standards
- Plumbing Design and Installation Reference Guide*, 2010 V2: 55
- Plumbing Design Manual*, 2010 V2: 55
- plumbing drawings
  - abbreviations, 2009 V1: 14–15
  - checklists, 2009 V1: 92–94

- comprehensive, 2009 V1: 264
- costs analysis phase, 2009 V1: 234
- defined, 2009 V1: 55
- DWG abbreviation, 2009 V1: 14
- ensuring high quality with detailed specs, 2009 V1: 253–254
- existing building alterations, 2009 V1: 266
- function evaluation, 2009 V1: 232–233
- functional development, 2009 V1: 246
- graphic conventions, 2009 V1: 100
- introduction, 2009 V1: 55
- samples of clear specifications, 2009 V1: 255, 260–261
- in specifications, 2009 V1: 63
- Plumbing Engineer*, 2010 V2: 55
- plumbing engineering
  - changes in technology and products, 2009 V1: 262
  - coordinating in fire protection design, 2011 V3: 29
  - defined, 2009 V1: 26
  - ensuring high quality in, 2009 V1: 253
- Plumbing Engineering and Design Handbook of Tables*, 2010 V2: 130
- Plumbing Engineering and Design Standard 45, 2010 V2: 55
- Plumbing Engineering Design Handbook*, 2012 V4: 2
- plumbing fittings. *See* fittings
- plumbing fixtures. *See* fixtures and fixture outlets
- Plumbing-Heating-Cooling Contractors-National Association (PHCC-NA), 2009 V1: 54, 87
- National Standard Plumbing Code*, 2010 V2: 115
- plumbing inspectors, 2009 V1: 26, 255
- Plumbing Manual*, 2010 V2: 96
- plumbing specifications. *See* specifications
- Plumbing Systems and Design*, 2010 V2: 29
- pneumatic control system, fresh water makeup, 2011 V3: 132–133
- pneumatic pressure differential switches, 2012 V4: 181
- pneumatic pressures, 2010 V2: 2–3, 2011 V3: 64
- pneumatic tank gauging, 2011 V3: 142
- pneumatically operated main drain modulating valves, 2011 V3: 131–132
- POC (points of connection), 2009 V1: 11
- point loading, 2012 V4: 133
- point-of-use reverse osmosis, 2012 V4: 198
- point-of-use ultrafiltration, 2010 V2: 201
- point-of-use vacuum systems, 2010 V2: 172
- point-of-use water heating, 2009 V1: 121, 2011 V3: 47
- points of connection (POC), 2009 V1: 11
- poisonous gases, 2011 V3: 267
- polar solvents, 2011 V3: 25
- polarization
  - defined, 2009 V1: 143
  - hydrogen film buildup, 2009 V1: 129
- polishing deionizers, 2010 V2: 205, 210
- polishing exchangers, 2010 V2: 206
- polishing water in pure water systems, 2010 V2: 221, 2012 V4: 198
- pollen, as contaminant in air, 2011 V3: 265
- pollutants, 2012 V4: 170
- pollution
  - air contaminants, 2011 V3: 264–265
  - contamination in compressed air, 2011 V3: 173
  - dilution, 2011 V3: 81
  - ecological piping, 2012 V4: 52
  - filtering air pollution, 2011 V3: 63
  - priority pollutants, 2011 V3: 81
  - rainwater and precipitation, 2010 V2: 45
  - sanitary precautions for wells, 2010 V2: 159
  - solar water heaters, 2011 V3: 189
  - storm-drainage systems and, 2010 V2: 41
- polyamide, 2009 V1: 32
- polyamide membranes, 2010 V2: 213, 2012 V4: 196
- polyaryl etherketone, 2009 V1: 32
- polybutylene (PB), 2009 V1: 32
  - applications, 2012 V4: 41–42
  - expansion and contraction, 2012 V4: 207
  - physical properties, 2012 V4: 50
  - standards, 2012 V4: 69
  - thermoplastics, 2012 V4: 39
- polycarbonate, 2009 V1: 32
- polychlorotrifluoroethylene, 2009 V1: 32
- polydiallyl phthalate, 2009 V1: 32
- polyelectrolytes, 2010 V2: 199
- polyester fixtures, 2012 V4: 1
- polyether etherketone, 2009 V1: 32
- polyethylene (PE), 2010 V2: 78, 191
  - bioremediation pretreatment systems, 2012 V4: 230
  - expansion and contraction, 2012 V4: 208
  - gas lines, 2011 V3: 257
  - gas systems, 2010 V2: 124
  - insulation, 2012 V4: 106
  - laboratory gas piping, 2011 V3: 276
  - PE abbreviation, 2009 V1: 32
  - standards, 2012 V4: 69
  - storage tanks, 2010 V2: 223
  - stress and strain figures, 2012 V4: 206
  - thermal expansion or contraction, 2012 V4: 207
  - types of, 2012 V4: 42–49
- polyethylene/aluminum/polyethylene (PE-AL-PE), 2012 V4: 49
- polyisobutylene, 2009 V1: 32
- polyisoprene, 2009 V1: 32
- polymer membranes, 2010 V2: 213
- polymeric silica, 2010 V2: 190
- polymers, 2009 V1: 26
- polyolefin piping, 2012 V4: 49
- polyphenylene sulfide, 2009 V1: 32
- polypropylene, 2009 V1: 32
- polypropylene piping
  - double containment, 2012 V4: 51
  - laboratories, 2010 V2: 232, 2011 V3: 42–43
  - pipe characteristics, 2012 V4: 39, 50
  - pure water systems, 2010 V2: 224
  - pure-water systems, 2011 V3: 49
  - soil and waste piping, 2010 V2: 13
  - standards, 2012 V4: 70
  - sulfuric acid and, 2011 V3: 85
  - USP water, 2010 V2: 223
  - VOCs and, 2010 V2: 190
  - water hammer and, 2010 V2: 71–72
- polypropylene-random (PP-R), 2012 V4: 52
- polypropylene storage tanks, 2010 V2: 223, 2011 V3: 84
- polystyrene insulation, 2012 V4: 106
- polystyrene resins, 2012 V4: 183
- polysulfone, 2009 V1: 32

- polysulfone membranes, 2010 V2: 213  
 polytetrafluoroethylene. *See* Teflon  
 polytrophic processes, 2009 V1: 27  
 polyurethane insulation, 2012 V4: 106  
 polyvalent ions, 2012 V4: 199  
 polyvinyl acetate (PVA), 2012 V4: 108  
 polyvinyl carbazol, 2009 V1: 32  
 polyvinyl chloride (PVC), 2010 V2: 71, 78, 94  
   corrosion, 2009 V1: 141  
   fixtures, 2012 V4: 1  
   fountain systems, 2011 V3: 102  
   insulation jackets, 2012 V4: 108  
   low extractable PVC, 2012 V4: 52  
   noise, 2010 V2: 14  
   pipe characteristics, 2012 V4: 39, 50  
   piping, 2010 V2: 190  
   pure-water systems, 2011 V3: 49  
   PVC abbreviation, 2009 V1: 32  
   sanitary drainage, 2010 V2: 12–13  
   shower pans, 2012 V4: 16  
   storage tanks and hazardous wastes, 2011 V3: 84  
   stress and strain figures, 2012 V4: 206  
   sulfuric acid and, 2011 V3: 85  
   thermal expansion or contraction, 2012 V4: 207  
   types of piping, 2012 V4: 49  
   volatile organic compounds, 2010 V2: 190  
 polyvinyl-fluoride. *See* polyvinylidene fluoride (PVDF)  
 polyvinyl formal, 2009 V1: 32  
 polyvinylidene chloride, 2009 V1: 32  
 polyvinylidene fluoride (PVDF), 2010 V2: 13, 71  
   distilled water piping, 2012 V4: 193  
   insulation jackets, 2012 V4: 108  
   piping, 2010 V2: 223, 224, 2011 V3: 49, 2012 V4: 52  
   PVDF abbreviation, 2009 V1: 32  
   standards, 2012 V4: 70  
 ponding, 2010 V2: 47, 51  
 ponds, stabilization, 2010 V2: 150  
 pools, 2009 V1: 27. *See also* reflecting pools; swimming pools  
   codes and standards, 2011 V3: 100–101  
   fixture requirements, 2011 V3: 109  
   interactive, 2011 V3: 100  
   safety regulations, 2011 V3: 104–106  
 poor value, defined, 2009 V1: 209  
 pop-up sprinklers, 2011 V3: 93  
 population density, 2010 V2: 99  
 porcelain enameled steel fixtures  
   defined, 2012 V4: 1  
   standards, 2012 V4: 2  
 pore size in filter membranes, 2010 V2: 213  
 pores, 2009 V1: 27  
 porous paper filters, 2012 V4: 181  
 porous soils, 2011 V3: 91  
 porous stone tubes, 2012 V4: 181  
 portable fire extinguishers, 2009 V1: 13, 2011 V3: 28–29  
 portable propane tanks, 2010 V2: 132  
 Portland cement, 2012 V4: 230  
 positive attachments, defined, 2009 V1: 185  
 positive-displacement air compressors, 2011 V3: 62, 174  
 positive-displacement meters, 2010 V2: 59, 88  
 positive-displacement pumps, 2012 V4: 91  
 post indicator valves (PIV), 2009 V1: 15, 2011 V3: 220–221  
 pot and pan sinks, 2011 V3: 39, 2012 V4: 154, 155  
 potable water, 2012 V4: 170. *See also* drinking water; private water systems; wells  
 potash alum, 2010 V2: 199  
 potassium, 2010 V2: 189, 190, 2012 V4: 173, 198  
 potassium bicarbonate, 2010 V2: 190  
 potassium carbonate, 2010 V2: 190  
 potassium chloride, 2010 V2: 190  
 potassium hydroxide, 2010 V2: 147  
 potassium permanganate, 2010 V2: 160, 2012 V4: 173  
 potential energy (PE)  
   calculating, 2009 V1: 2  
   defined, 2011 V3: 185  
   velocity head and, 2009 V1: 5  
 potential head, 2012 V4: 101  
 potentiometric surfaces of aquifers, 2010 V2: 157  
 POTW (Publicly Owned Treatment Works), 2011 V3: 83, 2012 V4: 227  
 POU filtration, 2010 V2: 201  
 pounding forces in water. *See* water hammer  
 pounds (lb, LBS)  
   converting to SI units, 2009 V1: 39  
   pounds per cubic foot (lb/ft<sup>3</sup>), 2009 V1: 15  
   pounds per square foot (psf, PSF), 2009 V1: 15  
   pounds per square inch (psi, PSI), 2009 V1: 2, 15, 2011 V3: 30, 184  
   pounds per square inch absolute (psia), 2009 V1: 15, 2010 V2: 166, 2011 V3: 78, 172  
   pounds per square inch gauge (psig), 2009 V1: 15, 2010 V2: 166, 2011 V3: 78, 172  
   symbols for, 2009 V1: 15  
 power  
   conversion factors, 2009 V1: 36  
   converting to SI units, 2009 V1: 38  
   measurements, 2009 V1: 34  
 power/capacity characteristic curves, 2012 V4: 95–97  
 power company off-peak power savings, 2009 V1: 119  
 power steam, 2010 V2: 200  
 power usage, economizing on, 2009 V1: 119  
 powered vaporizers, 2011 V3: 57  
 POWTS. *See* private onsite wastewater treatment systems  
 pozzolan, 2012 V4: 230  
 PP. *See* polypropylene piping  
 PP-R (polypropylene-random), 2012 V4: 52, 70–71  
 PPIC (Plumbing and Piping Industry Council), 2009 V1: 160  
 ppm, PPM (parts per million). *See* parts per million (ppm, PPM)  
 PPS (polyphenylene sulfide), 2009 V1: 32  
 Practical Design of a High-purity Water System, 2010 V2: 225  
 Practical Plumbing Design Guide, 2010 V2: 55  
 pre-action systems, 2009 V1: 28, 2011 V3: 9, 10–11, 29  
 pre-action valves, 2009 V1: 13  
 pre-bid information, 2009 V1: 56  
 pre-cast manholes, 2011 V3: 226, 230  
 pre-cast water storage tanks, 2010 V2: 162  
 pre-coolers, 2011 V3: 186, 2012 V4: 220  
 pre-engineered cathodically protected steel tanks, 2011 V3: 138  
 pre-engineered dry-chemical systems, 2011 V3: 24  
 pre-engineered fountains, 2011 V3: 98  
 pre-engineered wet chemical systems, 2011 V3: 24



- pre-fabricated grease interceptor standards, 2012 V4: 145
- pre-fabricated shower bases, 2012 V4: 13
- pre-fabricated shower enclosures, 2012 V4: 13
- pre-fabricated water storage tanks, 2010 V2: 162
- pre-formed insulation for valves and fittings, 2012 V4: 110
- pre-heated feed water, 2012 V4: 194
- pre-plumbed vaults, fountain equipment, 2011 V3: 99
- pre-rinse spray valves
  - LEED 2009 baselines, 2010 V2: 25
- pre-softening distillation feed water, 2012 V4: 191
- pre-treatment in pure water systems, 2010 V2: 221
- pre-treatment ordinances, 2011 V3: 83
- precipitates in water, 2010 V2: 160, 198, 2012 V4: 202
- precipitation. *See* rainwater and precipitation
- precision in measurements, 2009 V1: 33
- predicting water deposits and corrosion, 2010 V2: 196–197
- prefilters
  - air compressors, 2011 V3: 178
  - feed water, 2010 V2: 194
- prefixes in SI units, 2009 V1: 34
- premium grade PVC piping, 2011 V3: 49
- preparation
  - checklists, 2009 V1: 91–92
  - in plumbing cost estimation, 2009 V1: 85
  - section in specifications, 2009 V1: 71
  - in value engineering presentations, 2009 V1: 249
- Preparation phase in value engineering, 2009 V1: 209
- preparing for jobs, checklists, 2009 V1: 91–92
- PRES (pressure). *See* pressure
- Presentation phase in value engineering, 2009 V1: 209, 249
- presets, defined, 2012 V4: 133
- President's Committee on Employment of the Handicapped, 2009 V1: 97
- PRESS (pressure). *See* pressure
- press-connect joints, 2012 V4: 58
- press-fitted ends on valves, 2012 V4: 80
- pressure (PRESS, PRES, P). *See also* pressure drops or differences
  - air-consuming devices, 2011 V3: 180
  - air pressure, 2011 V3: 264
  - barometric. *See* barometric pressure
  - compressed air, 2011 V3: 172, 178, 181
  - conversion factors, 2009 V1: 36
  - differential, trap, 2011 V3: 165
  - examples for pipe sizing, 2010 V2: 87–89
  - fixture requirements, 2010 V2: 89
  - flow and air, 2010 V2: 2
  - fluctuation warnings, 2011 V3: 67
  - fluctuations, 2012 V4: 117
  - friction head, 2009 V1: 2, 6, 2010 V2: 61–63
  - friction loss and, 2009 V1: 2, 2010 V2: 87
  - head (hd), 2009 V1: 14, 2012 V4: 101
  - head coefficient, defined, 2012 V4: 101
  - hydraulic shock, 2009 V1: 6
  - hydrostatic pressure, 2010 V2: 3–4
  - measurements, 2009 V1: 34, 2010 V2: 3–4, 84, 165–166
  - natural gas, 119–121, 2010 V2: 115
  - nozzle pressure flow tables, 2011 V3: 3
  - pressure-regulating valves, 2010 V2: 69–70
  - pressure sensors, 2010 V2: 63
  - pressure-volume relationships (gas laws), 2010 V2: 126
  - pressure waves. *See* water hammer
  - pump affinity laws, 2009 V1: 6
  - pump head, 2010 V2: 61–63
  - relationship, hydrostatic fluids, 2012 V4: 159–160
  - relative discharge curves, 2011 V3: 211
  - relief valves, 2010 V2: 106
  - sizing pipes and, 2010 V2: 78–84
  - soil pressures, 2011 V3: 138
  - in specific applications
    - booster pump systems, 2010 V2: 61–68
    - carbon dioxide extinguishing systems, 2011 V3: 26
    - centralized chilled water systems, 2012 V4: 221, 223
    - closed hot-water systems, 2012 V4: 209
    - condensate piping, 2011 V3: 166
    - distilled water distribution, 2012 V4: 194
    - domestic water supply, 2011 V3: 210
    - expansion tanks, 2010 V2: 67–68
    - fire pumps, 2011 V3: 21–22
    - gas boosters, 2010 V2: 125–128
    - gravity tank systems, 2010 V2: 66
    - heavy flow drains, 2010 V2: 9
    - hot-water system pressures, 2010 V2: 97
    - interstitial tank monitoring, 2011 V3: 143
    - laboratory gas systems, 2011 V3: 276
    - natural gas pressure, 2011 V3: 254–255, 256
    - natural gas systems, 2010 V2: 115, 119–121, 126, 127, 129
    - nitrogen surgical instruments, 2011 V3: 56–57
    - nitrous oxide, 2011 V3: 60
    - plastic piping systems, 2011 V3: 49
    - pneumatic pressures in sanitary drains, 2010 V2: 2–3
    - propane tanks, 2010 V2: 132
    - saturated steam, 2011 V3: 159–161
    - sewage lift stations, 2011 V3: 229
    - sprinkler systems, 2011 V3: 3, 13–14, 14
    - storm-drainage stacks, 2010 V2: 50
    - submersible fuel pumps, 2011 V3: 151
    - vacuum cleaning system requirements, 2010 V2: 181
    - water mains, 2011 V3: 206
    - water softeners, 2012 V4: 185
  - stack flow capacity and, 2010 V2: 3–4
  - suds pressure zones, 2010 V2: 37–38
  - system head loss checklist, 2011 V3: 154
  - tests
    - medical gas systems, 2011 V3: 74, 75–76
    - storage tanks, 2011 V3: 152–153
    - water flow tests, 2010 V2: 84–87
  - vacuum defined, 2010 V2: 165
  - vacuum pressure measurement, 2010 V2: 166
  - velocity head (h), 2009 V1: 5
  - velocity of water in pipes and, 2010 V2: 75, 76–78, 78
  - water hammer and, 2010 V2: 71–72
  - water meters and, 2010 V2: 88
  - water vapor in air and, 2011 V3: 172–173
- pressure-assist water closets, 2009 V1: 127
- pressure-balancing fixtures. *See* pressure-regulating or reducing valves (PRV)
- pressure classes, ductile iron cement-lined pipe, 2012 V4: 29
- pressure deaerators, 2012 V4: 176
- pressure dew points, 2011 V3: 266
- pressure diatomaceous earth filters, 2011 V3: 120
- pressure differential flow sensors, 2011 V3: 124

- pressure differential switches, 2012 V4: 181
- pressure drops or differences (PD, DELTP)
  - air filtration and, 2011 V3: 180
  - backflow preventers and, 2011 V3: 215
  - calculating, 2009 V1: 2
  - compressed air systems, 2011 V3: 72–73, 177, 181, 182, 184
  - defined, 2010 V2: 136, 2012 V4: 202
  - double-check valves and, 2011 V3: 215
  - examples for pipe sizing, 2010 V2: 87–89
  - fittings, 2011 V3: 214
  - fuel systems, 2011 V3: 151
  - gas boosters, 2010 V2: 128
  - gas filters and, 2011 V3: 273
  - gas line filters and, 2011 V3: 254
  - gas valves and, 2011 V3: 274
  - gravity filters, 2012 V4: 179–180
  - installing taps, 2011 V3: 210–214
  - laboratory gas systems, 2011 V3: 276, 279
  - measuring in water flow tests, 2010 V2: 84
  - medical air, 2011 V3: 68–69
  - medical gas, 2011 V3: 68
  - natural gas systems, 2010 V2: 115, 119–121
  - piping runs, 2011 V3: 214
  - pressure drop curves, 2012 V4: 186, 225
  - sanitary drainage, 2010 V2: 2
  - sprinkler hydraulic calculations, 2011 V3: 14
  - steam, 2011 V3: 159–161
  - strainers and, 2011 V3: 216
  - vacuum cleaning systems, 2010 V2: 181–184
  - vacuum exhauster sizing, 2010 V2: 184
  - vacuum piping, 2010 V2: 174–176
  - vacuum pressures, 2010 V2: 168
  - valve sizing, 2012 V4: 83
  - valves and fittings, 2010 V2: 90–91, 2011 V3: 214
  - water meters, 2010 V2: 84, 2011 V3: 216
  - water softeners and, 2012 V4: 185
- pressure filters
  - backwashing, 2012 V4: 180, 181
  - compared to diatomaceous earth, 2012 V4: 182
  - defined, 2012 V4: 180
  - horizontal pressure sand filters, 2012 V4: 180
  - multimedia depth filters, 2012 V4: 180
  - vertical pressure sand filters, 2012 V4: 180
- pressure gauges
  - backwashing, 2012 V4: 181
  - with gauge cocks (PG), 2009 V1: 10
  - measurements, 2010 V2: 166
- pressure loss. *See* pressure drops
- pressure maintenance (jockey) pumps, 2009 V1: 23
- pressure media filters, 2010 V2: 201
- pressure piping
  - double containment, 2012 V4: 56
  - expansion and contraction, 2012 V4: 207
  - glass pipe, 2012 V4: 35
  - polypropylene-random, 2012 V4: 52
- pressure product-dispensing systems, 2011 V3: 146
- pressure ratings, 2009 V1: 27
- pressure-regulating or reducing valves (PRV), 2010 V2: 94
  - health care water supplies, 2011 V3: 46
  - irrigation systems, 2011 V3: 95
  - natural gas systems, 2010 V2: 115, 118
  - pressure-relief valves (PV), 2009 V1: 10
  - shower valves, 2010 V2: 62–63, 2012 V4: 16
  - symbols for, 2009 V1: 9, 15
  - tank size and, 2010 V2: 66
  - tub valves, 2012 V4: 17
  - types of, 2010 V2: 69–70
- Pressure Regulating Values for Liquefied Petroleum Gas*, 2010 V2: 115
- pressure regulators
  - compressed air systems, 2011 V3: 179
  - deluge valves, 2011 V3: 10
  - flushometer tanks, 2012 V4: 6
  - laboratory gas cylinders, 2011 V3: 271–272
  - natural gas systems, 2011 V3: 254–255
  - water storage tanks, 2010 V2: 163–164
- pressure relief valves (PV), 2009 V1: 10, 15
- Pressure Sewer Demonstration at the Borough of Phoenixville, Pennsylvania*, 2010 V2: 154
- pressure sewers, 2010 V2: 144
- pressure swing air dryers, 2011 V3: 179
- pressure switches (PS), 2009 V1: 10
- pressure tanks, 2011 V3: 136
- pressure-type vacuum breakers, 2012 V4: 163
- pressure vacuum breakers (PVBs), 2012 V4: 166, 170
- pressure-volume relationships (gas laws), 2010 V2: 126
- pressure water coolers, 2012 V4: 216, 217, 220
- pressure water filters, 2010 V2: 159
- pressure waves. *See* water hammer
- pressurized fuel delivery systems, 2011 V3: 145, 151–152
- pretreated feed water, 2012 V4: 194
- pretreating effluent. *See* bioremediation pretreatment systems
- prices, 2009 V1: 210. *See also* costs and economic concerns
- primary barriers for infectious wastes, 2010 V2: 240
- primary tanks
  - aboveground types, 2011 V3: 148
  - construction, 2011 V3: 139
  - interstitial monitoring, 2011 V3: 143
  - underground tanks, 2011 V3: 138
- prime costs, 2009 V1: 217
- primers, 2009 V1: 136
- priming in dry-pipe systems, 2011 V3: 8
- priority pollutants, 2011 V3: 81
- prism-like soils, 141, 2010 V2: 140
- private onsite wastewater treatment systems (POWTS)
  - aerobic wastewater treatment plants, 2010 V2: 150
  - collection and treatment alternatives, 2010 V2: 144–145
  - defined, 2009 V1: 27
  - distribution boxes, 2010 V2: 148–149
  - estimating sewage quantities, 2010 V2: 150–152
  - inspection, 2010 V2: 153
  - introduction, 2010 V2: 139
  - large systems, 150, 2010 V2: 149
  - primary collection and treatment systems, 2010 V2: 139
  - private sewers, 2009 V1: 27
  - septic tanks, 2010 V2: 145–149
  - soil-absorption systems, 2010 V2: 139–142
- private sewage disposal systems, 2009 V1: 27
- private unit weighting in fixture flow rate estimates, 2012 V4: 186
- private use
  - defined, 2009 V1: 27

- lavatories, 2012 V4: 9
- private water systems
  - codes and standards, 2010 V2: 155
  - drinking water demand, 2010 V2: 159
  - initial operation and maintenance, 2010 V2: 164
  - introduction, 2010 V2: 155
  - matching water storage to pump flow, 2010 V2: 162
  - performance specifications, 2010 V2: 164
  - sources of supply, 2010 V2: 155
  - system equipment, 2010 V2: 160–164
  - water quality, 2010 V2: 159–160
  - wells, 2010 V2: 155–157
- Proceedings of the Third National Conference on Individual On Site Wastewater Systems*, 2010 V2: 154
- process gases, 2011 V3: 266
- Process Piping Design (ASME B31.3)*, 2011 V3: 176, 277
- process wastewater, 2012 V4: 175
- Procurement and Contracting Requirements Group, 2009 V1: 58, 72
- producer costs, 2009 V1: 217
- producer gas, 2010 V2: 114
- producers (vacuum)
  - defined, 2010 V2: 178
  - locating, 2010 V2: 181
  - sizing, 2010 V2: 184
- product costs, 2009 V1: 217
- product dispensing systems
  - aboveground tank systems, 2011 V3: 149
  - underground tank systems
    - dispenser pans, 2011 V3: 146
    - fire suppression, 2011 V3: 146–147
    - fuel islands, 2011 V3: 146
    - fuel transactions, 2011 V3: 147
    - pressure dispensing, 2011 V3: 146
    - product dispensers, 2011 V3: 146
- product level gauging, 2011 V3: 148, 149
- product spec sheet examples, 2009 V1: 256
- product standards, 2009 V1: 61, 2012 V4: 168
- product substitutions, 2009 V1: 62
- product water. *See* treated water
- production wells in geothermal energy, 2009 V1: 123
- productivity rates, in cost estimation, 2009 V1: 87–88
- products
  - costs, 2009 V1: 217
  - detail/product/material specification checklist, 2009 V1: 215
  - section in specifications, 2009 V1: 63, 71
  - in specifications, 2009 V1: 64
  - value engineering questions, 2009 V1: 209
- professionals, defined, 2012 V4: 170
- profit markup in cost determinations, 2009 V1: 210
- programmers, irrigation systems, 2011 V3: 95
- project conditions section in specifications, 2009 V1: 64, 70
- project costs, 2009 V1: 210
- project manuals
  - contents of, 2009 V1: 56–57
  - defined, 2009 V1: 55
- propagation velocity, 2009 V1: 6
- propane, 2010 V2: 114. *See also* fuel-gas piping systems;
  - liquified petroleum gas
  - glossary, 2010 V2: 135–136
  - laboratory use, 2010 V2: 121
  - physical properties, 2010 V2: 113
  - sizing systems, 2010 V2: 135
- Propane 101 (propane101.com)*, 2010 V2: 137
- propane regulators, 2010 V2: 132–133
- propane torches, 2010 V2: 133
- propane vaporizers, 2010 V2: 134
- propeller water meters, 2010 V2: 60
- property protection in fire protection, 2011 V3: 1
- prophylactic additives to water, 2010 V2: 160
- proportional solubility law, 2010 V2: 72
- proportions of septic tanks, 2010 V2: 146
- proprietary names in specifications, 2009 V1: 60, 61–62
- proprietary specifications, 2009 V1: 61–62
- propylene, 2010 V2: 114
- propylene glycol, 2009 V1: 141
- Protected Aboveground Tanks for Flammable and Combustible Liquids (UL 2085)*, 2011 V3: 137
- protected end of galvanic series, 2009 V1: 132
- protection
  - insulation, 2012 V4: 106–109
  - section in specifications, 2009 V1: 72
  - storage tanks, 2011 V3: 149
  - value engineering contract document clauses, 2009 V1: 251
- protection saddles, 2012 V4: 133
- protection shields
  - defined, 2012 V4: 133
  - hangers and supports, 2012 V4: 121
- protective coatings, 2009 V1: 136. *See also* coated metal
- protective potential, defined, 2009 V1: 143
- protective saddles, 2012 V4: 121
- protein-forming foam, 2011 V3: 25
- protein-mixed chemical concentrates, 2011 V3: 25
- protocol gases, 2011 V3: 266
- Provent single-stack plumbing systems, 2010 V2: 17–18
- PRV (pressure-regulating or reducing valves). *See*
  - pressure-regulating or reducing valves
- prying actions in seismic protection, 2009 V1: 182
- PS (polysulfone), 2009 V1: 32
- PS (pressure switches), 2009 V1: 10
- PS standards. *See* under International Association of Plumbing and Mechanical Officials (IAPMO)
- pseudo-dynamic elastic analysis, 2009 V1: 151
- Pseudo Value Engineers, 2009 V1: 249
- Pseudomonas aeruginosa*, 2010 V2: 43
- psf, PSF (pounds per square foot), 2009 V1: 15
- psi, PSI (pounds per square inch)
  - converting to metric units, 2011 V3: 30
  - measurements, 2011 V3: 184
  - psi absolute (psia, PSIA), 2009 V1: 15, 2010 V2: 166, 2011 V3: 78, 172
  - psi gage (psig, PSIG), 2009 V1: 15, 2010 V2: 166, 2011 V3: 172
  - psi gauge (psig, PSIG), 2011 V3: 78
  - symbols for, 2009 V1: 15
- psia, PSIA (psi absolute), 2009 V1: 15, 2010 V2: 166, 2011 V3: 78, 172
- psig, PSIG (psi gage), 2009 V1: 15, 2010 V2: 166, 2011 V3: 78, 172
- psychrometry, defined, 2011 V3: 186
- PTFE. *See* Teflon (PTFE)
- public, educating on graywater systems, 2010 V2: 27–28

- public areas
  - fixtures for, 2011 V3: 35
  - heel-proof grates, 2010 V2: 11
  - sediment buckets, 2010 V2: 11
- public hydrants, 2009 V1: 12
- Public Law 90-480, 2009 V1: 98
- Public Law 93-112, 2009 V1: 98
- Public Law 98, 2011 V3: 137
- Public Law 616, 2011 V3: 137
- public sewers
  - availability of, 2011 V3: 225
  - defined, 2009 V1: 27
  - discharging into, 2010 V2: 227
  - neutralizing acid wastes for, 2010 V2: 235
  - public storm sewer systems, 2010 V2: 41, 2011 V3: 249
  - radioactive waste systems and, 2010 V2: 240
- public swimming pools. *See* swimming pools
- public unit weighting in fixture flow rate estimates, 2012 V4: 186
- public use
  - defined, 2009 V1: 27
  - lavatories, 2012 V4: 9
- public utilities, 2010 V2: 113, 116
- public water supply. *See* municipal water supply
- Publicly Owned Treatment Works (POTW), 2011 V3: 83, 2012 V4: 227
- pull-out spray accessories, 2012 V4: 11, 13
- pulsation, air compressors, 2011 V3: 177
- pulse remote-readout gas meters, 2010 V2: 116
- pump affinity laws, 2011 V3: 125
- pump discharge lines (PD), 2009 V1: 8
- pump performance curves, 2012 V4: 101
- pumper connections, 2009 V1: 12
- pumping
  - defined, 2011 V3: 186
  - septic tanks, 2010 V2: 145
  - wells, 2010 V2: 157–158
- pumping head, 2010 V2: 161
- pumps
  - acoustics, 2012 V4: 138
  - affinity laws, 2012 V4: 94, 95
  - applications
    - booster pump systems, 2010 V2: 61–68
    - centralized drinking-water coolers, 2012 V4: 222, 224
    - chemical feed, 2011 V3: 129–130
    - chilled drinking-water systems, 2012 V4: 221
    - cooling vacuum pumps, 2010 V2: 171
    - distilled water systems, 2012 V4: 191, 192
    - domestic booster, 2012 V4: 97
    - drainage, 2012 V4: 98–99
    - drainage systems, 2012 V4: 98–99
    - fire pumps, 2011 V3: 21–22
    - fire suppression, 2012 V4: 98
    - geothermal energy systems, 2009 V1: 123
    - gravity tank systems, 2010 V2: 65–66
    - house pumps, 2010 V2: 66
    - hydropneumatic-tank systems, 2010 V2: 62, 64–65
    - liquid fuel systems, 2011 V3: 151–152
    - liquid-waste decontamination systems, 2010 V2: 240
    - sewage lift stations, 2011 V3: 229
    - solar, circulating system, 2011 V3: 197
    - solar systems, 2011 V3: 200, 201–202
    - specialty, 2012 V4: 97–99
    - storm drainage backup systems, 2010 V2: 41
    - sump pumps in sanitary drainage systems, 2010 V2: 8–9
    - swimming pools, 2011 V3: 104, 110, 114, 122–123, 125–126
    - systems for water supplies, 2010 V2: 160–162
    - water circulation, 2012 V4: 98
    - well pumps, 2010 V2: 160–162
  - as source of plumbing noise, 2009 V1: 189
  - automatic shutdown, 2011 V3: 84
  - bases, 2010 V2: 158, 161
  - casings, 2012 V4: 91, 92
  - characteristic curves, 2012 V4: 95–97
  - controls, 2012 V4: 99–100
  - direct connection hazards, 2012 V4: 161
  - earthquake protection, 2009 V1: 157
  - efficiency, 2009 V1: 6–7, 2012 V4: 93–94
  - environmental concerns, 2012 V4: 99
  - glossary, 2012 V4: 100–102
  - impellers, 2012 V4: 91
  - installation, 2012 V4: 100
  - matching water storage to pump flow, 2010 V2: 162
  - motor controls, 2010 V2: 63–64
  - mounting details, 2009 V1: 204
  - noise mitigation, 2009 V1: 194–201
  - overview, 2012 V4: 91
  - in parallel, defined, 2012 V4: 101
  - performance, 2012 V4: 95–97
  - power/capacity characteristic curves, 2012 V4: 95–97
  - pump affinity laws, 2009 V1: 6, 2011 V3: 125
  - purging vacuum pumps, 2010 V2: 171
  - repairing, 2012 V4: 99
  - seals, 2012 V4: 91, 92
  - secondary containment areas, 2011 V3: 84
  - in series, defined, 2012 V4: 101
  - staging, 2012 V4: 97
  - sulfuric acid and, 2010 V2: 231
  - temperature maintenance, 2012 V4: 98
  - timers, 2010 V2: 64
  - types of
    - acid feed, 2011 V3: 129–130
    - axial, 2012 V4: 91
    - centrifugal, 2012 V4: 91, 91–97
    - ejector pumps, 2011 V3: 228–229
    - mixed-flow, 2012 V4: 91
    - multiple pump systems, 2010 V2: 63
    - multistage, 2012 V4: 97
    - parallel pump systems, 2012 V4: 97
    - positive-displacement, 2012 V4: 91
    - regenerative pumps, 2012 V4: 97
    - submersible, 2010 V2: 158, 2011 V3: 151–152, 233
    - vertical, 2012 V4: 92, 97
    - volute, 2012 V4: 92
  - vibration isolation, 2009 V1: 202, 2012 V4: 137
  - volute, 2012 V4: 97
- Pumps and Pump Systems*, 2009 V1: 39
- purchasers in cost equation, 2009 V1: 217
- pure air properties, 2011 V3: 263–264
- pure water, 2010 V2: 219, 2012 V4: 175, 196
- pure-water systems. *See also* water purification
  - defined, 2010 V2: 187

health care facilities, 2011 V3: 46, 47–49  
 piping materials, 2011 V3: 48–49  
 types of pure water, 2011 V3: 47

purge valves, 2011 V3: 275

purging  
 gas manifolds and regulators, 2011 V3: 275  
 laboratory gas lines, 2011 V3: 270  
 laboratory gas systems, 2011 V3: 280  
 medical gas zones, 2011 V3: 67, 74  
 natural gas systems, 2011 V3: 257  
 vacuum pumps, 2010 V2: 171

purified gas grade, 2011 V3: 267

purified water (PW), 2010 V2: 72, 74, 219, 2012 V4: 35, 175. *See also* pure-water systems; water purification

purifiers, laboratory gas systems, 2011 V3: 273

purity  
 compressed air, 2011 V3: 180  
 laboratory gases, 2011 V3: 263, 273  
 monitors, 2012 V4: 193  
 testing medical gas systems, 2011 V3: 75–76

push-connect joints, 2012 V4: 58

push-on joints, 2011 V3: 221

push-seal gasketed drains, 2010 V2: 13

push-seal gasketed outlets, 2010 V2: 13

putrefaction, 2009 V1: 27

*Putting Industrial Vacuum to Work*, 2010 V2: 186

puzzles  
 Nine Dots exercise, 2009 V1: 225, 252  
 Six Sticks exercise, 2009 V1: 225, 252

PV (plug valves). *See* plug valves (PV)

PV (pressure relief valves), 2009 V1: 15

PVA (polyvinyl acetate), 2012 V4: 108

PVBs. *See* pressure vacuum breakers (PVBs)

PVC. *See* polyvinyl chloride (PVC)

PVC (polyvinyl chloride), 2010 V2: 94

PVC piping  
 expansion and contraction, 2012 V4: 208  
 standards, 2012 V4: 69–70

PVDC (polyvinylidene chloride), 2009 V1: 32

PVDF (polyvinyl-fluoridine). *See* polyvinylidene fluoride (PVDF)

PVDM (polyvinyl formal), 2009 V1: 32

PVE (Pseudo Value Engineers), 2009 V1: 249

PVK (polyvinyl carbazol), 2009 V1: 32

PW (pure water). *See* pure-water systems; purified water; water purification

pyramids, calculating volume, 2009 V1: 4

pyrogens, 2010 V2: 188, 213  
 distilled water and, 2012 V4: 175, 192  
 intravenous injections and, 2012 V4: 192  
 laboratory grade water, 2012 V4: 198  
 pure water systems and, 2011 V3: 47

pyrophoric gases, 2011 V3: 267

**Q**

qt, QT (quarts), 2009 V1: 39

quads, converting to SI units, 2009 V1: 39

quality  
 appearance of installations, 2009 V1: 262–263  
 building noise and perceptions of, 2009 V1: 187  
 building occupants and, 2009 V1: 263

building owners and, 2009 V1: 262

contractors and, 2009 V1: 262

in cost estimation, 2009 V1: 89

costs vs. benefits, 2009 V1: 253

equipment supports, 2009 V1: 258

low cost vs. high quality, 2009 V1: 263–264

makeshift or field-devised methods, 2009 V1: 254–257

mock-ups, 2009 V1: 264

quality assurance in specifications, 2009 V1: 63, 70

quality control section in specifications, 2009 V1: 64, 72

regional and climate considerations, 2009 V1: 262

researching readily-available products and technologies, 2009 V1: 262

safety and, 2009 V1: 258–262

specification clarity and, 2009 V1: 253–254, 264

of water, 2010 V2: 27–28, 159–160. *See also* water analysis; water purification

quantities. *See also* demand  
 clean gas agents, 2011 V3: 27  
 in creativity checklist, 2009 V1: 227  
 irrigation water, 2011 V3: 91  
 water supplies, 2011 V3: 2–6

quarter-circle rotary sprinklers, 2011 V3: 94

quarter-turn valves, 2012 V4: 73

quarts (qt, QT), 2009 V1: 39

questions in value engineering presentations, 2009 V1: 249

quick-coupling method of irrigation, 2011 V3: 92

quick-disconnect couplings, 2011 V3: 184

quick-opening devices, 2011 V3: 9

quick-response sprinklers, 2009 V1: 29

quick valve closure, 2010 V2: 71

quieting pipes, 2010 V2: 13–14

**R**

R (hydraulic radii), 2009 V1: 1

°R, R (Rankines), 2009 V1: 15, 30

R, R (thermal resistance), 2012 V4: 103, 105

R, R- (refrigerants), 2009 V1: 140

R-13 and R-13A fire-protection systems, 2012 V4: 39

RAD (radiation). *See* radiation

rad, RAD (radians). *See* radians

rad/s (radians per second), 2009 V1: 34

rad/s<sup>2</sup> (radians per second squared), 2009 V1: 34

radial flow, 2012 V4: 101

radians (RAD)  
 measurement unit conversions, 2009 V1: 34  
 radians per second, 2009 V1: 34  
 radians per second squared, 2009 V1: 34

radiant emittance (exitance), 2011 V3: 191

radiant energy, 2012 V4: 195

radiant flux, 2011 V3: 191

radiant intensity, 2011 V3: 191

radiation (RADN, RAD)  
 defined, 2011 V3: 191  
 nature of, 2010 V2: 236–237  
 radiation equivalent to man (rem), 2010 V2: 237  
 rads (radioactive dosage), 2010 V2: 237  
 treatment facilities, 2010 V2: 238

radicals (ions), 2009 V1: 134, 143, 2010 V2: 229

radio frequency remote-readout gas meters, 2010 V2: 116

radioactive waste drainage and vents  
 allowable radiation levels, 2010 V2: 237

- approval process and applications, 2010 V2: 238
- diluting radwaste, 2010 V2: 240
- introduction, 2010 V2: 235–236
- measuring radiation, 2010 V2: 237
- nature of radiation, 2010 V2: 236–237
- pipe selection, 2010 V2: 239
- radioactive materials, 2010 V2: 238
- shielding systems, 2010 V2: 238
- system design criteria, 2010 V2: 238–240
- radioactivity
  - defined, 2010 V2: 236–237
  - radioactive half lives, 2010 V2: 238
  - radioactive isotopes, 2010 V2: 236–237, 238
- radiological characteristics of drinking water, 2010 V2: 217
- Radiological Safety Officers, 2010 V2: 238
- radium 226, 2010 V2: 238
- radius screwed ells, 2010 V2: 93
- RADN (radiation). *See* radiation
- radon gas, 2010 V2: 160, 190, 217
- radwaste (waterborne radioactive waste), 2010 V2: 236
- rain shutoff devices, 2011 V3: 96
- Rainbird Company, 2011 V3: 96
- Rainfall Rates: How Much Rain Is Enough in Design?*, 2010 V2: 55
- rainwater and precipitation
  - calculating intensity, 2010 V2: 44–46
  - calculating time of concentration, 2010 V2: 44–46
  - capturing rainwater, 2009 V1: 126
  - cisterns, 2010 V2: 162, 2012 V4: 236
  - duration, 2011 V3: 241–242
  - flow rates, 2010 V2: 53
  - imperviousness factor, 2011 V3: 239
  - inlet times, 2011 V3: 242
  - intensity-duration-frequency curves, 2011 V3: 239, 244–248
  - pipe loads, 2012 V4: 115
  - pollution, 2010 V2: 45
  - polypropylene-random piping, 2012 V4: 52
  - precipitation, defined, 2009 V1: 27
  - rainfall rates, 2010 V2: 57, 2011 V3: 239, 240
  - rainwater drains (SD, ST). *See* storm-drainage systems
  - regional requirements for plumbing installations, 2009 V1: 262
  - return periods, 2011 V3: 240–241
  - runoff patterns, 2010 V2: 43
  - runoff volume calculation example, 2010 V2: 56
  - siphonic roof drains, 2010 V2: 53
  - storing in controlled flow systems, 2010 V2: 52–53
  - storm-drainage systems, 2010 V2: 41
- raised-floor areas, 2011 V3: 27
- ramp-drain grates, 2010 V2: 11
- ramps, swimming pools, 2011 V3: 134–135
- random hangers, 2012 V4: 133
- range ability, gas meters, 2010 V2: 117
- Rankines (°R, R), 2009 V1: 15, 30, 2011 V3: 184
- ranking functions in value engineering, 2009 V1: 235
- rapid sand/direct filtration package plants, 2010 V2: 218
- rate of corrosion
  - acidity, 2009 V1: 134
  - Faraday's Law, 2009 V1: 134
  - film formation, 2009 V1: 135
  - homogeneity in, 2009 V1: 134
  - oxygen content, 2009 V1: 134
  - temperature, 2009 V1: 135
  - velocity in, 2009 V1: 135
- rate of flow. *See* flow rates
- rated vacuum levels, 2010 V2: 166–167
- ratings
  - drinking water coolers, 2012 V4: 215–216
  - insulation smoke requirements and ratings, 2012 V4: 104
  - LEED, 2012 V4: 234
  - load ratings. *See* load ratings
  - portable fire extinguishers, 2011 V3: 28
  - saturated steam pressure valves, 2012 V4: 78
  - valves (v, V, VLV), 2012 V4: 78
  - water, oil, and gas (WOG) pressure rating, 2012 V4: 78, 84
- ratio of specific heats, defined, 2011 V3: 186
- Rational Method, 2009 V1: 7, 2010 V2: 42–43, 2011 V3: 238–239
- raw sewage, 2009 V1: 27
- raw water, 2010 V2: 187, 220
- RCP (reinforced concrete pipe), 2012 V4: 29
- RCRA (Resource Conservation and Recovery Act), 2010 V2: 242, 2011 V3: 82, 83, 137
- rcvr; RCVR (receivers), 2010 V2: 170, 173
- RD. *See* roof drainage
- re-flashing, 2011 V3: 23
- reaction forces in earthquakes, 2009 V1: 180
- Reactive Hazard gases, 2011 V3: 263
- reactive silica, 2010 V2: 190
- reactivity, hangers and supports and, 2012 V4: 117
- ready mix concrete, 2012 V4: 230
- reagent grade water, 2010 V2: 219, 2012 V4: 197, 198
- real costs, 2009 V1: 218
- rear wall grab bars, 2009 V1: 106
- reasonable care, defined, 2012 V4: 170
- reasoning against value engineering, 2009 V1: 225
- REC (receivers), 2010 V2: 170, 173
- receiver tanks
  - medical air compressors, 2011 V3: 62–63
  - vacuum systems, 2011 V3: 64
- receivers (rcvr, RCVR, REC), 2010 V2: 170, 173
- receiving costs, 2009 V1: 217
- receptors, 2009 V1: 27
- recessed-box hose bibbs, 2009 V1: 10
- recessed grease interceptors, 2012 V4: 154
- recessed sprinklers, 2009 V1: 29
- recessed water coolers, 2012 V4: 217–218, 218
- recharge basins, 2011 V3: 250
- rechargeable air chambers, 2010 V2: 73
- recharging aquifers, 2010 V2: 155
- rechlorination treatments, 2010 V2: 110–111
- reciprocating air compressors, 2011 V3: 62, 174–175, 177, 2012 V4: 84
- reciprocating (rotary) piston pumps, 2010 V2: 169
- recirculating hot-water systems, 2010 V2: 109
- recirculating sand filter sewage systems, 2010 V2: 145
- recirculation systems
  - for high purity water, 2011 V3: 48
  - for hot water, 2010 V2: 105
- reclaimed water. *See* graywater systems
- reclamation, wastewater, 2012 V4: 236–237
- recombined FOG (fats, oil, and grease), 2012 V4: 227

- Recommendation phase in value engineering, 2009 V1: 209, 249
- Recommendations for a New ADAAG*, 2009 V1: 115
- Recommended Practice for Backflow Prevention and Cross-connection Control*, 2010 V2: 95
- Recommended Practice for Fire Flow Testing and Marking of Fire Hydrants (NFPA 291)*, 2011 V3: 3, 30
- Recommended Practice for Handling Releases of Flammable and Combustible Liquids and Gases (NFPA 329)*, 2011 V3: 137
- recovered energy, 2009 V1: 128
- recovering heat from water heaters, 2010 V2: 100–101
- recovery in reverse osmosis, 2010 V2: 211
- recovery pressure, defined, 2011 V3: 186
- recovery rooms
  - fixtures, 2011 V3: 39
  - health care facilities, 2011 V3: 36
  - medical gas stations, 2011 V3: 53, 56
  - medical vacuum, 2011 V3: 54
- recreational establishments
  - estimating sewage quantities, 2010 V2: 151
  - septic tank/soil-absorption systems for, 150, 2010 V2: 149
- recreational pools, 2011 V3: 107
- rectangles, calculating area, 2009 V1: 3
- rectangular bath seats, 2009 V1: 114
- rectangular solids, calculating volume, 2009 V1: 4
- rectifiers, 2009 V1: 139, 140
- recycled water systems. *See* graywater systems
- recycling systems, salt, 2012 V4: 189
- red brass, 2009 V1: 132
- reduced noise transmission, 2010 V2: 13–14
- reduced-port ball valves, 2012 V4: 75
- reduced pressure
  - conditions in water storage tanks, 2010 V2: 163
  - defined, 2011 V3: 187
  - fall-off, 2012 V4: 80
  - in pressure-regulated valves, 2010 V2: 94
  - reduced-pressure backflow preventers, 2010 V2: 94
  - reduced pressure zones (RPZ), 2009 V1: 15, 2010 V2: 60–61, 94, 2011 V3: 215, 220
- reduced-pressure-principle backflow devices (RPBDs) (RPZs), 2010 V2: 94
  - costs and locations for, 2012 V4: 168
  - defined, 2012 V4: 165, 170
- reduced pressure zone backflow preventers, 2009 V1: 27, 2012 V4: 163
- reduced-size venting, 2010 V2: 18–19
- reduced temperature, defined, 2011 V3: 187
- reduced water-flow rates, 2009 V1: 118
- reduced water pressure differential, 2012 V4: 80
- reduced zone backflow preventers (RZBP), 2009 V1: 10
- reducers, defined, 2009 V1: 27
- reducing bushings, 2010 V2: 92
- redundancy in hazardous waste systems, 2011 V3: 84
- reference standard specifications, 2009 V1: 61
- references
  - bioremediation systems, 2012 V4: 229–230
  - cold water systems, 2010 V2: 95–96
  - conserving energy, 2009 V1: 128
  - designing for people with disabilities, 2009 V1: 115
  - fire-protection systems, 2011 V3: 30
  - formulae, symbols, and terminology, 2009 V1: 39
  - gasoline and diesel-oil systems, 2011 V3: 156
  - graywater systems, 2010 V2: 29
  - health care facilities, 2011 V3: 78
  - irrigation systems, 2011 V3: 96
  - sanitary drainage systems, 2010 V2: 19
  - seismic protection, 2009 V1: 185
  - special-waste drainage systems, 2010 V2: 246
  - steam and condensate systems, 2011 V3: 169
  - vacuum systems, 2010 V2: 186
  - water treatment and purification, 2010 V2: 224–225
- references section in specifications, 2009 V1: 63, 69
- reflecting pools
  - codes and standards, 2011 V3: 100–101
  - defined, 2009 V1: 27
  - design, 2011 V3: 98
  - flow rates, 2011 V3: 100
  - interactive, 2011 V3: 100
  - overview, 2011 V3: 98
- refrigerant after-coolers, 2011 V3: 178
- refrigerants (R, R-), 2009 V1: 140
- refrigerated air dryers, 2011 V3: 178
- refrigeration loads, 2012 V4: 222, 223, 224
- refrigeration mechanical rooms, 2009 V1: 158
- refrigeration piping, 2012 V4: 29, 32
- refrigeration systems
  - centralized chilled water systems, 2012 V4: 222
  - heat reclamation, 2009 V1: 123
  - waste heat usage, 2009 V1: 123, 124
  - water coolers, 2012 V4: 219–220
- regenerable ion exchange, 2010 V2: 205
- regenerants, dealkazing and, 2010 V2: 199
- regeneration controls on ion exchangers, 2012 V4: 183–184
- regeneration cycle
  - in dealkazing, 2010 V2: 199
  - defined, 2012 V4: 202
  - in deionizing, 2010 V2: 206–208, 207
  - in demineralizers, 2011 V3: 48, 2012 V4: 182
  - in ion exchange, 2010 V2: 208, 2012 V4: 183–184
  - salt recycling, 2012 V4: 189, 191
  - service deionization, 2012 V4: 182
  - sodium chloride usage, 2012 V4: 184
  - in water softeners, 2010 V2: 210, 2012 V4: 185, 189
- regenerative alternative media filters, 2011 V3: 122
- regenerative diatomaceous earth filters, 2011 V3: 120–122
- regenerative pumps (turbines), 2012 V4: 97
- regional authorities, 2010 V2: 227
- regional requirements for plumbing installations, 2009 V1: 262
- registers in fuel dispensers, 2011 V3: 146
- regulated substances, 2011 V3: 136
- regulations. *See* codes and standards
- regulator creep, 2011 V3: 179, 272
- regulator relief vents, 2010 V2: 121
- regulators, 2009 V1: 27. *See* specific types of regulators
  - propane, 2010 V2: 132–133
  - purging, 2011 V3: 275
- Rehabilitation Act of 1973 (93-112), 2009 V1: 98
- reinforced concrete pipe (RCP), 2012 V4: 29
- reinforced thermosetting resin pipe (RTRP), 2012 V4: 53
- reinforcing ribs in tanks, 2011 V3: 138
- reject stream from reverse osmosis, 2010 V2: 211
- relative discharge curves, 2011 V3: 211

- relative humidity (rh, RH), 2009 V1: 15, 2011 V3: 186, 265
- relative velocity, 2012 V4: 146
- relay interface controls, 2011 V3: 67
- reliability of water supplies, 2011 V3: 2, 6
- relief valves
  - centralized drinking-water systems, 2012 V4: 223
  - compressed air systems, 2011 V3: 180–181
  - fire pumps, 2011 V3: 22
  - gas regulators, 2011 V3: 255
  - hot-water systems, 2010 V2: 106, 2012 V4: 209
  - laboratory gas systems, 2011 V3: 274
  - propane tanks, 2010 V2: 133
  - sizing, 2010 V2: 106
  - water-pressure regulators and, 2012 V4: 80
- Relief Valves for Hot Water Supply Systems*, 2010 V2: 112
- relief vents
  - defined, 2009 V1: 27
  - gas regulator relief vents, 2010 V2: 117–118
  - gas systems, 2010 V2: 121
  - gas trains, 2011 V3: 255
  - offsets, 2010 V2: 37
- remote-control irrigation valves, 2011 V3: 94
- remote earth (remote electrodes), 2009 V1: 143
- remote electrodes, 2009 V1: 143
- remote fill ports, 2011 V3: 139–140, 148
- remote leakage from tanks, 2011 V3: 144
- remote portions of fire design areas, 2011 V3: 12
- remote-readout gas meters, 2010 V2: 116
- remote-readout water meters, 2010 V2: 60
- remote secondary-containment enclosures, 2011 V3: 148
- remote water coolers, 2012 V4: 216
- removal ratios for grease interceptors, 2012 V4: 148
- Remove Organics by Activated Carbon Adsorption, 2010 V2: 225
- removing tanks, 2011 V3: 154
- rems (radiation equivalent to man), 2010 V2: 237
- renewable energy resources, 2011 V3: 189
- renovations, cost estimating and, 2009 V1: 90
- repetition in value engineering presentations, 2009 V1: 249
- replacements for Halon gases, 2011 V3: 27
- Report on Hydraulics and Pneumatics of Plumbing Drainage Systems, 2010 V2: 19
- reports, physical condition of buildings, 2009 V1: 267–269
- required NPSH, 2012 V4: 101
- research facilities, radiation in, 2010 V2: 238
- research-grade gases, 2011 V3: 267
- Research Report: Water Reuse Standards and Verification Protocol, 2010 V2: 29
- researching new technologies and products, 2009 V1: 262
- reserves (connected standbys), 2011 V3: 27
- reservoirs, 2010 V2: 47
  - condensate drainage, 2011 V3: 164
  - defined, 2012 V4: 133
  - municipal, 2011 V3: 6
  - storm drainage systems, 2010 V2: 41
- residential dual check valves, 2012 V4: 170–171
- residential garage sediment buckets, 2010 V2: 11
- residential kitchen faucets, 2010 V2: 25
- residential kitchen sinks
  - faucets, 2012 V4: 12
  - types and requirements, 2012 V4: 10–12
- residential land use, runoff, 2010 V2: 42
- residential sprinkler systems (fire protection), 2011 V3: 18
- residential systems
  - cold-water systems. *See* cold-water systems
  - estimating sewage quantities, 2010 V2: 150–152
  - firefighting demand flow rates, 2011 V3: 224
  - fixture drainage loads, 2010 V2: 3
  - gas appliances, 2010 V2: 116
  - hot-water systems. *See* hot-water systems
  - irrigation, 2011 V3: 92
  - lavatory flow rates, 2012 V4: 9
  - numbers of fixtures, 2012 V4: 21
  - propane tanks, 2010 V2: 133–134
  - sewage-disposal systems. *See* private onsite wastewater treatment systems (POTWS)
  - sprinklers, 2009 V1: 29
  - typical graywater supply and demand, 2010 V2: 24
  - water supply. *See* domestic water supply
- residual acids, 2012 V4: 177
- residual pressure
  - defined, 2009 V1: 27, 2010 V2: 94
  - domestic water supply, 2011 V3: 208–210
  - fire hydrants, 2011 V3: 3
  - sprinkler hydraulic calculations, 2011 V3: 13
- residual radiation, 2010 V2: 239
- resilient mounts
  - calculating vibration, 2012 V4: 140–141
  - economic concerns, 2012 V4: 143
  - natural frequencies and, 2012 V4: 138
  - vibration calculator, 2012 V4: 140–141
- resilient pipe isolation, 2009 V1: 191, 201
- resilient pipe supports, 2012 V4: 133
- resilient valve seating, 2012 V4: 76
- resilient wedge valve design, 2012 V4: 74
- resin beads, 2010 V2: 206
- resins, dissolved metal removal, 2011 V3: 87
- resins, ion-exchange
  - continuous deionization, 2010 V2: 209–210
  - defined, 2010 V2: 205, 2012 V4: 183, 202
  - in diluting compartments, 2010 V2: 209
  - overview, 2010 V2: 205–206
  - regenerating, 2010 V2: 206
  - strong-acid and weak-acid, 2010 V2: 206
  - volatile organic compounds in, 2010 V2: 191
- resistance ratings (fire loads), 2011 V3: 2
- resistivity
  - defined, 2009 V1: 27, 143
  - low extractable PVC, 2012 V4: 52
  - resistivity meters, 2012 V4: 183, 193
  - soil, 2009 V1: 138
- resonance and ringing
  - calculating, 2012 V4: 138
  - preventing, 2012 V4: 118
  - upper floor installations, 2012 V4: 142–143
  - vibration and, 2012 V4: 137
- resonant amplification, defined, 2012 V4: 137
- resource conservation, 2009 V1: 117
- Resource Conservation and Recovery Act, 2009 V1: 117, 2010 V2: 242, 2011 V3: 82, 137
- resources
  - gasoline and diesel-oil systems, 2011 V3: 156
  - health care facilities, 2011 V3: 78
  - industrial wastewater treatment, 2011 V3: 89



- irrigation systems, 2011 V3: 96–97
- solar energy, 2011 V3: 203
- respirators, 2010 V2: 229, 231
- response factor in seismic protection, 2009 V1: 177
- response in pressure-regulated valves, 2010 V2: 94
- response spectrum in earthquakes, 2009 V1: 151, 180
- restaurants, 150, 2010 V2: 149. *See also* food-processing areas and kitchens
  - drinking fountain usage, 2012 V4: 223
  - fixtures, 2012 V4: 20
  - grease interceptors, 2012 V4: 145
  - water consumption, 2012 V4: 187
- restraints and restraining control devices
  - defined, 2012 V4: 133
  - for earthquakes, 2009 V1: 158, 183
  - for fire-protection joints, 2011 V3: 221
  - illustrated, 2012 V4: 121
- restricted areas (facilities with radiation), 2010 V2: 237
- restrooms. *See* water-closet compartments; water closets
- retail stores, 2012 V4: 223
- retaining straps, 2012 V4: 133
- retard chambers, 2011 V3: 6, 7
- retention basins, 2011 V3: 250
  - bioremediation systems, 2012 V4: 228
  - FOG bioremediation systems, 2012 V4: 228
- retention periods for grease interceptors, 2012 V4: 147
- retention ratios in bioremediation, 2012 V4: 230
- retirement costs, in labor costs, 2009 V1: 86
- retractable ceiling medical gas columns, 2011 V3: 56
- return air (ra, RA), 2009 V1: 262
- return bends, 2010 V2: 93
- return circuits, 2009 V1: 129
- return offsets, 2009 V1: 27
- return periods, 2009 V1: 27
- return periods in rainfall, 2010 V2: 57, 2011 V3: 240–241
- reusing water. *See* graywater systems
- rev, REV (revolutions), 2009 V1: 15
- revent pipes, 2009 V1: 27. *See also* individual vents
- reverse flow
  - active control, 2012 V4: 164–166
  - air gaps, 2012 V4: 162–164, 167
  - barometric loops, 2012 V4: 164
  - causes, 2012 V4: 160–162
  - passive control, 2012 V4: 162–164
  - vacuum breakers, 2012 V4: 164, 166, 167
  - water distribution hazards, 2012 V4: 161, 162
- reverse osmosis (RO)
  - applications, 2012 V4: 198–199
  - cartridges, 2010 V2: 194
  - continuous deionization and, 2010 V2: 210
  - defined, 2010 V2: 211–213, 2012 V4: 175
  - drinking-water coolers, 2012 V4: 221
  - health care facilities, 2011 V3: 48
  - history and current technology, 2012 V4: 196–197
  - laboratory grade water comparison, 2012 V4: 197–198
  - membrane configurations, 2010 V2: 211–212
  - membrane selection, 2010 V2: 213
  - overview, 2012 V4: 195–196
  - polishing systems, 2012 V4: 198
  - polymer membranes, 2010 V2: 213
  - silica and, 2010 V2: 190
  - small drinking water systems, 2010 V2: 218
  - VOCs in membranes, 2010 V2: 191
  - water quality, 2012 V4: 197–198
  - water softening pretreatment, 2012 V4: 187
  - water supply (RO), 2009 V1: 8
- Reverse Osmosis and Nanofiltration System Design*, 2010 V2: 224
- reverse-trap water closets, 2012 V4: 2
- reversible potential, defined, 2009 V1: 143
- revolutions (rev, REV)
  - revolutions per minute (rpm, RPM), 2009 V1: 15
  - revolutions per second (rps, RPS), 2009 V1: 15
- Reynold's number for turbulence, 2009 V1: 2, 2010 V2: 74–75, 77, 2012 V4: 146
- RF remote-readout gas meters, 2010 V2: 116
- RFP (fiberglass reinforced plastic), 2010 V2: 78, 94
- rgh, RGH (roughness). *See* roughness of pipes
- rh, RH (relative humidity). *See* relative humidity
- RHO (density). *See* density
- rhomboids, calculating area, 2009 V1: 4
- rhombuses, calculating area, 2009 V1: 3
- RI (Ryzner stability index), 2010 V2: 196
- Richardson, D.W., Sr., 2010 V2: 224
- rigging, 2012 V4: 133
- right-angle triangles, calculating area, 2009 V1: 4
- rigid braces, 2012 V4: 133
- rigid ceiling medical gas columns, 2011 V3: 56
- rigid cellular urethane, 2012 V4: 107
- rigid hangers, 2012 V4: 133
- rigid pipes
  - expansion of, 2012 V4: 208
  - plastic piping, 2011 V3: 150
- rigid supports, 2012 V4: 133
- rim top test, 2012 V4: 5
- rims
  - defined, 2009 V1: 27
  - on urinals, 2009 V1: 108
  - rim top test, 2012 V4: 5
  - water closets, 2012 V4: 4
- ring bands, 2012 V4: 133
- ring buoys, 2011 V3: 135
- ring hangers and supports, 2012 V4: 119
- ring-securing methods around drains, 2010 V2: 16
- ringing in pipes. *See* resonance and ringing
- rinsing in regeneration cycle, 2010 V2: 206, 208, 2012 V4: 202
- ripraps, 2009 V1: 27
- riser clamps, 2009 V1: 194, 2012 V4: 119, 120, 134
- riser hangers, 2012 V4: 134
- riser-mounted sprinklers, 2011 V3: 93
- risers
  - bracing, 2009 V1: 161, 171
  - checklists, 2009 V1: 94
  - defined, 2009 V1: 27, 2011 V3: 78, 2012 V4: 134
  - earthquake protection and joints, 2009 V1: 161
  - hangers and supports, 2012 V4: 65
  - natural gas piping, 2010 V2: 131
  - noise mitigation, 2009 V1: 191
  - riser clamps, 2012 V4: 120, 134
  - riser down (elbows), 2009 V1: 10
  - riser hangers, 2012 V4: 134
  - riser-mounted sprinklers, 2011 V3: 93
  - riser up (elbows), 2009 V1: 11

- symbols for, 2009 V1: 12
  - thermal expansion and contraction, 2012 V4: 206
  - rises or drops, 2009 V1: 11
  - rising stems (RS)
    - defined, 2012 V4: 89
    - with inside screws, 2012 V4: 79
    - with outside screws, 2012 V4: 78–79
  - Risk Guides in value engineering, 2009 V1: 248
  - riveted steel piping, 2010 V2: 75, 78
  - rms (root main square), 2009 V1: 15
  - RNA materials, 2012 V4: 194
  - RO (reverse osmosis). *See* reverse osmosis
  - roadblocks to creativity, 2009 V1: 225
  - rock salt, 2010 V2: 210
  - rod couplings, 2012 V4: 134
  - rod hangers, 2012 V4: 134
  - rod stiffeners, 2012 V4: 124, 134
  - rods and anchors, 2012 V4: 124, 134
  - Roentgens, 2010 V2: 237
  - roll and plate devices, 2012 V4: 134
  - roll grooved joints, 2012 V4: 58
  - roll hangers, 2012 V4: 134
  - roll-in shower compartments, 2009 V1: 110–111
  - roll plates, 2012 V4: 134
  - roll stands, 2012 V4: 134
  - roll trapezes, 2012 V4: 134
  - rollers, 2012 V4: 64, 65, 121
  - roof drainage, 2010 V2: 41
    - as source of plumbing noise, 2009 V1: 188
    - avoiding septic tank disposal, 2010 V2: 147
    - controlled flow systems, 2010 V2: 52–53
    - limited-discharge roof drains, 2011 V3: 250
    - RD abbreviation, 2009 V1: 15
    - roof drain sizes, 2010 V2: 54
    - roof drains, defined, 2009 V1: 27
    - siphonic roof drains, 2010 V2: 53
  - roofing
    - design considerations in seismic protection, 2009 V1: 180
    - imperviousness factors, 2011 V3: 239
    - roof penetrations, 2010 V2: 34
  - roofing tar kettles, 2010 V2: 133
  - root main square (rms), 2009 V1: 15
  - rotary gas meters, 2010 V2: 116–117
  - rotary lobe compressors, 2011 V3: 175
  - rotary lobe (roots) pumps, 2010 V2: 169
  - rotary piston pumps, 2010 V2: 169
  - rotary pop-up sprinklers, 2011 V3: 92, 93
  - rotary screw air compressors, 2011 V3: 62, 175
  - rotary vane, once-through-oil pumps, 2010 V2: 169
  - rotating filters, 2011 V3: 88
  - rotational natural frequencies, 2012 V4: 138
  - rotors in gas boosters, 2010 V2: 125
  - rotting cork, 2012 V4: 139
  - rough-ins
    - checklist, 2009 V1: 95
    - examples of poor quality, 2009 V1: 255
    - roughing in, defined, 2009 V1: 27
    - water closets, 2012 V4: 4
  - rough vacuum, 2010 V2: 165
  - roughness of pipes
    - fairly rough pipe, 2010 V2: 81
    - fairly smooth pipe, 2010 V2: 80
    - laminar flow and, 2010 V2: 74
    - pipe sizing and, 2010 V2: 75–84
    - pipe types and, 2010 V2: 78
    - rough pipe, 2010 V2: 82
    - smooth pipe, 2010 V2: 79
    - types of pipes and, 2010 V2: 75
  - round bowls on water closets, 2012 V4: 3
  - round surfaces, heat loss and, 2012 V4: 110
  - RPBDs. *See* reduced-pressure-principle backflow devices
  - rpm, RPM (revolutions per minute), 2009 V1: 15
  - rps, RPS (revolutions per second), 2009 V1: 15
  - RPZ (reduced pressure zones), 2009 V1: 15, 2010 V2: 60–61, 62–63, 94, 2011 V3: 215, 220
  - RPZ (reduced-pressure-principle backflow devices)
    - costs and locations for, 2012 V4: 168
    - defined, 2012 V4: 165
  - RS. *See* rising stems (RS)
  - RSOs (Radiological Safety Officers), 2010 V2: 238
  - RTRP (reinforced thermosetting resin pipe), 2012 V4: 53
  - rubber
    - noise mitigation, 2009 V1: 190, 194
    - vibration control, 2012 V4: 138
    - vibration insulation, 2012 V4: 139
  - rubber compression gaskets, 2012 V4: 26
  - rubber facing in dry-pipe clappers, 2011 V3: 8
  - rubber gaskets, 2012 V4: 29
  - rubber-in-shear isolators, 2009 V1: 158
  - rubber insulation, 2012 V4: 105, 110
  - rubber isolation devices
    - noise mitigation, 2009 V1: 197–198
    - rubber insulation, 2012 V4: 105, 110
    - with steel spring isolators, 2012 V4: 139–142
    - vibration control, 2012 V4: 138
  - rubble drains (french drains), 2009 V1: 24
  - rules in Function Analysis, 2009 V1: 218
  - running loads, condensate drainage, 2011 V3: 165
  - running traps, 2011 V3: 45
  - runoff
    - imperviousness factor, 2011 V3: 239
    - patterns, 2010 V2: 43
    - Rational Method, 2010 V2: 42–43
    - rational method and, 2011 V3: 238–239
    - Rational method for calculating, 2009 V1: 7
    - volume calculation, commercial sites, 2010 V2: 56
  - runouts, 2009 V1: 27
  - Russell SRTA (Stationary Reflector/Tracking Absorber)
    - system, 2011 V3: 195–196
  - rust
    - as contaminant in air, 2011 V3: 265
    - formation in iron pipes, 2009 V1: 129
    - rusting, defined, 2009 V1: 143
  - RV (pressure-relief valves). *See* pressure-regulating or reducing valves
  - Ryzner stability index (RI), 2010 V2: 196
  - RZBP (reduced zone backflow preventers), 2009 V1: 10
- ## S
- S (entropy), 2009 V1: 34
  - S (siemens), 2009 V1: 34
  - S (soil). *See* soils
  - S (soil sewers), 2009 V1: 8
  - S (conductance), 2009 V1: 34

- s, SEC (seconds), 2009 V1: 33
- s traps (unvented traps), 2011 V3: 45
- sacrificial anodes, 2009 V1: 137
- saddles and rollers, 2012 V4: 64, 119, 121, 134
- saddles for tanks, 2011 V3: 155
- Safe Drinking Water Act of 1974, 2010 V2: 155, 159, 187, 217, 2012 V4: 173, 225
- Safe Handling of Acids, 2010 V2: 246
- safety. *See also* hazards
  - controlled substance spills, 2010 V2: 186
  - flammable and volatile liquids, 2010 V2: 244–246
  - fountains, 2011 V3: 100
  - gas boosters, 2010 V2: 125
  - gas utility controllers and laboratory service panels, 2010 V2: 121
  - gases in septic tanks, 2010 V2: 148
  - hot-water systems, 2010 V2: 97, 111
  - life safety in fire protection, 2011 V3: 1
  - propane, 2010 V2: 131
  - propane tanks, 2010 V2: 132, 133–134
  - quality installations and, 2009 V1: 258–262
  - radioactive waste-drainage systems, 2010 V2: 239
  - Radiological Safety Officers, 2010 V2: 238
  - reflecting pools and, 2011 V3: 100
  - safety factors, defined, 2012 V4: 134
  - sanitary precautions for wells, 2010 V2: 159
  - storm drainage collection systems, 2010 V2: 46
  - swimming pools, 2011 V3: 104–106, 135
  - types of acids, 2010 V2: 230–232
  - vacuum cleaning system issues, 2010 V2: 186
  - water features, 2011 V3: 134
- Safety and Health Regulations for Construction (OSHA 29 CFR 1926)*, 2011 V3: 136
- safety cabinets, 2010 V2: 241
- safety factors, defined, 2012 V4: 134
- safety shut-off devices, 2010 V2: 136
- sal soda. *See* sodium carbonate (soda ash)
- sales tax, in plumbing cost estimation, 2009 V1: 86
- salesmanship in value engineering, 2009 V1: 249
- salt-laden air, 2009 V1: 262
- salt splitting, 2010 V2: 199
- salt water, 2012 V4: 117
- salts. *See also* sodium chloride
  - defined, 2012 V4: 202
  - in distilled water, 2012 V4: 191–192
  - ions in reverse osmosis, 2010 V2: 187
  - in irrigation water, 2011 V3: 91
  - nanofiltration, 2012 V4: 199
  - recycling systems, water softeners, 2012 V4: 189
  - storage, 2012 V4: 189
  - water hardness and, 2012 V4: 176
  - water purity and, 2012 V4: 175
  - water softener consumption, 2012 V4: 187, 189
- samples
  - acid wastes, 2011 V3: 45
  - infectious waste systems, 2010 V2: 242
  - radioactive waste effluent, 2010 V2: 240
- sampling manholes, 2011 V3: 45
- SAN (sanitary sewers), 2009 V1: 8, 28. *See also* sanitary drainage systems
- San Diego Gas & Electric Company, 2009 V1: 128
- San Fernando Earthquake, 2009 V1: 152
- sand filtration
  - drinking water, 2010 V2: 159–160, 218
  - earthquake damage to filters, 2009 V1: 152
  - horizontal pressure sand filters, 2012 V4: 180
  - laboratory water, 2010 V2: 201
  - pure water systems, 2010 V2: 221
  - sand filters defined, 2009 V1: 28
  - sewage treatment, 2010 V2: 145
  - swimming pools, 2011 V3: 110, 114, 117–118
  - vertical pressure sand filters, 2012 V4: 180
- sand points, 2010 V2: 157
- sands
  - graywater irrigation systems and, 2010 V2: 25
  - imperviousness factors, 2011 V3: 239
  - porous soils, 2011 V3: 91, 96
  - in soil texture, 2010 V2: 140
  - storm water infiltration, 2010 V2: 48
- sanistans, 2011 V3: 40
- sanitary building drains. *See also* sanitary drainage systems
  - as source of plumbing noise, 2009 V1: 188
  - cast-iron soil pipe, 2012 V4: 25
- sanitary, defined, 2009 V1: 28
- sanitary drain system pumps, 2012 V4: 98
- sanitary drainage fitting codes, 2009 V1: 44
- sanitary drainage systems
  - alternative disposal methods, 2011 V3: 237
  - alternative systems, 2010 V2: 16–19
  - building sewers (house drains), 2010 V2: 14–15, 2012 V4: 25
  - codes and standards, 2010 V2: 1
  - components, 2010 V2: 8–12, 2011 V3: 225–228
  - connections, 2011 V3: 226, 249
  - defined, 2010 V2: 1
  - drainage loads, 2010 V2: 3
  - drainage structures, 2011 V3: 226–228
  - fittings, 2009 V1: 44
  - fixture discharge characteristics, 2010 V2: 3
  - floor leveling around drains, 2010 V2: 16
  - flow in, 2010 V2: 1–2
  - force main connections, 2011 V3: 234
  - graywater systems and, 2010 V2: 27–28
  - grease interceptors, 2011 V3: 226
  - grease interceptors and, 2012 V4: 154
  - health care facilities, 2011 V3: 42–46
  - joining methods, 2010 V2: 13–14
  - kitchen areas, 2010 V2: 15
  - laboratories, 2011 V3: 43–44
  - materials for, 2010 V2: 13
  - overview, 2011 V3: 225
  - pipes, 2009 V1: 44
  - pneumatic pressures in, 2010 V2: 2–3
  - preliminary information, 2011 V3: 205
  - protection from damage, 2010 V2: 16
  - Provent systems, 2010 V2: 17–18
  - public sewer availability, 2011 V3: 225
  - reduced-size venting, 2010 V2: 18–19
  - sample letters, 2011 V3: 225
  - sanitary sewers (SAN, SS), 2009 V1: 8, 28
  - sanitation and cleaning, 2010 V2: 15
  - self-cleansing velocities, 2010 V2: 7
  - sewage lift stations, 2011 V3: 228–237

- single-stack systems, 2010 V2: 18
- sizing, 2011 V3: 224, 225
- sloping drain capacities, 2010 V2: 5–8
- Solvent systems, 2010 V2: 17–18
- stack capacities, 2010 V2: 3–5
- supports, 2010 V2: 12
- thermal expansion, 2010 V2: 16
- trenching and bedding, 2011 V3: 225–226, 227
- vacuum drainage systems, 2010 V2: 19
- waterproofing, 2010 V2: 15–16
- sanitary fixture units (SFU), 2009 V1: 15
- sanitary joints, 2011 V3: 48–49
- sanitary sewer pipe codes, 2009 V1: 44
- sanitary sewer systems. *See* sanitary drainage systems
- sanitary tees
  - flow capacity and, 2010 V2: 4
  - water closet installation, 2012 V4: 5
- sanitaryware. *See* fixtures
- sanitation. *See also* cleanouts
  - feed water, 2010 V2: 195
  - fixture materials and, 2012 V4: 1
  - floor drains, 2012 V4: 17
  - precautions for wells, 2010 V2: 159
  - sanitary seals on wells, 2010 V2: 156
  - stainless steel piping, 2012 V4: 56
  - water softeners, 2010 V2: 211
- sanitizer levels, swimming pools, 2011 V3: 127
- sanitizers/oxidizers
  - feed system, 2011 V3: 130–131
  - hospitals, 2011 V3: 40
  - ozone system, 2011 V3: 133–134
  - UV system, 2011 V3: 133–134
- Sansone, John T., 2010 V2: 55
- SARA Title III Act (Superfund Amendment and Reauthorization Act of 1986), 2011 V3: 137
- sasol, 2010 V2: 114
- sat., SAT (saturation). *See* saturation
- saturated air and vapor mixtures, 2011 V3: 187, 265
- saturated steam
  - defined, 2011 V3: 157–158
  - pressure, 2011 V3: 159–161
  - valve ratings, 2012 V4: 78
- saturated vapor pressure, 2011 V3: 187
- saturation (sat., SAT)
  - defined, 2011 V3: 187
  - of soils, 2010 V2: 141
  - of water with calcium carbonate, 2010 V2: 196
- saturation pressure, 2011 V3: 187
- SAVE (Society of American Value Engineering), 2009 V1: 207
- sawcutting trenches, labor productivity rates, 2009 V1: 87
- Saybolt Seconds Furol (ssf, SSF), 2011 V3: 137
- Saybolt Seconds Universal (ssu, SSU), 2011 V3: 137
- SBR (styrene butadiene), 2009 V1: 32
- SC (sillcocks), 2009 V1: 15
- scalars, defined, 2009 V1: 85
- scalding water, 2010 V2: 97, 111, 2012 V4: 112
- scale and scale formation
  - boilers, 2010 V2: 215
  - chlorides and sulfates, 2010 V2: 190
  - cooling towers, 2010 V2: 217
  - distilled water and, 2012 V4: 191–192
  - fixtures and appliances, 2012 V4: 185
  - hardness and, 2010 V2: 189, 2012 V4: 176
  - impure water and, 2012 V4: 173–174
  - Langelier saturation index, 2010 V2: 196
  - magnesium and, 2010 V2: 190
  - predicting water deposits and corrosion, 2010 V2: 196–197
  - removing with water softening, 2010 V2: 210
  - Ryzner stability index, 2010 V2: 196
  - in stills, 2012 V4: 192
  - temperature and, 2012 V4: 185
  - total dissolved solids and, 2010 V2: 193
  - water deposits and corrosion, 2010 V2: 195–196
  - water piping systems, 2010 V2: 160
- scale plates, 2012 V4: 134
- scanning electron microscopy, 2010 V2: 188. *See also* electron microscopes
- scavenging adapters, 2011 V3: 66
- scfh (standard cfh), 2010 V2: 126
- scfm, SCFM (standard cubic feet per minute)
  - ambient free air and, 2010 V2: 166
  - compressed air pipe sizing, 2011 V3: 183
  - compressed air tools, 2011 V3: 180
  - defined, 2011 V3: 78, 187
  - medical air compressors, 2011 V3: 62
  - medical vacuum systems, 2011 V3: 64
  - sizing gas systems, 2011 V3: 269
- scfs, SCFS (cubic feet per second), 2009 V1: 34
- Schedule 10 steel pipe, 2012 V4: 37
- Schedule 40 ABS pipe, 2012 V4: 51
- Schedule 40 plastic pipe, 2012 V4: 59
- Schedule 40 polypropylene pipe, 2012 V4: 51
- Schedule 40 polyvinyl pipe, 2012 V4: 49
- Schedule 40 PVC plastic, 2011 V3: 13, 2012 V4: 49
- Schedule 40 PVDF pipe, 2012 V4: 52
- Schedule 40 steel pipe, 2012 V4: 44–45
- Schedule 80 ABS pipe, 2012 V4: 51
- Schedule 80 CPVC plastic pipe, 2012 V4: 193
- Schedule 80 plastic pipe, 2012 V4: 59
- Schedule 80 polypropylene pipe, 2012 V4: 51
- Schedule 80 polyvinyl pipe, 2012 V4: 49
- Schedule 80 PVC plastic, 2012 V4: 49
- Schedule 80 PVDF pipe, 2012 V4: 52
- Schedule 80 steel pipe, 2012 V4: 46–47
- schedules (pipe size), 2009 V1: 28
- schedules (project)
  - checklist, 2009 V1: 94–95
  - section in specifications, 2009 V1: 64, 70, 72
- school laboratories. *See* laboratories
- schools
  - hot water demand, 2010 V2: 99
  - laboratory gas systems, 2010 V2: 121
  - numbers of fixtures for, 2012 V4: 20, 22
  - septic tank systems for, 150, 2010 V2: 149
  - shower room grates, 2010 V2: 11
  - swimming pools and, 2011 V3: 108
  - vacuum calculations for, 2010 V2: 180
  - water consumption, 2012 V4: 187, 223
- Schueler, Thomas R., 2010 V2: 55
- scope lines, 2009 V1: 219
- scoring pipes and equipment, 2012 V4: 173
- screening

- in graywater treatment, 2010 V2: 25
  - vacuum exhaust piping, 2010 V2: 184
- screw compressors, 2011 V3: 175, 177
- screw pumps, 2010 V2: 169
- screwed bonnets, 2012 V4: 79, 89
- screwed ells, 2010 V2: 93
- screwed ends of valves, 2012 V4: 79
- screwed fittings, 2009 V1: 152
- screwed-lug type valves, 2012 V4: 76
- screwed mechanical joints, 2010 V2: 232
- screwed tees, 2010 V2: 93
- screwed union-ring bonnets, 2012 V4: 79
- scrub-up sinks, 2011 V3: 36, 38, 40
- scum in septic tanks, 2010 V2: 145
- scuppers, 2009 V1: 28, 2010 V2: 52
- SCW (soft cold water), 2009 V1: 8
- SD (storm or rainwater drains). *See* storm-drainage systems
- SDI (service deionization), 2012 V4: 182
- SDI (silt density index), 2010 V2: 194
- SDR (standard dimension ratio)
  - abbreviation for, 2009 V1: 15
  - HDPE pipe, 2012 V4: 42
  - PP-R pipe, 2012 V4: 52
  - SDR21 PVC pipe, 2012 V4: 49
  - SDR26 PVC pipe, 2012 V4: 49
- SE (sea level). *See* sea level
- sea level (sl, SL, SE)
  - atmospheric pressure, 2011 V3: 186
  - barometric pressure, 2011 V3: 172
  - vacuum ratings, 2010 V2: 166
- sealed sprinklers, 2011 V3: 8
- sealing grouts in wells, 2010 V2: 158
- seals
  - butterfly valve seals, 2012 V4: 84
  - elastomeric seals or gaskets, 2012 V4: 207
  - flashing rings, 2010 V2: 11
  - floor drains in infectious waste systems, 2010 V2: 242
  - pumps, 2012 V4: 91, 92
  - seal liquids in vacuum pumps, 2010 V2: 170
  - trap seals in floor drains, 2010 V2: 11
  - water closets, 2012 V4: 5
  - well fixtures, 2010 V2: 158
- seamless copper pipe, 2012 V4: 29–30
- seamless copper water tube, 2012 V4: 29–40
- seamless steel piping, 2012 V4: 37
- seasonal flow rates, 2012 V4: 186
- seats
  - accessible shower compartments, 2009 V1: 112
  - bathtub and shower seats, 2009 V1: 109, 114–115
  - seat fouling tests, 2012 V4: 5
  - toilets, 2009 V1: 108
  - water closets, 2012 V4: 4–5
- seats (valves)
  - seat erosion, 2012 V4: 74
  - seat tests, 2012 V4: 87
- seawater, 2009 V1: 141
- second-guessing designs, 2009 V1: 208
- second-stage propane regulators, 2010 V2: 132–133
- secondary containment
  - of hazardous wastes, 2011 V3: 84
  - of infectious wastes, 2010 V2: 240
- secondary containment tanks
  - aboveground types, 2011 V3: 147–148
  - interstitial monitoring, 2011 V3: 143
  - interstitial spaces, 2011 V3: 139
  - underground tanks, 2011 V3: 139
- secondary functions, 2009 V1: 219, 223
- secondary gas regulators, 2010 V2: 121
- secondary pipe liquid monitoring, 2011 V3: 145
- secondary pipe vapor monitoring, 2011 V3: 145
- secondary roof drains, 2009 V1: 28
- secondary storm-drainage systems
  - controlled-flow systems, 2010 V2: 52–53
  - planning for in design, 2010 V2: 52
  - scuppers, 2010 V2: 52
- seconds (s, SEC), 2009 V1: 33
- Seconds Redwood, 2011 V3: 137
- Seconds Saybolt Furol (SSF), 2011 V3: 137
- Seconds Saybolt Universal (SSU), 2011 V3: 137
- section modulus, 2012 V4: 205
- Sectionformat, 2009 V1: 59, 62–65
- sections
  - in *Manual of Practice*, 2009 V1: 68–72
  - MasterFormat 2004, 2009 V1: 59–60
  - of pump equipment, 2010 V2: 161
  - in specifications, 2009 V1: 62–65
- security of oxygen storage areas, 2011 V3: 59
- sediment
  - removing, 2010 V2: 198–199
  - in water, 2010 V2: 188
- sediment buckets
  - kitchen drains, 2010 V2: 15–16
  - materials, 2010 V2: 13
  - in oil collectors, 2010 V2: 12
  - in sanitary drainage systems, 2010 V2: 11
- sedimentation
  - bioremediation systems, 2012 V4: 228
  - in graywater treatment, 2010 V2: 25
  - turbidity and, 2012 V4: 175
  - in water treatment, 2010 V2: 198–199
- seepage beds. *See* soil-absorption sewage systems
- seepage flanges, 2010 V2: 15–16
- seepage pits, 2009 V1: 28, 2010 V2: 25, 2011 V3: 237
- seiches, 2009 V1: 149
- seismic, defined, 2009 V1: 185
- seismic control devices, 2009 V1: 190, 2012 V4: 134
- seismic design categories, 2009 V1: 157
- Seismic Design for Buildings*, 2009 V1: 174, 185
- seismic forces, hangers and supports, 2012 V4: 65, 117
- seismic joints, crossing, 2009 V1: 152
- seismic loads, 2012 V4: 134
- seismic protection
  - calculating seismic forces, 2009 V1: 179–180
  - causes and effects of earthquakes, 2009 V1: 148–149
  - codes and standards, 2009 V1: 147, 174
  - computer analysis of piping systems, 2009 V1: 180
  - damage from earthquakes, 2009 V1: 149
  - design considerations, 2009 V1: 180–182
  - earthquake measurement and seismic design, 2009 V1: 151–152
  - equipment protection, 2009 V1: 153–158
  - glossary, 2009 V1: 185
  - introduction, 2009 V1: 145–148

- learning from past earthquakes, 2009 V1: 152–153
- pipe restraints, 2009 V1: 158–179, 2010 V2: 12, 16, 2011 V3: 18
- plumbing equipment, 2009 V1: 262
- potential problems, 2009 V1: 183
- references, 2009 V1: 185
- seismic loads, defined, 2009 V1: 145
- seismic risk maps, 2009 V1: 145–146
- underground storage tanks and, 2011 V3: 138
- Seismic Restraint Manual Guidelines for Mechanical Systems*, 2009 V1: 185
- selective attack corrosion, 2009 V1: 131–132
- selective surfaces, 2011 V3: 191
- selectivity coefficients, 2010 V2: 205
- self-bracing problems in seismic protection, 2009 V1: 184
- self-cleansing velocities, 2010 V2: 7
- self-closing valves, 2011 V3: 35
- self-contained breathing units, 2010 V2: 229, 231
- self-contained fountains, 2011 V3: 98
- self-extinguishing, defined, 2009 V1: 28
- self-jetting well points, 2010 V2: 157
- self-metering faucets, 2012 V4: 12
- self-priming pumps, 2011 V3: 110, 122
- self-regulating heat-trace systems, 2010 V2: 105–106
- self-scouring velocity in sewers, 2011 V3: 225
- self-siphonage, 2010 V2: 2
- self-venting in Provent systems, 2010 V2: 17–18
- self-venting in Sovent systems, 2010 V2: 17–18
- selling functions, 2009 V1: 218
- SEMI (Semiconductor Equipment Manufacturers Institute), 2010 V2: 187, 218
- semi-ambulatory individuals
  - semi-ambulatory disabilities, 2009 V1: 99
  - water closet requirements, 2009 V1: 108
- semi-automatic grease interceptors, 2012 V4: 151
- semi-circular lavatories, 2012 V4: 10
- semi-engineered drawings, 2012 V4: 134
- semi-engineered hanger assemblies, 2012 V4: 134
- semi-instantaneous water heaters, 2010 V2: 104
- semi-permeable membranes, 2011 V3: 48, 2012 V4: 196
- semi-recessed water coolers, 2012 V4: 218
- semiautomatic changeover manifolds, 2011 V3: 271
- semiautomatic dry standpipe systems, 2011 V3: 20
- Semiconductor Equipment and Materials International, 2010 V2: 187, 218
- Sendelbach, M.G., 2010 V2: 225
- seniors. *See* elderly
- sensible heat (SH)
  - defined, 2009 V1: 128, 2011 V3: 157
  - heat transfer efficiency and, 2011 V3: 162
- sensitivity in pressure-regulated valves, 2010 V2: 94
- sensors
  - corrosive-waste systems, 2011 V3: 43
  - faucet controls, 2009 V1: 128
  - flow, swimming pools, 2011 V3: 114–115, 124–125
  - grease removal devices, 2012 V4: 151–152
  - hazardous material level sensors, 2011 V3: 84
  - level-sensing, swimming pools, 2011 V3: 131–132
  - line-pressure sensors, 2011 V3: 67
  - liquid fuel leakage, 2011 V3: 145
  - pH sensors, 2011 V3: 44
  - pressure sensors, 2010 V2: 63
  - separating systems
    - for acid waste, 2010 V2: 229, 235
    - bioremediation pretreatment systems, 2012 V4: 230
    - FOG bioremediation systems, 2012 V4: 228
    - grease interceptors, 2012 V4: 146–148
    - for oil, 2010 V2: 245–246
  - separator/filters in air compressors, 2011 V3: 178, 180
  - separators, grease, 2012 V4: 151
  - separators in vacuum cleaning systems
    - kinds of materials, 2010 V2: 184
    - location, 2010 V2: 181
    - pressure loss, 2010 V2: 184
    - types of systems, 2010 V2: 178–179
  - septic tanks
    - biological treatment of sewage in, 2010 V2: 145
    - chemicals in, 2010 V2: 147
    - cleaning, 2010 V2: 148
    - clogging materials, 2010 V2: 147–148
    - compartments, 2010 V2: 147
    - defined, 2009 V1: 28
    - estimating sewage quantities, 2010 V2: 150–152
    - grease interceptors, 2010 V2: 147
    - institutional and recreational establishments, 2010 V2: 149–150
    - percolation rates and, 2010 V2: 153
    - sanitary sewers and, 2011 V3: 237
    - sizing, 2010 V2: 146
    - solids removal, 2010 V2: 145
    - specifications, 2010 V2: 145–147
    - venting, 2010 V2: 148
  - septum filters, 2010 V2: 218
  - sequence
    - of project phases, cost estimates and, 2009 V1: 90
    - section in specifications, 2009 V1: 64, 70
  - sequential functions in FAST approach, 2009 V1: 221–223
  - series of pumps, 2012 V4: 97, 101
  - series water conditioning equipment, 2012 V4: 186
  - service cocks, 2010 V2: 91
  - service conditions, defined, 2012 V4: 134
  - service connections for water piping, 2012 V4: 67
  - service deionization, 2010 V2: 208–209
  - service deionization (SDI), 2012 V4: 182
  - service factors, 2009 V1: 28
  - service flow rates for water softeners, 2012 V4: 185
  - service gaskets, 2012 V4: 57
  - service hot water, 2009 V1: 28
  - service runs, defined, 2012 V4: 202
  - service sinks, 2010 V2: 86, 99
    - abbreviations, 2009 V1: 15
    - defined, 2012 V4: 12
    - noise mitigation, 2009 V1: 199
    - required fixtures, 2012 V4: 20–23
  - Service Station Tankage Guide (API 1611)*, 2011 V3: 156
  - service stations, 2011 V3: 147
  - service valves, propane tanks, 2010 V2: 133
  - service water heating, solar, 2011 V3: 196–199
  - service-weight cast-iron soil pipe, 2012 V4: 25, 28
  - services
    - costs, 2009 V1: 210
    - ongoing and one-time costs, 2009 V1: 217
  - set pressure in pressure-regulated valves, 2010 V2: 94, 106

- settlement. *See* bedding and settlement; creep; sedimentation
- settling tanks, 2011 V3: 88, 2012 V4: 179
- settling velocity, 2012 V4: 146
- severe backflow hazards, 2011 V3: 215
- sewage, defined, 2009 V1: 28. *See also* effluent
- sewage effluent. *See* effluent
- sewage ejectors, 2009 V1: 28, 2011 V3: 228, 2012 V4: 98
- sewage lift stations, 2011 V3: 228–236
  - flow rates, 2011 V3: 236
  - force mains, 2011 V3: 236
  - overview, 2011 V3: 228–229
  - pipes, 2011 V3: 236
  - required head, 2011 V3: 229
  - sewage pumps, 2011 V3: 229
  - storage basins, 2011 V3: 235–236
  - vacuum and pressure venting, 2011 V3: 236–237
  - velocity in pipes, 2011 V3: 236
- sewage pumps, 2012 V4: 98–99
- sewage systems. *See* sewer systems
- sewage treatment plants, 2010 V2: 27–28
- sewer gas, 2010 V2: 114
- sewer mains, 2012 V4: 29
- sewer systems. *See also* building sewers; private onsite wastewater treatment systems (POWTS); public sewers; soil-absorption sewage systems; specific types of sewers
  - combined systems, 2011 V3: 249
  - direct connection hazards, 2012 V4: 161
  - discharge from laboratories, 2011 V3: 43–44
  - preliminary information, 2011 V3: 205
  - sample sewer services letter, 2011 V3: 260
  - sanitary sewer systems, 2011 V3: 225–237. *See also* sanitary drainage systems
  - sewer manholes, 2012 V4: 161
  - sewer video equipment, 2010 V2: 10
  - storm sewers, 2011 V3: 237–243
- SFU (sanitary fixture units), 2009 V1: 15
- SG. *See* specific gravity (SG)
- SH (sensible heat), 2009 V1: 128
- SH (showers). *See* showers
- shaking vacuum filter bags, 2010 V2: 179
- shallow-end depth of swimming pools, 2011 V3: 107
- shallow fill, building sewers and, 2010 V2: 14
- shallow manholes, 2011 V3: 228, 232
- shallow wells, 2010 V2: 155, 156, 162
- shapes of swimming pools, 2011 V3: 108
- shear lugs, 2012 V4: 134
- shear motions, preventing, 2009 V1: 153, 183, 184
- sheet copper, 2012 V4: 16
- sheet flows, 2011 V3: 242
- sheet lead, 2012 V4: 16
- Sheet Metal and Air Conditioning Contractors' National Association (SMACNA), 2009 V1: 160, 185
- Sheet Metal Industry Fund, 2009 V1: 185
  - Guidelines for Seismic Restraints of Mechanical Systems*, 2009 V1: 180
- shell-and-coil compressors, 2012 V4: 221
- shell-and-tube condensers, 2012 V4: 221
- shell-and-tube heat exchangers, 2009 V1: 123, 2011 V3: 167–169
- shell tests, 2012 V4: 87
- shelving
  - accessibility in toilet and bathing rooms, 2009 V1: 105
  - ambulatory accessible toilet compartments, 2009 V1: 107
- shielded hubless coupling, 2012 V4: 57
- shielding on radioactive drainage systems, 2010 V2: 238
- shields. *See* protection shields
- Shigella, 2010 V2: 43
- shine. *See* radiation
- shipping costs, 2009 V1: 90, 217
- shock absorbers. *See* water hammer arresters
- shock absorbers, cork as, 2012 V4: 139
- shock arrestors in noise mitigation, 2009 V1: 192
- shock intensity of water hammer, 2010 V2: 71
- Sholes, Christopher, 2009 V1: 225
- shopping centers, 2010 V2: 24. *See also* retail stores
- shops. *See* retail stores
- short circuiting in grease interceptors, 2012 V4: 150
- short-circuiting installations, 2009 V1: 140
- shot-in concrete anchors, 2009 V1: 154, 184
- shower pans, 2012 V4: 16
- shower valves
  - flow rates, 2012 V4: 16
  - installation, 2012 V4: 16
  - types, 2012 V4: 16
- showerheads
  - LEED 2009 baselines, 2010 V2: 25
  - low flow, 2009 V1: 127
  - noise mitigation, 2009 V1: 194, 200
  - poor installation of, 2009 V1: 255
  - poor installations of, 2009 V1: 257
  - scaling, 2010 V2: 111
  - wasted water, 2009 V1: 127
  - water usage reduction, 2012 V4: 236
- showers
  - abbreviation for, 2009 V1: 15
  - body sprays, 2012 V4: 16
  - emergency showers, 2010 V2: 229, 231, 2012 V4: 17–18
  - enclosures, 2009 V1: 112
  - fixture pipe sizes and demand, 2010 V2: 86
  - fixture-unit loads, 2010 V2: 3
  - flow rates, 2012 V4: 13
  - grab bars, 2009 V1: 112–114
  - grates in school shower rooms, 2010 V2: 11
  - graywater supply and demand, 2010 V2: 24
  - graywater systems, 2009 V1: 126
  - health care facilities, 2011 V3: 36, 40
  - hot water demand, 2010 V2: 99
  - hydrotherapy, 2011 V3: 38
  - labor rooms, 2011 V3: 39
  - minimum numbers of, 2012 V4: 20–23
  - noise mitigation, 2009 V1: 198, 201
  - patient rooms, 2011 V3: 37
  - pressure reducing balancing valves and, 2010 V2: 62–63
  - public areas in health care facilities, 2011 V3: 37
  - rates of sewage flows, 153, 2010 V2: 152
  - reduced water usage, 2009 V1: 118
  - reducing flow rates, 2009 V1: 126
  - requirements, 2012 V4: 13–16
  - seats, 2009 V1: 114–115
  - shower compartment accessibility, 2009 V1: 110–112
  - spray units, 2009 V1: 109–110, 112
  - standards, 2012 V4: 2

- swimming pool bathhouses, 2011 V3: 110
- swimming pool facilities, 2011 V3: 109
- thresholds, 2009 V1: 112
- water fixture unit values, 2011 V3: 206
- Shreir, L.L., 2009 V1: 144
- shrinkage of ceramic fixtures, 2012 V4: 1
- shrub sprinkler heads, 2011 V3: 94
- Shumann, Eugene R., 2010 V2: 55
- shut-off devices
  - defined, 2010 V2: 136
  - fuel dispensers, 2011 V3: 146
  - gas cabinets, 2011 V3: 270
  - laboratory gas systems, 2011 V3: 274
- shut-off valves
  - earthquake-sensitive valves, 2009 V1: 153
  - medical gases, 2011 V3: 66–67
- shutdown pump features, 2010 V2: 63
- shutdown relays, 2011 V3: 28
- shutoff NPSH, 2012 V4: 101
- Shweitzer, Philip A., 2011 V3: 89
- SI units. *See* International System of Units
- siamese fire-department connections, 2009 V1: 12, 28. *See also* fire-protection systems
- side-beam brackets, 2012 V4: 134
- side-beam clamps, 2012 V4: 134
- side reach for wheelchairs, 2009 V1: 99–101, 104
- side spray accessories, 2012 V4: 11, 13
- sidesway prevention, 2009 V1: 183
- sidewalk fire-department connections, 2009 V1: 12
- sidewall areas, 2009 V1: 28
- sidewall grab bars, 2009 V1: 106
- sidewall sprinklers, 2009 V1: 13, 29
- Siegrist, R., 2010 V2: 29
- siemens, 2009 V1: 34
- sight disabilities, 2009 V1: 99
- signals for fire alarms, 2011 V3: 6
- significant digits, 2009 V1: 33
- significant movement, 2012 V4: 134
- sil-fos solder, 2012 V4: 79
- silencers
  - on air compressors, 2011 V3: 175
  - on vacuum systems, 2010 V2: 179
- silica, 2010 V2: 190, 2012 V4: 182
- silica gel, 2011 V3: 179
- silicates, 2010 V2: 189, 2012 V4: 197
- silicon, 2010 V2: 189
- silicon iron piping, 2010 V2: 14, 2012 V4: 53
- sill cocks, 2009 V1: 15
- silt
  - content of water, 2011 V3: 91
  - loams, 2011 V3: 91
  - removing, 2010 V2: 198–199
  - silt density index, 2010 V2: 194
  - in soil texture, 2010 V2: 140
  - in water, 2010 V2: 188
- silt density index (SDI), 2010 V2: 194
- silver, 2009 V1: 129, 132
- silver solder, 2009 V1: 132, 2012 V4: 79
- A Simple Method for Retention Basin Design*, 2010 V2: 55
- simplex gas booster systems, 2010 V2: 119, 120
- simultaneous operators of vacuum systems, 2010 V2: 180, 183
- simultaneous-use factors. *See* diversity factor
- sine wave configurations of pipe, 2012 V4: 208
- single. *See also* headings beginning with “one-”, “mono-”, etc.
- single-acting altitude valves, 2010 V2: 163
- single-acting cylinders in compressors, 2011 V3: 174
- single-acting devices, 2012 V4: 134
- single-compartment septic tanks, 2010 V2: 147
- single-compartment sinks, 2012 V4: 11
- single-degree-of-freedom systems, 2009 V1: 150
- single-effect stills, 2012 V4: 192
- single-occupant toilet rooms, 2012 V4: 21
- single pipe rolls, 2012 V4: 134
- single-seated pressure-regulated valves, 2010 V2: 69–70
- single-stack systems, 2010 V2: 18
- single stacks, 2010 V2: 39
- single-stage distillation, 2010 V2: 200
- single-stage gas regulators, 2011 V3: 272
- single-step deionization (mixed bed), 2010 V2: 206, 208
- single-wall tanks, 2011 V3: 139
- sink-disposal units. *See* food waste grinders
- sinks and wash basins. *See also* lavatories
  - accessibility, 2009 V1: 108–109
  - faucets, 2012 V4: 12–13
  - fixture pipe sizes and demand, 2010 V2: 86
  - fixture-unit loads, 2010 V2: 3
  - food-preparation, 2011 V3: 39
  - general category of, 2012 V4: 12
  - graywater and, 2010 V2: 23–24, 2012 V4: 238
  - health care facilities, 2011 V3: 36, 40
  - hot water demand, 2010 V2: 99
  - infectious waste drainage, 2010 V2: 241
  - kitchen sinks, 2012 V4: 10–12
  - laboratory rooms, 2011 V3: 41
  - laboratory sink drainage rates, 2010 V2: 235
  - laundry sinks, 2012 V4: 12
  - neutralizing acid from, 2010 V2: 235
  - noise mitigation, 2009 V1: 193, 197, 198
  - pharmacies and drug rooms, 2011 V3: 38
  - poor installations of, 2009 V1: 257
  - public areas in health care facilities, 2011 V3: 35
  - rates of sewage flows, 2010 V2: 153
  - service sinks, 2012 V4: 12
  - standards, 2012 V4: 2
  - surgical scrub-up areas, 2011 V3: 38
  - traps and acid wastes, 2011 V3: 45–46
  - water fixture unit values, 2011 V3: 206
- sintered metal filters, 2011 V3: 273
- SIP (steam in place), 2011 V3: 277
- siphon jet urinals, 2012 V4: 8
- siphon jet water closets, 2012 V4: 2
- siphonage. *See* back-siphonage
- Siphonic Roof Drainage*, 2010 V2: 55
- siphonic roof drains, 2010 V2: 53
- Siphonic Roof Drains*, 2010 V2: 55
- siphons in secondary containment areas, 2011 V3: 84
- site coefficients in seismic force calculations, 2009 V1: 174–177
- site storm drainage, 2009 V1: 7
- site utilities
  - domestic water supply, 2011 V3: 206–208, 259
  - fire-protection water supply, 2011 V3: 218–225
  - natural gas services, 2011 V3: 251–257, 261



- off-peak power savings, 2009 V1: 119
- overview, 2011 V3: 205
- preliminary information, 2011 V3: 205
- sample general notes, 2011 V3: 258
- sanitary sewer services, 2011 V3: 224–237, 260
- storm sewers, 2011 V3: 237–243, 260
- swimming pool locations and, 2011 V3: 107
- sites
  - geological stability of, 2010 V2: 24
  - irrigation system plans, 2011 V3: 96
  - obtaining plans, 2011 V3: 205
- sitz baths, 2010 V2: 99, 2011 V3: 36, 40
- Six Sticks exercise, 2009 V1: 225, 252
- Sixth National Symposium on Individual and Small Community Sewage Systems, 2010 V2: 55
- sizing
  - acid-neutralization tanks, 2011 V3: 44
  - acid-waste drainage system pipes, 2010 V2: 235
  - air compressors, 2011 V3: 63, 174–176
  - air receivers, 2011 V3: 177–178
  - bioremediation pretreatment systems, 2012 V4: 229, 230
  - centralized drinking-water coolers, 2012 V4: 222, 223–224
  - clean agent gas pipes, 2011 V3: 28
  - cleanouts, 2010 V2: 9–10
  - cold-water system pipes, 2010 V2: 73–90, 75–84
  - compressed air piping, 2011 V3: 177, 183
  - conveyance piping, storm drainage, 2010 V2: 47
  - corrugated steel gas piping systems, 2010 V2: 123
  - cryogenic tanks, 2011 V3: 59
  - distillation systems, 2012 V4: 193
  - domestic water heaters, 2010 V2: 98–99
  - elevated water tanks, 2010 V2: 65–66, 68
  - expansion tanks, 2012 V4: 209, 212
  - floor drains, 2010 V2: 10–11
  - gas boosters, 2010 V2: 127–128
  - gas line filters, 2011 V3: 254
  - gas meters, 2011 V3: 254
  - gas piping, 2009 V1: 7
  - gas regulators, 2011 V3: 255
  - grab bars, 2009 V1: 112
  - grease interceptors, 2012 V4: 155–156
  - high-pressure condensate piping, 2011 V3: 166
  - hot-water circulation systems, 2010 V2: 105
  - hydropneumatic tanks, 2010 V2: 64–66
  - irrigation, 2011 V3: 92
  - laboratory gas systems, 2011 V3: 269, 275–276, 277–280
  - liquefied petroleum gas systems, 2010 V2: 135
  - liquid fuel piping, 2011 V3: 150–151
  - medical air compressors, 2011 V3: 63
  - medical gas systems, 2011 V3: 50, 68–69, 70, 71
  - medical vacuum systems, 2011 V3: 64, 70
  - natural gas piping, 2010 V2: 123, 126, 128–131, 130–131, 2011 V3: 256
  - nitrogen gas systems, 2011 V3: 64, 70
  - nitrous oxide systems, 2011 V3: 60, 61, 70, 71
  - nominal pipe size, 2010 V2: 165
  - oxygen systems, 2011 V3: 60, 70, 71
  - pipe examples for cold-water systems, 2010 V2: 87–89
  - pressure and, 2010 V2: 78–84
  - pressure and temperature relief valves, 2010 V2: 106
  - pressure-regulated valves, 2010 V2: 69–70
  - project size and cost estimates, 2009 V1: 89
  - review of pipe procedures, 2010 V2: 84–87
  - roof drainage systems, 2010 V2: 51, 53–54
  - sanitary sewer systems, 2011 V3: 224, 225
  - septic tanks, 2010 V2: 146
  - sewage life station pipes, 2011 V3: 236
  - soil absorption systems, 2010 V2: 143
  - solar energy systems, 2011 V3: 193, 196–199
  - special-waste system pipes, 2010 V2: 228, 229, 230, 231
  - sprinkler system pipes, 2011 V3: 13, 14
  - standpipe systems, 2011 V3: 21
  - steam distribution piping, 2011 V3: 159–161
  - storm drainage systems, 2010 V2: 53–54, 54
  - storm sewers, 2011 V3: 243–249
  - storm water ditches, 2011 V3: 250
  - submersible pumps, 2011 V3: 146, 151–152
  - swimming pools, 2011 V3: 106–107
  - toilet compartments, 2009 V1: 105–106
  - vacuum system receivers, 2010 V2: 170
  - vacuum systems, 2010 V2: 174–178
    - exhaust, 2011 V3: 65
    - pumps, 2011 V3: 65
    - vacuum cleaning inlets, tools, and tubing, 2010 V2: 180
    - vacuum cleaning piping network, 2010 V2: 181–183
    - vacuum cleaning system separators, 2010 V2: 186
    - vacuum exhaust pipes, 2010 V2: 178
    - vacuum piping, 2010 V2: 174–176, 2011 V3: 73
    - vacuum producers (exhausters), 2010 V2: 184
    - vacuum pumps, 2010 V2: 176
  - valves, 2012 V4: 83
  - velocity and, 2010 V2: 76–78
  - vents, 2010 V2: 35–37
  - vertical stacks, 2010 V2: 5
  - water hammer arresters, 2010 V2: 72–73
  - water mains, 2011 V3: 6
  - water meters, 2010 V2: 60–61
  - water-pressure regulators, 2012 V4: 82
  - water softeners, 2012 V4: 186, 188, 190
  - water storage tanks, 2010 V2: 162
  - wells, 2010 V2: 156
- sketches. *See also* plumbing drawings
  - costs analysis phase, 2009 V1: 234
  - function evaluation, 2009 V1: 232–233
  - functional development, 2009 V1: 246
- skimmers
  - FOG separation, 2012 V4: 228
  - fountains, 2011 V3: 102
  - grease interceptors, 2012 V4: 151
  - skimming trays, 2012 V4: 151
  - surge capacity, 2011 V3: 111–112
  - swimming pools, 2011 V3: 114, 117
- skimming oils, 2011 V3: 88
- sl, SL (sea level), 2010 V2: 166
- slabs, in radioactive waste systems, 2010 V2: 240
- slack cables in earthquake protection, 2009 V1: 158
- slaughterhouses, 2010 V2: 15
- sleepers, 2012 V4: 134
- sleeves, pipe, 2012 V4: 123–125
- slide plates, 2012 V4: 134
- slides, 2011 V3: 134
- sliding motions

- preventing for pipes or equipment, 2009 V1: 153
- of seismic plates, 2009 V1: 148
- sliding stems on valves, 2012 V4: 79
- sliding supports, 2012 V4: 134
- sliding vane compressors, 2011 V3: 175, 177
- sliding vane pumps, 2010 V2: 173
- slime, 2010 V2: 195, 2012 V4: 177
- slime bacteria, 2010 V2: 188
- slip, defined, 2011 V3: 187, 2012 V4: 101
- slip expansion joints, 2012 V4: 207
- slip fittings, 2012 V4: 134
- slip joints, 2009 V1: 28
- slip-resistant bases in baths, 2012 V4: 16
- slip RPM, defined, 2011 V3: 187
- slip type couplings, 2012 V4: 63
- slop sinks, 2012 V4: 161
- slope
  - of ditches, 2011 V3: 250
  - of floors, 2011 V3: 110
  - of sewers, 2011 V3: 224
  - of sites, 2010 V2: 42, 2011 V3: 96, 242
- sloping drains
  - fixture loads, 2010 V2: 6, 8–9
  - Manning formula, 2009 V1: 1
  - minimum slope of piping, 2010 V2: 6
  - sanitary drainage systems, 2010 V2: 5–8
  - self-cleansing velocities, 2010 V2: 7
  - steady flow in, 2010 V2: 6
- slow sand filtration, 2010 V2: 218
- sludge
  - activated sludge systems, 2011 V3: 88
  - defined, 2009 V1: 28, 2010 V2: 195
  - from water softeners, 2010 V2: 160
  - removal, 2011 V3: 88
  - in septic tanks, 2010 V2: 145
- slugs of water, 2010 V2: 2, 3
- slurry feed system, diatomaceous earth, 2011 V3: 120
- SMACNA (Sheet Metal and Air Conditioning Contractors' National Association), 2009 V1: 160, 185
- small bore pipes, 2010 V2: 239
- small-diameter gravity sewers, 2010 V2: 144
- smoke
  - requirements for insulation, 2012 V4: 104
  - vacuum systems and, 2011 V3: 64
- smoke detectors, 2009 V1: 20, 2011 V3: 28
- smooth piping, 2010 V2: 79
- smothering fires, 2011 V3: 24
- snaking pipes, 2012 V4: 208, 209
- sniffer systems (LPG), 2010 V2: 135
- snow
  - as part of total load, 2012 V4: 115
  - regional requirements for plumbing installations, 2009 V1: 262
  - snow melting piping, 2012 V4: 32
- sneubbers, 2012 V4: 134
- sneubbing devices for earthquake protection, 2009 V1: 156, 157, 180
- soaking combustibles in inerting atmosphere, 2011 V3: 26
- soap dispensers, 2012 V4: 11
- soaps, 2009 V1: 141. *See also* suds
  - in gray water, 2010 V2: 27
  - in septic tanks, 2010 V2: 147
- soapstone fixtures, 2012 V4: 1, 12
- Social Security taxes, in labor costs, 2009 V1: 86
- Society of American Value Engineering (SAVE), 2009 V1: 207, 209
- socket fusion joins, 2012 V4: 61
- socket-type joints, 2011 V3: 257
- socket welding
  - defined, 2010 V2: 239
  - socket-end welding, 2012 V4: 79
  - socket-joint welding, 2012 V4: 61
  - socket-weld end connections, 2009 V1: 22
- soda ash. *See* sodium carbonate (soda ash)
- sodium, 2010 V2: 189, 190
  - defined, 2012 V4: 202
  - formula, 2012 V4: 173
  - laboratory grade water, 2012 V4: 198
  - nanofiltration, 2012 V4: 199
- sodium aluminate, 2010 V2: 199, 2012 V4: 178
- sodium azide, 2010 V2: 13
- sodium bicarbonate, 2010 V2: 190, 2012 V4: 173
- sodium bisulfate, 2010 V2: 160, 2011 V3: 87
- sodium carbonate (soda ash), 2010 V2: 190, 2012 V4: 173, 183
- sodium chloride, 2010 V2: 190, 2012 V4: 173, 182
- sodium cycle ion exchange, 2010 V2: 210, 2012 V4: 176
- sodium hexametaphosphate, 2009 V1: 140, 2010 V2: 160
- sodium hydroxide (lye or caustic soda), 2010 V2: 147, 207
  - formula, 2012 V4: 173
  - regeneration and, 2012 V4: 183, 184
- sodium hypochlorite, 2010 V2: 160, 2011 V3: 87
- sodium ion exchange plants, 2012 V4: 184
- sodium silicate, 2009 V1: 140
- sodium sulfate, 2010 V2: 189, 2012 V4: 173
- sodium thiosulfate, 2010 V2: 160
- soft cold water (SCW), 2009 V1: 8
- soft conversions, 2009 V1: 33
- soft water (SW), 2012 V4: 175, 202. *See also* water softeners
- softening membranes. *See* nanofiltration
- softening water. *See* water softeners
- software. *See* computer programs
- soil-absorption sewage systems
  - allowable rates of sewage application, 2010 V2: 153
  - alternative components, 2010 V2: 144–145
  - choosing absorption systems, 2010 V2: 142
  - construction considerations, 2010 V2: 143–144
  - drain fields defined, 2009 V1: 21
  - drain fields, defined, 2009 V1: 21
  - estimating sewage quantities, 2010 V2: 150–152
  - estimating soil absorption potential, 2010 V2: 139–142
  - individual wastewater treatment plants, 2010 V2: 150
  - inspection, 2010 V2: 153
  - institutional and recreational establishments, 2010 V2: 149–150
  - mound systems, 2010 V2: 142
  - percolation rates for soils, 2010 V2: 141–142
  - setbacks, 2010 V2: 142
  - sizing, 2010 V2: 143
- soil-moisture monitors, 2011 V3: 96
- soil pipes, 2009 V1: 28
- soil sewers (S, SS), 2009 V1: 8
- soil stacks, 2010 V2: 1
- soil vents. *See* stack vents
- soils

- abbreviation for, 2009 V1: 15
- color, 141, 2010 V2: 140
- depth, 2010 V2: 141
- graywater irrigation systems and, 2010 V2: 24–25
- irrigation and, 2011 V3: 91, 96
- maps of, 2010 V2: 140
- percolation tests, 2010 V2: 141–142
- profiles, 2011 V3: 91, 205
- rainfall, municipalities, 2010 V2: 57
- resistivity, 2009 V1: 138
- runoff, 2010 V2: 42
- in seismic force calculations, 2009 V1: 174
- storm water infiltration, 2010 V2: 48
- structure, 2010 V2: 141
- swelling characteristics, 2010 V2: 141
- swimming pool locations and, 2011 V3: 107
- texture, 2010 V2: 140–141
- underground tanks and, 2011 V3: 138
- solar absorptance, defined, 2011 V3: 191
- Solar and Sustainable Energy Society of Canada web site, 2011 V3: 203
- solar constants, 2011 V3: 192
- The Solar Decision Book*, 2011 V3: 203
- solar degradation, 2011 V3: 192
- Solar Design Workbook*, 2011 V3: 204
- solar energy. *See also* green building and plumbing
  - collecting methods, 2011 V3: 193
  - commercial applications, 2011 V3: 190
  - Compound Parabolic Concentrator (CPC) system, 2011 V3: 196
  - concentrating collectors, 2011 V3: 190, 193, 195–196
  - copper pipe, 2012 V4: 32
  - costs, 2011 V3: 189, 192, 193
  - CPC equations, 2011 V3: 196
  - definitions, 2011 V3: 188–189, 190–193
  - estimating calculations, 2011 V3: 193
  - f-chart sizing method, 2011 V3: 196–199
  - flat-plate collectors, 2011 V3: 190, 193–195
  - glossary, 2011 V3: 190–193
  - home water heating, 2011 V3: 189, 196–199
  - LEED credits, 2011 V3: 190
  - light, defined, 2011 V3: 188–189
  - photovoltaics, 2011 V3: 188–189
  - resources, 2011 V3: 203
  - sizing, 2011 V3: 193, 196–199
  - solar energy sources, 2009 V1: 128
  - solar system definitions, 2011 V3: 192
  - specifications, 2011 V3: 199–203
  - SRTA equations, 2011 V3: 195–196
  - Stationary Reflector/Tracking Absorber (SRTA) system, 2011 V3: 195–196
  - sun, overview of, 2011 V3: 188
  - tax credits, 2011 V3: 190
  - thermal, defined, 2011 V3: 188–189
  - thermal efficiency equations, 2011 V3: 194–195
  - thermal water heaters, 2010 V2: 104
  - vacuum tube collectors, 2011 V3: 190, 193
  - water heaters, 2009 V1: 121–122, 2010 V2: 104, 2012 V4: 241
- Solar Energy Industries Association web site, 2011 V3: 203
- Solar Energy Research Institute, 2011 V3: 204
- solar energy systems
  - heat exchangers, 2011 V3: 201
  - heat pumps, 2011 V3: 203
  - insulation, 2011 V3: 203
  - pumps, 2011 V3: 200, 201–202
  - sizing, 2011 V3: 196–199
  - solar panels, 2011 V3: 199, 201
  - storage tanks, 2011 V3: 203
  - water heaters, 2011 V3: 202, 2012 V4: 241
- Solar Energy Systems Design*, 2011 V3: 204
- Solar Energy Thermal Processes*, 2011 V3: 203
- Solar Heating and Cooling*, 2011 V3: 203
- Solar Heating Design by the f-Chart Method*, 2011 V3: 204
- The Solar Heating Design Process*, 2011 V3: 204
- Solar Heating Systems*, 2011 V3: 204
- The Solar Hydrogen Civilization*, 2011 V3: 203
- solar panel layouts, 2011 V3: 199, 201
- Solar Rating and Certification Corporation (SRCC), 2009 V1: 122, 2011 V3: 203
- solar water heaters, 2012 V4: 241
- Solar Water Heaters: A Buyer's Guide*, 2011 V3: 204
- soldering
  - clearance for, 2012 V4: 25
  - copper water tube, 2012 V4: 30
  - corrosion and, 2009 V1: 136
  - defined, 2009 V1: 28, 2012 V4: 58
  - fluxes, 2012 V4: 59
  - lead-free solders, 2012 V4: 59
  - lead in solder, 2012 V4: 220
  - soldered joints and earthquake protection, 2009 V1: 160
  - valve ends, 2012 V4: 79
- solenoid valves, 2009 V1: 9, 2010 V2: 118
- solid angles, 2009 V1: 34
- solid toilet seats, 2012 V4: 4
- solid waste disposal
  - as energy source, 2009 V1: 122
  - solid waste incineration systems, 2009 V1: 122
  - solids removal in septic tanks, 2010 V2: 145
- solid wedge discs, 2012 V4: 74
- solid wedges, 2012 V4: 89
- solids
  - rectangular, 2009 V1: 4
  - solids interceptors, 2011 V3: 45
  - in water, 2010 V2: 193
- solids-handling pumps, 2012 V4: 98
- soluble silica, 2010 V2: 190
- solute. *See* treated water
- solution sinks, 2011 V3: 38
- Solution Source for Steam, Air, and Hot Water Systems*, 2011 V3: 169
- solutions to puzzles, 2009 V1: 252
- solvents
  - PEX piping and, 2012 V4: 49
  - in pure-water systems, 2011 V3: 49
- sonic cleaners, 2011 V3: 40
- sound isolation in building code requirements, 2009 V1: 188
- Sound Transmission Class (STC), 2009 V1: 187
- sounds. *See* acoustics in plumbing systems
- sour gas, 2011 V3: 252
- source shut-off valves, 2011 V3: 66
- source water
  - defined, 2010 V2: 187
  - pure-water systems, 2010 V2: 220

- sources of information in value engineering, 2009 V1: 209–210, 216
- Sources of Pollutants in Wisconsin Stormwater*, 2010 V2: 55
- sources, vacuum, 2010 V2: 169–171, 173, 176
- Solvent single-stack plumbing systems, 2010 V2: 17–18, 39
- sp ht, SP HT (specific heat), 2009 V1: 34
- sp vol, SP VOL (specific volume). *See* specific volume
- space, confined
- insulation and, 2012 V4: 113
  - water softeners and, 2012 V4: 188
- space heating
- equipment condensate traps, 2011 V3: 166–167
  - solar, 2011 V3: 198
- spacing
- around water closets, 2012 V4: 5–6
  - drinking fountains, 2012 V4: 13
  - expansion joints, 2012 V4: 207
  - grab bars for accessibility, 2009 V1: 112–113
  - hangers and supports, 2012 V4: 65, 116, 122
  - lavatories, 2012 V4: 10
  - manholes, 2011 V3: 233
  - urinals, 2012 V4: 9
  - of vacuum inlets, 2010 V2: 180
- span gases, 2011 V3: 266
- spas, 2010 V2: 111, 2011 V3: 109
- spec, SPEC (specifications). *See* specifications
- special components, defined, 2012 V4: 134
- special sprinklers, 2009 V1: 29
- special tools, defined, 2012 V4: 171
- special-waste drainage systems
- acid-waste systems, 2010 V2: 229–236
  - chemical-waste systems, 2010 V2: 242–243
  - codes and standards, 2010 V2: 227
  - fire-suppression water drainage, 2010 V2: 243–244
  - flammable and volatile liquids, 2010 V2: 244–246
  - future growth of systems, 2010 V2: 229
  - general design considerations, 2010 V2: 229
  - infectious and biological waste systems, 2010 V2: 240–242
  - introduction, 2010 V2: 227
  - pH values in waste, 2010 V2: 228–229
  - piping and joint selection, 2010 V2: 228
  - planning for larger systems, 2010 V2: 229
  - radioactive waste drainage and vents, 2010 V2: 238–240
  - references, 2010 V2: 246
  - separating systems, 2010 V2: 229
  - sizing piping, 2010 V2: 228, 230, 231
  - special wastes defined, 2009 V1: 28
  - system approval requirements, 2010 V2: 227–228
- specialty gases
- classification of, 2011 V3: 266–267
  - generating, 2011 V3: 270
- specialty pumps, 2012 V4: 97–99
- specialty water closets, 2009 V1: 127
- specific conductance, 2010 V2: 193
- specific energy, converting to SI units, 2009 V1: 38
- specific functionality, defined, 2009 V1: 219
- specific gravity (SG), 2009 V1: 28
- defined, 2010 V2: 136, 2011 V3: 136, 187
  - gases, table of, 2011 V3: 267
  - natural gas, 2010 V2: 126, 131
  - plastic pipe, 2012 V4: 50
  - propane, 2010 V2: 131
  - PVC pipe, 2012 V4: 49
  - sizing gas systems, 2011 V3: 269
  - symbols for, 2009 V1: 15
  - table of substances, 2011 V3: 168–169
- specific heat (sp ht, SP HT, C)
- defined, 2011 V3: 187
  - measurements, 2009 V1: 34
  - table of substances, 2011 V3: 168–169
- specific humidity, 2011 V3: 186
- specific resistance in water, 2010 V2: 192, 2011 V3: 47, 2012 V4: 175
- specific speed, defined, 2012 V4: 95, 101
- specific volume (sp vol, SP VOL, V, CVOL)
- defined, 2011 V3: 187
  - expansion and, 2012 V4: 209
  - measurements, 2009 V1: 34
  - saturated steam, 2011 V3: 157–158
- Specification for Aluminum-alloy Seamless Pipe and Seamless Extruded Tube*, 2010 V2: 122
- Specification for Field Welded Tanks for Storage of Production Liquids (API 12D)*, 2011 V3: 88
- Specification for Seamless Copper Tube for Air-conditioning and Refrigeration Field Service*, 2010 V2: 122
- Specification for Shop Welded Tanks for Storage of Production Liquids (API 12F)*, 2011 V3: 88
- specifications (spec, SPEC). *See also* construction contract documents; project manuals; names of specific listing agencies; *names under publishing agencies (American National Standards Institute, etc.); titles of specific documents*
- checklist, 2009 V1: 94–95
  - comprehensive, 2009 V1: 264
  - computer production of, 2009 V1: 65
  - contents of sections, 2009 V1: 62–65
  - costs associated with, 2009 V1: 217
  - ensuring high quality with detailed specs, 2009 V1: 253–254
  - in FAST approach, 2009 V1: 221
  - formats, 2009 V1: 57
  - introduction, 2009 V1: 55
  - keeping up to date with products and technologies, 2009 V1: 262
  - MasterFormat, 2009 V1: 58
  - MasterFormat 2004, 2009 V1: 72–83
  - MasterFormat Level Four (1995), 2009 V1: 68–69
  - MasterFormat Level One (1995), 2009 V1: 66
  - MasterFormat Level Three (1995), 2009 V1: 68
  - MasterFormat Level Two (1995), 2009 V1: 66–68
  - methods for creating, 2009 V1: 60–62
  - noise specifications, 2009 V1: 205–206
  - problems with reuse, 2009 V1: 57
  - in project manuals, 2009 V1: 56
  - questioning in value engineering, 2009 V1: 208
  - specific language in, 2009 V1: 254
  - “specifications” as incorrect term, 2009 V1: 55
  - Unifomat, 2009 V1: 57–58, 65–66
- Specifications for Making Buildings and Facilities Usable by the Physically Handicapped*, 2009 V1: 97
- Specifications Group, 2009 V1: 58, 72–74
- specimen-type water closets, 2011 V3: 38

- Spectext, 2009 V1: 65
- speed of pumps, 2009 V1: 6
- Speller, Frank N., 2009 V1: 144
- Spencer Turbine Co., 2010 V2: 186
- spherical soil structure, 141, 2010 V2: 140
- spider guides, 2012 V4: 135
- spigot outlets, 2010 V2: 13
- spill-resistant vacuum breakers, 2012 V4: 163, 166, 171
- spills
  - aboveground tank systems, 2011 V3: 148
  - acids, 2010 V2: 229
  - controlled substances, 2010 V2: 186
  - industrial waste, 2011 V3: 84
  - oil, 2010 V2: 244–246
  - underground liquid fuel tanks, 2011 V3: 140–141
- spineboards, 2011 V3: 135
- spiral wound modules
  - in cross-flow filtration, 2010 V2: 213
  - in reverse osmosis (SWRO), 2010 V2: 194, 211–212
- Spitzglass formula, 2009 V1: 7, 2010 V2: 130
- spkr. *See* sprinkler systems (fire protection)
- splashing, air gaps and, 2012 V4: 167
- split-case horizontal end-suction pumps, 2011 V3: 21
- split-pipe rings, 2012 V4: 120
- split rim toilet seats, 2012 V4: 4
- split-ring hangers, 2012 V4: 104
- split rings, 2012 V4: 130
- split-wedge discs, 2012 V4: 74
- split wedges, 2012 V4: 89
- sponge rubber isolators, 2009 V1: 198
- sports facilities, numbers of fixtures for, 2012 V4: 20
- spout location on water fountains, 2009 V1: 101
- spray heads on irrigation sprinklers, 2011 V3: 92–93
- spray nozzle waterfall aerators, 2010 V2: 198
- spray units
  - in bathtubs, 2009 V1: 109–110
  - in showers, 2009 V1: 112
- spray valves, pre-rinse
  - LEED 2009 baselines, 2010 V2: 25
- spring-actuated check valves, 2012 V4: 76–77, 84
- spring cushion hangers or rolls, 2012 V4: 121, 135
- spring hangers, 2012 V4: 121, 135
- spring isolators
  - illustrated, 2009 V1: 204
  - noise mitigation, 2009 V1: 194
  - problems in seismic protection, 2009 V1: 182, 183
  - pump isolation and, 2009 V1: 196
  - stored energy in, 2009 V1: 158
- spring lines, 2009 V1: 28
- spring-loaded pressure regulators, 2012 V4: 82
- spring supports, 2009 V1: 180
- spring-sway braces, 2012 V4: 135
- spring tube benders, 2012 V4: 61
- springing pipes, 2012 V4: 25
- Sprinkler Irrigation, 2011 V3: 96
- Sprinkler Irrigation Systems, 2011 V3: 96
- sprinkler systems (fire protection)
  - automatic sprinkler system types, 2009 V1: 28
  - combined dry-pipe and pre-action, 2011 V3: 10–11
  - concealed sprinklers, 2009 V1: 29
  - corrosion-resistant sprinklers, 2009 V1: 29
  - defined, 2009 V1: 28–29
  - deluge systems, 2011 V3: 9–10
  - design density, 2011 V3: 11–12
  - direct connection hazards, 2012 V4: 161
  - drop nipples on pendent sprinklers, 2009 V1: 13
  - dry upright sprinklers, 2009 V1: 29
  - earthquake damage to, 2009 V1: 152
  - in elevator shafts, 2011 V3: 29
  - extended-coverage sidewall sprinklers, 2009 V1: 29
  - fire hazard evaluation, 2011 V3: 2
  - fire pumps for, 2011 V3: 21–22
  - firefighting water drainage, 2010 V2: 243–244
  - flush sprinklers, 2009 V1: 29
  - foam extinguishers, 2011 V3: 25–26
  - fully-sprinklered spaces, 2009 V1: 12
  - gas cabinets, 2011 V3: 270
  - heads, 2009 V1: 13
  - history of, 2011 V3: 1
  - hydraulic design, 2011 V3: 11–13
  - intermediate-level sprinklers, 2009 V1: 29
  - large-drop sprinklers, 2009 V1: 29
  - nipped-up sprinklers, 2009 V1: 13
  - non-sprinklered spaces, 2009 V1: 12
  - numbers of sprinklers in operation, 2011 V3: 12
  - occupancy classification, 2009 V1: 28
  - open sprinklers, 2009 V1: 29
  - ornamental sprinklers, 2009 V1: 29
  - partially-sprinklered spaces, 2009 V1: 12
  - pendent sprinklers, 2009 V1: 13, 29
  - pipe materials, 2011 V3: 20
  - pre-action systems, 2011 V3: 9
  - quick-response sprinklers, 2009 V1: 29
  - recessed sprinklers, 2009 V1: 29
  - residential, 2009 V1: 29, 2011 V3: 18
  - sediment buckets in drains, 2010 V2: 11
  - seismic protection and, 2009 V1: 177
  - sidewall sprinklers, 2009 V1: 13, 29
  - special sprinklers, 2009 V1: 29
  - sprinkler types, 2009 V1: 28–29, 2011 V3: 6–11
  - supports and hangers, 2011 V3: 18, 19
  - system design, 2011 V3: 2–18
  - temperature rating, 2011 V3: 18
  - time frames for water delivery, 2011 V3: 9
  - usage, 2011 V3: 14, 18
  - water demands, 2010 V2: 159, 2011 V3: 2–6
- sprinkler systems (irrigation)
  - concepts, 2011 V3: 92
  - impact heads, 2011 V3: 93
  - lawn sprinklers, 2009 V1: 8
  - sample information sheet, 2011 V3: 97
  - shrub heads, 2011 V3: 94
  - spray heads, 2011 V3: 92–93
  - trickle irrigation, 2011 V3: 94
- spurs, 2011 V3: 226
- sq., SQ (squares). *See* squares
- square-edged inlets, 2010 V2: 93
- square feet, calculating, 2011 V3: 30
- square foot [m<sup>2</sup>] method, defined, 2009 V1: 89
- squares (sq., SQ)
  - calculating area, 2009 V1: 3
  - converting to SI units, 2009 V1: 39
- sr (steradians), 2009 V1: 34
- SRRC (Solar Rating and Certification Corp.), 2009 V1: 122

- SRTA (Stationary Reflector/Tracking Absorber) system, 2011 V3: 195–196
- SS (sanitary sewers), 2009 V1: 8, 28. *See also* sanitary drainage systems
- SS (service sinks). *See* service sinks
- SSD (subsoil or footing drains), 2009 V1: 8
- ssf, SSF (Saybolt Seconds Furol), 2011 V3: 137
- ssu, SSU (Saybolt Seconds Universal), 2011 V3: 137
- ST (storm or rainwater drains). *See* storm-drainage systems
- stability index (Ryzner), 2010 V2: 196
- stabilization ponds, 2010 V2: 150
- stabilized chlorines, 2011 V3: 128
- stack vents
  - air in, 2010 V2: 2
  - defined, 2009 V1: 29, 2010 V2: 33
  - sizing, 2010 V2: 35–37
  - stack venting defined, 2009 V1: 29
- stacks. *See* vertical stacks
- staff areas (health care facilities), 2011 V3: 35
- staff lounges, 2011 V3: 36
- staged evaporation, 2010 V2: 200
- stages in pump equipment, 2010 V2: 161
- staging, pumps, 2012 V4: 97
- stagnant water, 2010 V2: 72
- stain-resistance testing, 2012 V4: 1
- staining fixtures and appliances with hard water, 2012 V4: 185
- stainless steel
  - bioremediation pretreatment systems, 2012 V4: 230
  - commercial sinks, 2012 V4: 11
  - electromotive force series, 2009 V1: 132
  - fixtures, 2011 V3: 35, 2012 V4: 1
  - gas storage, 2011 V3: 268
  - glass pipe couplings, 2012 V4: 36
  - gutters, 2011 V3: 113
  - jackets, 2012 V4: 108
  - laboratory gas piping, 2011 V3: 276
  - mesh insulation jackets, 2012 V4: 108
  - nickel content, 2012 V4: 1
  - passivation, 2009 V1: 136
  - pumps, 2011 V3: 123
  - reverse osmosis equipment, 2012 V4: 196
  - valves, 2012 V4: 77
  - worm gear clamps, 2012 V4: 57
- stainless-steel drains, 2010 V2: 240
- stainless-steel grates, 2010 V2: 15
- stainless-steel piping
  - distilled water piping, 2012 V4: 193
  - exposed piping on storage tanks, 2011 V3: 148
  - industrial waste pipe, 2010 V2: 239
  - pure-water system, 2011 V3: 49
  - soil and waste pipe, 2010 V2: 13
  - special uses, 2012 V4: 54–56
  - USP water, 2010 V2: 223, 224
  - vacuum systems, 2010 V2: 173
- stainless-steel storage tanks, 2010 V2: 223, 2011 V3: 84
- stairs and stairwells
  - aboveground storage tanks, 2011 V3: 148
  - standpipe systems, 2011 V3: 20
- stall urinals, 2012 V4: 8
- stanchions, 2012 V4: 119, 121, 135
- stand pipes, 2012 V4: 125
- standard (std, STD), 2009 V1: 15
- standard air, 2011 V3: 187
- standard atmospheres, defined, 2011 V3: 172
- standard atmospheric pressure
  - defined, 2011 V3: 187
  - in vacuums, 2010 V2: 165
- standard cartridge depth filtration, 2010 V2: 201
- standard cfh (scfh), 2010 V2: 126
- standard cubic feet per minute (scfm). *See* scfm, SCFM (standard cubic feet per minute)
- standard dimension ratio (SDR), 2009 V1: 15, 29, 2012 V4: 42
- standard fire-protection symbols, 2009 V1: 12–13
- standard fire tests, 2011 V3: 2
- Standard for Bulk Oxygen Systems at Consumer Sites (NFPA 50)*, 2011 V3: 57, 78
- Standard for Color-marking of Compressed Gas Cylinders Intended for Medical Use (CGA C-9)*, 2011 V3: 78
- Standard for Combustible Metals (NFPA 484)*, 2011 V3: 30
- Standard for Disinfecting Water Mains*, 2010 V2: 95
- Standard for Disinfection of Water Storage Facilities*, 2010 V2: 95
- Standard for Dry Chemical Extinguishing Systems (NFPA 17)*, 2011 V3: 24, 30
- Standard for Energy Conservation in New Building Design (ASHRAE 90A)*, 2011 V3: 203
- Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2010 V2: 136
- Standard for Health-care Facilities*, 2010 V2: 172, 2011 V3: 78, 263
- Standard for Health-care Facilities (NFPA 99)*, 2011 V3: 51, 76
- Standard for Hypochlorites*, 2010 V2: 95
- Standard for Liquid Chlorine*, 2010 V2: 95
- Standard for Low-, Medium-, and High-Expansion Foam (NFPA 11)*, 2011 V3: 25, 30
- Standard for Parking Structures*, 2010 V2: 115
- Standard for Portable Fire Extinguishers (NFPA 10)*, 2011 V3: 28, 30
- Standard for Tank Vehicles for Flammable and Combustible Liquids (NFPA 385)*, 2011 V3: 137
- Standard for the Design and Installation of Oxygen-fuel Gas Systems for Welding, Cutting, and Allied Processes*, 2010 V2: 137
- Standard for the Installation of Foam-Water Sprinkler Systems and Foam-Water Spray Systems (NFPA 16)*, 2011 V3: 25, 30
- Standard for the Installation of Nitrous Oxide Systems at Consumer Sites (CGA G-8.1)*, 2011 V3: 78
- Standard for the Installation of Private Fire Service Mains and their Appurtenances*, 2011 V3: 30
- Standard for the Installation of Sprinkler Systems (NFPA 13)*, 2009 V1: 185, 2011 V3: 30
- Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, 2011 V3: 18
- Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, 2011 V3: 18
- Standard for the Installation of Standpipe and Hose Systems (NFPA 14)*, 2011 V3: 30

- Standard for the Installation of Stationary Pumps for Fire Protection (NFPA 20)*, 2011 V3: 30
- Standard for Water Spray Fixed Systems for Fire Protection (NFPA 15)*, 2011 V3: 24
- Standard for Wet Chemical Extinguishing Agents*, 2011 V3: 24? 30
- standard free air  
   at atmospheric pressure (scfm). See scfm, SCFM (standard cubic feet per minute)  
   in vacuum sizing calculations, 2010 V2: 175
- Standard Handbook for Mechanical Engineers*, 2009 V1: 1
- Standard Method of Test of Surface Burning Characteristics of Building Materials (NFPA 255)*, 2011 V3: 69
- Standard of Testing to Determine the Performance of Solar Collections (ASHRAE 93)*, 2011 V3: 203
- Standard on Carbon Dioxide Extinguishing Systems (NFPA 12)*, 2011 V3: 30
- Standard on Clean Agent Extinguishing Systems (NFPA 2001)*, 2011 V3: 30
- Standard on Halon 1301 Fire Extinguishing Systems (NFPA 12A)*, 2011 V3: 27, 30
- Standard on Water Mist Fire Protection Systems (NFPA 750)*, 2011 V3: 25, 30
- standard plumbing and piping symbols, 2009 V1: 7–15
- Standard Plumbing Code*, 2010 V2: 55
- standard-port ball valves, 2012 V4: 75
- standard ports, 2012 V4: 89
- standard pressure and temperature (SPT), defined, 2011 V3: 187
- standard reference points (compressed air), 2011 V3: 172
- Standard Specification for Aluminum and Aluminum-Alloy Drawn Seamless Tubes (ASTM B210)*, 2010 V2: 122, 2011 V3: 277
- Standard Specification for Copper-brazed Steel Tubing*, 2010 V2: 122
- Standard Specification for Pipe, Steel, Black and Hot-dipped, Zinc-coated Welded and Seamless*, 2010 V2: 122
- Standard Specification for Seamless and Welded Austenitic Stainless Steel Sanitary Tubing (ASTM A270)*, 2011 V3: 276
- Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service*, 2010 V2: 122
- Standard Specification for Seamless Copper Tube (ASTM B75)*, 2011 V3: 276
- Standard Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service (ASTM B280)*, 2011 V3: 276
- Standard Specification for Seamless Copper Tube for Medical Gas Systems (ASTM B819)*, 2011 V3: 276
- Standard Specification for Seamless Copper Water Tube (ASTM B88)*, 2010 V2: 122, 2011 V3: 276
- Standard Specification for Thermoplastic Gas Pressure Pipe*, 2010 V2: 123–124
- standard temperature and pressure, 2009 V1: 29
- Standard Text Method for Surface Burning Characteristics of Building Materials*, 2010 V2: 122, 224
- standard water closets, 2012 V4: 4
- standard-weight steel pipe, 2012 V4: 37
- standards. See codes and standards
- standby losses in circulating systems, 2009 V1: 119
- standing water, 2010 V2: 49
- standpipe systems  
   classifications and characteristics, 2011 V3: 18, 20–21  
   defined, 2009 V1: 29–30, 2012 V4: 101  
   fire pumps for, 2011 V3: 21  
   flatland storage tanks, 2010 V2: 162  
   standpipe air chambers, 2010 V2: 72, 73  
   standpipes, defined, 2012 V4: 101  
   symbols for, 2009 V1: 13  
   system classes of service, 2009 V1: 30  
   system types, 2009 V1: 30
- startup loads, condensate drainage, 2011 V3: 163
- state agencies, 2010 V2: 227, 238, 2011 V3: 82
- state frost lines, 2011 V3: 218, 220
- state, gas, 2011 V3: 187
- state rainfall rate tables, 2010 V2: 57
- states in creativity checklist, 2009 V1: 227
- static cake diatomaceous earth filters, 2011 V3: 120
- static deflection (d)  
   defined, 2012 V4: 137  
   for pump vibration, 2012 V4: 138
- static head  
   calculating, 2009 V1: 2  
   defined, 2012 V4: 97, 101  
   gallons per minute and, 2010 V2: 73  
   velocity head and, 2009 V1: 5  
   well pumps, 2010 V2: 161
- static pressure (SP)  
   defined, 2010 V2: 94  
   domestic water supply, 2011 V3: 208–210  
   elevation and, 2010 V2: 84  
   fire hydrants, 2011 V3: 4  
   irrigation flow, 2011 V3: 96  
   sprinkler hydraulic calculations, 2011 V3: 13  
   water mains, 2011 V3: 206
- static pressure head, 2012 V4: 101
- static suction head, 2012 V4: 101
- static suction lift, 2012 V4: 101
- static wells, 2010 V2: 157–158
- stationary propane tanks, 2010 V2: 132
- Stationary Reflector/Tracking Absorber (SRTA) system, 2011 V3: 195–196
- stations (medical gas and vacuum)  
   ceiling outlets, 2011 V3: 55–56  
   estimating number, 2011 V3: 50–51, 52–53  
   inlets, 2011 V3: 78  
   medical gas diversity factors, 2011 V3: 70  
   medical vacuum, 2011 V3: 54  
   order of gas outlets, 2011 V3: 51  
   outlets, 2011 V3: 78  
   patient headwall gas systems, 2011 V3: 51, 55  
   surgical ceiling columns, 2011 V3: 55–56  
   terminals, 2011 V3: 51–54  
   types of, 2011 V3: 56
- STC (Sound Transmission Class), 2009 V1: 187
- std, STD (standard), 2009 V1: 15
- steady flow  
   continuous flow rates, 2012 V4: 186  
   in horizontal drains, 2010 V2: 6–8, 8–9
- steady-state heat balance equations, 2010 V2: 100
- steam and condensate systems  
   condensate drainage, 2011 V3: 163–166

- condensate removal, 2011 V3: 161–162
- distilling water from steam, 2010 V2: 200
- distribution piping, 2011 V3: 159–161
- flash, 2011 V3: 157–159, 166
- fouling, 2011 V3: 162
- geothermal, 2009 V1: 123
- high-pressure steam, 2009 V1: 9, 2012 V4: 86–87
- low-pressure steam, 2009 V1: 9, 2012 V4: 85–86
- medium-pressure steam, 2009 V1: 9, 2012 V4: 86
- overview, 2011 V3: 157
- pressure drop, 2011 V3: 159–161
- references, 2011 V3: 169
- saturated steam, 2011 V3: 157–158, 159–161
- steam atmospheric vents, 2009 V1: 9
- steam heat in distillation, 2012 V4: 192
- steam traps, 2009 V1: 11
- traps, 2011 V3: 162–163
- velocity, 2011 V3: 159–160
- waste heat usage of condensate, 2009 V1: 123
- water hammer, 2011 V3: 162
- steam deaerators, 2010 V2: 199
- steam-fired water heaters, 2009 V1: 121
- steam in place (SIP), 2011 V3: 277
- steam indirect-fired water heaters, 2010 V2: 104
- steam tables, 2012 V4: 161
- steam traps, 2009 V1: 11
- steam vaporizers, 2011 V3: 57
- steam working pressure (SWP), 2009 V1: 15, 2012 V4: 83
- steatite fixtures, 2012 V4: 1
- steel. *See also* stainless steel; steel piping
  - anchoring to, 2012 V4: 123
  - beam connections in pipe bracing, 2009 V1: 168, 169
  - in electromotive force series, 2009 V1: 132
  - fixtures, 2012 V4: 1
  - floor decks in earthquakes, 2009 V1: 160
  - in galvanic series, 2009 V1: 132
  - storage tanks, 2011 V3: 138
  - stress and strain figures, 2012 V4: 206
  - thermal expansion or contraction, 2012 V4: 207
  - underground tanks, 2011 V3: 155
  - water tanks, 2010 V2: 162
- Steel Above Ground Tanks for Flammable and Combustible Liquids (UL 142)*, 2011 V3: 88, 137, 147
- steel bands, 2012 V4: 119
- steel clamps, 2012 V4: 119
- steel clips, 2012 V4: 119
- steel fixtures, 2012 V4: 1
- steel pipe sleeves, 2012 V4: 67
- steel piping. *See also* galvanized-steel piping; stainless-steel piping
  - dimensions, 2012 V4: 44–47
  - fuel-product dispensing, 2011 V3: 149
  - hangers, 2012 V4: 122
  - Manning formula and, 2011 V3: 242
  - natural gas, 2011 V3: 257
  - natural gas systems, 2010 V2: 122
  - radioactive wastes, 2010 V2: 239
  - roughness, 2010 V2: 78
  - standards, 2012 V4: 69
  - surface roughness, 2010 V2: 75
  - Teflon lined, 2012 V4: 52
  - types, 2012 V4: 36–37, 44–45
  - velocity and, 2010 V2: 78
  - welded joints, 2012 V4: 61
- steel protection saddles and shields, 2012 V4: 119
- steel riser clamps, 2012 V4: 119
- steel spring isolators, 2009 V1: 196–197, 2012 V4: 139–142
- steel stanchions, 2012 V4: 119
- steel strap hangers, 2012 V4: 65
- Steel Tank Institute (STI), 2011 V3: 137
- steel trapezes, 2012 V4: 119
- steel tubing, 2010 V2: 122
- steel welded attachments, 2012 V4: 119
- Steele, Alfred, 2009 V1: 39, 2010 V2: 46, 47, 55, 96
- steep grass area, runoff, 2010 V2: 42
- steep head curves, 2012 V4: 101
- stems
  - defined, 2012 V4: 89
  - on valves, 2012 V4: 78
- Stenzel, Mark H., 2010 V2: 225
- step-down gas regulators, 2010 V2: 121
- steradians, 2009 V1: 34
- sterilization
  - feed water, 2010 V2: 195
  - infectious waste systems, 2010 V2: 242
  - insulation on pipes, 2012 V4: 104
  - laboratory gas systems, 2011 V3: 277
  - pure water systems, 2010 V2: 223
  - ultraviolet, 2011 V3: 48, 2012 V4: 195
- sterilizers, 2011 V3: 39, 40, 42, 2012 V4: 161
- Stevens Building Technology Research Laboratory, 2010 V2: 18
- Steward SRTA (Stationary Reflector/Tracking Absorber) system, 2011 V3: 195–196
- STI (Steel Tank Institute), 2011 V3: 137
- sticking (manual tank gauging), 2011 V3: 142
- stills, 2010 V2: 200, 202–204
  - baffle systems, 2012 V4: 192
  - decentralized or centralized, 2012 V4: 192
  - distillation, 2012 V4: 189–194
  - heat sources for, 2012 V4: 191
  - hospital requirements, 2011 V3: 42
  - maintenance, 2012 V4: 198
  - multiple-effect, 2012 V4: 192
  - pure-water systems, 2011 V3: 48
  - scaling in, 2012 V4: 192
  - single-effect stills, 2012 V4: 192
  - steam heating, 2012 V4: 192
  - storage reservoirs, 2012 V4: 193
  - types of, 2012 V4: 192–193
  - vapor-compression, 2012 V4: 192
- Stokes law, 2012 V4: 148, 178
- stop plugs, 2012 V4: 89
- stop valves, 2009 V1: 30, 2011 V3: 35
- stops, 2012 V4: 135
- storage
  - costs, 2009 V1: 217
  - of distilled water, 2012 V4: 193
  - fire hazard evaluation, 2011 V3: 2
  - gravity filters and, 2012 V4: 180
  - of gray water, 2010 V2: 22, 27–28
  - of laboratory gases, 2011 V3: 267–270
  - of medical gases
    - medical compressed air, 2011 V3: 61–64



- nitrogen, 2011 V3: 63–64
- nitrous oxide, 2011 V3: 59–60
- oxygen, 2011 V3: 57–59
- propane tanks, 2010 V2: 131–134
- of pure water, 2010 V2: 223
- of rainwater, 2010 V2: 52–53
- of salt, 2012 V4: 189
- section in specifications, 2009 V1: 63–64, 70
- of sewage in septic tanks, 2010 V2: 146
- tanks, rainwater, 2012 V4: 238
- storage basins, sewage lift stations, 2011 V3: 235–236
- storage devices (thermal), 2011 V3: 192
- storage media (thermal), 2011 V3: 192
- storage reservoirs, 2011 V3: 84
- storage rooms, 2011 V3: 68
- storage subsystems, 2011 V3: 192
- storage tanks. *See* tanks
- storage water heaters, 2009 V1: 121. *See also* tank-type water heaters
- stores. *See* retail stores
- storm building drains. *See* storm-drainage systems
- storm drainage
  - accessibility, 2010 V2: 48–49
  - calculating intensity, 2010 V2: 44–46
  - calculating time of concentration, 2010 V2: 44–46
  - collection systems, 2010 V2: 46
  - contaminants, 2010 V2: 43–44
  - conveyance, 2010 V2: 46–47
  - detention, 2010 V2: 47–48
  - hydrographs, 2010 V2: 43
  - infiltration, 2010 V2: 48
  - introduction, 2010 V2: 42
  - maintenance, 2010 V2: 48–49
  - pollution, 2010 V2: 45
  - rainfall for selected municipalities, 2010 V2: 57
  - Rational Method, 2010 V2: 43
  - runoff patterns, 2010 V2: 43
  - runoff volume calculation example, 2010 V2: 56
  - storm events, 2010 V2: 42
  - treatment, 2010 V2: 48
  - vector control, 2010 V2: 49
  - water quality, 2010 V2: 43
- Storm Drainage Design and Detention using the Rational Method*, 2010 V2: 55
- storm-drainage pipe codes, 2009 V1: 42
- storm-drainage systems. *See also* rainwater and precipitation
  - building drainage systems, 2010 V2: 49–54
  - calculations, 2010 V2: 53–54
  - cast-iron soil-pipe building drains, 2012 V4: 25
  - clear water waste branches, 2010 V2: 50
  - codes, 2009 V1: 42–44, 2011 V3: 238
  - codes and standards, 2010 V2: 41–42
  - controlled-flow systems, 2010 V2: 52–53
  - design criteria, 2010 V2: 49–54
  - design storms, 2011 V3: 239
  - disposal methods, 2011 V3: 249–250
  - introduction, 2010 V2: 41
  - materials, 2010 V2: 42
  - overview, 2011 V3: 237
  - pipe sizing and layout, 2010 V2: 49–54
  - preliminary information, 2011 V3: 205
  - rainfall intensity-frequency-duration charts, 2011 V3: 244–248
  - Rational method, 2009 V1: 7, 2011 V3: 238–239
  - reinforced concrete pipe building drains, 2012 V4: 29
  - roof drainage, 2010 V2: 51–53
  - sample utility letters, 2011 V3: 238
  - secondary drainage systems, 2010 V2: 52
  - sizing, 2011 V3: 243–249
  - sizing ditches, 2011 V3: 250
  - storm drains (SD, ST), 2009 V1: 8
  - storm sewers defined, 2009 V1: 30
  - system design procedure, 2011 V3: 243–249
- storm water, 2009 V1: 30. *See also* graywater; wastewater codes and standards, 2010 V2: 22
  - contaminant concentration, 2010 V2: 27
  - defined, 2010 V2: 21
  - introduction, 2010 V2: 21
  - water balance, 2010 V2: 21–23, 28
- Storm Water Retention Methods*, 2010 V2: 55
- Stormwater: The Dark Side of Stormwater Runoff Management*, 2010 V2: 55
- STPs (sewage treatment plants), 2010 V2: 22, 27–28
- straight lobe compressors, 2011 V3: 175
- straight-reading volume meters, 2012 V4: 183
- strain
  - defined, 2009 V1: 30
  - maximum allowable, 2012 V4: 205–206
- strainers
  - basket strainers, 2010 V2: 92
  - cold water systems, 2010 V2: 60
  - distributors in water softeners, 2012 V4: 201
  - pressure losses, 2011 V3: 216
  - roof drains, 2010 V2: 53
  - sanitary drainage systems, 2010 V2: 11
  - sediment buckets, 2010 V2: 11
  - swimming pools, 2011 V3: 124
  - symbols for, 2009 V1: 10
- strap hangers, 2012 V4: 128
- straps, 2012 V4: 135
- stratification in water heaters, 2010 V2: 105
- stray current corrosion, 2009 V1: 132, 143
- stream regulators for water coolers, 2012 V4: 219, 222
- stream-spray irrigation sprinklers, 2011 V3: 94
- streams, irrigation systems and, 2010 V2: 25
- street pressure, 2009 V1: 30
- stress
  - conversion factors, 2009 V1: 36
  - defined, 2009 V1: 30
  - maximum allowable, 2012 V4: 205–206
  - measurements, 2009 V1: 34
  - stress analysis, 2012 V4: 135
- stress-accelerated corrosion, 2009 V1: 143
- stress corrosion, 2009 V1: 143
- stress-corrosion cracking, 2009 V1: 131, 143, 2010 V2: 195
- strip-chart recorder water meters, 2010 V2: 60
- strong-base regeneration, 2010 V2: 206, 207
- strongbacks, 2009 V1: 154
- strontium 90, 2010 V2: 238
- structural angle bracing, 2009 V1: 160
- structural attachments, 2012 V4: 135
- structural channel bracing, 2009 V1: 160
- structural strength

- bath and shower seats, 2009 V1: 114–115
- grab bars, 2009 V1: 114–115
- structural stresses on piping systems, 2012 V4: 117
- structure-borne sound, 2009 V1: 187
- structured biofilms, 2012 V4: 229
- strut bracing, 2009 V1: 166, 168
- strut clamps, 2012 V4: 135
- struts, 2012 V4: 135
- studs in noise mitigation, 2009 V1: 193
- styrene butadiene, 2009 V1: 32
- styrofoam blocking on glass pipe, 2012 V4: 35
- sub-micron cartridge filtration, 2010 V2: 201
- sub-sterilizing rooms, 2011 V3: 36, 39
- submerged inlet hazards, 2012 V4: 161
- submersible pumps
  - design, 2012 V4: 99
  - illustrated, 2011 V3: 233
  - mounting, 2012 V4: 100
  - protection of wells, 2010 V2: 158
  - shallow wells, 2010 V2: 162
  - sizing, 2011 V3: 151–152
  - underground storage tanks, 2011 V3: 146
  - well pumps, 2010 V2: 160
- submittals section in specifications, 2009 V1: 63, 69
- subsidence
  - basin design, 2012 V4: 178
  - turbidity and, 2012 V4: 178
- subsoil drainage pipe, 2009 V1: 44
- subsoil drains (SSD), 2009 V1: 8, 30
- substances, amount (moles), 2009 V1: 33
- substituting products
  - in proprietary specifications, 2009 V1: 62
  - value engineering process and, 2009 V1: 207
- subsurface drip irrigation systems, 2010 V2: 25
- subsurface obstructions, swimming pool locations and, 2011 V3: 107
- subsurface waste-disposal systems. *See* soil-absorption sewage systems
- subsurface water. *See* ground water
- subsystems, solar, 2011 V3: 192
- subterranean vaults, fountain equipment, 2011 V3: 99–100
- subway vibration and resonance, 2012 V4: 118
- Suction Fittings for Use in Swimming Pools, Wading Pools, and Hot Tubs (ASME A112.18.8)*, 2011 V3: 101, 104, 112, 135
- suction fittings, swimming pools, 2011 V3: 101, 104, 112
- suction fuel-delivery systems, 2011 V3: 145
- suction head, defined, 2012 V4: 101
- suction inlets in storage tanks, 2010 V2: 163
- suction lift, defined, 2012 V4: 101
- suction piping, 2010 V2: 163
- suction pressure
  - defined, 2011 V3: 187
  - fountains, 2011 V3: 100
- suction sump pumps, 2011 V3: 101
- suction-type pumps, 2010 V2: 157
- sudden enlargements, 2010 V2: 92
- suds
  - pressure zones, 2009 V1: 30, 2010 V2: 37–38
  - venting, 2010 V2: 37–38
- sulfate-reducing bacteria, 2010 V2: 188
- sulfates, 2010 V2: 189, 190, 206
  - defined, 2012 V4: 202
  - nanofiltration, 2012 V4: 199
  - sulfate ions, 2012 V4: 173
  - water hardness and, 2012 V4: 176
- sulfides, 2009 V1: 136
- sulfites, 2010 V2: 189, 216
- sulfur, 2010 V2: 189
- sulfur dioxide, 2011 V3: 87, 265
- sulfuric acid
  - demineralizers, 2012 V4: 183
  - formula, 2012 V4: 173
  - from cation exchange, 2012 V4: 184
  - in regeneration, 2010 V2: 207
  - special wastes, 2010 V2: 230–232
  - storage tanks, 2011 V3: 85
  - in water chemistry, 2010 V2: 189
- sulfurous acid, 2010 V2: 189
- sulphate. *See* sulfates
- summary section in specifications, 2009 V1: 63, 69
- sumps and sump pumps
  - capacity, 2011 V3: 237
  - containment sumps, 2011 V3: 139
  - duplex sump pump systems, 2010 V2: 8
  - elevation and, 2012 V4: 98
  - field-fabricated sumps, 2011 V3: 105–106
  - fixture-unit values, 2010 V2: 8–9
  - flexible pipe connectors, 2011 V3: 150
  - floor drains and, 2010 V2: 10
  - fountains, 2011 V3: 100–102
  - liquid-waste decontamination systems, 2010 V2: 242
  - noise mitigation, 2009 V1: 203
  - roof drainage and, 2010 V2: 54
  - sanitary drainage systems, 2010 V2: 8–9, 9–10
  - sewage life stations, 2011 V3: 235–236
  - sump pits, 2010 V2: 242
  - sump pumps defined, 2009 V1: 30
  - sumps defined, 2009 V1: 30
  - swimming pools, 2011 V3: 112
- Sun, T.Y., 2009 V1: 185
- sunlight
  - overview, 2011 V3: 188
  - plastic corrosion, 2009 V1: 141
  - protecting against, 2010 V2: 16, 2011 V3: 148
  - solar energy. *See* solar energy
- super flushes, 2009 V1: 30
- supercritical flow. *See* hydraulic jumps in flow
- Superfund Amendment and Reauthorization Act of 1986 (SARA Title III), 2011 V3: 82, 137
- superheated air and vapor mixtures, 2011 V3: 187
- superstrut bracing, 2009 V1: 163
- supervised heat-up method, condensate drainage, 2011 V3: 163–164
- supervisory (tamper) switches, 2009 V1: 30
- supplementary conditions, 2009 V1: 56
- supplementary units of measurement, 2009 V1: 34
- supplies (sply., SPLY, SUP), 2009 V1: 217
- support and hanger loads
  - calculating for hangers and supports, 2012 V4: 115–116
  - cold loads, 2012 V4: 129
  - deadweight loads, 2012 V4: 129
  - design considerations, 2012 V4: 115–118
  - design loads, 2012 V4: 129

- dynamic loads, 2012 V4: 129
- friction loads, 2012 V4: 130
- hot loads, 2012 V4: 131
- hydrostatic loads, 2012 V4: 131
- load ratings, 2012 V4: 122, 124
- operating loads, 2012 V4: 132
- seismic loads, 2012 V4: 134
- thermal loads, 2012 V4: 135
- thrust loads, 2012 V4: 135
- trip-out loads, 2012 V4: 135
- water hammer loads, 2012 V4: 136
- wind loads, 2012 V4: 136
- support drawings, 2012 V4: 128, 135
- supporting rolls, 2012 V4: 119
- supports and hangers. *See also* support and hanger loads
  - allowing for expansion and contraction, 2012 V4: 207
  - alternate attachment to hangers, 2009 V1: 167
  - anchoring and anchor types, 2012 V4: 123, 123–125
  - clean agent gas pipes, 2011 V3: 28
  - clear specifications for, 2009 V1: 255
  - codes and standards, 2009 V1: 43
  - defined, 2009 V1: 30, 2012 V4: 130, 132, 135
  - design considerations, 2012 V4: 115–118
    - acoustics, 2012 V4: 118
    - loads, 2012 V4: 115–116
    - manmade environmental conditions, 2012 V4: 118
    - natural environmental conditions, 2012 V4: 117
    - pressure fluctuations, 2012 V4: 117
    - structural stresses, 2012 V4: 117
    - thermal stresses, 2012 V4: 116
  - drawings and plans, 2012 V4: 128, 132, 135
  - earthquake bracing, 2009 V1: 160
  - engineering issues, 2012 V4: 115–118
  - glossary, 2012 V4: 125–136
  - hanger rod gravity forces in earthquakes, 2009 V1: 180
  - hangers, defined, 2009 V1: 24
  - illustrated, 2012 V4: 121
  - installation productivity rates, 2009 V1: 86, 89
  - insulation for, 2012 V4: 104, 105, 110
  - load ratings, 2012 V4: 122, 124
  - materials, 2009 V1: 43, 2012 V4: 122
  - medical gas piping, 2011 V3: 68
  - noise mitigation, 2009 V1: 190, 191, 196, 203
  - plan locations, 2012 V4: 132
  - poor installations of, 2009 V1: 259
  - reactivity and conductivity, 2012 V4: 117
  - sanitary drainage systems, 2010 V2: 12
  - selection criteria, 2012 V4: 118–122
  - spacing, 2012 V4: 65, 116, 122
  - sprinkler systems, 2011 V3: 18, 19
  - symbols for, 2009 V1: 13
  - types of, 2012 V4: 63–66, 118–122
    - beam clamps, 2012 V4: 120
    - brackets, 2012 V4: 121
    - clevis hangers, 2012 V4: 120
    - concrete inserts, 2012 V4: 120
    - hanger assemblies, 2012 V4: 130, 132
    - pipe clamps, 2012 V4: 120
    - pipe rollers, 2012 V4: 121
    - pipe slides, supports, anchors, and shields, 2012 V4: 121
    - spring hangers and constant supports, 2012 V4: 121
    - vacuum cleaning tubing, 2010 V2: 179
- surface abrasions
  - corrosion and, 2009 V1: 136
  - grab bars, 2009 V1: 113
- surface burning pipe characteristics, 2010 V2: 224
- surface fault slips, 2009 V1: 149
- surface fires, 2011 V3: 23
- surface-mounted pumps, 2010 V2: 160
- surface ponds, 2010 V2: 47
- surface runoff. *See* runoff
- surface skimmers. *See* skimmers
- surface temperature of insulation, 2012 V4: 111
- surface-type sprinkler spray heads, 2011 V3: 92–93
- surface water
  - as feed water for pure water systems, 2010 V2: 220
  - carbon dioxide in, 2012 V4: 176
  - defined, 2010 V2: 188
  - discharge permits for, 2011 V3: 83
  - need for treatment, 2012 V4: 173–174
- Surface Water Treatment Rule, 2010 V2: 217
- surfaces of fixture materials, 2012 V4: 1
- surge capacity, swimming pools, 2011 V3: 111–112
- surge pressure. *See* water hammer
- surge tanks, 2010 V2: 25
- surge vessels (tanks), swimming pools, 2011 V3: 113, 116
- surges in horizontal drains, 2010 V2: 5
- surgical ceiling columns, 2011 V3: 55–56
- surgical clean-up areas, 2011 V3: 36
- surgical gas track systems, 2011 V3: 56
- surgical instruments, 2011 V3: 56, 64
- surgical scrub areas, 2011 V3: 36
- surgical supply areas, 2011 V3: 36
- surgical vacuum (SV), 2009 V1: 9
- surveys
  - cross connections, 2012 V4: 171
  - existing buildings, 2009 V1: 265–270, 267–270
  - plumbing cost estimation, 2009 V1: 85
  - water softener data, 2012 V4: 189
- suspended equipment
  - earthquake restraints, 2009 V1: 154
  - fixed suspended equipment, 2009 V1: 157
  - poor installations of, 2009 V1: 258, 259
  - vibration-isolated, suspended equipment, 2009 V1: 158
- suspended metals in wastes, 2011 V3: 87
- suspended piping
  - earthquake recommendations, 2009 V1: 152
  - noise mitigation, 2009 V1: 192, 195
- suspended solids. *See also* turbidity
  - defined, 2010 V2: 188
  - filtration, 2010 V2: 201
  - removing, 2010 V2: 199
  - total suspended solids, 2010 V2: 193
  - turbidity, 2010 V2: 188
- suspended tanks, 2009 V1: 153
- suspension, defined, 2010 V2: 188, 2012 V4: 202
- suspension hangers. *See* supports and hangers
- sustainable design, 2012 V4: 233
- SV (surgical vacuum), 2009 V1: 9
- SV (service) cast-iron soil pipe, 2012 V4: 25, 28
- swamp gas, 2010 V2: 190
- Swartman, Robert K., 2011 V3: 204

- sway bracing. *See also* lateral and longitudinal sway bracing; restraints and restraining control devices
- acceptable types, 2009 V1: 181
  - horizontal loads for, 2009 V1: 178–179
  - illustrated, 2012 V4: 126
  - lateral and longitudinal, 2009 V1: 175–176, 178
  - longitudinal and transverse, 2009 V1: 172, 173
  - noise mitigation and, 2009 V1: 190
  - potential problems, illustrated, 2009 V1: 183
- sway in piping, 2009 V1: 152
- sweep fittings, 2012 V4: 223
- swelling characteristics of soils, 2010 V2: 141
- swimming pools
- bathhouses, toilets, and showers, 2011 V3: 110
  - chemical controls, 2011 V3: 127–131
  - chemistry, 2011 V3: 115
  - circulation, 2011 V3: 113–116
  - circulation pumps, 2011 V3: 122–123
  - defined, 2009 V1: 30
  - dehumidification, 2011 V3: 127
  - design parameters, 2011 V3: 106–110
  - direct connection hazards, 2012 V4: 161
  - feed systems, 2011 V3: 127–131
  - filters
    - diatomaceous earth, 2011 V3: 119–122
    - overview, 2011 V3: 114
    - sand, 2011 V3: 117–118
  - fixture requirements, 2011 V3: 109
  - flow control devices, 2011 V3: 125–126
  - flow sensors, 2011 V3: 124–125
  - fresh water makeup, 2011 V3: 132–133
  - grate materials, 2010 V2: 13
  - handicapped access, 2011 V3: 134–135
  - health codes, 2011 V3: 106
  - heat recovery, 2011 V3: 127
  - inlets, 2011 V3: 135
  - ladders, 2011 V3: 134–135
  - level control systems, 2011 V3: 131–132
  - location, 2011 V3: 107
  - main drains, 2011 V3: 132
  - numbers of fixtures for, 2012 V4: 20
  - numbers of swimmers, 2011 V3: 106
  - operating systems, 2011 V3: 111–116
  - overview, 2011 V3: 104
  - ozone system, 2011 V3: 133
  - physical characteristics, 2011 V3: 107–110
  - ramps, 2011 V3: 134–135
  - safety equipment, 2011 V3: 135
  - size and capacity, 2011 V3: 106–107
  - skimmers, 2011 V3: 114, 117
  - specialty systems, 2011 V3: 116, 133–134
  - strainers, 2011 V3: 124
  - surge vessels, 2011 V3: 113, 116
  - underwater lights, 2011 V3: 135
  - UV system, 2011 V3: 133–134
  - water features, 2011 V3: 134
  - water heating, 2011 V3: 126–127
- swing check valves, 2010 V2: 92, 164, 2012 V4: 76, 84, 89
- swing eyes, 2012 V4: 119
- swing loops, 2012 V4: 206
- swinging on pipes, 2012 V4: 116
- switch-gear rooms, 2011 V3: 68
- swivel pipe rings, 2012 V4: 135
- swivel turnbuckles, 2012 V4: 135
- SWP (steam working pressure), 2009 V1: 15, 2012 V4: 83
- SWRO (spiral wound modules), 2010 V2: 194, 211–212
- SYGEF piping, 2011 V3: 49
- symbols
  - fire protection, 2009 V1: 12–13
  - references, 2009 V1: 39
  - standardized plumbing and piping symbols, 2009 V1: 7–15
- Synthesis phase in value engineering, 2009 V1: 209
- synthetic fiber gas filters, 2011 V3: 252
- synthetic resins, 2010 V2: 205
- SYS (systems), 2009 V1: 128
- system curve analysis for pumps, 2012 V4: 95–97
- system descriptions in specifications, 2009 V1: 63, 69
- system head curves, 2012 V4: 95, 102
- system performance criteria in specifications, 2009 V1: 63, 69
- Systeme International d’Unites. *See* International System of Units (SI)
- systems (SYS)
  - defined, 2009 V1: 128
  - diagramming, 2009 V1: 223
  - value engineering questions, 2009 V1: 209
- Systems and Applications Handbook*, ASHRAE, 2011 V3: 204
- ## T
- t (metric tons), 2009 V1: 34
- T (temperature). *See* temperature
- T (teslas), 2009 V1: 34
- T (time). *See* time
- t-joints, 2012 V4: 58
- T (tera) prefix, 2009 V1: 34
- t, TD (temperature differences), 2009 V1: 128
- T&P valves (temperature and pressure relief), 2010 V2: 106
- T4 or T6 aluminum temper, 2011 V3: 277
- tablespoons, converting to SI units, 2009 V1: 39
- tabular take-off sheets, in cost estimations, 2009 V1: 86
- take-off estimating method, cost estimating, 2009 V1: 86–87
- Take the Guesswork out of Demineralizer Design*, 2010 V2: 224
- taking pretty to the bank, 2009 V1: 262–263
- tamper switches, 2009 V1: 30
- tamping fill, 2010 V2: 15
- Tanaka, T., 2010 V2: 225
- tangential-flow filtration, 2010 V2: 201, 211
- tank-mounted product dispensers, 2011 V3: 149
- tank-type water closets, 2009 V1: 127
- tank-type water heaters, 2009 V1: 121
- tankless water heaters, 2009 V1: 120
- tanks. *See also* septic tanks
  - abandonment and removal, 2011 V3: 154
  - buoyant forces, 2011 V3: 241
  - calculating volume, 2010 V2: 64–66
  - carbon dioxide extinguishing systems, 2011 V3: 26
  - connections and access, 2011 V3: 139, 148
  - construction, 2011 V3: 139
  - corrosion protection, 2011 V3: 148
  - earthquake damage, 2009 V1: 152, 153

- earthquake protection, 2009 V1: 154–157, 182, 183  
 filling and spills, 2011 V3: 139–140, 148  
 flow-through periods, 2012 V4: 147  
 gauges, 2011 V3: 148  
 hazardous waste incompatibilities, 2011 V3: 83–84, 84  
 installation, 2011 V3: 154–156  
 insulation, 2012 V4: 110  
 leak prevention and monitoring, 2011 V3: 148–149  
 Legionella growth in, 2010 V2: 109  
 materials, 2011 V3: 138–139, 147–148  
 overflow prevention, 2011 V3: 141, 148  
 protection, 2011 V3: 149  
 tank end deflection, 2011 V3: 154  
 tank farms, 2009 V1: 139  
 tightness testing, 2011 V3: 142–143, 153  
 types of  
   aboveground tanks, 2011 V3: 84, 147–149  
   break tanks, 2012 V4: 168  
   chilled drinking-water systems, 2012 V4: 222, 224  
   cryogenic, 2011 V3: 57  
   distilled water systems, 2011 V3: 48  
   drinking water storage, 2010 V2: 162  
   expansion tanks, 2010 V2: 67–68, 2012 V4: 209–213  
   fire-protection supplies, 2011 V3: 219  
   firefighting drainage, 2010 V2: 244  
   gravity tank systems, 2010 V2: 65–66  
   hydropneumatic-tank systems, 2010 V2: 64–65, 64–66  
   kill tanks, 2010 V2: 241–242  
   liquefied petroleum gas, 2010 V2: 131–135  
   liquid fuel tanks, 2011 V3: 139–140  
   natural gas systems, 2010 V2: 131–135  
   product dispensing systems, 2011 V3: 149  
   propane, 2010 V2: 131–134  
   radioactive wastes, 2010 V2: 240  
   rainwater, 2012 V4: 238  
   settling tanks, 2011 V3: 88  
   solar energy systems, 2011 V3: 203  
   solar water heaters, 2009 V1: 121  
   storage tanks, defined, 2011 V3: 136  
   storm drainage detention, 2010 V2: 47–48  
   suspended, 2009 V1: 157  
   thermal expansion tanks, 2010 V2: 106  
   underground tanks, 2011 V3: 84, 139–140  
   water storage tanks, 2010 V2: 223, 2011 V3: 46  
   vapor recovery, 2011 V3: 149  
   venting, 2011 V3: 141, 148  
   volume calculations, 2012 V4: 147  
 tannin in water, 2012 V4: 202  
 tape thread sealants, 2012 V4: 60  
 tapping illegally into water lines, 2010 V2: 59  
 tapping valves, 2012 V4: 67  
 taps  
   large wet tap excavations, 2011 V3: 213  
   pressure loss and, 2011 V3: 210–214  
 target areas in water closets, 2012 V4: 3  
 taste of drinking water, 2010 V2: 160, 217  
 tax credits, solar energy, 2011 V3: 190  
 Tax Incentives Assistance Project (TIAP) web site, 2011 V3: 203  
 taxes  
   in labor costs, 2009 V1: 86  
   in plumbing cost estimation, 2009 V1: 86  
 Taylor, Halsey Willard, 2012 V4: 215  
 TD (temperature differences), 2009 V1: 128  
 TD (turndown ratio), 2010 V2: 127  
 TDS (total dissolved solids). *See* total dissolved solids (TDS)  
 TE (top elevation), 2009 V1: 15  
 teaspoons, converting to SI units, 2009 V1: 39  
 technetium 99, 2010 V2: 238  
*Techniques of Value Analysis and Engineering*, 2009 V1: 252  
 technology advances, value engineering and, 2009 V1: 208  
*Technology for the Storage of Hazardous Liquids*, 2011 V3: 89  
 tectonic plates, 2009 V1: 148  
 tee-wyes, flow capacity and, 2010 V2: 4  
 tees (TEE), 2009 V1: 10, 30  
 Teflon (PTFE), 2009 V1: 32, 2010 V2: 239  
   as contaminant in air, 2011 V3: 265  
   joint caulking, 2011 V3: 46  
   pipes, 2012 V4: 52  
   polytetrafluoroethylene, 2009 V1: 32  
   valve seating, 2012 V4: 76, 77  
 temp., TEMP (temperatures). *See* temperature  
 TEMP. HW (tempered hot water), 2009 V1: 8  
 TEMP. HWR (tempered hot water recirculating), 2009 V1: 8  
 temperature (temp., TEMP T)  
   acid wastes, 2011 V3: 43  
   air pressure and, 2011 V3: 264  
   bathtub water notes, 2009 V1: 110  
   compressed air systems and, 2011 V3: 178  
   conversion factors, 2009 V1: 36, 37  
   cooling air compressors, 2011 V3: 178  
   corrosion rates and, 2009 V1: 135  
   CPVC vs. PVC piping, 2012 V4: 51  
   deaeration water temperatures, 2010 V2: 199  
   defined, 2011 V3: 187  
   degree systems, 2009 V1: 30  
   density and viscosity of water and, 2012 V4: 178  
   dew points, 2011 V3: 173  
   drinking-water coolers and, 2012 V4: 216  
   drops in flowing water, 2012 V4: 112–113  
   elevated temperatures for removing Legionella, 2010 V2: 109–110  
   energy conservation, 2009 V1: 117–118  
   expansion and contraction and, 2012 V4: 67  
   feed water temperature and deposits, 2010 V2: 197, 214, 221  
   flue gases, 2010 V2: 119  
   gas regulators and, 2011 V3: 272  
   hangers and supports and, 2012 V4: 119  
   hot-water properties, 2010 V2: 107  
   hot-water relief valves, 2010 V2: 106  
   hot-water temperatures, 2010 V2: 101, 102–104, 105, 2011 V3: 39, 47  
   insulation and temperature loss, 2012 V4: 103  
   laboratory gases, 2011 V3: 275, 279  
   Legionella growth and, 2010 V2: 108–110  
   maintenance hot-water temperatures, 2010 V2: 105–106  
   maintenance, pumps, 2012 V4: 98  
   measurements, 2009 V1: 33  
   microbial control in water, 2010 V2: 214  
   mixed-water temperatures, 2010 V2: 101

- natural gas, 2010 V2: 126
- non-SI units, 2009 V1: 34
- oxygen and corrosion implications, 2012 V4: 176
- pipe classification, 2012 V4: 118
- pipe expansion and contraction, 2009 V1: 3
- propane vaporization and, 2010 V2: 134
- PVC pipe and, 2012 V4: 51
- rating, sprinkler systems (fire protection), 2011 V3: 18
- scalding water, 2010 V2: 111
- scaling and, 2012 V4: 185
- settling velocity and, 2012 V4: 146
- shower compartments, 2009 V1: 112, 2012 V4: 16
- special-waste effluent, 2010 V2: 228
- specific resistance and, 2010 V2: 192
- sprinkler head ratings, 2011 V3: 13
- storage tanks and piping, 2011 V3: 154
- surface temperature of insulation, 2012 V4: 111
- swimming pool heaters, 2011 V3: 126
- temperature differences (TD,  $\Delta t$ , TDIF), 2009 V1: 128
- temperature stratification, 2011 V3: 154
- thermal expansion, 2012 V4: 205
- thermal support systems and earthquakes, 2009 V1: 160
- water heaters, 2010 V2: 97, 101
- water vapor in air and, 2011 V3: 172–173
- water volume and, 2010 V2: 67–68
- Temperature-actuated Mixing Valves for Plumbed Emergency Equipment*, 2010 V2: 105
- Temperature-actuating Mixing Valves for Hot Water Distribution Systems*, 2010 V2: 104–105
- temperature-pressure-relief valves (TPV, TPRV), 2009 V1: 10, 2010 V2: 106
- temperature stratification, 2011 V3: 154
- tempered water
  - abbreviation for, 2009 V1: 15
  - defined, 2009 V1: 30
  - tempered hot water (TEMP. HW, TW), 2009 V1: 8
- tempered hot water recirculating (TEMP. HWR, TWR), 2009 V1: 8
- temporary hardness, 2012 V4: 176
- tensile strength
  - plastic pipe, 2012 V4: 50
  - PVC pipe and, 2012 V4: 51
- tensile stresses
  - expansion and contraction, 2012 V4: 67
  - stacks, 2012 V4: 208
  - with temperature change, 2012 V4: 206
- Tension 360 bracing, 2009 V1: 162
- tension problems in seismic protection, 2009 V1: 184
- Tentative Provisions for the Development of Seismic Regulations for Buildings*, 2009 V1: 174, 185
- tera prefix, 2009 V1: 34
- terminal elements, defined, 2009 V1: 128
- terminal length, defined, 2010 V2: 1
- terminal velocity
  - defined, 2010 V2: 1
  - stack capacities and, 2010 V2: 4
  - stack terminal velocity, 2009 V1: 3
- terminal vents, 2010 V2: 34
- terra-cotta pipe sleeves, 2012 V4: 67
- terrazzo fixtures, 2012 V4: 1
- tertiary treatment of gray water, 2010 V2: 26–27, 27–28
- teslas, 2009 V1: 34
- test block conditions in gas boosters, 2010 V2: 128
- Test for Surface Burning Characteristics of Building Materials*, 2010 V2: 224
- test headers, 2009 V1: 12
- test-method standards, 2009 V1: 61
- test station cathodic protection, 2009 V1: 140
- testing
  - cold-water systems, 2010 V2: 90
  - compressed air systems, 2011 V3: 183
  - gaseous fire-suppression systems, 2011 V3: 28
  - hot-water relief valves, 2010 V2: 106
  - hydrants, 2011 V3: 3–4
  - hydraulic soil conditions, 2010 V2: 139–142
  - insulation, 2012 V4: 104
  - laboratory gas systems, 2011 V3: 280
  - liquid fuel systems, 2011 V3: 152–154
  - medical gas alarms, 2011 V3: 74–75
  - medical gas systems, 74–76, 2011 V3: 69
  - natural gas services, 2011 V3: 257
  - percolation rates for soils, 2010 V2: 141–142
  - pipes for radioactive waste systems, 2010 V2: 239
  - plastic fixtures, 2012 V4: 1
  - seat tests (valves), 2012 V4: 87
  - shell tests (valves), 2012 V4: 87
  - tank tightness testing, 2011 V3: 142–143, 153
  - urinal tests, 2012 V4: 8
  - water closet flushing, 2012 V4: 4–5
  - welders for radioactive pipe systems, 2010 V2: 239
  - wells, 2010 V2: 158
- tetrafluoroethylene (TFE), 2012 V4: 36, 60, 84
- tetrafluoroethylene valve seating, 2012 V4: 74
- text, abbreviations in, 2009 V1: 14–15
- texture of soils, 2010 V2: 140–141
- TFE (tetrafluoroethylene), 2012 V4: 36, 60, 84
- TFE (tetrafluoroethylene) valve seating, 2012 V4: 74
- that is (i.e.), 2009 V1: 15
- theaters
  - drinking fountain usage, 2012 V4: 223
  - vacuum calculations for, 2010 V2: 180
- theoretical barometric pressure, 2011 V3: 172
- theoretical horsepower, 2011 V3: 186
- therapy pools, 2011 V3: 107, 111
- therm, converting to SI units, 2009 V1: 39
- thermal compressors, 2011 V3: 187
- thermal conductivity (k, K)
  - insulation, 2012 V4: 103
  - measurements, 2009 V1: 34
  - plastic pipe, 2012 V4: 50
- thermal contraction and plumbing noise, 2009 V1: 189.
  - See also* contraction of materials
- thermal efficiency
  - defined, 2009 V1: 30, 128
  - water heaters and, 2010 V2: 107–108
- thermal energy, 2011 V3: 188–189
- thermal expansion. *See* expansion (exp, EXP, XPAN)
- Thermal Expansion and Contraction in Plastic Piping Systems*, 2009 V1: 206
- thermal-hydraulic irrigation valves, 2011 V3: 94
- thermal insulation thickness, 2009 V1: 118
- thermal loads, 2012 V4: 135
- thermal resistance (R, R, RES), 2012 V4: 103
- thermal-shock protection, 2009 V1: 112

- thermal storage devices and media, 2011 V3: 192
- thermal stresses on piping systems, 2012 V4: 116
- thermal-support systems, earthquakes and, 2009 V1: 160
- thermal transmittance (U), 2012 V4: 103
- thermocompression distillation, 2010 V2: 200
- thermodynamic disc traps, 2011 V3: 162
- thermometers, 2009 V1: 10
- thermoplastic piping, 2010 V2: 123, 2012 V4: 39, 208
- thermoplastic valves, 2012 V4: 77
- thermoset plastic, 2011 V3: 138, 2012 V4: 39
- thermostatic bellows steam traps, 2011 V3: 162
- thermostatic-mixing shower valves, 2009 V1: 15, 2012 V4: 16, 18
- thermostatic-mixing tub valves, 2012 V4: 17
- thermostatic steam traps, 2011 V3: 162
- thermostats (T STAT)
  - chilled drinking-water systems, 2012 V4: 221
  - drinking water coolers, 2012 V4: 220
- thermosyphon in fluids, 2011 V3: 192
- thermosyphon solar systems, 2009 V1: 122, 2011 V3: 192, 198
- thickness (thkns, THKNS, THK)
  - insulation, 2012 V4: 106, 107, 110–112
  - of soils, 2010 V2: 141
- thin skin membranes, 2012 V4: 197
- thinking outside the box, 2009 V1: 225
- thkns, THKNS (thickness). *See* thickness
- thousand cubic feet (Mcf, MCF), 2009 V1: 15
- thousand pounds (kip, KIP), 2009 V1: 15
- thread cutting, 2012 V4: 61
- thread lubricants, 2012 V4: 60
- thread sealants, 2012 V4: 60–61
- threaded end connections, 2009 V1: 22
- threaded joints
  - earthquake protection, 2009 V1: 160
  - mechanical joints, 2012 V4: 57
  - preparing, 2012 V4: 60–61
- threaded outlet drain body, 2010 V2: 14
- threaded outlets, 2010 V2: 13
- threaded rod couplings, 2012 V4: 135
- threaded rods, 2012 V4: 122, 135
- three-bolt pipe clamps, 2012 V4: 135
- three-compartment sinks, 2012 V4: 11
- thresholds in shower compartments, 2009 V1: 112
- throttling valves, 2012 V4: 73
- thrust blocks, 2009 V1: 30, 2011 V3: 223
- thrust loads, 2012 V4: 135
- tie rods, 2011 V3: 221
- TIG (tungsten inert gas), 2012 V4: 61
- tight piping systems, 2009 V1: 160
- tightness testing, 2011 V3: 142–143, 153
- tiles in absorption systems, 2010 V2: 143
- time (T)
  - clean agent gas fire suppression, 2011 V3: 28
  - of concentration in runoff, 2011 V3: 241–242
  - in creativity checklist, 2009 V1: 227
  - intervals in hydraulic shock, 2009 V1: 6
  - in measurements, 2009 V1: 33
  - non-SI units, 2009 V1: 34
  - time in pipes, 2011 V3: 242–243
  - time-temperature curves in fire tests, 2011 V3: 2–3
- time delays in clean gas extinguishing systems, 2011 V3: 28
- time history
  - computer analysis, 2009 V1: 180
  - earthquakes, 2009 V1: 150, 151
- timers for pumps, 2010 V2: 64
- tin
  - coatings for distillers, 2012 V4: 192
  - corrosion, 2009 V1: 129
  - distillation systems, 2012 V4: 192
  - galvanic series, 2009 V1: 132
  - piping, 2010 V2: 75
  - tin-lined copper pipes, 2011 V3: 49
- tipping prevention, 2009 V1: 183
- tissue-culture rooms, 2011 V3: 47
- titanium, 2009 V1: 132, 2011 V3: 24, 2012 V4: 192
- titration, 2012 V4: 203
- TOC (total organic carbon), 2010 V2: 194
- TOC (total oxidizable carbon), 2012 V4: 52
- toe clearance in toilet compartments, 2009 V1: 105
- toilet compartments. *See* water-closet compartments
- toilet flanges, 2009 V1: 198
- toilet paper
  - dispensers, 2009 V1: 106
  - in septic tanks, 2010 V2: 147
- toilets. *See also* water closets
  - dual-flush
    - fixture drain flow, 2010 V2: 2
    - fixture-unit loads, 2010 V2: 3
    - LEED 2009 baselines, 2010 V2: 25
  - low-flow
    - fixture drain flow, 2010 V2: 2
    - vacuum toilets, 2010 V2: 19
- tolerance, 2009 V1: 33
- tons (TON), 2009 V1: 39
- tools
  - tool access in cleanouts, 2010 V2: 9–10
  - for vacuum cleaning systems, 2010 V2: 180
- top-beam clamps, 2012 V4: 135
- top coats, 2009 V1: 136
- top elevation (TE), 2009 V1: 15
- top-spud water closets, 2012 V4: 3
- torch testing, 2012 V4: 1
- torches, propane-powered, 2010 V2: 133
- tornados, 2009 V1: 262
- Toro Company, 2011 V3: 96
- torque
  - conversion factors, 2009 V1: 35
  - converting to SI units, 2009 V1: 38
  - measurements, 2009 V1: 34
- Torr, 2009 V1: 30
- torrs, 2010 V2: 166
- total alkalinity, 2010 V2: 189
- total connected loads, 2011 V3: 51, 252, 256
- total costs
  - defined, 2009 V1: 217
  - generalized, 2009 V1: 217
- total developed lengths, 2012 V4: 206, 207
- total discharge head, defined, 2012 V4: 102
- total dissolved solids (TDS), 2010 V2: 193, 217, 2012 V4: 203
- total dynamic head (TDH), 2010 V2: 161, 2011 V3: 123
- total fixture count weights, 2012 V4: 186
- total flooding systems
  - carbon dioxide systems, 2011 V3: 26

- dry-chemical extinguishing systems, 2011 V3: 23
- total head, 2010 V2: 161
  - centrifugal pumps, 2012 V4: 93
  - defined, 2012 V4: 91, 102
  - impeller tip velocity and, 2012 V4: 95
  - pump efficiency, 2012 V4: 94
- total head/capacity curves, 2012 V4: 95–97
- total head curves, 2012 V4: 95–97
- total loads (pipe supports), 2012 V4: 115–116
- total organic carbon (TOC), 2010 V2: 194
- total oxidizable carbon (TOC), 2012 V4: 52, 195
- total pressure loss method, 2010 V2: 87, 89, 94–95
- total pumping head, 2010 V2: 161
- total suspended solids, 2010 V2: 193
- total trihalomethanes (TTHM), 2010 V2: 110
- total work force in vacuum systems, 2010 V2: 169
- tower water. *See* cooling-tower water
- towers in standpipe systems, 2011 V3: 21
- toxic, defined, 2009 V1: 31
- toxic gases, 2011 V3: 267, 275–276
- TPRV. *See* TPV (temperature-pressure-relief valves)
- TPV (temperature-pressure-relief valves), 2009 V1: 10, 2010 V2: 106
- TR-55, 2010 V2: 44–46
- trace elements in water, 2010 V2: 190
- Trace Level Analysis of High Purity Water*, 2010 V2: 224
- tractor-type grates, 2010 V2: 11
- traffic loads
  - automotive traffic and grates, 2010 V2: 11
  - bioremediation pretreatment systems, 2012 V4: 230
  - cleanouts and, 2010 V2: 9
  - grates and strainers, 2010 V2: 11
  - traffic vibration or resonance, 2012 V4: 118
- trailer parks
  - septic tank systems for, 2010 V2: 149–150
  - sewers, 2009 V1: 31
- transactions, fuel, 2011 V3: 147
- transfer fluid, heat, 2011 V3: 192
- transfer-type showers, 2009 V1: 112
- transferring hazardous wastes, 2011 V3: 84
- transition fittings, 2011 V3: 256
- transition joints, 2012 V4: 57
- transmissibility of vibration
  - designing, 2012 V4: 137
  - upper floor installation, 2012 V4: 142–143
  - varying frequency ratios and, 2012 V4: 138–139
- transmittance, 2011 V3: 193
- transmitted forces, 2012 V4: 138
- transport trucks, 2011 V3: 57
- Transportation Department. *See* U.S. Department of Transportation
- transportation gas service, 2010 V2: 114
- transportation gas services, 2011 V3: 252
- transverse bracing, 2009 V1: 159, 160, 185. *See also* lateral and longitudinal sway bracing
- transverse sway bracing, 2009 V1: 172
- trap design, 2010 V2: 31–32
- trap primers, 2009 V1: 31
- trap seals
  - defined, 2009 V1: 31
  - factors in trap seal loss, 2010 V2: 31–32
  - floor drains, 2010 V2: 11, 2012 V4: 17
  - introduction, 2010 V2: 31–32
  - primer devices, 2012 V4: 17
  - reducing trap seal losses, 2010 V2: 31–32
  - tests, 2012 V4: 5
- trapeze hangers
  - bracing pipes on trapeze, 2009 V1: 168, 171
  - defined, 2012 V4: 135
  - illustrated, 2012 V4: 64, 121
  - noise isolation, 2009 V1: 196
  - potential problems in bracing, 2009 V1: 183
  - preference for, 2012 V4: 65
  - selecting, 2012 V4: 119
- trapeziums, calculating area, 2009 V1: 4
- trapezoids, calculating area, 2009 V1: 4
- traps. *See also* trap seals
  - building traps, defined, 2009 V1: 18
  - condensate drainage, 2011 V3: 166
  - defined, 2009 V1: 30, 31
  - distance from vent connections, 2010 V2: 34
  - grease interceptors, 2012 V4: 145, 154
  - heat exchangers, 2011 V3: 167–169
  - introduction, 2010 V2: 31–32
  - sink traps, 2011 V3: 45–46
  - space heating equipment, 2011 V3: 166–167
  - special-waste drainage systems, 2010 V2: 228
  - steam, 2011 V3: 162–163
  - urinals, 2012 V4: 8
- travel devices, 2012 V4: 135
- travel indicators, 2012 V4: 135
- travel scales, 2012 V4: 135
- travel stops, 2012 V4: 135
- TRC (tubular modules in reverse osmosis), 2010 V2: 211–212
- treated water. *See also* water treatment
  - defined, 2010 V2: 187
  - from reverse osmosis, 2010 V2: 211
  - systems. *See* graywater systems
- Treating Cooling Water*, 2010 V2: 225
- treatment
  - biosolids, 2012 V4: 238–240
  - gray water, 2010 V2: 25–27, 27–28
  - oil in water, 2010 V2: 245–246
  - storm drainage, 2010 V2: 48
- Treatment of Organic Chemical Manufacturing Wastewater for Reuse (EPA 600)*, 2011 V3: 89
- treatment plants. *See also* names of specific treatment plants (chemical treatment, water treatment)
- treatment rooms
  - fixtures, 2011 V3: 38
  - health care facilities, 2011 V3: 36
  - medical gas stations, 2011 V3: 52
  - medical vacuum, 2011 V3: 54
  - water demand, 2011 V3: 46
- tree piping systems, 2011 V3: 12
- trench drains
  - in chemical plants, 2010 V2: 243
  - defined, 2012 V4: 17, 18
- trenches
  - absorption trenches. *See* soil-absorption sewage systems
  - labor productivity rates, 2009 V1: 87–88
  - sanitary sewer services, 2011 V3: 225–226, 227



- storage tank piping, 2011 V3: 155
- Tri-Services Manual*, 2009 V1: 174, 180
- triage rooms, 2011 V3: 38
- triangles
  - calculating area, 2009 V1: 4–5
  - exercise, 2009 V1: 225, 252
  - rule for sink location, 2012 V4: 11
- trichlor, 2011 V3: 128
- trichloroethylene, 2011 V3: 66
- trickle collectors, 2011 V3: 191
- trickle irrigation, 2011 V3: 94
- trickling filters, 2011 V3: 88
- triggering clean agent gas fire suppression, 2011 V3: 28
- trihalomethanes, 2010 V2: 213, 2012 V4: 177
- trip-out loads, 2012 V4: 135
- triple points, 2009 V1: 31
- triplex vacuum pump arrangements, 2010 V2: 178
- trisodium phosphate, 2010 V2: 12
- TROs (tubular modules in reverse osmosis), 2010 V2: 211–212
- truss-type bracing, 2009 V1: 182
- tsunamis, 2009 V1: 149
- TTHM (total trihalomethanes), 2010 V2: 110
- TU (turbidity units), 2012 V4: 175
- tub fillers, 2012 V4: 17
- tube ozone units, 2010 V2: 214
- tube pulls, 2009 V1: 31
- tube washers, 2011 V3: 41
- tuberculation, 2009 V1: 143
- tubing
  - natural gas systems, 2010 V2: 122–124
  - vacuum cleaning hose capacity, 2010 V2: 180
- tubular-bag separators, 2010 V2: 178
- tubular membranes, 2012 V4: 196
- tubular modules in reverse osmosis, 2010 V2: 211–212
- Tully, G.F., 2011 V3: 204
- tungsten inert gas (TIG), 2012 V4: 61
- tunnels, vibration and resonance from, 2012 V4: 118
- turbidity
  - clarification of, 2010 V2: 198–199, 2012 V4: 178–179
  - defined, 2009 V1: 31, 2010 V2: 188, 2012 V4: 203
  - drinking water, 2010 V2: 217
  - filter beds and, 2012 V4: 180
  - measuring, 2010 V2: 193
  - treating in water, 2012 V4: 175
- turbidity units (TU), 2012 V4: 175
- turbine gas meters, 2010 V2: 116–117
- turbine meters, 2010 V2: 88
- turbine pumps, 2010 V2: 160–161, 162, 2011 V3: 123–124, 2012 V4: 97
- turbine water meters, 2010 V2: 60, 61
- turbo machines. *See* pumps
- turbo pumps, 2010 V2: 169
- turbo-surgical instruments, 2011 V3: 56
- turbulence
  - defined, 2009 V1: 31
  - determining friction, 2010 V2: 74–75
  - floatation and, 2012 V4: 150
  - in grease interceptors, 2012 V4: 147
  - in rate of corrosion, 2009 V1: 135
  - turbulent flow in pipes, 2009 V1: 2
- turf
  - imperviousness factors, 2011 V3: 239
  - runoff, 2010 V2: 42
- turnbuckles
  - defined, 2012 V4: 136
  - illustrated, 2012 V4: 64, 120, 124
  - use of, 2012 V4: 65
- turndown ratio (TD), 2010 V2: 127
- turnover rate, swimming pools, 2011 V3: 111
- TW (tempered hot water). *See* tempered water
- twin-agent dry-chemical systems, 2011 V3: 23
- twin-stage propane regulators, 2010 V2: 133
- twisting motions, hangers and, 2012 V4: 116
- two. *See also* entries beginning with double-, dual-, or multiple-
  - two-bed deionizing units, 2011 V3: 48
  - two-compartment septic tanks, 2010 V2: 147
  - two-compartment sinks, 2012 V4: 11
  - two-pipe venturi suction pumps, 2010 V2: 157
  - two-point vapor recovery, 2011 V3: 145
  - two-stage propane regulators, 2010 V2: 133
  - two-stage reduction, 2010 V2: 69
  - two-step deionization (dual-bed), 2010 V2: 206, 207
  - two-valve parallel pressure-regulated valves, 2010 V2: 69–70
  - two-way braces, 2012 V4: 136
  - two-word expressions of functions, 2009 V1: 218, 225
  - TWR (tempered hot water recirculating), 2009 V1: 8
  - TYP (typical), 2009 V1: 15
  - Type 1 air compressors, 2011 V3: 62
  - Type 2 air compressors, 2011 V3: 62
  - Type A gray-water systems, 2010 V2: 26
  - Type ACR/MED pipes, 2012 V4: 32
  - Type ACR pipes, 2012 V4: 32
  - Type B gas vents, 2010 V2: 136
  - Type B gray-water systems, 2010 V2: 26
  - Type B vent codes, 2009 V1: 43
  - Type B-W gas vents, 2010 V2: 136
  - Type DWV pipes, 2012 V4: 32, 33–34
  - Type G copper, 2012 V4: 32, 34
  - Type K copper
    - copper water tube, 2012 V4: 29
    - dimensions and capacity, 2012 V4: 33–34
    - lengths, standards, and applications, 2012 V4: 32
    - medical gas tube, 2011 V3: 69, 2012 V4: 33–34
  - Type L copper
    - copper water tube, 2012 V4: 29
    - dimensions and capacity, 2012 V4: 35–36
    - lengths, standards, and applications, 2012 V4: 32
    - medical gas tube, 2011 V3: 69, 2012 V4: 33–34
    - natural gas, 2011 V3: 257
  - Type L gas vents, 2010 V2: 136
  - Type L vent codes, 2009 V1: 43
  - Type M copper
    - copper water tube, 2012 V4: 29
    - dimensions and capacity, 2012 V4: 37–38
    - lengths, standards, and applications, 2012 V4: 32
  - Type OXY/ACR pipes, 2012 V4: 32
  - Type OXY, MED pipes, 2012 V4: 32
  - Type OXY/MED pipes, 2012 V4: 32
  - typhoid, 2012 V4: 177
  - typhoons, 2012 V4: 117
  - typical (TYP), 2009 V1: 15

## U

- U bolts, 2012 V4: 120
- U, U (heat transfer coefficients) (U factor), 2012 V4: 104
- U-bolts, 2012 V4: 64, 120, 136
- UF. *See* ultrafilters and ultrafiltration
- UF membranes, 2010 V2: 191
- UFAS (Uniform Federal Accessibility Standard), 2009 V1: 97–98
- Uhlig, Herbert H., 2009 V1: 144
- UHP (utility horsepower), 2012 V4: 102
- UL listings. *See* Underwriters Laboratories, Inc. (UL)
- ULC (Underwriters Laboratories of Canada), 2009 V1: 41–42
- ULF. *See* ultra-low-flow water closets
- ultra-clean tanks, gas cylinders, 2011 V3: 268
- ultra-high purity gas grade, 2011 V3: 267, 276
- ultra-high purity plus gas grade, 2011 V3: 267
- ultra-high vacuum, 2010 V2: 165
- ultra-low-flow water closets
  - operation, 2009 V1: 127
  - water usage rates, 2009 V1: 127
- ultra-pure water (UPW), 2012 V4: 52
- ultra-pure water systems, 2010 V2: 218
- ultra zero gas grade, 2011 V3: 267
- ultrafilters and ultrafiltration
  - cross-flow filtration, 2010 V2: 201, 213
  - defined, 2012 V4: 199
  - membrane filters, 2010 V2: 211
  - oil spills, 2010 V2: 245
- Ultraviolet Disinfection in Biotechnology: Myth vs. Practice*, 2010 V2: 224
- ultraviolet disinfection standards, 2012 V4: 195
- ultraviolet rays. *See* UV (ultraviolet rays)
- U.N. World Commission on the Environment and Development, 2012 V4: 233
- unassisted creativity, 2009 V1: 227
- unbalanced forces, vibration and, 2012 V4: 138
- unblockable drains, 2011 V3: 105
- unconsolidated aquifers, 2010 V2: 157
- undamped mechanical systems, 2009 V1: 150
- under-counter grease interceptors, 2012 V4: 154
- under-counter mounted lavatories, 2012 V4: 10
- under-counter mounted sinks, 2012 V4: 11
- under-film corrosion, 2009 V1: 143
- under-floor areas, 2011 V3: 27
- under-table waste and vent piping, 2011 V3: 46
- underground building sanitary pipe codes, 2009 V1: 44
- underground digging, planning impacts of, 2012 V4: 118
- underground inspections, 2009 V1: 95
- underground piping
  - acid-waste piping, 2010 V2: 234
  - cast-iron soil pipe, 2012 V4: 25
  - coatings, 2009 V1: 136
  - defined, 2009 V1: 31
  - materials for, 2010 V2: 12–13
  - medical gas piping, 2011 V3: 68
  - thermal expansion and contraction, 2012 V4: 208–209
  - underground building sanitary pipe codes, 2009 V1: 44
  - valves, 2012 V4: 88
- underground pressurized fuel delivery systems, 2011 V3: 145
- underground sprinklers, 2011 V3: 92
- underground storage tanks (USTs)
  - abandonment and removal, 2011 V3: 154
  - codes and standards, 2011 V3: 137
  - connections and access, 2011 V3: 139
  - construction, 2011 V3: 139
  - defined, 2011 V3: 136
  - dispenser pans, 2011 V3: 146
  - filling and spills, 2011 V3: 139–140
  - fire suppression, 2011 V3: 146–147
  - fuel islands, 2011 V3: 146
  - fuel transactions, 2011 V3: 147
  - hazardous wastes, 2011 V3: 84
  - leak detection and system monitoring, 2011 V3: 141–145
  - liquid fuel storage tanks, 2011 V3: 139–140
  - materials, 2011 V3: 138
  - overflow prevention, 2011 V3: 141
  - product dispensing systems, 2011 V3: 146–147
  - testing, 2011 V3: 152
  - vapor recovery systems, 2011 V3: 145–146
  - venting, 2011 V3: 141
- underground suction fuel delivery systems, 2011 V3: 145
- underground valves, 2012 V4: 88
- Understanding the Virginia Graeme Baker Pool and Spa Safety Act*, 2011 V3: 135
- underwater pool lights, 2011 V3: 135
- underwriters. *See* insurance
- Underwriters Laboratories, Inc. (UL)
  - abbreviation for, 2009 V1: 32
  - list of standards, 2009 V1: 54
  - publications (discussed)
    - fiberglass pipe, 2012 V4: 53
    - flame testing standards, 2012 V4: 105
    - gas booster components, 2010 V2: 125
    - hot-water components, 2010 V2: 106, 112
    - pipe hangers, 2011 V3: 18
    - surface burning pipe characteristics, 2010 V2: 224
    - valve fire protection approvals, 2012 V4: 87–88
    - valve standards, 2012 V4: 73
  - publications (listed)
    - UL 142: Steel Above Ground Tanks for Flammable and Combustible Liquids*, 2011 V3: 88, 137, 147
    - UL 2080: Fire Resistant Tanks for Flammable and Combustible Liquids*, 2011 V3: 147
    - UL 2085: Insulated Aboveground Tanks for Flammable and Combustible Liquids*, 2011 V3: 137
  - web site, 2011 V3: 89
- Underwriters Laboratories of Canada, 2009 V1: 41–42
- unemployment taxes, in labor costs, 2009 V1: 86
- ungridded piping systems, 2011 V3: 12
- uniform attack corrosion, 2009 V1: 129–130
- Uniform Building Code (UBC)*, 2009 V1: 185, 2012 V4: 225
- Uniform Federal Accessibility Standard (UFAS), 2009 V1: 97–98
- uniform flow
  - in horizontal drains, 2010 V2: 6–8
  - Manning formula, 2009 V1: 1
- Uniform Plumbing Code*, 2009 V1: 206, 2010 V2: 39, 115, 136
- building fixture requirements, 2012 V4: 18
- graywater, 2010 V2: 22

- grease interceptor requirements, 2012 V4: 156–157
- minimum fixture requirements, 2012 V4: 22–23
- vent sizing, 2010 V2: 39–40
- uniform pressure loss method, 2010 V2: 87, 89, 95
- Uniformat specification system, 2009 V1: 57–58, 65–66
- unintended uses of piping, 2012 V4: 116
- uninterrupted water supplies, 2011 V3: 46
- uninterruptible gas services, 2011 V3: 251
- union bonnets, 2012 V4: 90
- union rings, 2012 V4: 90
- union shoulder pieces, 2012 V4: 90
- union threaded pieces, 2012 V4: 90
- unions (joints)
  - defined, 2012 V4: 90
  - flanged, 2009 V1: 10
  - screwed, 2009 V1: 10
  - union bonnets, 2012 V4: 90
  - union rings, 2012 V4: 79, 90
  - union shoulder pieces, 2012 V4: 90
  - union threaded pieces, 2012 V4: 90
- unions (labor), 2009 V1: 90, 2012 V4: 113
- unisex toilet rooms, 2012 V4: 19
- unit costs, in plumbing cost estimation, 2009 V1: 85
- unit heaters, condensate traps, 2011 V3: 167
- United States agencies and departments. *See* U.S. agencies and departments
- United States Pharmacopoeia. *See* U.S. Pharmacopoeia (USP)
- units, measurement. *See* measurement units
- Universal Plumbing Code (UPC)*, 2009 V1: 15
- universities. *See also* laboratories
  - diversity factor calculations, 2010 V2: 176
  - laboratory gas systems, 2010 V2: 121
- unknowns in value engineering presentations, 2009 V1: 249
- unobstructed reach for wheelchairs, 2009 V1: 103, 104
- unoccupied buildings, conserving energy in, 2009 V1: 119
- unrestricted areas (facilities with radiation), 2010 V2: 237
- unsanitary, defined, 2009 V1: 31
- untreated water. *See* water impurities
- up flow, defined, 2012 V4: 203
- UPC (*Universal Plumbing Code*), 2009 V1: 15
- UPC vent sizing, 2010 V2: 39–40
- upfeed risers, 2012 V4: 220
- upper-floor installations, 2012 V4: 142–143
- upright sprinklers, 2009 V1: 13, 29
- upstream, defined, 2009 V1: 31
- UPW (ultrapure water), 2012 V4: 52
- UR. *See* urinals (UR)
- Urban Hydrology for Small Watersheds*, 2010 V2: 44, 55
- urban storm water, 2010 V2: 27
- urinals (UR). *See also* water closets
  - abbreviation for, 2009 V1: 15
  - accessibility design, 2009 V1: 108
  - chase size, 2012 V4: 9
  - exclusion from gray-water systems, 2010 V2: 21
  - fixture pipe sizes and demand, 2010 V2: 86
  - flushing requirements, 2012 V4: 8–9
  - gray water use, 2010 V2: 23–24
  - health care facilities, 2011 V3: 35, 36
  - installation requirements, 2012 V4: 9
  - LEED 2009 baselines, 2010 V2: 25
  - minimum number for buildings, 2012 V4: 22–23
  - noise mitigation, 2009 V1: 197
  - reducing flow rates, 2009 V1: 126
  - specialty urinals, 2009 V1: 127
  - standards, 2012 V4: 2
  - submerged inlet hazards, 2012 V4: 161
  - swimming pool facilities, 2011 V3: 109
  - testing, 2012 V4: 8
  - traps, 2012 V4: 8
  - types, 2012 V4: 8
  - typical use, 2010 V2: 23
  - ultra low flow, 2009 V1: 127
  - water fixture unit values, 2011 V3: 206
  - water usage reduction, 2012 V4: 236
  - waterless, 2012 V4: 8
- U.S. Architectural and Transportation Barriers Compliance Board (ATBCB), 2009 V1: 98, 99
- U.S. Army Corps of Engineers
  - specifications, 2009 V1: 57
  - U.S. Army Corps of Engineers Manual*, 2010 V2: 137
  - value engineering, 2009 V1: 207
- U.S. Centers for Disease Control and Prevention, 2009 V1: 14, 2010 V2: 108–109
- U.S. Department of Commerce, National Information Services, 2010 V2: 29
- U.S. Department of Defense, 2009 V1: 185, 208
  - Tri-Services Manual*, 2009 V1: 180
- U.S. Department of Energy, 2009 V1: 42
  - Active Solar Energy System Design Practice Manual*, 2011 V3: 204
  - Energy Efficiency and Renewable Energy web site, 2011 V3: 204
  - Greening Federal Facilities Guide*, 2009 V1: 126
- U.S. Department of Health and Environmental Control, 2010 V2: 112
- U.S. Department of Health and Human Services, 2011 V3: 35
- U.S. Department of Housing and Urban Development, 2009 V1: 97, 99
- U.S. Department of the Army, 2010 V2: 55
- U.S. Department of Transportation (DOTn), 2009 V1: 14, 52, 2010 V2: 132
- U.S. Environmental Protection Agency
  - aggressiveness index, 2010 V2: 196
  - chemical waste system codes and, 2010 V2: 242
  - Effluent Guideline program, 2011 V3: 82–83
  - industrial waste water defined, 2011 V3: 81
  - publications (discussed)
    - bioremediation standards, 2012 V4: 227
    - drinking water standards, 2012 V4: 173
    - laboratory gas regulations, 2011 V3: 263
    - potable water treatment technologies, 2010 V2: 187
    - private water wells, 2010 V2: 155
    - storage tank regulations, 2011 V3: 137
    - tank leak detection regulations, 2011 V3: 141
    - ultraviolet disinfection standards, 2012 V4: 195
  - publications (listed), 2010 V2: 154
    - EPA 440: The EPA Effluent Guidelines Series*, 2011 V3: 89
    - EPA 600/2-79-130: Activated Carbon Process for Treatment of Wastewater Containing Hexavalent Chromium*, 2011 V3: 89
    - EPA 600: Treatment of Organic Chemical*

*Manufacturing Wastewater for Reuse*, 2011 V3: 89

regulations, 2011 V3: 81, 82

Safe Drinking Water Act and, 2010 V2: 159

special waste drainage codes and, 2010 V2: 227

water consumption statistics, 2009 V1: 127

website, 2011 V3: 156

U.S. Federal Specifications (FS), 2012 V4: 225

U.S. Food and Drug Administration, 2010 V2: 220, 224, 227

  feed water components, 2010 V2: 220

  PVDF standards, 2012 V4: 70

U.S. General Services Administration, 2009 V1: 185, 2010 V2: 29

U.S. Government Printing Office, 2011 V3: 89

U.S. Green Building Council (USGBC), 2009 V1: 32, 2012 V4: 2, 233

U.S. Occupational Safety and Health Administration, 2010 V2: 232

U.S. Pharmacopoeia (USP)

  feed water values, 2010 V2: 220

  PVDF standards, 2012 V4: 70

  USP nomographs, 2010 V2: 218

  USP purified water, 2010 V2: 219, 221

  water treatment standards, 2010 V2: 187

U.S. Public Health Service (USPHS), 2010 V2: 154

U.S. Veterans Administration, 2009 V1: 185

U.S. War Department, 2010 V2: 55

USACOE. *See* U.S. Army Corps of Engineers

usage. *See* demand

usages in swimming pools, 2011 V3: 107

use factors

  air compressors, 2011 V3: 183

  compressed air systems, 2011 V3: 183

USEPA. *See* U.S. Environmental Protection Agency

users in cost equation, 2009 V1: 217

USGBC. *See* U.S. Green Building Council (USGBC)

USP. *See* U.S. Pharmacopoeia (USP)

USP gas grade, 2011 V3: 267

USPHS (U.S. Public Health Service), 2010 V2: 154

USTs. *See* underground storage tanks (USTs)

utilities. *See* site utilities

utility controllers (gas systems), 2010 V2: 121

utility costs, lowering, 2009 V1: 119

utility gas. *See* fuel-gas piping systems

utility horsepower (UHP), 2012 V4: 102

*Utility LP-Gas Plant Code*, 2010 V2: 137

utility sinks, 2011 V3: 36

utility water treatment, 2010 V2: 214–215

UV (ultraviolet rays), 2009 V1: 15

  Legionella control, 2010 V2: 110

  sterilization, 2011 V3: 48

  swimming pool sterilization, 2011 V3: 133–134

  ultraviolet radiation, defined, 2011 V3: 193

  ultraviolet radiation treatment of water, 2010 V2: 110, 213, 218, 222, 223, 2012 V4: 193, 195

UV treatment of water, 2010 V2: 160

## V

v, V (valves). *See* valves

V (specific volume). *See* specific volume

V (velocity of uniform flow), 2009 V1: 1

V (velocity). *See* velocity

V (vents). *See* vents and venting systems

V (volts). *See* volts

v/v (volume to volume), 2010 V2: 191

vac, VAC (vacuum). *See* vacuum (vac, VAC)

vacation pay, in labor costs, 2009 V1: 86

vacuum (vac, VAC)

  defined, 2009 V1: 31, 2010 V2: 165, 2012 V4: 171

  perfect vacuum, 2011 V3: 172

  sewage lift stations, 2011 V3: 236–237

  surgical use, 2011 V3: 56

  symbols for, 2009 V1: 9, 15

  valves for systems, 2012 V4: 84–85

vacuum breakers, 2009 V1: 31. *See also* backflow preventers

  atmospheric, 2012 V4: 166

  defined, 2010 V2: 95, 2012 V4: 171

  illustrated, 2012 V4: 167

  types of, 2012 V4: 164

vacuum cleaning systems, 2010 V2: 178–186. *See also* vacuum systems

  cleanouts, 2010 V2: 186

  codes and standards, 2010 V2: 178

  components, 2010 V2: 178–179

  friction losses, 2010 V2: 181–184, 184

  inlet locations and spacing, 2010 V2: 180

  piping, 2010 V2: 179

  separators, 186, 2010 V2: 184

  simultaneous operators, 2010 V2: 180

  sizing exhausters, 2010 V2: 184

  types, 2010 V2: 178

*Vacuum Cleaning Systems*, 2010 V2: 186

vacuum deaerators, 2010 V2: 199, 2012 V4: 176

vacuum drainage systems, 2010 V2: 19

vacuum levels

  defined, 2010 V2: 165

  in exhauster sizing, 2010 V2: 184

vacuum-operated waste transport system, 2012 V4: 236

*Vacuum Piping Systems*, 2010 V2: 186

vacuum producers (exhausters), 2010 V2: 178, 181, 184

vacuum product dispensers, 2011 V3: 146, 149

vacuum pumps, 2010 V2: 169–170, 176, 2011 V3: 50, 65

vacuum relief valves, 2009 V1: 31

vacuum sand filters, 2011 V3: 118–119

*Vacuum Sewage Collection*, 2010 V2: 154

vacuum sewers, 2010 V2: 144

vacuum sources, 2010 V2: 169–171, 173, 174, 176

*Vacuum Sources*, 2010 V2: 186

vacuum systems, 2010 V2: 178–186. *See also* vacuum cleaning systems

  altitude adjustments, 2010 V2: 166–167

  codes and standards, 2010 V2: 172

  color coding, 2011 V3: 55

  fundamentals, 2010 V2: 165

  general layout, 2010 V2: 174

  introduction, 2010 V2: 165

  laboratory systems, 2010 V2: 173, 2011 V3: 41–42

  leakage, 2010 V2: 177, 178

  Level 1 defined, 2011 V3: 78

  Level 3 defined, 2011 V3: 78

  levels, 2011 V3: 34–35

  medical gas system switches, 2011 V3: 66

  medical vacuum

- design checklist, 2011 V3: 50
- diversity factors, 2011 V3: 70
- laboratory outlets, 2011 V3: 41–42
- number of stations, 2011 V3: 51, 52–53
- oral surgery equipment, 2011 V3: 42
- patient vacuum, 2011 V3: 77
  - pipng systems, 2011 V3: 54, 64–65
- pipng, 2010 V2: 173, 2011 V3: 69, 73
- pressure drop, 2010 V2: 168
- pressure measurement, 2010 V2: 166
- pump curves, 2010 V2: 168
- purchasing, 2010 V2: 170
- references, 2010 V2: 186
- sizing, 2010 V2: 174–178, 2011 V3: 69, 73
- time to reach rated vacuum, 2010 V2: 167–168
- vacuum-pressure gauges, 2010 V2: 171
- vacuum sources, 2010 V2: 169–171, 173, 176
- velocity calculations, 2010 V2: 169
- work forces, 2010 V2: 169
- vacuum tube collectors, 2011 V3: 190, 193
- valence, 2010 V2: 188, 189, 205
- Value Analysis*, 2009 V1: 252
- value, defined, 2009 V1: 209
- value engineering (VE)
  - arguments against, 2009 V1: 225
  - checklists
    - creativity worksheets, 2009 V1: 226
    - detail/product/material specification checklists, 2009 V1: 215
    - evaluation checklists, 2009 V1: 230–231
    - function definitions forms, 2009 V1: 219–224, 222
    - functional evaluation worksheets, 2009 V1: 236–247
    - idea development and estimated cost forms, 2009 V1: 234
    - idea evaluation worksheets, 2009 V1: 245
    - project information checklists, 2009 V1: 211–216
    - project information sources checklists, 2009 V1: 216
    - questions checklists, 2009 V1: 209
    - recommendation worksheets, 2009 V1: 249, 250
  - compared to cost fitting, 2009 V1: 249
  - contract document clauses, 2009 V1: 251
  - cost information, 2009 V1: 217–218
  - creativity process, 2009 V1: 223–229
  - defined, 2009 V1: 207
  - elements of, 2009 V1: 209
  - Evaluation phase, 2009 V1: 229–235
  - Function Analysis phase, 2009 V1: 218–223
  - Functional Development sketches, 2009 V1: 232–233
  - Gut Feel Index, 2009 V1: 235–248
  - Information phase, 2009 V1: 209–218
  - job plan phases, 2009 V1: 209
  - overview, 2009 V1: 207–208
  - pre-recommendation questions, 2009 V1: 248
  - purpose, 2009 V1: 207–208
  - qualitative results, 2009 V1: 208
  - Recommendation/presentation phase, 2009 V1: 249
  - results of, 2009 V1: 252
  - Risk Guides, 2009 V1: 248
  - salesmanship in, 2009 V1: 249
  - science of, 2009 V1: 251–252
  - second creativity, cost, and evaluation analysis, 2009 V1: 235
  - value changes, 2009 V1: 208
  - value defined, 2009 V1: 209
  - Value Engineering, A Plan for Invention*, 2009 V1: 252
  - Value Engineering, A Systematic Approach*, 2009 V1: 252
  - Value Engineering Change Proposals (VECP)*, 2009 V1: 251
  - Value Engineering for the Practitioner*, 2009 V1: 252
  - Value Engineering in the Construction Industry*, 2009 V1: 252
  - Value Engineering Job Plan (VEJP)*, 2009 V1: 209
  - Value Engineering: Practical Applications*, 2009 V1: 252
  - Value Engineering, Theory and Practice in Industry*, 2009 V1: 252
  - valve-per-sprinkler irrigation, 2011 V3: 92
  - valved zones in irrigation systems, 2010 V2: 25
  - valves (v, V, VLV). *See also* specific types of valves
    - applications
      - compressed air systems, 2011 V3: 176, 2012 V4: 84
      - emergency gas shutoffs, 2010 V2: 121
      - equivalent lengths for natural gas, 2010 V2: 123
      - fire-protection systems, 2012 V4: 87–88
      - gas regulators, 2011 V3: 272
      - gasoline and LPG service, 2012 V4: 87
      - high-pressure steam service, 2012 V4: 86–87
      - high-rise service, 2012 V4: 88
      - high-temperature hot-water service, 2012 V4: 87
      - hot and cold domestic water, 2012 V4: 83–84
      - hydrostatic relief, swimming pools, 2011 V3: 112–113
      - infectious waste systems, 2010 V2: 242
      - irrigation systems, 2011 V3: 94–95
      - laboratory gas systems, 2011 V3: 273–274
      - low-pressure steam and general service, 2012 V4: 85–86
      - medical air compressors, 2011 V3: 63
      - medical gas control valves, 2011 V3: 66–67
      - medical gas systems, 2012 V4: 85
      - medium-pressure steam service, 2012 V4: 86
      - propane tanks, 2010 V2: 133
      - pure water systems, 2010 V2: 224
      - steam traps, 2011 V3: 162–163
      - testing in medical gas systems, 2011 V3: 74
      - vacuum systems, 2011 V3: 65, 2012 V4: 84–85
    - as source of plumbing noise, 2009 V1: 189
    - closing quickly, 2010 V2: 71
    - codes and standards, 2009 V1: 44, 2012 V4: 73
    - components, 2012 V4: 78–80
    - defined, 2009 V1: 31
    - domestic pressure drops and, 2011 V3: 214
    - end connections, 2012 V4: 79–80
    - friction loss in, 2010 V2: 90–91
    - glossary of terms, 2012 V4: 88–90
    - installing insulation, 2012 V4: 110
    - materials for, 2012 V4: 77
    - noise mitigation, 2009 V1: 194–201
    - operating conditions, 2012 V4: 73
    - pressure losses, 2012 V4: 83
    - ratings, 2012 V4: 78
    - in risers, 2009 V1: 10
    - service considerations, 2012 V4: 73
    - sizing, 2012 V4: 83
    - stems, 2012 V4: 78
    - sulfuric acid and, 2010 V2: 230
    - types of, 2012 V4: 73–77

- angle valves, 2012 V4: 75
- automatic shutdown, 2011 V3: 84
- ball valves, 2012 V4: 75, 83, 84–85, 88
- butterfly valves, 2012 V4: 76, 84, 86, 88
- check valves, 2012 V4: 73, 84, 86, 87, 88, 89
- deluge, 2011 V3: 9–10
- diaphragm-actuated, 2011 V3: 125
- double-check valve assemblies, 2012 V4: 165
- float-operated main drain butterfly, 2011 V3: 132
- flush valve vacuum breakers, 2012 V4: 166
- gate valves, 2012 V4: 73–74, 83, 85, 86, 89
- globe valves, 2012 V4: 74–75, 83, 86, 87, 89
- lift check valves, 2012 V4: 76
- manual butterfly, 2011 V3: 125
- multi-turn valves, 2012 V4: 73
- nonlubricated plug valves, 2012 V4: 87
- plug valves, 2012 V4: 77
- pneumatically operated main drain modulating, 2011 V3: 131–132
- quarter-turn valves, 2012 V4: 73
- swing check valves, 2012 V4: 76
- water-pressure regulators. *See* water-pressure regulators
  - water-saving, 2009 V1: 127
- water-pressure regulators, 2012 V4: 82
- weight of, 2012 V4: 115
  - in yard boxes (YB), 2009 V1: 10
- vandal-proof grates and strainers, 2010 V2: 11
- vandalism
  - dressings rooms, 2011 V3: 110
  - fasteners on grates and strainers, 2010 V2: 11
  - protecting against, 2010 V2: 16
- vane-type water-flow indicators, 2011 V3: 6
- vapor barriers
  - defined, 2012 V4: 136
  - insulation, 2012 V4: 105, 107
  - perm rating, 2012 V4: 104
  - types of, 2012 V4: 112
- vapor-compression distillation, 2010 V2: 200, 2012 V4: 192
- vapor contamination in air, 2011 V3: 265
- vapor pressure, 2009 V1: 31, 2011 V3: 187
- vapor recovery systems
  - aboveground tank systems, 2011 V3: 149
  - classifications, 2011 V3: 137
  - hazardous wastes, 2011 V3: 84
  - testing, 2011 V3: 153
  - underground tank systems, 2011 V3: 145–146
- vapor return valves, propane tanks, 2010 V2: 133
- vaporization, propane tanks, 134, 2010 V2: 132
- vaporizers, 2011 V3: 57
- vapors, hazardous
  - acid wastes and, 2010 V2: 229, 231
  - atmospheric tank venting and, 2011 V3: 141
  - contamination in compressed air, 2011 V3: 173
  - hydrocarbons, 2011 V3: 136–137
  - monitoring, 2011 V3: 142, 144, 145
  - vapor pockets, 2011 V3: 153
  - VOCs, 2010 V2: 190
- variability, defined, 2012 V4: 136
- variable-area flow meters, 2011 V3: 177, 275
- variable-frequency drives (VFD), 2011 V3: 125–126
- variable-speed drivers, 2011 V3: 22
- variable-speed pressure booster pumps, 2012 V4: 102
- variable-speed pumps, 2010 V2: 63, 2011 V3: 125
- variable spring hanger indicators, 2012 V4: 136
- variable spring hangers, 2012 V4: 136
- varnishes in septic tanks, 2010 V2: 147
- vaults, subterranean fountain, 2011 V3: 99–100
- VECP (Value Engineering Change Proposals), 2009 V1: 251
- vector control, storm drainage, 2010 V2: 49
- vegetable oil, 2010 V2: 11
- vegetable peelers, 2012 V4: 161
- vehicular traffic, 2010 V2: 11
- VEJP (Value Engineering Job Plan), 2009 V1: 209
- vel., VEL (velocity). *See* velocity
- velocity (vel., VEL, V)
  - air in vents and, 2010 V2: 35
  - centralized drinking-water cooler systems, 2012 V4: 223
  - cold-water systems, 2010 V2: 75, 76–78
  - conversion factors, 2009 V1: 36
  - defined, 2009 V1: 31
  - earthquakes, 2009 V1: 150
  - floating velocity, 2012 V4: 146
  - flow from outlets, 2009 V1: 6
  - hydraulic shock, 2009 V1: 6
  - intake air in compression systems, 2011 V3: 182
  - irregularity of shapes and, 2012 V4: 146
  - Legionella growth in systems and, 2010 V2: 109
  - liquid fuel piping, 2011 V3: 151
  - measurements, 2009 V1: 34
  - non-SI units, 2009 V1: 34
  - open-channel flow, 2009 V1: 1
  - in rate of corrosion, 2009 V1: 135
  - self-scouring velocity in sewers, 2011 V3: 225
  - settling, 2012 V4: 146
  - sewage life stations, 2011 V3: 236
  - sizing method for pipes, 2010 V2: 71–72
  - steam, 2011 V3: 159–160
  - storm water in ditches, 2011 V3: 250
  - swimming pool drains, 2011 V3: 104–105
  - terminal velocity, defined, 2010 V2: 1
  - types of piping and, 2010 V2: 78
  - vacuum cleaning systems, 183, 2010 V2: 181
  - vacuum systems, 2010 V2: 169
    - water hammer and, 2010 V2: 71–72, 73, 76–78
- velocity head (h), 2009 V1: 5, 2012 V4: 102
- velocity-limited devices, 2012 V4: 136
- velocity pipe sizing method, 2010 V2: 89
- vent connectors, defined, 2010 V2: 136
- vent gases, defined, 2010 V2: 136
- vent-limiting devices, 2010 V2: 117
- vent pipes
  - cast-iron soil pipe, 2012 V4: 25
  - glass pipe, 2012 V4: 35
- vent stack terminals, 2010 V2: 34
- vent stacks
  - air in, 2010 V2: 2
  - defined, 2009 V1: 31, 2010 V2: 35
  - design, 2010 V2: 35
  - sizing, 2010 V2: 35–37
- vent systems codes, 2009 V1: 43
- ventilators, 2011 V3: 69
- vents and venting systems (V, vent, VENT). *See also* vent stack terminals; vent stacks

- aboveground tank systems, 2011 V3: 148
- acid-waste systems, 2010 V2: 229, 234, 2011 V3: 42
- air admittance valves, 2010 V2: 39
- alternative systems, 2010 V2: 39
- atmospheric tank venting, 2011 V3: 148
- chemical-waste systems, 2010 V2: 243
- combination drain and vent, 2010 V2: 33
- duct seismic protection, 2009 V1: 145
- factors in trap seal loss, 2010 V2: 31–32
- fire-suppression drainage and, 2010 V2: 244
- fixture vents, 2010 V2: 32–34, 38–39
- force mains, 2011 V3: 234–235
- gas appliances, 2010 V2: 117, 118
- gas regulator relief vents, 2010 V2: 117–118
- gas venting categories, 2010 V2: 119
- grease interceptors, 2012 V4: 154, 155
- infectious waste systems, 2010 V2: 242
- introduction, 2010 V2: 31, 34–35
- island vents, 2010 V2: 34
- jurisdictions, 2010 V2: 39–40
- laboratory waste and vent piping, 2011 V3: 46
- loop venting, 2009 V1: 31
- main vents, 2010 V2: 37
- manholes, 2011 V3: 228, 233
- mechanical area, fountain equipment, 2011 V3: 99
- natural gas venting systems, 2010 V2: 118–119
- noise mitigation, 2009 V1: 195
- offsets, 2010 V2: 37
- oil separators, 2010 V2: 246
- oxygen storage areas, 2011 V3: 59
- Philadelphia stack, 2010 V2: 39
- propane systems, 2010 V2: 134–135
- reduced-size venting, 2010 V2: 18–19
- sanitary drainage systems, 2010 V2: 18–19
- septic tank vents, 2010 V2: 148
- sewage lift stations, 2011 V3: 236–237
- single stack, 2010 V2: 39
- sizes and lengths, 2009 V1: 3, 2010 V2: 35–37
- sizing, 2010 V2: 39–40
- Sovent systems, 2010 V2: 39
- special-waste drainage systems, 2010 V2: 228
- storm-drainage stacks, 2010 V2: 50
- suds venting, 2010 V2: 37–38
- swimming pools, 2011 V3: 108
- symbols for, 2009 V1: 8, 15
- testing, 2011 V3: 153
- thermal expansion and contraction, 2012 V4: 207–208
- traps and trap seals, 2010 V2: 31–32
- underground liquid fuel tanks, 2011 V3: 141
- vent-limiting devices, 2010 V2: 117
- vented inlet tees in septic tanks, 2010 V2: 146
- waste anesthetic gas management, 2011 V3: 65–66
- waste stacks, 2010 V2: 33
- venturi suction pumps, 2010 V2: 157
- verbs in function analysis, 2009 V1: 218, 219, 225
- vert., VERT (vertical). *See* vertical
- vertical forces, 2009 V1: 183
- vertical high-rate sand filters, 2011 V3: 118
- vertical leaders, 2010 V2: 50
- vertical movement of hangers and supports, 2012 V4: 118
- vertical natural frequencies, 2012 V4: 138
- vertical pipes, 2009 V1: 31, 2012 V4: 119
- vertical pressure media filters, 2010 V2: 201
- vertical pressure sand filters, 2012 V4: 180
- vertical pumps, 2012 V4: 96, 97
- vertical risers for vacuum systems, 2010 V2: 180
- vertical seismic load, 2009 V1: 177
- vertical shaft turbine pumps, 2009 V1: 23
- vertical stacks
  - anchors, 2012 V4: 207
  - calculating terminal velocity and length, 2009 V1: 3
  - defined, 2010 V2: 1
  - fittings, 2010 V2: 1
  - flow in, 2010 V2: 1–2
  - hydraulic jumps and, 2010 V2: 2, 35
  - loading tables, 2010 V2: 4
  - maximum fixture-unit values, 2010 V2: 4
  - multistory stacks, 2010 V2: 5
  - noise mitigation, 2009 V1: 194
  - pneumatic pressure in, 2010 V2: 2–3
  - sizing, 2010 V2: 5
  - stack capacities, 2010 V2: 3–5
  - stacks, defined, 2009 V1: 29
  - storm-drainage stacks, 2010 V2: 50
  - thermal expansion or contraction, 2012 V4: 207
  - weight of, 2010 V2: 2
- vertical turbine pumps
  - fire pumps, 2011 V3: 21
  - illustrated, 2010 V2: 161
  - private water systems, 2010 V2: 160–161
  - shallow wells, 2010 V2: 162
  - swimming pools, 2011 V3: 123–124
- vertical velocity, 2012 V4: 146
- VGB (Virginia Graeme Baker Pool and Spa Safety Act), 2011 V3: 101, 104–106, 112
- VGB stamps, 2011 V3: 104, 112
- viable-count essays, 2010 V2: 188
- vibrating fill above sewers, 2010 V2: 15
- vibration and vibration isolation
  - applications, 2012 V4: 142–143
  - calculating, 2012 V4: 140–141
  - compressed air systems, 2011 V3: 182
  - compression joints, 2012 V4: 57
  - defined, 2012 V4: 137
  - earthquakes
    - earthquake vibration periods, 2009 V1: 150
    - floor-mounted equipment, 2009 V1: 157–158
    - piping and, 2009 V1: 160
    - suspended equipment, 2009 V1: 158
  - formulas for transmissibility, 2012 V4: 138–139
  - glossary, 2012 V4: 137
  - hangers and supports and, 2012 V4: 118
  - natural or free vibration, 2009 V1: 150
  - noise-related lawsuits, 2009 V1: 263
  - piping, 2009 V1: 160, 2012 V4: 143. *See also* water hammer
  - pumps, 2009 V1: 196, 202, 2012 V4: 99
  - speed and vibration control, 2012 V4: 143
  - types of vibration control devices
    - cork, 2012 V4: 139
    - defined, 2012 V4: 136
    - elastomers, 2012 V4: 139
    - neoprene rubber, 2012 V4: 139
    - steel spring isolators, 2012 V4: 139–142

- vibration isolation mounts, 2009 V1: 153
  - vibration isolators, 2012 V4: 137
  - water supply systems, 2009 V1: 191–192
  - vibration isolation devices. *See* vibration and vibration isolation
  - video equipment, 2010 V2: 10
  - vinyl coatings, 2009 V1: 136
  - Virginia Graeme Baker Pool and Spa Safety Act (VGB), 2011 V3: 101, 104–106, 112
  - viruses
    - defined, 2012 V4: 203
    - distilled water and, 2012 V4: 192
    - in feed water, 2010 V2: 188, 213
    - ozone treatments and, 2012 V4: 194
    - storm water, 2010 V2: 43, 49
  - visc. *See* viscosity (visc, VISC, MU)
  - viscosity (visc, VISC, MU)
    - calculating values of, 2009 V1: 2
    - defined, 2011 V3: 136
    - kinematic, 2010 V2: 73, 74, 77
    - measurements, 2009 V1: 34
    - settling velocity and, 2012 V4: 178
  - visual inspections, 2009 V1: 267–270
  - visualization in function analysis, 2009 V1: 219
  - Viton, 2009 V1: 32
  - vitreous china fixtures, 2011 V3: 35, 2012 V4: 1, 2
  - vitriified clay, 2009 V1: 31
  - vitriified clay piping, 2010 V2: 75, 243, 2011 V3: 242
    - characteristics, 2012 V4: 53
    - dimensions, 2012 V4: 54
    - standards, 2012 V4: 71
  - VLV (valves). *See* valves
  - VOCs (volatile organic compounds). *See* volatile organic compounds
  - vol., VOL (volume). *See* volume
  - volatile liquids, 2010 V2: 12, 244–246
  - volatile organic compounds (VOCs), 197, 2009 V1: 15, 2010 V2: 187, 190, 2011 V3: 137, 145
  - volatile substances in distillation, 2012 V4: 191
  - volcanoes, 2009 V1: 148
  - volts (V, E, VOLTS)
    - decomposition potential defined, 2009 V1: 142
    - measurement conversions, 2009 V1: 34
  - volume (vol., VOL)
    - calculating, 2009 V1: 3–5
    - conversion factors, 2009 V1: 36
    - flow rate measurements, 2009 V1: 34, 2010 V2: 166
    - formulas, 2012 V4: 147
    - gas particles, 2011 V3: 171
    - initial and expanded water volume, 2012 V4: 209
    - nominal volume, 2012 V4: 211
    - non-SI units, 2009 V1: 34
    - saturated steam, 2011 V3: 157–158
    - sink volume calculations, 2012 V4: 155
    - volumetric expansion, 2012 V4: 211
    - water calculations, 2010 V2: 67–68
  - volume to volume (v/v), 2010 V2: 191
  - volumetric expansion, 2012 V4: 211
  - volute pumps, 2012 V4: 92
  - volutes, 2012 V4: 97
  - vortex in storm drainage collection systems, 2010 V2: 46
- ## W
- W (walls), 2009 V1: 202
  - W (waste sewers), 2009 V1: 8, 15
  - W (watts). *See* watts
  - W/m K (watts per meter per kelvin), 2009 V1: 34
  - w/w (weight to weight), 2010 V2: 191
  - wading areas, 2011 V3: 107
  - wading pools, 2011 V3: 109, 111
  - wafer butterfly valves, 2010 V2: 179
  - wafer-style valves, 2012 V4: 76
  - WAG (waste anesthetic gases), 2011 V3: 65–66
  - WAGD (waste anesthetic-gas disposal), 2011 V3: 55, 65–66, 78
  - wages, in labor costs, 2009 V1: 86
  - waiting rooms, 2011 V3: 36
  - WAL (walls), 2009 V1: 202
  - walking, noise of, 2009 V1: 187–188
  - wall carriers, 2012 V4: 5–6
  - wall cleanouts (WCO), 2009 V1: 11
  - wall-hung equipment
    - earthquake restraints, 2009 V1: 155
    - quality installations, 2009 V1: 259
  - wall-hung fixtures, noise mitigation and, 2009 V1: 197
  - wall-hung lavatories, 2012 V4: 10
  - wall-hung urinals, 2012 V4: 9
  - wall-hung water closets, 2009 V1: 197, 2012 V4: 3, 5–6
  - wall-hung water coolers, 2012 V4: 217, 218
  - wall hydrants (WH), 2009 V1: 10, 12, 15, 31, 2010 V2: 86
  - wall inlets, swimming pools, 2011 V3: 135
  - wall-mounted medical gas stations, 2011 V3: 56
  - walls (W, WAL), 2009 V1: 202
  - ward rooms, 2011 V3: 37
  - ware washers, 2012 V4: 229
  - warning systems (medical gas), 2011 V3: 67, 74–75
  - warping, joints resistant to, 2012 V4: 57
  - warranty section in specifications, 2009 V1: 64, 70–71
  - Warren, Alan W., 2010 V2: 55
  - wash basins. *See* sinks and wash basins
  - wash-down urinals, 2012 V4: 8
  - wash troughs, 2012 V4: 180
  - washdown water closets, 2012 V4: 2
  - washing floors with gray water, 2010 V2: 21
  - washing machines. *See* laundry systems and washers
  - washout urinals, 2012 V4: 8
  - washout water closets, 2012 V4: 2
  - washrooms. *See* water-closet compartments
  - waste, defined, 2009 V1: 31
  - waste anesthetic-gas disposal, 2011 V3: 55, 65–66, 78
  - waste brines, 2010 V2: 148, 210
  - waste-disposal units. *See* food waste grinders
  - waste fitting standards, 2012 V4: 2
  - waste grinders, 2011 V3: 36. *See also* food waste grinders
  - waste-heat usage, 2009 V1: 123–126
  - waste-heat vaporizers, 2011 V3: 57
  - waste oil (WO), 2009 V1: 8, 2011 V3: 136
  - waste oil vents (WOV), 2009 V1: 8
  - waste or soil vents. *See* stack vents
  - waste pipes, 2009 V1: 31, 2012 V4: 25
  - waste sewers (W), 2009 V1: 8, 15
  - waste stacks, 2010 V2: 1
  - vents, 2010 V2: 33
  - waste streams



- evaluation, 2011 V3: 83
- segregating, 2011 V3: 86
- waste transport, vacuum-operated, 2012 V4: 236
- wastewater. *See also* graywater; storm water; wastewater management
  - codes and standards, 2010 V2: 22
  - defined, 2010 V2: 21
  - introduction, 2010 V2: 21
  - issues of concern, 2010 V2: 22, 24
  - LEED certification, 2010 V2: 21
  - water balance, 2010 V2: 21–23, 28
- Wastewater Engineering: Treatment/Disposal/Reuse*, 2010 V2: 154
- wastewater heat recovery, 2009 V1: 125
- wastewater management. *See also* graywater systems; private onsite wastewater treatment systems (POWTS)
  - biosolids, 2012 V4: 238–240
  - black water, 2012 V4: 237, 238, 239
  - energy requirements, 2012 V4: 241
  - graywater, 2012 V4: 236–237, 238, 239
  - individual aerobic wastewater treatment, 2010 V2: 150
  - industrial wastewater treatment. *See* industrial wastewater treatment
  - overview, 2012 V4: 236
  - rainwater, 2012 V4: 236
  - reclaimed and gray water systems, 2009 V1: 126, 2010 V2: 25–27
- wastewater pumps, 2012 V4: 98–99
- WAT (watts). *See* watts
- water (WTR). *See also* water analysis; water chemistry; water-distribution pipes and systems
  - as seal liquid in liquid ring pumps, 2010 V2: 170
  - average daily use, 2009 V1: 117
  - contamination in compressed air, 2011 V3: 173
  - distribution hazards, cross-connections, 2012 V4: 161, 162
  - expansion formulas, 2012 V4: 209–211
  - formula, 2012 V4: 173
  - freezing points (fp, FP), 2012 V4: 112–113
  - graywater. *See* graywater systems
  - human body, need for, 2012 V4: 215
  - kinematic viscosity, 2010 V2: 73, 74, 77
  - lead-free legislation, 2012 V4: 225
  - mass and volume calculations, 2010 V2: 67–68
  - methods for treatment, 2012 V4: 175–177
  - oil-water separation, 2011 V3: 88
  - plastic corrosion and, 2009 V1: 141
  - portable fire extinguishers, 2011 V3: 29
  - quality, storm drainage, 2010 V2: 43
  - samples of, 2010 V2: 91
  - specific volumes, 2012 V4: 209
  - temperature drop, 2012 V4: 112–113
  - thermodynamic properties, 2012 V4: 209
  - types of
    - deionized water, 2012 V4: 175
    - distilled water (DL), 2012 V4: 175
    - high purity water, 2012 V4: 195, 197–198
    - potable water, 2012 V4: 52, 174–175
    - purified water (PW), 2012 V4: 175
    - raw water, 2012 V4: 174
    - reagent and laboratory grades, 2012 V4: 197–198
    - soft water (SW), 2012 V4: 175
    - tower water, 2012 V4: 175
  - wastewater. *See* wastewater
  - weight calculations, 2012 V4: 209
- water absorption, plastic pipe and, 2012 V4: 50
- water analysis
  - aggressiveness index, 2010 V2: 196
  - codes and standards, 2010 V2: 187
  - example report, 2010 V2: 192
  - introduction, 2010 V2: 191
  - pH, 2010 V2: 192, 197
  - predicting water deposits and corrosion, 2010 V2: 196–197
  - references, 2010 V2: 224–225
  - Ryzner stability index, 2010 V2: 196
  - silt density index, 2010 V2: 194
  - specific conductance, 2010 V2: 193
  - total dissolved solids, 2010 V2: 193
  - total organic carbon, 2010 V2: 194
  - total suspended solids, 2010 V2: 193
  - water softeners and, 2012 V4: 187
- water attractions, 2011 V3: 109
- water balance, 2010 V2: 21–23, 28, 2011 V3: 128
- water chemistry
  - elements, acids, and radicals in water, 2010 V2: 189
  - introduction, 2010 V2: 187–188
- water chillers, 2012 V4: 215
- water circulation pumps, 2012 V4: 98
- water-closet compartments
  - accessibility, 2009 V1: 105–108
  - ambulatory-accessible toilet compartments, 2009 V1: 106
  - patient rooms, 2011 V3: 37
  - single-occupant unisex toilet rooms, 2012 V4: 21
  - spacing, 2012 V4: 5–6
  - swimming pool bathhouses, 2011 V3: 110
- water-closet flanges, 2012 V4: 5
- water closets (WC). *See also* urinals
  - abbreviation for, 2009 V1: 15
  - accessibility design, 2009 V1: 105–108
  - bariatric, 2012 V4: 4, 6
  - bolts, 2012 V4: 5
  - chase size, 2012 V4: 6, 7
  - conserving water in, 2010 V2: 149
  - exclusion from gray-water systems, 2010 V2: 21
  - fixture pipe sizes and demand, 2010 V2: 86
  - fixture-unit loads, 2010 V2: 3
  - flushing performance testing, 2012 V4: 4–5
  - flushing systems, 2012 V4: 6–8
  - gray water usage, 2010 V2: 22–24
  - in health care facilities, 2011 V3: 35, 36, 37
  - high-efficiency toilets (HET), 2009 V1: 127
  - installation requirements, 2012 V4: 5–6
  - minimum numbers of, 2012 V4: 20–23
  - mounting, 2012 V4: 3
  - noise mitigation, 2009 V1: 192, 194
  - poor installations of, 2009 V1: 255, 257
  - rates of sewage flows, 2010 V2: 153
  - reducing flow rates, 2009 V1: 126
  - seats, 2012 V4: 4
  - shapes and sizes, 2012 V4: 3–4
  - specimen-type, 2011 V3: 38
  - standards, 2012 V4: 2, 5
  - submerged inlet hazards, 2012 V4: 161

- swimming pool facilities, 2011 V3: 109
- types of, 2009 V1: 127, 2012 V4: 2–3
- ultra-low-flow, 2009 V1: 127
- water conservation, 2009 V1: 127
- water fixture unit values, 2011 V3: 206
- water usage reduction, 2012 V4: 236
- water column (wc), 2012 V4: 5
- water conditioning. *See also* water purification; water softeners; water treatment
  - defined, 2010 V2: 187
  - drinking water coolers, 2012 V4: 220–221
  - glossary, 2012 V4: 199–203
- water-conditioning or treating devices, 2009 V1: 31
- Water Conditioning Manual*, 2010 V2: 224
- water conservation. *See* conserving water
- water consumption. *See* demand
- water consumption tests, 2012 V4: 5, 8
- water-cooled after-coolers, 2011 V3: 178
- water-cooled condensers, 2012 V4: 220
- water coolers. *See* drinking-water coolers
- water damage
  - insulation and, 2012 V4: 103, 107, 113
  - sprinkler systems, 2011 V3: 2
  - swimming pool bathhouses, 2011 V3: 110
- water deposits, 2010 V2: 195, 196–197
- Water Distributing Systems for Buildings, 2010 V2: 96
- water distribution, defined, 2010 V2: 95
- water-distribution pipes and systems. *See also* cold-water systems; hot-water systems
  - codes, 2009 V1: 45
  - defined, 2009 V1: 31, 2012 V4: 171
  - hazardous connections, 2012 V4: 161
  - pipe codes, 2009 V1: 45
  - service connections, 2012 V4: 67
  - water supply and distribution symbols, 2009 V1: 12
  - water supply systems, 2009 V1: 31
  - weight of water-filled pipes, 2009 V1: 177
- Water Efficiency design (LEED), 2012 V4: 2
- water features, 2011 V3: 134
- water fixture units (WFU), 2009 V1: 15
- water-flow indicators, 2011 V3: 6
- water flow tests, 2010 V2: 84–87
- water for injection (WFI), 2010 V2: 219, 221, 223, 2012 V4: 192, 199
- water gas, 2010 V2: 114
- water glass, 2009 V1: 140
- water hammer
  - as source of plumbing noise, 2009 V1: 189
  - calculating hydraulic shock, 2009 V1: 6
  - condensates and, 2011 V3: 162
  - controlling water hammer, 2010 V2: 72–73
  - defined, 2009 V1: 31, 2010 V2: 70–73
  - fuel dispensers, 2011 V3: 151
  - hangers and supports and, 2012 V4: 117
  - noise mitigation, 2009 V1: 192
  - shock intensity, 2010 V2: 71
  - sizing of arresters, 2010 V2: 72–73
  - symbols on arresters, 2010 V2: 72
  - system protection and control, 2010 V2: 72–73
  - velocity and, 2010 V2: 76–78
  - water hammer loads, 2012 V4: 136
- water hammer arresters (WHA)
  - as protection and control, 2010 V2: 72–73
  - codes, 2009 V1: 43
  - defined, 2009 V1: 31
  - noise mitigation, 2009 V1: 192
  - sizing, 2010 V2: 72–73
  - symbols, 2009 V1: 10, 2010 V2: 72
- water heaters. *See also* hot-water systems
  - avoiding standby losses, 2009 V1: 119
  - booster water heaters, 2009 V1: 121, 2010 V2: 104
  - codes, 2009 V1: 43
  - conserving energy, 2009 V1: 117–120, 119
  - earthquake damage, 2009 V1: 152
  - earthquake protection, 2009 V1: 153, 154–157
  - efficiency, 2010 V2: 97–98
  - energy efficiency, 2012 V4: 241
  - expansion tanks, 2010 V2: 67–68
  - explosions, 2010 V2: 97
  - gas efficiency, 2010 V2: 115
  - gas water heaters, 2009 V1: 121
  - hard water and, 2012 V4: 185
  - heat recovery, 2010 V2: 100–101
  - improper installations, 2009 V1: 253–254
  - indirect-fired, 2010 V2: 104
  - locations of, 2009 V1: 120
  - materials expansion, 2012 V4: 211
  - noise mitigation, 2009 V1: 199
  - overview, 2010 V2: 101–105
  - point-of-use booster heaters, 2011 V3: 47
  - product spec sheets, 2009 V1: 256
  - relief valves, 2012 V4: 209
  - sizing, 2010 V2: 98–99
  - solar, 2011 V3: 189, 196–199, 202, 2012 V4: 241
  - solar thermal, 2010 V2: 104
  - steam indirect-fired, 2010 V2: 104
  - stratification in water heaters, 2010 V2: 105
  - suspended, 2009 V1: 258
  - swimming pools, 2011 V3: 126–127
  - temperature, 2010 V2: 97, 101
  - thermal efficiency, 2010 V2: 107–108
  - types of systems, 2009 V1: 120
  - venting systems, 2010 V2: 118
- water horsepower, 2012 V4: 102
- water impurities, 2010 V2: 188–191
  - alkalinity, 2010 V2: 189
  - analysis and measurement, 2010 V2: 191–194
  - biological fouling, 2010 V2: 195, 217
  - conditions and recommended treatments, 2012 V4: 174, 175–184
  - dissolved gases, 2010 V2: 190
  - hardness, 2010 V2: 189
  - microorganisms, 2010 V2: 188
  - need for treatment, 2012 V4: 173–174
  - specific resistance, 2010 V2: 192
  - suspended solids, 2010 V2: 188
  - treatment methods, 2010 V2: 197–214
  - volatile organic compounds, 2010 V2: 190
- water lateral, defined, 2010 V2: 95
- water levels, fountains, 2011 V3: 102
- water mains
  - age and size, 2011 V3: 6
  - copper pipe, 2012 V4: 29, 32
  - defined, 2009 V1: 31

- fire-protection connections, 2011 V3: 217, 220
- inspection checklist, 2009 V1: 95
- pressure and, 2011 V3: 206
- sprinkler systems, 2011 V3: 3
- water makeup, 2012 V4: 224
- Water Management: A Comprehensive Approach for Facility Managers*, 2010 V2: 29
- water management plans, 2009 V1: 126
- water meters
  - domestic water meters, 2010 V2: 59–60
  - flow-pressure loss averages, 2010 V2: 61
  - irrigation, 2011 V3: 95–96
  - loss of pressure, 2010 V2: 84
  - pressure losses, 2011 V3: 216
  - readings in consumption estimates, 2012 V4: 186
- water mist extinguishing systems, 2011 V3: 24–25
- Water Mist Fire Protection Systems (NFPA 750)*, 2011 V3: 30
- water motor gongs, 2011 V3: 6
- water, oil, and gas (WOG) pressure rating, 2009 V1: 15, 2012 V4: 78, 84
- water pipes. *See* cold-water systems; hot-water systems; water-distribution pipes and systems
- water polishing, 2012 V4: 198
- water pressure
  - excess water pressure, 2010 V2: 68–70
  - gravity-tank systems, 2010 V2: 65–66
  - hydropneumatic-tank systems, 2010 V2: 64–65
  - water hammer and, 2010 V2: 72
- water-pressure regulators
  - installing, 2012 V4: 82
  - selection and sizing, 2012 V4: 80–82
  - types of, 2012 V4: 80–82
- water pumps. *See* pumps
- water purification and quality
  - central purification equipment, 2010 V2: 223–234
  - Clean Water Act, 2011 V3: 82–83
  - codes and standards, 2010 V2: 187, 218
  - conductivity/resistivity meters, 2012 V4: 183
  - glossary, 2012 V4: 199–203
  - gray-water systems, 2010 V2: 27–28
  - introduction, 2010 V2: 159
  - measuring, 2012 V4: 175
  - methods, 2011 V3: 47–48
  - pharmaceutical systems, 2010 V2: 219
  - polishers and, 2010 V2: 210
  - pure-water systems defined, 2010 V2: 187
  - references, 2010 V2: 224–225
  - reverse osmosis and, 2012 V4: 197–198
  - specific resistance of pure water, 2010 V2: 192
  - system design, 2010 V2: 221
  - types of water
    - biopure water, 2012 V4: 175
    - deionized water, 2012 V4: 175
    - distilled water (DL), 2012 V4: 175
    - feed water, 2010 V2: 219
    - grades of laboratory water, 2010 V2: 219
    - high-purity water, 2011 V3: 47, 2012 V4: 175, 197, 197–198, 202
    - potable water, 2012 V4: 174–175
    - reagent and laboratory grades, 2012 V4: 197–198
    - water impurities, 2010 V2: 188–191
- water quality. *See* water purification and quality
- water-resistivity meters, 2010 V2: 193
- water-reuse systems. *See* graywater systems
- water rise tests, 2012 V4: 5
- water risers, 2009 V1: 31
- water saver devices in reverse osmosis, 2012 V4: 198
- water seals, 2009 V1: 31
- water service
  - calculation worksheet, 2011 V3: 207
  - defined, 2010 V2: 95
- water-service pipes, defined, 2009 V1: 31
- water service entrances, 2012 V4: 171
- water shock absorbers. *See* water hammer arresters (WHA)
- water slides, 2011 V3: 107
- water softeners
  - as pretreatments, 2012 V4: 187
  - chemicals, 2012 V4: 173, 175
  - for distillation, 2012 V4: 194
  - earthquake damage, 2009 V1: 152
  - efficiency, 2012 V4: 188
  - exchanging contaminants, 2012 V4: 198
  - fixture flow rates for, 2012 V4: 186
  - hardness exchange ability, 2012 V4: 187
  - hardness of water, 2010 V2: 189
  - ion-exchange, 2010 V2: 201, 2012 V4: 182–184, 184
  - leakage, 2010 V2: 210
  - overview, 2012 V4: 184–185
  - pure water systems, 2010 V2: 222
  - regeneration, 2012 V4: 185, 187
  - salt recycling systems, 2012 V4: 189
  - salt storage, 2012 V4: 189
  - selection factors, 2012 V4: 185–188
  - single or multiple systems, 2012 V4: 188
  - sizing, 2012 V4: 188, 190
  - space needs, 2012 V4: 188
  - survey data, 2012 V4: 189
  - types of, 2010 V2: 160, 210
  - utility water, 2010 V2: 215
  - waste brines, 2010 V2: 148
- water consumption guide, 2012 V4: 187
- water sports, 2011 V3: 107
- water spray fixed extinguishing systems, 2011 V3: 24
- Water Spray Fixed Systems for Fire Protection (NFPA 15)*, 2011 V3: 30
- water-storage tanks
  - earthquake damage, 2009 V1: 152
  - fire-protection water supply, 2011 V3: 225
  - pressure regulators, 2010 V2: 163–164
  - types of, 2010 V2: 162
- water levels in, 2010 V2: 162
- water supply fixture units (WSFU), 2010 V2: 76
- water-supply systems. *See* cold-water systems; domestic water supply; fire-protection systems; hot-water systems; private water systems; water-distribution pipes and systems; wells
- Water Systems for Pharmaceutical Facilities*, 2010 V2: 224
- water tables
  - underground storage tanks and, 2011 V3: 138
  - wells, 2010 V2: 157–158
- Water Tanks for Fire Protection*, 2010 V2: 162
- water temperature. *See also* hot-water temperatures
  - bathtub water notes, 2009 V1: 110

- chilled water systems, 2012 V4: 221
- deaeration water temperatures, 2010 V2: 199
- feed water temperature and deposits, 2010 V2: 197, 214, 221
- hot-water properties, 2010 V2: 107
- hot-water relief valves, 2010 V2: 106
- hot-water temperatures, 2010 V2: 101, 102–104, 2011 V3: 39, 47
- maintenance hot-water temperatures, 2010 V2: 105–106
- mixed-water temperatures, 2010 V2: 101
- scalding water, 2010 V2: 111
- shower compartments, 2009 V1: 112, 2012 V4: 16
- swimming pools, 2011 V3: 108
- water heaters, 2010 V2: 97, 101
- water toys, 2011 V3: 107
- water treatment
  - boiler feed water, 2010 V2: 215–216
  - chemicals, 2012 V4: 173
  - codes and standards, 2010 V2: 187
  - conditions and recommended treatments, 2012 V4: 175–184
  - cooling towers, 2010 V2: 216–217
  - corrosion inhibitors, 2009 V1: 141
  - defined, 2010 V2: 187
  - drinking water, 2010 V2: 218
  - external and internal treatments, 2012 V4: 174
  - fountains and pools, 2011 V3: 98
  - methods of producing, 2012 V4: 175
  - microbial control, 2010 V2: 213–214
  - references, 2010 V2: 224–225
  - series equipment, 2012 V4: 186
  - specific impurities, 2012 V4: 174
  - surface and groundwater needs, 2012 V4: 173–174
  - swimming pools, 2011 V3: 110
  - types of
    - aeration, 2010 V2: 197–198
    - chlorination, 2012 V4: 177–178
    - clarification, 2010 V2: 198–199, 2012 V4: 178–179
    - copper-silver ionization, 2012 V4: 199
    - deaeration, 2010 V2: 199
    - dealkalizing, 2010 V2: 199
    - decarbonation, 2010 V2: 199
    - demineralization, 2012 V4: 182–184
    - distillation, 2010 V2: 199–201, 2012 V4: 189–194
    - filtration, 2010 V2: 201–204, 2012 V4: 179–182, 199
    - ion-exchange and removal, 2010 V2: 201–211, 2012 V4: 182–184
    - membrane filtration and separation, 2010 V2: 201, 211–213
    - nanofiltration, 2012 V4: 199
    - ozonation, 2012 V4: 194–195
    - reverse osmosis, 2012 V4: 175, 195–199
    - service deionized water, 2012 V4: 182
    - ultrafiltration, 2012 V4: 199
    - ultraviolet light, 2012 V4: 193
    - water purification, 2010 V2: 218–219
    - water softening, 2010 V2: 210, 2012 V4: 184–189
  - utility water treatment, 2010 V2: 214–215
  - water impurities, 2010 V2: 188–191
- Water Treatment for HVAC and Potable Water Systems*, 2010 V2: 224
- Water Use in Office Buildings*, 2010 V2: 29
- Water: Use of Treated Sewage on Rise in State*, 2010 V2: 29
- Water Uses Study*, 2010 V2: 29
- water utility letters, 2011 V3: 208
- water vapor in air
  - compressed air, 2011 V3: 265–266
  - physics of, 2012 V4: 103
  - properties, 2011 V3: 172–173
  - removing, 2011 V3: 273
- water wells. *See* wells
- water working pressure (WWP), 2009 V1: 15, 2012 V4: 88
- waterborne radioactive waste (radwaste), 2010 V2: 236
- waterfall aerators, 2010 V2: 198
- waterfalls, 2011 V3: 100
- waterless urinals, 2009 V1: 127, 2012 V4: 8
- waterproof manholes, 2011 V3: 228, 233
- waterproofing drains, 2010 V2: 15–16, 53
- watts (W, WAT)
  - converting to SI units, 2009 V1: 39
  - defined, 2011 V3: 193
  - measurement conversions, 2009 V1: 34
  - W/m K (watts per meter per kelvin), 2009 V1: 34
- wave actions in water (tsunamis), 2009 V1: 149
- wave pools, 2011 V3: 107–108
- wax ring seals, 2012 V4: 5
- Wb (webers), 2009 V1: 34
- WC. *See* water closets (WC)
- wc (water column), 2012 V4: 5
- WCO (wall cleanouts), 2009 V1: 11
- WD (wind). *See* wind
- weak-base regeneration, 2010 V2: 206, 207
- weather conditions, 2009 V1: 90
  - aboveground tanks and, 2011 V3: 148
  - domestic water service pressure and, 2011 V3: 210
  - irrigation and, 2011 V3: 91, 96
  - pipe insulation, 2012 V4: 107
  - pipe supports and, 2012 V4: 115
  - regional requirements for plumbing installations, 2009 V1: 262
- webers, 2009 V1: 34
- wedges (valves), 2012 V4: 90
- weep holes, 2010 V2: 16, 2012 V4: 16
- weight (wt, WT)
  - clean agent gas fire containers, 2011 V3: 27
  - horizontal loads of piping, 2009 V1: 177
  - piping, earthquake protection and, 2009 V1: 159
  - in seismic force calculations, 2009 V1: 177
  - water, 2012 V4: 209
  - weight loss in corrosion, 2009 V1: 134
- weight to weight (w/w), 2010 V2: 191
- weighted evaluations in value engineering, 2009 V1: 235
- weighting flow rates in fixture estimates, 2012 V4: 186
- weirs, 2011 V3: 100
- Welded and Seamless Wrought-Steel Pipe*, 2010 V2: 122
- welded attachments and supports, 2012 V4: 119, 121
- welded beam attachments, 2012 V4: 136
- welded ends on valves, 2012 V4: 79
- welded joints, 2012 V4: 58, 61
- welded pipe attachments, 2012 V4: 136
- welded steel piping, 2012 V4: 37
- Welded Tanks for Oil Storage (API 250)*, 2011 V3: 88
- welding
  - clearance for, 2012 V4: 25

- corrosion and, 2009 V1: 136
- earthquake protection techniques, 2009 V1: 159
- problems in seismic protection, 2009 V1: 184
- types of, 2012 V4: 61
- weld decay defined, 2009 V1: 143
- welded joints in radioactive waste systems, 2010 V2: 239
- weldless eye nuts, 2012 V4: 136
- wells
  - bored wells, 2010 V2: 156–157
  - driven wells, 2010 V2: 157
  - dug and augered wells, 2010 V2: 156
  - equilibrium equations for wells, 2010 V2: 157–158
  - gray-water irrigation systems and, 2010 V2: 24
  - hydraulics of, 2010 V2: 157–158
  - initial operation and maintenance, 2010 V2: 164
  - introduction, 2010 V2: 155–156
  - irrigation usage, 2011 V3: 96
  - jetted wells, 2010 V2: 157
  - matching water storage to pump flow, 2010 V2: 162
  - monitoring fumes, 2011 V3: 144
  - monitoring groundwater, 2011 V3: 143–144
  - performance specifications, 2010 V2: 164
  - protection of, 2010 V2: 159
  - pumps, 2010 V2: 160–162
  - system equipment, 2010 V2: 160–164
  - types of, 2010 V2: 155
  - water demand and, 2010 V2: 159
  - water quality, 2010 V2: 159–160
- West Nile virus, 2010 V2: 49
- wet-bulb temperature (wbt, WBT), 2011 V3: 187
- wet chemical extinguishing systems, 2011 V3: 24
- wet floors in chemical plants, 2010 V2: 243
- wet gas, 2011 V3: 187, 252
- wet helical-lobe units, 2011 V3: 187
- wet niche lights, 2011 V3: 135
- wet-pipe systems, 2009 V1: 28, 2011 V3: 6, 7
- wet rotor pumps, 2012 V4: 93
- wet standpipe systems, 2009 V1: 30, 2011 V3: 20
- wet-tap excavations, 2011 V3: 213
- wet vacuum-cleaning systems (WVC)
  - defined, 2010 V2: 178
  - illustrated, 2010 V2: 185
  - pitch, 2010 V2: 186
  - separators, 2010 V2: 179
  - symbols for, 2009 V1: 9
- wet venting, 2009 V1: 31, 2010 V2: 32
- wet wells
  - capacity, 2011 V3: 237
  - sewage life stations, 2011 V3: 235–236
- wetted surfaces, propane tanks, 2010 V2: 132
- Weymouth formula, 2009 V1: 7, 2010 V2: 130
- WFI (water for injection), 2010 V2: 219, 221, 223
- WFU (water fixture units), 2009 V1: 15
- wfu (water fixture units), 2009 V1: 23
- WH (wall hydrants), 2009 V1: 10, 12, 15
- WHA (water hammer arresters). *See* water hammer arresters
- What Future Role for Pressure Sewers?*, 2010 V2: 154
- wheel loads, 2012 V4: 230
- wheelchairs
  - adult-sized, dimensions, 2009 V1: 100
  - anthropometrics for wheelchairs, 2009 V1: 99–101
  - approaches and reaches, 2009 V1: 102
  - clear space for, 2009 V1: 99–101
  - toilet and bathing rooms, 2009 V1: 104–105
  - water cooler accessibility, 2012 V4: 217–218
- wheeled fire extinguishers, 2011 V3: 23, 29
- WHEN relationship, 2009 V1: 223
- whirlpool bathtubs, 2010 V2: 111, 2012 V4: 16
- whirlpools, 2011 V3: 111
- Whitney, Eli, 2009 V1: 225
- WHY logic path, 2009 V1: 223
- wind (WD)
  - effect on irrigation sprinklers, 2011 V3: 93
  - hangers and supports and, 2012 V4: 117
  - wind loads, 2012 V4: 136
- Windows TR-55, 2010 V2: 44–46
- Winston Compound Parabolic Concentrator (CPC) system, 2011 V3: 196
- wire drawing, 2012 V4: 74, 80
- wire hooks, 2012 V4: 136
- wire mesh insulation jackets, 2012 V4: 108
- wire ropes, 2012 V4: 128
- wire screens for diatomaceous earth filters, 2012 V4: 181
- wire wound tubes for diatomaceous earth filters, 2012 V4: 181
- wireless meter-reading equipment, 2010 V2: 116
- Wisconsin Administrative Code*, 2011 V3: 135
- Wisconsin Department of Natural Resources, 2010 V2: 55
- Wisconsin DNR, 2010 V2: 29
- WO (waste oil), 2009 V1: 8
- WOG (water, oil, and gas pressure rating). *See* water, oil, and gas (WOG) pressure rating
- Wolf, J.B., 2010 V2: 29
- wood, anchoring into, 2012 V4: 123
- wood shrinkage, protecting against, 2010 V2: 16
- wood stave piping, 2010 V2: 75, 78
- Woodcock, J.J., 2010 V2: 29
- word processing of specifications, 2009 V1: 65
- work
  - conversion factors, 2009 V1: 35
  - converting to SI units, 2009 V1: 38
  - defined, 2009 V1: 56, 2011 V3: 187
  - measurements, 2009 V1: 35
- work change directives, 2009 V1: 57
- work functions in value engineering, 2009 V1: 218
- working deionizers, 2010 V2: 205
- working hours, in cost estimation, 2009 V1: 90
- working occupants, 2010 V2: 99
- working pressure, vacuum systems, 2010 V2: 171
- workmanship standards, 2009 V1: 61, 253–254
- workmen's compensation, in labor costs, 2009 V1: 86
- worksheets. *See* checklists and forms
- World Aquatic Health Conference, 2011 V3: 122, 135
- worst case possibilities, radiation and, 2010 V2: 239
- worth, defined, 2009 V1: 209
- WOV (waste oil vents), 2009 V1: 8
- wrist blades on faucets, 2011 V3: 35
- written amendments, 2009 V1: 57
- wrought iron piping, 2010 V2: 75, 78
  - natural gas systems, 2010 V2: 122
- WSFU (water supply fixture units), 2010 V2: 76
- wt, WT (weight). *See* weight

WVC (wet vacuum cleaning). *See* wet vacuum-cleaning systems

WWP (water working pressure), 2009 V1: 15, 2012 V4: 88

WWP-541 federal standard, 2012 V4: 225

wyes, 2010 V2: 32–33, 2012 V4: 5

Wyly, R.S., 2010 V2: 4

## X

x-ray areas, 2011 V3: 42, 52

x-rays, 2010 V2: 236–237

X#A (compressed air). *See* compressed air

XH (extra heavy) cast iron soil pipe, 2012 V4: 25–26

XP explosion-proof construction, 2010 V2: 125

XP junction boxes, 2010 V2: 125

XPAN (expansion). *See* expansion

## Y

y (years), 2009 V1: 34

yard hydrants (YD), 2009 V1: 15

yards (yd, YD), 2009 V1: 39

yards and lawns

lawn imperviousness factors, 2011 V3: 239

lawn sprinkler supply (LS), 2009 V1: 8

storm-drainage systems and, 2010 V2: 41

yard cleanouts (CO), 2009 V1: 11

YB (valves in yard boxes), 2009 V1: 10

YD (yard hydrants), 2009 V1: 15

yd, YD (yards), 2009 V1: 39

year-round pools, 2011 V3: 108

years (yr, YR), 2009 V1: 34

Yeh, K.L., 2010 V2: 225

yellow brass, 2009 V1: 132

YMCA's, 2010 V2: 99

yoke vents, 2009 V1: 31, 2010 V2: 35

Young, Virgil E., 2011 V3: 96

yr, YR (years), 2009 V1: 34

Yrjanainen, Glen, 2010 V2: 55

## Z

z, Z (zones), 2009 V1: 174

ZCV (zone control valves), 2009 V1: 15

Zelmanovich, Y., 2010 V2: 224

zeolite process, 2010 V2: 160

zeolites, 2010 V2: 205, 2011 V3: 87

zero-flow potential, 2009 V1: 143

zero gas grade, 2011 V3: 267

zero governor regulators, 2010 V2: 117

zero governors, 2011 V3: 255

zeta potential, 2010 V2: 198

zinc

anodes, 2009 V1: 139

brass and bronze, 2012 V4: 77

corrosion, 2009 V1: 129, 2012 V4: 176

electromotive force series, 2009 V1: 132

galvanic series, 2009 V1: 132

storm water, 2010 V2: 27

zinc-coated piping, 2010 V2: 122

ZN (zones), 2009 V1: 174

zone control valves (ZCV), 2009 V1: 15

zone valves, 2011 V3: 50, 66

zones (z, Z, ZN), in seismic force calculations, 2009 V1: 174

